

A-118

GPC II-118

ELECTRICAL POWER SYSTEMS

DOCKETED  
USNRC

A.C. SOURCES

SHUTDOWN

'95 JUL 27 P4:34

LIMITING CONDITION FOR OPERATION

~~OFFICE OF SECRETARY~~  
~~DOCKETING & SERVICE~~  
BRANCH

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the Onsite Class 1E Distribution System, and
- b. One diesel generator with:
  - 1) A day tank containing a minimum volume of 650 gallons (52% of instrument span) (LI-9018, LI-9019) of fuel,
  - 2) A fuel storage system containing a minimum volume of 68,000 gallons of fuel (76% of instrument span) (LI-9024, LI-9025), and
  - 3) A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, immediately suspend all operations involving CORE ALTERATIONS, positive reactivity changes, movement of irradiated fuel, or crane operation with loads over the fuel storage pool, and provide relief capability for the Reactor Coolant System in accordance with Specification 3.4.9.3. In addition, when in MODE 5 with the reactor coolant loops not filled, or in MODE 6 with the water level less than 23 feet above the reactor vessel flange, immediately initiate corrective action to restore the required sources to OPERABLE status as soon as possible.

SURVEILLANCE REQUIREMENTS

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the requirements of Specifications 4.8.1.1.1, 4.8.1.1.2 (except for Specification 4.8.1.1.2a.5), and 4.8.1.1.3.

NUCLEAR REGULATORY COMMISSION GPC

Docket No. 50-424/425-OLA-3 EXHIBIT NO. II-118

In the matter of Georgia Power Co. et al., Vogtle Units 1 & 2

Staff  Applicant  Intervenor  Other

Identified  Received  Rejected Reporter KHW

Date 7/14/95 Witness Masborough

VOGTLE UNITS - 1 & 2

3/4 8-10

9508110334 950714  
PDR ADOCK 05000424  
G PDR