

Docket No. 50-275

MAY 30 1984

Pacific Gas and Electric Company  
77 Beale Street, Room 1435  
San Francisco, California 94106

Attention: Mr. J. O. Schuyler, Vice-President  
Nuclear Power Generation

Gentlemen:

Subject: NRC Enforcement Conference

This refers to the Enforcement Conference held with Mr. G. A. Maneatis and other members of your staff at the NRC Region V office in Walnut Creek, California on May 1, 1984. The conference was in regard to the special NRC inspection conducted during the period of April 7-17, 1984, regarding the facts and circumstances associated with the unusual event of April 6, 1984. This event involved the disabling of the Boron Injection Tank (BIT) inlet and outlet valves which blocked the flow path of the Emergency Core Cooling System (ECCS). The event is discussed in detail in NRC Inspection Report No. 50-275/84-06.

Sincerely,

*orig signed*  
T. W. Bishop, Director  
Division of Reactor Safety  
and Projects

Enclosure:  
NRC Inspection  
Report 50-275/84-14

bcc: RSB/Document Control Desk (RIDS)

Distributed by RV:  
State of CA  
Mr. Martin, RV

RV/jk  
HERNANDEZ *K*  
5/2/84

*38*  
BISHOP  
5/14/84

*Johnson*  
5/24/84

8406050302 840530  
PDR ADOCK 05000275  
G PDR

*IEB*