In the matter of Georgia Power Co. et al., Vogtle Units 1 & 2

Reporter

Staff Applicant Intervenor Other 

Date 07-06-95 Witness Mosbough

1 INT. EXH. 110A '95 JUL 27 P2:44 2 TAPE 34 3 DATE: 4-4-90 4 TR. 7-8 OFFICE OF SECRETARY DOCKETING & SERVICE 5 BRANCH We need to have an agreed upon plan line by 6 MCCOY: 7 line of all the things we ought to look at and test for and all 8 that before we test those switches that have failed. If we don't 9 we're going to get down to the point that we can't go back and 10 determine (inaudible), 'cause people are still coming up with 11 theories and ideas and all that for Mr. Chaffe. And, you know, if we are really talking about things in the micron, five microns cr 12 less range (inaudible) in our shop. 13 I don't think sc. 14 BURR: 15 VOICE: (Inaudible). MCCOY: You have to have a microscope basically to see 16 that. 17 18 KOCHERY: (Inaudible) the vented air want to see 19 (inaudible). MCCOY: You got to have a filter. This is not like 20 taking a cloth and put it on like they do in startup testing. This 21 22 is much finer than that. 23 VOICE: Well, we've got, we've got all these other 24 switches that we have taken out now, right, air, that have been in 25 the system in the past. We've got seven switches, seven temperature 26 VOICE: 27 switches. 28 VOICE: They are all quarantined. NUCLEAR REGULATORY COMMISSION Docket No. 50-424/425-OLA-3 EXHIBITNO. Int II-110A

9508150246

1 VOICE: Yeah. And they're all quarantined.

2 VOICE: At some point we are going to disassemble these 3 things. And when you disassemble them, we can look inside of them 4 and see if there is debris or junk in there.

KOCHERY: That's what -- that's what the Calcon guy said if there - the switch is (inaudible) because of some of the debris - when you open the switch and you can see that (inaudible).

BURR: Normally, you can see something with your eye.

MOSBAUGH: It's not so small as microns, you know. One
thing that I think we probably ought to do to prove or disprove the

particle theory is -- you know we've got some of these lines out there, you know. They are asking about the air quality and so

forth. You could take one of these testing lines and, essentially

14 --

5

6

7

8

9

10

11

12

13

19

20

21

22

23

24

25

26

15 MCCOY: Blow it down.

MOSBAUGH: Do an air blow and do a white cloth and if there is debris in there, we really ought to know about it. And if there is not then it supports our case.

MCCOY: I think that is a reasonable thing to do at some point on the air supply (inaudible).

BOCKHOLD: [NRC, GPC: What, what, what, what] [INT: Lets, lets, lets, lets, lets, uh,] you and I talk first, and we need to decide on an [NRC, GPC: organization (inaudible) --] [INT: organizational plan].

MCCOY: What we really need to do right now is [NRC, GPC: to keep things] [INT: keeping this thing] going, our test plan

that is, that is --1 BOCKHOLD: Our test plan is going. 2 Yeah, but we've got our key individuals here. MCCOY: 3 We need to let them go --BOCKHOLD: 5 That's right. MCCOY: 6 BOCKHOLD: -- and just you and I talk about organization 7 now. The diesel people need to go work on the diesel procedures that we have going on. I need to read that. After I read that I 8 will re-concur. I will get back to you guys. Okay - have I got 9 any questions? 10 11 12 13

[penlant1] B:\wpdocs\tlp\license.pro\tapes.int\final\34~ex.110

14