

DOCKETED
USMRC

INT. EXH. 53
TAPE 184

'95 JUL 27 P2:42

Date: End of August

Location: 2nd floor Service Building
Office of Secretary
DOCKETING & SERVICE
BRANCH

SEGMENT #1
TR. 26

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

BOCKHOLD: Lets go to the first paragraph.

HORTON: Hold on a minute. There's another issue on this page.

HORTON: Uh, previously Note 2 said, well we'll get to it in a minute in that paragraph, but I want to point out to the board members the one, two three, four, five, six, the first seven runs, 120 thru 126. We -- we're fixing to count start attempts in that Note 2 as -- not counting five, the first five starts. I just want everybody to look at it now when we get back to the verbiage we're going to need to address our Vogtle definition of a post maintenance start. This is an issue with the NRC.

BOCKHOLD: What that we --

HORTON: That we have post maintenance, uh, shakedown is the word that is used by one of the region folks.

BOCKHOLD: What. I mean if you got, if you are doing a post maintenance run and you had the machine apart, uh --

HORTON: There's no such thing in the reg. guide.

AUFDENKAMPE: I remember all of a sudden. The more I do the more I remember. What we did was tie the words, should be considered valid tests and failures together.

HORTON: I think it's the first sentence in

R:\wpdocs\trp\license pr\tapes.int\184-EX.53

NUCLEAR REGULATORY COMMISSION

Docket No. 50-424/425-OLA-3 EXHIBIT NO. Int II-53

In the matter of Georgia Power Co. et al., Vogtle Units 1 & 2

Staff Applicant Intervenor Other

Identified Received Rejected Reporter CR

Date 07-06-95 Witness Mosbaugh

9508170101 950706
PDR ADOCK 05000424
T PDR

1 paragraph 7 on the next page.

2 AUFDENKAMPE: They should be considered valid tests.

1 SEGMENT #2
2 TR. 28, 29
3
4

5 HORTON: Okay, my final issue here is really with
6 number 124. Uh, based on my research, we're hard pressed to call
7 that a post maintenance run. I'm not sure how somebody decided
8 previously that starts [NRC, GPC: 123 and 124] [INT: 120 through
9 124] were post maintenance runs.

10 BOCKHOLD: Was that in, in any of the previous
11 documentation?

12 VOICE: No.

13 HORTON: Well every sheet is checked off post
14 maintenance --

15 BOCKHOLD: No, no, no, no, no, no I'm talking about
16 the LER. Are there any other (inaudible). Then, then it's not an
17 issue.
18
19