

DmB



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

*Serving The Best Location in the Nation*

MURRAY R. EDELMAN  
VICE PRESIDENT  
NUCLEAR

May 24, 1984

PRINCIPAL STAFF			
✓ RA	<i>la</i>	DPRP	
D/RA		DE	
A/RA		DRMSP	
PC		DRMA	
FAO		SCS	
SGA		ML	
ENF		File	<i>la</i>

*orig + 1*

Mr. James G. Keppler  
Regional Administrator, Region III  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

RE: Perry Nuclear Power Plant  
Docket Nos. 50-440; 50-441  
Flexible Coupling Drive Hubs  
Supplied by Transamerica Delaval,  
Inc. [RDC 92(84)]

Dear Mr. Keppler:

Our interim report to you dated February 17, 1984, stated that we anticipated filing our final report concerning flexible coupling drive hubs supplied by Transamerica Delaval Inc. by May 31, 1984.

Inspections are currently in progress to determine if this potential deficiency is applicable to the four Standby Diesel Generator Units supplied to Perry Nuclear Power Plant. We now anticipate filing our final report on this subject by July 31, 1984, subsequent to completion of these inspections.

Please contact us if you have any questions.

Sincerely,

Murray R. Edelman  
Vice President  
Nuclear Group

MRE:pab

cc:Mr. M. L. Gildner  
NRC Site Office

Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

U.S. Nuclear Regulatory Commission  
c/o Document Management Branch  
Washington, D.C. 20555

Records Center, SEE-IN  
Institute of Nuclear Power Operations  
1100 Circle 75 Parkway, Suite 1500  
Atlanta, Georgia 30339

8406050387 840524  
PDR ADOCK 05000440  
S PDR

MAY 29 1984

IE 27

/o