



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 25, 1984

Docket Nos: 50-329 OM, OL
and 50-330 OM, OL

Mr. J. W. Cook
Vice President
Consumers Power Company
1945 West Parnall Road
Jackson, Michigan 49201

Dear Mr. Cook:

Subject: Request for Additional Information Regarding
Volume IX of Seismic Margin Review Reports

The NRC staff, with the technical assistance of its consultant from Energy Technology Engineering Center, has reviewed mechanical engineering aspects of Volume IX of the Seismic Margin Review reports. Volume IX, entitled "Balance of Plant (BOP) Class 1, 2 and 3 Piping, Pipe Supports and Valves", was forwarded under your coverletter dated February 9, 1984.

We find that additional information, identified in the enclosure, is needed to complete this review. Please provide your response to the enclosure within 30 days of receipt of this letter. A copy of your response should also be forwarded directly to our ETEC consultant. Contact our project manager should you require clarification of the enclosure or are unable to meet this response date.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

A handwritten signature in cursive script that reads "Elinor G. Adensam".

Elinor G. Adensam, Chief
Licensing Branch No. 4
Division of Licensing

Enclosure:
As stated

cc: See next page

8406060024 840525
PDR ADOCK 05000329
A PDR

DESIGNATED ORIGINAL
Certified By A handwritten signature in cursive script, likely of the certifying official, written over the "Certified By" text.

MIDLAND

Mr. J. W. Cook
Vice President
Consumers Power Company
1945 West Parnall Road
Jackson, Michigan 49201

cc: Michael I. Miller, Esq.
Ronald G. Zamarin, Esq.
Alan S. Farnell, Esq.
Isham, Lincoln & Beale
Three First National Plaza,
51st floor
Chicago, Illinois 60602

James E. Brunner, Esq.
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Ms. Mary Sinclair
5711 Summerset Drive
Midland, Michigan 48640

Stewart H. Freeman
Assistant Attorney General
State of Michigan Environmental
Protection Division
720 Law Building
Lansing, Michigan 48913

Mr. Wendell Marshall
Route 10
Midland, Michigan 48640

Mr. R. B. Borsum
Nuclear Power Generation Division
Babcock & Wilcox
7910 Woodmont Avenue, Suite 220
Bethesda, Maryland 20814

Cherry & Flynn
Suite 3700
Three First National Plaza
Chicago, Illinois 60602

Mr. Don van Farrowe, Chief
Division of Radiological Health
Department of Public Health
P. O. Box 33035
Lansing, Michigan 48909

Mr. Steve Gadler
2120 Carter Avenue
St. Paul, Minnesota 55108

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
Route 7
Midland, Michigan 48640

Ms. Barbara Stamiris
5795 N. River
Freeland, Michigan 48623

Mr. Paul A. Perry, Secretary
Consumers Power Company
212 W. Michigan Avenue
Jackson, Michigan 49201

Mr. Walt Apley
c/o Mr. Max Clausen
Battelle Pacific North West Labs
(PNWL)
SIGMA IV Building
Battelle Blvd.
Richland, Washington 99352

Mr. I. Charak, Manager
NRC Assistance Project
Argonne National Laboratory
9700 South Cass Avenue
Argonne, Illinois 60439

James G. Keppler, Regional Admin.
U.S. Nuclear Regulatory Commission,
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. J. W. Cook

- 2 -

cc: Mr. Ron Callen
Michigan Public Service Commission
6545 Mercantile Way
P. O. Box 30221
Lansing, Michigan 48909

Ms. Julie Morrison
Midland Daily News
124 McDonald Street
Midland, Michigan 48640

Billie Pirner Garde
Director, Citizens Clinic
for Accountable Government
Government Accountability Project
Institute for Policy Studies
1901 Que Street, N.W.
Washington, D. C. 20009

Mr. Howard Levin, Project Manager
TERA Corporation
7101 Wisconsin Avenue
Bethesda, Maryland 20814

Ms. Lynne Bernabei
Government Accountability Project
1901 Q Street, N.W.
Washington, D. C. 20009

Supplemental page to the Midland OM, OL Service List

Mr. J. W. Cook

- 3 -

cc: Commander, Naval Surface Weapons Center
ATTN: P. C. Huang
White Oak
Silver Spring, Maryland 20910

Mr. L. J. Auge, Manager
Facility Design Engineering
Energy Technology Engineering Center
P. O. Box 1449
Canoga Park, California 91304

Mr. Neil Gehring
U.S. Corps of Engineers
NCEED - T
7th Floor
477 Michigan Avenue
Detroit, Michigan 48226

Charles Bechhoefer, Esq.
Atomic Safety & Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. Frederick P. Cowan
Apt. B-125
6125 N. Verde Trail
Boca Raton, Florida 33433

Jerry Harbour, Esq.
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Geotechnical Engineers, Inc.
ATTN: Dr. Steve J. Paulos
1017 Main Street
Winchester, Massachusetts 01890

ATTN: Clyde Herrick
Franklin Research Center
20th & Race Streets
Philadelphia, Pennsylvania 19103

Mr. Patrick Bassett
Energy Division
Norwest Bank Minneapolis, N.A.
8th and Marquette
Minneapolis, Minnesota 55479

ENCLOSURE

REQUEST FOR ADDITIONAL INFORMATION AND CLARIFICATION
REGARDING VOLUME IX TO SMR REPORT

Provide the following additional information and clarifications with respect to Volume IX, "Balance of Plant Class 1, 2 and 3 Piping, Pipe Supports and Valves", which is part of the Seismic Margin Review Reports for Midland:

1. Explain the derivation of EQ (5-1).
(Pg. IX-5-3)
2. Explain "Drawings of each pipe support were also reviewed in order to assess appropriateness of stiffness assumptions used in modeling." Was generic stiffness, estimated and/or calculated stiffness or NUPIPE default stiffness used?
(Pg. IX-6-1)
3. Explain why two "Class 1 and 3/4" Class 1 lines were analyzed in accordance with Class 2 rules because of the small line size."
(Pg. IX-6-5)
4. Explain your use of 3% (SSE) damping for the 12" nominal line. This is not in agreement with Reg. Guide 1.61 October 1976. The Reg. Guide states that 2% (SSE) damping should be used for lines equal to or less than 12".
(Pgs. IX-6-6, IX-6-32)
5. With respect to thermal anchor displacements, does the Z displacement include the radial expansion of the 36" diameter of the 36" - 2 CCA-1 line?
(Pg. IX-6-22)
6. Explain why the assumption that the seismic displacement of the reactor building supports being out-of phase with the auxiliary building supports will always result in higher support loads.
(Pgs. IX-6-32, IX-6-70, IX-6-83)
7. Your statement "With the 3% damped spectra being selected since virtually the entire system consists of large piping equal to or greater than 12-inch nominal diameter" does not agree with Reg. Guide 1.61 October 1976. Large piping is defined as greater than 12" and small piping is defined as equal to or less than 12". Thus the 2% damped spectra should be used for the 12" line 12"-1HCB-6. Justify or correct the value used.
(Pg. IX-6-55)
8. Explain why there is no Z earthquake anchor displacement for anchor nodes 800 and 875.
(Pg. IX-6-83)
9. Explain why all the thermal anchor displacements for the four different operating cases are the same.
(Pg. IX-6-104)

9. Explain why all the thermal anchor displacements for
(Pg. IX-6-104) the four different operating cases are the same.
10. The snubber at Node 395 (1-610-3-22) has a seismic
(Pg. IX-7-13) margin load of ± 2802 lb and a CM and $F_{sme} = 4.61$.
The snubber at Node 406 (1-610-3-45) has a seismic
margin load of ± 2785 lb and a CM and $F_{sme} = 1.55$.
Explain why there is a large difference in the CM
values.
11. The snubber at Node 214 (0-618-1-502) implies that
(Pg. IX-7-24) it may be a Pacific Scientific Snubber Model 10K
or equivalent. If this is true explain why its
stiffness which is 1.74×10^5 in was not included
in the computer model for the 36" piping of the
service water system along with the calculated
beam and strainer nozzle stiffness.
12. What ASME Section III Edition Stress Indices for
General Class 1 Analysis did the NUPIPE computer use?
13. The staff assumes the following to be typographical
errors. Please confirm this assumption, or justify
your position:

<u>Page</u>	<u>Staff Comment</u>
IX-4-1	"SSE" should be "SME" (two places).
IX-5-8	"Snubber (z)" should be "Y Restraint". See Pg. IX-7-25.
IX-6-178 and IX-6-198 to 201	"Class 2 Stresses" should be "Class 3 Stresses".