

231 W Michigan, P.O. Bax 2045, Milwaukee, WI 53201

(414) 221-2345

VPNPD-92-008 NRC-92-001

January 9, 1992

U. S. NUCLEAR REGULATORY COMMISSION Document Control Desk Mail Station P1-137 Washington, D. C. 20555

Gentlemen:

DOCKETS 50-266 AND 50-301 MONTHLY OPERATING REPORTS POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Attached are monthly operating reports for Units 1 and 2, Point Beach Nuclear Plant, for the calendar month of December 1991.

Very truly yours,

James J. Zach Vice President

Nuclear Power

dpg

Attachments

Copies to L. L. Smith, PSCW

NRC Regional Administrator, Region III

NRC Resident Inspector

140000

9201140137 921391 PDR ADDCK 05000266 1824

#### OPERATING DATA REPORT

DOCKET NO. 50-266

DATE: January 6, 1992

COMPLETED BY: D. C. Peterson

TELEPHONE: 414/755-2321, Ext. 361

### OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT UNIT 1 . NOTES

2. REPORTING PERIOD: DECEMBER 1991

3. LICENSED THERMAL POWER (MWT): 1518.5

4. NAMEPLATE RATING (GROSS MWE): 523.8

5. DESIGN ELECTRICAL RATING (NET MWE): 497.

6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.

NOT APPLICABLE

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NOT APPLICABLE

10. REASONS FOR RESTRICTIONS, (IF ANY): NOT APPLICABLE

	THIS MONTH	YR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	744	8,760	185,424
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	7,622.9	153,390.5
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	652.7
14. HOURS GENERATOR ON LINE	744.0	7,525.1	150,428.7
15. UNIT RESERVE SHUTDOWN HOURS	0.0	9.0	846.9
16. GROSS THERMAL ENERGY GENERATED (MWH)	1,091,753	11,243,308	210,650,003
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	368,860	3,801,350	71,103,730
18. NET ELECTRICAL ENERGY GENERATED (MWH)	353,157	3,628,733	67,749,773
19. UNIT SERVICE FACTOR	100.0	85.9	81.1
20. UNIT AVAILABILITY FACTOR	100.0	86.0	81.6
21. UNIT CAPACITY FACTOR (USING MDC NET)	97.9	85.4	74.9
22. UNIT CAPACITY FACTOR (USING DER NET)	95.5	83.3	73.5
23. UNIT FORCED OUTAGE RATE	0.0	1.3	1.7
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE	E. DATE, AND DURATE	ION OF EACH):	

April 10, 1992 to May 22, 1992 (42 days)

Refueling and Maintenance Outage 19.

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NOT SHUTDOWN

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

		POINT	BEACH NUCLEAR PLANT	DOCKET NO.	50-266
		AVERAGE	DAILY UNIT POWER LEVEL	UNIT NAME	Point Beach, Unit 1-
		MONTH	DECEMBER - 1991	DATE	January 6, 1992
				COMPLETED B	Y D. C. Peterson
				TELEPHONE	414/755-2321
DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVELMWe_NET
1	467	11	494	21	492
2	446	12	496	22	493
3	495	13	387	23	493
4	496	14	246	24	491
5	496	15	414	25	459
6	496	16	492	26	458
7	495	17	483	27	492
8	496	18	491	28	493
9	495	19	488	29	493
10	495	20	497	30	493

31

494

### POINT BEACH NUCLEAR PLANT

## UNIT SHUTDOWNS AND POWER REDUCTIONS

# REPORT MONTH DECEMBER - 1991

Docket No. 50-266 Unit Name Date Completed By

Point Be. b. Unit 1 January 6, 1992 D. C. Peterse 7

Telephone No. 414/755-2321, Lxt. 361

No.	Date	Type!	Duration	Reason <sup>2</sup>	Method of Shutting Down	Licensee Event	System	Component	Cause and Corrective Action
9	911213	F	N/A	F	5	N/A	WE	HTEXCH	Power reduction for condenser tube inspection and repair.
							44		
							11.		

F: Forced S: Scheduled <sup>2</sup>Reason:

A - Equipment Failure (explain)

B - Maintenance or Testing

C - Refueling

D - Regulatory Restriction

E - Operator Training & Licensing Exam

F - Administrative

G - Operational Error (explain)

H - Other (explain)

3Method:

1 - Manual

2 - Manual Scram

3 - Automatic Scram

4 - Continuation of Previous Shutdown

5 - Reduced Load

6 - Other (explain)

\*Exhibit G - Instructions for preparation of data entry sheets

LER file (NUREG-0161)

5Exhibit I - Same Source

DOCKET NO.

50-266

UNIT NAME

Point Beach Unit 1

DATE

January 6, 1992 COMPLETED BY D. C. Peterson

TELEPHONE

414/755-2321, Ext. 361

Unit 1 operated at approximately 474.7 MWe net throughout this report period with one significant load reduction for condenser tube inspection and repair.

Safety-related maintenance included the following: cleaned seat and plug of fuel oil transfer discharge check valve to stop back leakage; rebuilt fuel oil transfer pump and installed new pump housing; moved actuating arm and repositioned the close limit on auxiliary feedwater pump mini-recirc control valve; replaced auxiliary feedwater pump suction relief valve; checked lug torques on all breakers with field wiring attached on 125 DC distribution panels D-11 and D-13; changed high alarm setpoint on inverter room alarm temperature switch; replaced, calibrated and verified proper operation of safety injection pump discharge flow transmitters; replaced -25V power supply on N-44 nuclear instrumentation power range channel; and replaced breakers in DC distribution panel D-13.

#### OPERATING DATA REPORT

DOCKET NO. 50-301

DATE: January 6, 1992

COMPLETED BY: D. C. Peterson

TELEPHONE: 414/755-2321, Ext. 361

### OPERATING STATUS

NONE

1. UNIT NAME: POINT BEACH NUCLEAR PLANT UNIT 2 . NOTES 2. REPORTING PERIOD: DECEMBER 1991 3. LICENSED THERMAL POWER (MWT): 1518.5 4. NAMEPLATE RATING (GROSS MWE): 523.8 5. DESIGN ELECTRICAL RATING (NET MWE): 497.

6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.

7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 485. 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS NUMBER 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:

NOT APPLICABLE

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NOT APPLICABLE

10. REASONS FOR RESTRICTIONS, (IF ANY): NOT APPLICABLE

	THIS MONTH	YR TO DATE	CUMULATIVE
11. 'OURS IN REPORTING PERIOD	744	8,760	170,209
12. NUMBER OF HOURS REACTOR WAS CRITICAL	733.0	7,645.2	148,729.8
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	216.7
14. HOURS GENERATOR ON LINE	726.0	7,569.7	146,489.0
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	302.2
16. GROSS THERMAL ENERGY GENERATED (MWH)	1,064,971	11,302,748	209,467,157
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	362,530	3,862,120	71,159,380
18. NET ELECTRICAL ENERGY GENERATED (MWH)	346,784	3,687,712	67,819,778
19. UNIT SERVICE FACTOR	97.6	86.4	86.1
20. UNIT AVAILABILITY FACTOR	97.6	86.4	86.2
21. UNIT CAPACITY FACTOR (USING MDC NET)	96.1	86.8	81.5
22. UNIT CAPACITY FACTOR (USING DER NET)	93.8	84.7	80.2
23. UNIT FORCED OUTAGE RATE	0.0	0.4	1.1
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE,	DATE, AND DURATI	ON OF EACH):	

25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NOT SHUTDOWN

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

		POINT E	BEACH NUCLEAR PLANT	DOCKET NO.	50-301
		AVERAGE	DAILY UNIT POWER LEVEL	UNIT NAME	Point Beach, Unit 2
		MONT	H _ DECEMBER - 1991_	DATE	January 6, 1992
				COMPLETED B	Y D. C. Peterson
				TELEPHONE	414/755-2321
DAY	AVERAGE DAILY POWER LEVEL MWe LET	DAY	AVERAGE DAILY POWER LEVEL MWe NET	DAY	AVERAGE DAILY POWER LEVEL MWc NET
1	500	11	498	21	500
2	496	12	500	22	501
3	499	13	499	23	501
4	498	14	448	24	498
5	499	15	251	25	500
6	500	16	422	26	500
7	498	17	205	27	500
8	498	18	147	28	500
9	498	19	496	29	501
10	498	20	498	30	500
				31	501

### POINT BEACH NUCLEAR PLANT

# UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH DECEMVER- 1991

Docket No. Unit Name

50-301 Point Beach, Unit 2

Date

January 5, 1992 D. C. Peterson

Completed By

Telephone No. 414/755-2321, Ext. 361

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report No.	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause and Corrective Action To Prevent Recurrence
2	911214	F	N/A	F	5		WE	HTEXCH	Power Reduction for Condenser Tube inspection and repair.
3	911217	P	17.6	A	3	301-91-006	IA	ELECON	Supply lead to a DC Breaker was pulled loose while pulling cable, causing reactor protection circuits to deenergize, which caused the reactor to trip.
							214-41		

F: Forced

S: Scheduled

Reason:

A - Equipment Failure (explain)

B - Mastenance or Testing

C - Refueling

D - Regulatory Restriction

E - Operator Training & Licensing Exam

F - Administrative

G - Operational Error (explain)

H - Other (explain)

Method:

1 - Manual

2 - Manual Scram

3 - Automatic Scram

4 - Continuation of

Previous Shutdown

5 - Reduced Load

6 - Other (explain)

Exhibit G - Instructions

for preparation of data entry sheets

LER file (NUREG-0161)

5Exhibit I - Same Source

DOCKET NO.

50-301

UNIT NAME DATE

Point Beach Unit 2 January 6, 1992

COMPLETED BY D. C. Peterson

TELEPHONE 414/755-2321, Ext. 361

Unit 2 operated at approximately 466.1 MWe net throughout this report period with one significant load reduction and one reactor trip. The load reduction was a result of condenser tube inspection and repair; the reastor trip was caused by a supply lead to a DC breaker pulling loose, which deenergized DC distribution panel D-22 and resulted in a reactor trip.

During this period, Unit 2 experienced one reportable event in accordance with 10 CFR 50.73, LER 91-006, Unit 2 Reactor Trip, due to modification work.

Safety-related maintenance included the following: replaced and calibrated signal process assembly in gamma metrics startup rate meter; inspected and retightened coupling on steam sensing line to auxiliary feedwater turbine driven pump; replaced turbine independent overspeed protection Channel A speed control card; and replaced nut and retorqued safety injection piping support.