

JAN 10 1992

Docket No. 50-254
Docket No. 50- '5

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Senior Vice President
Licensing Department - Suite 300
Opus West III
1400 Opus Place
Downers Grove, IL 60515

Dear Mr. Reed:

This refers to the routine safety inspection conducted by Messrs. M. P. Huber and G. D. Replogle of this office on December 9 through 19, 1991. The inspection included a review of activities authorized for your Quad Cities Nuclear Power Station and the discussion of our findings with Mr. R. L. Bax and others of your staff at the conclusion of the inspection.

The areas examined during the inspection are identified in the report. These areas consisted primarily of a review of the Quad Cities Motor Operated Valve Program established in response to Generic Letter 89-10. Within this area, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in violation of NRC requirements. However, as described in the enclosed inspection report, you identified this violation, and to encourage and support licensee initiatives for self-identification and correction of violations, the violation is not being cited because the criteria specified in Section V.G of the "General Statement of Policy and Procedure for NRC Enforcement Actions," (Enforcement Policy, 10 CFR Part 2, Appendix C (1991)), were satisfied.

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC Public Document Room.

9201160011 920110
PDR ADOCK 05000254
Q PDR

1001

JAN 10 1992

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

Original Signed by Mark A. Ring

M. A. Ring, Chief
Engineering Branch

Enclosure: Inspection Reports

No. 50-254/91022(DRS);

No. 50-265/91018(DRS)

cc w/enclosure:

D. Galle, Vice President -
BWR Operations

T. Kovach, Nuclear Licensing
Manager

DCD/DCB (RIDS)

OC/LFDCE

W. Hodges, RI

A. Gibson, RII

S. Collins, RIV

R. Zimmerman, RV

T. Scarbrough, NRR

L. Olshan, NRR

Resident Inspectors - Quad
Cities, Dresden, LaSalle

Richard Hubbard

J. W. McCaffrey, Chief,
Public Utilities Division

Robert Newmann, Office of Public
Counsel, State of Illinois
Center

R. L. Bax, Station Manager

RIII
[Signature]
Huber/JK
01/09/92

RIII
[Signature]
Jacobson
01/09/92

[Signature]
RIII
[Signature]
B. Burgess
01/09/92

[Signature]
RIII
[Signature]
Ring
01/10/92