

The Light company

Houston Lighting & Power South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

January 14, 1992
ST-HL-AE-3973
File No.: G02
10CFR50.71

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

South Texas Project Electric Generating Station
Units 1 & 2
Docket Nos. STN 50-498 & 50-499
Monthly Operating Reports for December, 1991

Pursuant to 10CFR50.71(a) and South Texas Project Electric Generating Station (STPEGS) Technical Specification 6.9.1.5, attached are the Monthly Operating Reports for December, 1991.

If you should have any questions on this matter, please contact Mr. G. A. Ayala at (512) 972-8628.

William J. Jump

William J. Jump
Manager
Nuclear Licensing

MKI/lf

- Attachments: 1) STPEGS Unit 1 Monthly Operating Report - December, 1991
2) STPEGS Unit 2 Monthly Operating Report - December, 1991

Houston Lighting & Power Company
South Texas Project Electric Generating Station

ST-HL-AE- 3973
File No.:G02
Page 2

cc:

Regional Administrator, Region IV
Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011

George Dick, Project Manager
U.S. Nuclear Regulatory Commission
Washington, DC 20555

J. I. Tapia
Senior Resident Inspector
c/o U. S. Nuclear Regulatory
Commission
P. O. Box 910
Bay City, TX 77414

J. R. Newman, Esquire
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20036

D. E. Ward/T. M. Puckett
Central Power and Light Company
P. O. Box 2121
Corpus Christi, TX 78403

J. C. Lanier/M. B. Lee
City of Austin
Electric Utility Department
P.O. Box 1088
Austin, TX 78767

K. J. Fiedler/M. T. Hardt
City Public Service Board
P. O. Box 1771
San Antonio, TX 78296

Rufus S. Scott
Associate General Counsel
Houston Lighting & Power Company
P. O. Box 61867
Houston, TX 77208

INPO
Records Center
1100 Circle 75 Parkway
Atlanta, GA 30339-3064

Dr. Joseph M. Hendrie
50 Bellport Lane
Bellport, NY 11713

D. K. Lacker
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

Revised 10/11/91

LA/NRC/

SOUTH TEXAS PROJECT
ELECTRIC GENERATING STATION
UNIT 1
MONTHLY OPERATING REPORT
DECEMBER 1991
HOUSTON LIGHTING AND POWER CO.
NRC LOCKET NO. 50-498
LICENSE NO. NPF-76

Reviewed By: *[Signature]* 1-6-92
Supervisor Date
Reviewed By: *[Signature]* 1-7-92
Plant Engineering Manager Date
Approved By: *[Signature]* 1/9/92
Plant Manager Date

Monthly Summary

ATTACHMENT 1
ST-HL-AE-3973
PAGE 2 OF 6

STPEGS Unit 1 began the reporting period at 100% reactor power.

On 1st/7/91 reactor power was reduced to allow repair of the Main Feedwater Pump Speed Control Circuit.

The unit returned to 100% reactor power on 12/8/91 and operated for the remainder of the reporting period with no shutdowns or significant power reductions.

OPERATING DATA REPORT

ATTACHMENT 1
 ST-HL-AB-3973
 PAGE 3 OF 6

DOCKET NO. 50-498
 UNIT 1
 DATE Jan. 3, 1992
 COMPLETED BY A. P. Kent
 TELEPHONE 512/972-7786

OPERATING STATUS

1. REPORTING PERIOD: 12/01-12/31 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 3800
 MAX. DEPEND. CAPACITY (MWe-Net): 1250.6
 DESIGN ELECTRICAL RATING (MWe-Net): 1250.6
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL.....	<u>744.0</u>	<u>6238.9</u>	<u>20019.9</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE.....	<u>744.0</u>	<u>6070.8</u>	<u>19212.3</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWt)....	<u>2762897</u>	<u>22476114</u>	<u>70154322</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)..	<u>941970</u>	<u>7610510</u>	<u>23708000</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)....	<u>901694</u>	<u>7203886</u>	<u>22328369</u>
12. REACTOR SERVICE FACTOR.....	<u>100.0%</u>	<u>71.2%</u>	<u>68.1%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>71.2%</u>	<u>68.1%</u>
14. UNIT SERVICE FACTOR.....	<u>100.0%</u>	<u>69.3%</u>	<u>65.4%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>69.3%</u>	<u>65.4%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>96.9%</u>	<u>65.8%</u>	<u>60.8%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)...	<u>96.9%</u>	<u>65.8%</u>	<u>60.8%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>0.0%</u>	<u>11.4%</u>	<u>14.3%</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): N/A			
20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: N/A			

AVERAGE DAILY UNIT POWER LEVEL

ATTACHMENT 1
 ST-HL-AE-3973
 PAGE 4 OF 6

DOCKET NO. 50-498
 UNIT 1
 DATE Jan. 6, 1992
 COMPLETED BY A.P. Kent
 TELEPHONE 512/972-7786

MONTH DECEMBER

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	1223
2	1247
3	1. 8
4	1245
5	1238
6	1244
7	397
8	1025
9	1246
10	1244
11	1238
12	1232
13	1239
14	1253
15	1254
16	1256

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	1254
18	1246
19	1245
20	1244
21	1243
22	1240
23	1242
24	1247
25	1242
26	1248
27	1254
28	1257
29	1260
30	1260
31	1260

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-498
 UNIT 1
 DATE Jan. 3, 1992
 COMPLETED BY A.P. Kent
 TELEPHONE 512/972-7786

REPORT MONTH DECEMBER

No.	Date	Type	Duration (Hours)	Reason	Method of Shutting Down Reactor	Licensee Event Report #	System Code	Component Code	Cause & Corrective Action to Prevent Recurrence
91-11	911207	F	0.0	B	5	N/A	SJ	P	Reactor power was reduced to 20% to allow repair of the Main Feedwater Pump Speed Control Circuit.

1 F: Forced
 S: Scheduled

2 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

3 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont. of Existing Outage
 5-Reduction
 9-Other

4 IEEE 805-1983
 5 IEEE 803A-1983

PORVs and Safety Valves Summary

ATTACHMENT /
ST-HL-AE-3973
PAGE 6 OF 6

There were no PORV or Safety Valves challenged during the reporting period.

SOUTH TEXAS PROJECT
ELECTRIC GENERATING STATION
UNIT 2
MONTHLY OPERATING REPORT
DECEMBER 1991
HOUSTON LIGHTING AND POWER CO.
NRC DOCKET NO. 50-499
LICENSE NO. NPF-80

Reviewed By: *[Signature]* 1-6-92
Supervisor Date

Reviewed By: ^{JWH} *[Signature]* 1-7-92
Plant Engineering Manager Date

Approved By: *[Signature]* 1/1/92
Plant Manager Date

Monthly Summary

ATTACHMENT 2
ST-HL-AE-3973
PAGE 3 OF 7

STPEGS Unit 2 began the reporting period shutdown for refueling and scheduled maintenance. Due to corrective maintenance work on equipment required for start-up, the refueling outage was extended beyond the original scheduled start-up date of December 5, 1991. December 6, 1991 marked the beginning of forced shutdown time accrued to the unit.

The generator was synchronized to the grid on 12/16/91 at 0129 and the Turbine Overspeed Trip Test was performed successfully. The unit remained off line when problems were experienced with the Main Generator Seal Oil System not controlling pressure properly. The unit was taken to Mode 2 to implement corrective action. It was discovered that some relief valves were incorrectly installed and that an air side filter was installed backward causing high backpressure to develop and a relief valve to lift. The lifting of the relief valve prevented adequate pressure from being developed in the seals and a subsequent loss of hydrogen pressure in the generator. The filter was reversed.

The unit was returned to service for normal operation on 12/18/91 at 1852. On 12/22/91 reactor power was reduced to 12% to correct feedwater flow oscillations occurring on the 2B Steam Generator loop. The oscillations were caused by a bad positioner on a feedwater regulating valve.

On 12/24/91 with the unit at 30% reactor power and ramping up, a reactor trip and safety injection occurred due to low pressurizer pressure. The pressurizer spray valve on the 2A Reactor Coolant loop failed. The positioner arm from the spray valve had fallen off because of a loose support bolt/nut arrangement. The positioner arm was replaced.

With the unit in Mode 2, while attempting to transfer to governor valve control, the Electro-Hydraulic Control System responded incorrectly causing a turbine trip on 12/26/91. Investigations revealed no significant problems. Throttle and governor valve testing was performed with satisfactory results on 12/27/91.

The unit achieved Mode 1 on 12/27/91 at 0641 and was synchronized to the grid on 12/28/91 at 0129. The unit concluded the reporting period at 100% reactor power.

OPERATING DATA REPORT

ATTACHMENT 2
ST-HI-AE-3973
PAGE 3 OF 7

DOCKET NO. 50-499
UNIT 2
DATE Jan. 4, 1992
COMPLETED BY A.P. Kent
TELEPHONE 512/972-7786

OPERATING STATUS

1. REPORTING PERIOD: 12/01-12/31 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 3800
MAX. DEPEND. CAPACITY (MWe-Net): 1250.6
DESIGN ELECTRICAL RATING (MWe-Net): 1250.6
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL.....	<u>449.3</u>	<u>6441.3</u>	<u>15422.6</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE.....	<u>247.1</u>	<u>6136.6</u>	<u>14482.2</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWt).....	<u>553038</u>	<u>22688003</u>	<u>52393271</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)...	<u>154310</u>	<u>7644890</u>	<u>17667360</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)....	<u>120528</u>	<u>7255235</u>	<u>16704003</u>
12. REACTOR SERVICE FACTOR.....	<u>60.4%</u>	<u>73.5%</u>	<u>69.4%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>60.4%</u>	<u>73.5%</u>	<u>69.4%</u>
14. UNIT SERVICE FACTOR.....	<u>33.2%</u>	<u>70.1%</u>	<u>65.2%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>33.2%</u>	<u>70.1%</u>	<u>65.2%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>13.0%</u>	<u>66.2%</u>	<u>60.1%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)...	<u>13.0%</u>	<u>66.2%</u>	<u>60.1%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>60.4%</u>	<u>9.3%</u>	<u>16.4%</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE AND DURATION OF EACH): N/A			
20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: <u>N/A</u>			

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-499
UNIT 2
DATE Jan. 5, 1992
COMPLETED BY A.P. Kent
TELEPHONE 512/972-7786

MONTH DECEMBER

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
11	0
12	0
13	0
14	0
15	0
16	10

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	0
18	0
19	171
20	528
21	876
22	439
23	51
24	44
25	0
26	0
27	0
28	372
29	1005
30	1159
31	1209

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-499
 UNIT 2
 DATE Jan. 6, 1992
 COMPLETED BY A.P. Kent
 TELEPHONE 512/974-7786

REPORT MONTH DECEMBER

No.	Date	Type ¹	Duration (Hou:s)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
91-07	910914	S	120.0	C	4	N/A	N/A	N/A	Refueling and scheduled maintenance outage.
91-08	911206	F	241.5	B	9	N/A	N/A	N/A	Corrective maintenance work on equipment required for start-up.
91-09	911216	F	54.7	B	5	N/A	TB	FLT	The Main Generator Seal Oil System was not controlling pressure properly during Main Turbine testing. It was discovered that some pressure relief valves were incorrectly set and that an air side filter was installed backwards causing high backpressure to develop and a relief valve to lift. The lifting of the relief valve prevented adequate pressure from being developed at the seals and a subsequent loss of hydrogen pressure in the generator. The filter was reversed.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont. of Existing Outage
 5-Reduction
 9-Other

⁴
 IEEE 805-1983

⁵
 IEEE 803A-1983

ATTACHMENT 2
 ST-HL-AE-3973
 PAGE 5 OF 7

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-499
 UNIT 2
 DATE Jan. 6, 1992
 COMPLETED BY A.P. Kent
 TELEPHONE 512/972-7786

REPORT MONTH DECEMBER

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
91-10	911224	F	80.7	A	3	2-91-010	AB	SPT	<p>Reactor trip and safety injection occurred due to low pressurizer pressure. The pressurizer spray valve off of the 2A Reactor Coolant loop failed due to a positioner arm from the spray valve falling off because of a loose support bolt/nut arrangement. The positioner arm was replaced and its support supplemented by using a lock washer and a series of nuts. Corrective action to prevent recurrence will be discussed in the LER.</p> <p>With the unit in Mode 2, while attempting to transfer to governor valve control, the Electro-Hydraulic Control System responded incorrectly causing a turbine trip.</p> <p>Investigation revealed no significant problems. Throttle and governor valve testing was performed with satisfactory results.</p>

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Exam
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Cont. of Existing
 Outage
 5-Reduction
 9-Other

⁴ IEEE 805-1983

⁵ IEEE 803A-1983

ATTACHMENT 2
 ST-HL-AE-3973
 PAGE 6 OF 7

ATTACHMENT 2
ST-HL-AE-3973
PAGE 7 OF 7

FORVs and Safety Valves Summary

There were no FORV or Safety Valves challenged during the reporting period.