



**CENTERIOR
ENERGY**

PERRY NUCLEAR POWER PLANT

10 CENTER ROAD
PERRY, OHIO 44081
(216) 259-3737

Mail Address:
PO BOX 97
PERRY, OHIO 44081

Michael D. Lyster
VICE PRESIDENT - NUCLEAR

January 15, 1992
PY-CEI/NRR-1434 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Perry Nuclear Power Plant
Locket No. 50-440
Monthly Operating Report

Dear Sir:

Attached is the December 1991 Monthly Operating Report for Perry Unit 1. This report is submitted in accordance with Technical Specification 6.9.1.8.

If there are any questions, please feel free to call.

Sincerely,

Michael D. Lyster

MDL:DWC

Attachment

cc: NRR Project Manager
USNRC Senior Resident Inspector - Perry
USNRC, Region III
Director, Office of Resource Management
Ohio EPA

9201220243 911231
PDR ADDEN 05000440
R PDR

220165

Operating Companies
Cleveland Electric Illuminating
Toledo Edison

IE24
11

CLEVELAND ELECTRIC ILLUMINATING COMPANY

PERRY NUCLEAR POWER PLANT

December 1, 1991 - December 31, 1991

MONTHLY OPERATING REPORT TO NRC

DOCKET NUMBER : 50-440

LICENSE NUMBER: NPF-58

Table of Contents

Average Daily Unit Power Level	1
Operating Data Report	2
Unit Shutdowns and Power Reductions	3

Average Daily Unit Power Level

DOCKET NO. 50-440
UNIT Perry-1
DATE 1/15/92
Contact H.L. Hegrat
Telephone (216)259-3737

MONTH December 1991

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL</u> <u>(MWe-Net)</u>
1	1173	17	1177
2	1174	18	1181
3	1173	19	1181
4	1180	20	1178
5	1181	21	1175
6	1180	22	95
7	1171	23	0
8	1164	24	0
9	1174	25	0
10	1176	26	0
11	1174	27	0
12	1167	28	0
13	1169	29	0
14	1175	30	0
15	1179	31	0
16	1182		

Operating Data Report

UNIT: PERRY-1
DATE: 1/15/92

OPERATING STATUS

1. Docket: 50-440
2. Reporting Period: December 1991
3. Utility Contact: H.L. Hegrat (216) 259-3737
4. Licensed Thermal Power (MWt): 3579
5. Nameplate Rating (Gross MWe): 1250
6. Design Electrical Rating (Net MWe): 1191
7. Maximum Dependable Capacity (Gross MWe): 1225
8. Maximum Dependable Capacity (Net MWe): 1166
9. If changes occur in capacity ratings (Item Numbers 4 through 8) since last report, give reasons:
None
10. Power Level To Which Restricted, If Any (Net MWe): 100%
11. Reasons for Restrictions, If Any: Operating License Limit

	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
	744.0	8,760.0	36,108.0
	506.1	8,054.6	26,682.5
	0.0	0.0	0.0
	506.1	7,951.3	25,893.9
	0.0	0.0	0.0
	1,810,414	27,463,091	88,632,889
	621,555	9,410,388	30,494,802
	593,108	8,975,668	28,951,154
	68.0%	90.8%	71.7%
	68.0%	90.8%	71.7%
	68.4%	87.9%	69.9%
	66.9%	86.0%	67.3%
	32.0%	8.4%	8.1%
	237.9	724.5	2,283.3

UNIT SHUTDOWN AND POWER REDUCTIONS

REPORT MONTH December 1991

DOCKET NO. 50-440
 UNIT NAME Perry - 1
 DATE 1/15/92
 CONTACT H. L. Hegrat
 TELEPHONE (216)259-3737

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report No.	System Code ⁴	Component Code ⁵	Cause and Corrective Action to Prevent Recurrence
91-10	12/22/91	F	237.9	A	2	91-027	KE	PSX	Rupture of a non-isolatable 36" circulating water pipe elbow resulted in the unit being shutdown via a manual scram.

SUMMARY: During December 1991, Perry-1 began the month at full power operation. On December 22, 1991, the unit was shutdown as a result of a ruptured non-isolatable 36" circulating water pipe. The unit remained shutdown at month's end.

- ¹ F: Forced
 S: Scheduled
- ² Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

- ³ Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Continued
 5-Reduced Load
 9-Other

- ⁴ Exhibit 'C'-Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG1022)
- ⁵ Exhibit 1-Same Source