

RELATED CORRESPONDENCE

DOCKETED
USNRC

'84 JUN -6 A9:37 June 1, 1984

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
BRANCH

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of)	
)	Docket Nos. 50-445 and
TEXAS UTILITIES ELECTRIC)	50-446
COMPANY, <u>et al.</u>)	
)	(Application for
(Comanche Peak Steam Electric)	Operating Licenses)
Station, Units 1 and 2))	

AFFIDAVIT OF JOHN C. FINNERAN, JR.,
ROBERT C. IOTTI AND R. PETER DEUBLER
REGARDING DESIGN OF RICHMOND INSERTS
AND THEIR APPLICATION TO SUPPORT DESIGN

We, John C. Finneran, Jr., Robert C. Iotti, and R. Peter Deubler, being first duly sworn hereby depose and state as follows:¹

(Finneran) I am the Pipe Support Engineer for the Pipe Support Engineering Group at Comanche Peak Steam Electric Station. In this position, I oversee the design work of all pipe support design organizations for Comanche Peak. I have previously provided testimony in this proceeding. A statement of my professional and educational qualifications was received into evidence as Applicants' Exhibit 142B.

¹ Except as otherwise indicated, each Affiant attests to all parts of this affidavit.

(Iotti) I am the Chief Engineer, Applied Physics for Ebasco Services, Inc. I have been retained by Texas Utilities Electric Company to oversee the assessment of allegations regarding the design of piping and supports at Comanche Peak Steam Electric Station ("CPSES"). A statement of my educational and professional qualifications is attached to Applicants' letter of May 16, 1984 to the Licensing Board.

(Deubler) I am the Project Manager for the Comanche Peak Project and formerly Director of Engineering for NPS Industries, Inc. In this position, I oversee the design work of Nuclear Power Services on Comanche Peak including work related to the Richmond inserts. A statement of my professional and educational qualifications is submitted as Attachment G.

Q. What is the purpose of this Affidavit?

A. This Affidavit responds to six CASE allegations (see CASE's Proposed Findings at Section VIII) and two Board concerns (see Board Memorandum and Order of December 28, 1983 at 60-66) regarding the design of Richmond inserts. In addition, this Affidavit provides information in compliance with Items 10 and 11 of Applicants' Plan to Respond to Memorandum and Order (Quality Assurance for Design) ("Applicants' Plan") (February 3, 1984). CASE's six specific allegations are related to (1) the factor of safety used for Richmond inserts, (2) testing of Richmond inserts, (3) ability to resist axial torsion, (4) methods used to analyze connections, (5) bending moments in the bolts, and (6)

sharing of shear loads. Each item is addressed in the following sections of this Affidavit. In responding to CASE's concerns regarding items (1), (2) and (3) above, Applicants also address the two Board concerns and provide the information to comply with Applicants' Plan.

I. and II. FACTOR OF SAFETY USED FOR RICHMOND INSERTS AND TESTS

Q. Please state the concerns raised regarding the factor of safety used for Richmond inserts and associated testing.

A. This issue deals with a concern set forth in the Special Investigation Team's ("SIT") Report² that Applicants had employed a safety factor of 2 for Richmond inserts instead of the manufacturer's recommended value of 3.

The SIT and Board's concern is expressed in the Staff's Proposed Findings of Fact and Conclusions of Law (August 30, 1984) at 37-39. The two key issues regarding this area are (1) the appropriateness of Applicants' use of a safety factor which is lower than that recommended by the manufacturer, and (2) the lack of certain test data regarding Richmond inserts.

A. Factors of Safety

Q. Describe your evaluation of the safety factor used by Applicants as compared to that recommended by the manufacturer.

² NRC Inspection Report 50-445/82-26; 50-446/82-14 dated 2/15/83 at 17-23.

A. In the manufacturer's literature regarding Richmond inserts, based on testing the manufacturer specifies the ultimate loads associated with the various sized inserts. In addition, the manufacturer selects a factor of safety and back-calculates the corresponding allowable loads, i.e., the ultimate load divided by the safety factor is equal to the allowable load. It should be noted that this factor of safety and corresponding recommended allowable loads specified by the manufacturer apply only to the Richmond insert itself and not to the threaded rod (sometimes used interchangeably with bolt) which may be procured separately. Allowables for the threaded rod are those set forth in appropriate AISC Codes, e.g., for A-36 threaded rod the allowed load in shear is 17.7 kips.

In its design calculations, Applicants used higher allowable loads for the inserts than specified by the manufacturer. Accordingly, if the ultimate loads recommended by the manufacturer were applicable to Applicants' use of the inserts at CPSES, it could be viewed that Applicants had reduced the factor of safety recommended by the manufacturer. However, this is not the case. As set forth more fully below, taking into consideration all relevant factors (e.g., the differences between the conditions of the tests from which the Richmond insert manufacturer obtained its recommended ultimate loads and the conditions known by Applicants to exist in the actual

applications of the Richmond inserts at CPSES), the ultimate loads for the inserts are much higher than specified by the manufacturer, and the actual safety margins used by Applicants are essentially equivalent to those used by the manufacturer.

The current allowable recommended loads for the inserts by the Richmond Screw Anchor Co. are based on tests conducted at the Polytechnic Institute of Brooklyn in 1957. Richmond's recommended allowable (working) loads are based on the average ultimate test loads divided by a factor of safety which has varied over the years. Tests were conducted for 3/4, 1, and 1-1/4 inch diameter inserts in shear and 1 and 1-1/2 inch diameter inserts in tension. (However, at issue at CPSES are 1 inch and 1-1/2 inch inserts.)

For the shear tests, the concrete strength was 3220 psi, while for the tension tests the concrete strength was 2850 psi for the 1-inch diameter insert and 2950 psi for the 1-1/2 inch diameter insert. Data from the manufacturer's tests reflect that failure in all insert shear tests and the 1-1/2 inch insert tension tests occurred due to failure of the testing anchor stud bolt. Failure in the 1 inch tension test occurred due to failure of the insert by concrete cone pullout. It should be noted that failure of the insert can generally be equated with failure in the concrete resulting in a cone of concrete being pulled out ("concrete cone

pullout"³.) Table A specifies the manufacturer's recommended allowable loads, and in parentheses the associated factor of safety for each relevant size insert, as they evolved over the years.

TABLE A
Recommended Allowable Loads in Kips (Factor of Safety)

Richmond Bulletin	Shear		Tension	
	1"	1-1/2"	1"	1-1/2"
#6,1961			10.0 (2.3)	25 (2.6)
#6,1971			10.0 (2.3)	25 (2.6)
#6,1975	8.0 ^{xx,+} (3.0)	18* (3.0)	8.27 ⁺⁺ (3.0)	21.67 ⁺ (3.0)

* Estimated (apparently unsupported by manufacturer's tests)

+ Failure occurred in the testing anchor stud bolt

++ Failure occurred due to concrete cone pull-out

xx Ultimate shear load was in excess of 27,000 lbs., hence allowable could be 9.0 kips

From the foregoing, it can be seen that the failure modes of concern are either failure of the insert through concrete cone pullout or failure of the threaded rod or bolt used with the insert. As noted above, allowable loads and

³ Even if failure by internal damage of the insert occurs instead of concrete cone pullout, the load at which it occurs is essentially the same at which concrete cone pullout would occur (see the results of the March 1984 tests set forth in Attachment B).

factors of safety concerning the threaded rods used with the inserts are established by Code, adhered to by Applicants and not an issue here.

The major factor affecting cone pullout is the strength of the concrete in which the inserts are placed. Significantly, the manufacturer's tests were conducted with concrete which had a strength of between 2850 and 3220 psi (approximately 3000 psi). While the concrete at CPSES is designed for 4000 psi, it actually ranges from 4500 to above 5000 psi. We believe that the additional strength of the concrete results in a much higher ultimate failure load. Accordingly, it was Applicants' position that use of allowable loads higher than recommended by the manufacturer was justified based on the higher ultimate loads for the particular circumstances at CPSES, and the safety factor specified by the manufacturers would be essentially met.

Q. Have there been any analyses which verify the appropriateness of Applicants' position?

A. Yes. First we would like to discuss the safety factors in tension. The basis for Applicants' position that the ultimate load is much higher than established by the manufacturer's test has been verified by a simple comparison with the manufacturer's test results. The mechanism of tensile failure of Richmond inserts and concrete cone pullout is no doubt a complex mechanism difficult to

precisely analyze. However, the increase in the ultimate insert tensile capacity due to greater strength concrete can be conservatively calculated using the following equation:⁴

$$T = 4 \phi (f'_c)^{1/2}$$

where: T = ultimate tensile capacity

ϕ = empirically derived constant

f'_c = compressive strength of concrete

To determine the value of ϕ , we applied the above written formula to the manufacturer's test data (i.e., ultimate loads and compressive strength of concrete) and back calculated ϕ . The values for ϕ , calculated as noted above, are set forth in Table B. While the computed values relate only to the 1 and 1-1/2 inch inserts (the ones of concern), they compare favorably with values computed from other sized inserts.

TABLE B

Richmond Insert Dia. (in)	3/4	7/8	1	1-1/4	1-1/2
Value of ϕ	.85*	.81*	.84	.77*	.84**

* Deduced from manufacturer's allowable and a factor of safety of 3.0, not from direct test data, with $f'_c = 2850$ psi.

** This value is an estimate since the failure mode in the manufacturer's test was rod failure and not concrete failure. However, it is above .79 which is the value calculated assuming concrete failure occurred at rod failure.

⁴ This equation is well recognized in industry and extensively used in numerous text books and learned treatises.

Applying the imperically derived values of ϕ in equation, and factoring in the range of actual strengths of concrete used at CPSES, the ultimate tensile loads can be calculated. These calculated ultimate tensile loads along with the allowable design loads used at CPSES and the associated safety factor (ultimate load divided by allowable load) are set forth in Table C.

TABLE C

Estimated Ultimate Tensile Loads & Safety Factors For Richmond Inserts

Richmond Size	ϕ	Allowable Insert Loads Used In Design at CPSES	Estimated Ultimate Loads & (Safety Factors)		
			<u>4000 psi</u>	<u>4500 psi</u>	<u>5000 psi</u>
1"	.84	11.5 ^k	29.8 ^k (2.6)	31.6 ^k (2.7)	33.4 ^k (2.9)
1-1/2"	.84	31.3 ^k	80.9 ^k (2.6)	85.8 ^k (2.7)	90.4 ^k (2.9)

Thus, the estimated minimum safety factors for Richmond inserts in tension which result from the design approach employed at CPSES using actual conditions existing vary in reality between 2.7 to 2.9. (Even had a value of $\phi = .79$ been used, comparable safety factors would result, e.g., 2.7 instead of 2.9.)

It should be noted that out of 912 supports reviewed in Unit 1 and common areas employing Richmond inserts, 865 utilize low strength threaded rods (864 SA-36 and one SA-307 (bolt)). The remaining are high strength threaded rods (45

SA-193, one SA-108, one SA-325). The low strength threaded rods/bolts have lower allowable loads than the allowable loads for the Richmond inserts used in the CPSES design, noted above. Accordingly, while Table C sets forth the allowable loads for the Richmond inserts for pure tension or shear loads, the governing limits on design would not be the allowables for the inserts, but rather the allowable loads of the threaded rods. As a practical matter, however, since inserts and their rods are seldom loaded in pure tension or shear, but are loaded in combined loadings, the governing limit on design will be the interaction ratio for the insert.⁵

Q. On what basis was the shear allowable value established for the 1-1/2 inch insert in the absence of a shear test for that size insert?

A. The shear value was based on an extrapolation from the existing test data. The test on the 1 inch insert showed that the shear ultimate capacity was approximately equal to the tension ultimate capacity. It also showed that the ultimate shear capacity of the testings anchor studbolt governed rather than the insert's capacity. Therefore, the insert's capacity was actually higher than the shear failure

⁵ The interaction ration discussed later in this affidavit for either the insert or the threaded rod is expressed as $\frac{T}{T_A} + \frac{S}{S_A} < 1.0$ where T, S, T_A and S_A are the tension, shear, allowable tension and shear in the insert or threaded rod, and n = 4/3 for the insert and 2 for the rod.

load of the test. This prompted the Applicants to set the shear allowable for the insert equal to its pullout (tensile allowable). Applicants further reduced the shear allowable by multiplying its tension allowable by the ratio of the manufacturer's working shear load (18 kips for 1-1/2 inch insert), to the manufacturer's recommended working tensile load (21.67 kips for 1-1/2 inch insert).

B. Verification Tests

- Q. What tests have been conducted to demonstrate the effect of shear loads on Richmond inserts?
- A. To comply with the directives of the SIT, shear tests were conducted at CPSES on 1-1/2 inch Richmond inserts in March 1983. The test report summarizing those tests is included as Attachment A to this testimony. The salient conclusions of these test, are summarized below.

A total of nine specimens were tested. All utilized 1-1/2 inch type EC-6W inserts in concrete representative of the strength and reinforcement found at CPSES. For the test the concrete strength was approximately 4600 psi. On six specimens a 1 inch thick washer plate was inserted between the shear plate and the insert to represent the washer which is used in pipe hanger installations. Three specimens without washers employed A-490 bolts. Three more specimens with washers also used A-490 bolts, and finally the three remaining specimens (with washers) utilized SA-36 threaded rods.

In no case was the test permitted to go to ultimate failure. Loading application was halted where the load had reached a magnitude considered to be sufficient in comparison with the design load values. (At this point the NRC representative witnessing the test indicated his concurrence).

In spite of the fact that the test did not take the inserts to failure, the results indicated that the performance capabilities of the Richmond inserts in shear exceed the design allowable by a ratio in excess of 3.3 to 1. Because the tests did not go to failure, the actual ratio is higher and the results are conservative.

Moreover, test results for the specimens with and without the 1 inch thick washer were comparable, indicating that the presence of the washer has little effect on the performance of the threaded connection/bolt or the Richmond insert. If any bending stress is introduced in the bolt as a result of the 1 inch thick washer, the test results show that it is not significant enough to distinguish the difference. These results justify the shear allowables regarding Richmond inserts used by Applicants in the design of CPSES.

Q. Have other tests been conducted on the Richmond inserts?

A. Yes. As a result of the allegations by CASE that the preceding tests were not sufficient to address combined tension and shear loadings⁶ and the Board's concern with the absence of test data, Applicants proposed a plan⁷ which stated that Applicants would:

"Provide evidence of the capability of Richmond inserts to accept the maximum loads to which they will be subjected in tension, shear and combined tension and shear, with ample margins of safety. The evidence will be generated by a combination of tests and analyses."

To fulfill this plan Applicants performed another series of tests in March and April, 1984. A final report summarizing these tests is included as Attachment B to this testimony.

In summary, these tests were performed to determine the load carrying characteristics of 1-1/2 inch type EC-6W and 1 inch type EC-2W Richmond inserts when subjected to tension only, shear only and combined shear and tension loadings. The strength, deflections and type of deformations produced by these loadings were determined. The tension and shear testing conformed to the requirements of ASTM-E488-81, "Standard Test Methods for Strength of Anchors in Concrete and Masonry Elements." The number of samples of each diameter Richmond insert was in accordance with Section 7 of ASTM-E488-81. However, Applicants are not aware of any

⁶ CASE Proposed Findings of Fact and Conclusions of Law at Section VII and VIII.

⁷ Applicants' Plan at 7.

standard method or test for combined tension and shear. For such tests, tension and shear loads were applied to the test specimen in equal increments, i.e. the tension load was always equal to the shear load. (For a detailed description of the apparatus refer to Attachment B.)

The tests utilized a total of 30 Richmond inserts (fifteen 1-1/2 inch and fifteen 1 inch). To prepare for the tests these inserts and several more spares of both sizes were cast in concrete slabs which utilized the minimum type of surface reinforcement encountered in the field (#7 grade 60 bars at 10 inches on center in each direction near the surface). The concrete strength was also typical of that encountered in the field, having an average compressive strength in excess of 4900 psi.

To ensure that the tests actually tested the inserts' capacity (and not the capacity of the threaded rods), high strength threaded rods/bolts were utilized in all cases. As previously stated, in field installation it is the threaded rod which most often has the lower allowable load in pure shear or tension. In this regard, in its Proposed Findings at Section VII, CASE has alleged that the wrong allowables for inserts have been used at Comanche Peak. This is not so. The proper allowables for the inserts have been used.

The results of the tests are presented in Attachment B and summarized in Table D, below.

TABLE D

Ultimate Shear, Tensile and Combined Capacities of Richmond Inserts

Richmond Insert Dia.	Tension (T)			Shear (S)		
	Allowable (T _A)	Ultimate (T _U)	FS	Allowable (S _A)	Ultimate (S _U)	FS
1"	11.5 ^k	41.27 ^k	3.59	11.5 ^k	40.28	3.50
1-1/2"	31.3 ^k	101.96 ^k	3.26	27.0 ^k	94.34 ^k	3.49

Combined Shear and Tension⁺

1"	28.35 ^k (4.15)
1-1/2"	63.47 ^k (3.68)

+ Utilizes interaction formula $(T/T_U)^{4/3} + (S/S_U)^{4/3} = 1$.

Factor of Safety in this case is computed from

$$\left(\frac{T}{T_A \times FS}\right)^{4/3} + \left(\frac{S}{S_A \times FS}\right)^{4/3} = 1$$

The test results confirm the judgment of Applicants that (1) shear and tensile ultimate capacities are nearly the same and (2) the actual factors of safety are in excess of 3.0 for shear, tension and combined shear-tension loadings. An important concomitant result of this series of tests is the confirmation of the conservatism of the tension-shear interaction formula utilized for design. This formula, which is suggested by the PCI Design Handbook, Precast and Prestressed Concrete, 1971 at 6-20, states that the interaction between tension and shear goes as the 4/3 power. This formula is verified by the results of these

tests. See Attachment C which shows that all test points fall outside the interaction curve, thus providing evidence of the conservatism of the interaction formula.

Q. What would you conclude from the result of these and prior tests?

A. We would conclude that the margins of safety for Richmond inserts for loading in shear, tension and combined shear-tension for the conditions expected in the field are in excess of a factor of 3.0.

Q. In addition to the general concerns raised about testing of Richmond inserts, are there specific concerns about the tests which you wish to address?

A. Yes. Apparently faced with results of the 1983 shear tests which indicated the significant capacity of the Richmond inserts over design, CASE challenged the validity of the test by alleging that the conditions of the reinforcement in the concrete tests labs did not represent the conditions in the field. As stated in Attachment A, however, the concrete used in the tests was representative of concrete in the plant. Indeed, in Attachment A is the actual test report on the concrete used in the tests. Applicants have conducted a review of a representative sample of test reports of concrete used at CPSES to assure that such concrete is essentially the same as that used in the tests. In addition, Applicants have reviewed NCRs regarding concrete at CPSES to provide additional assurance that the concrete

used in these tests was representative of that used at CPSES. From our review, we conclude that test conditions are representative of conditions at CPSES.

Moreover, to be very conservative, the new tests conducted in March 1984, employed two layers of reinforcement rods rather than 4 layers used in the prior test and at CPSES. As seen in Attachment B, the capacities of the Richmonds were not impaired.

In any event, the difference in reinforcement in the concrete (the concern expressed by CASE) is not significant when compared to other factors. If rebar was a dominant factor, it would be evident from a comparison of the results of the March 1983 tests (using 4 layers of rebar) and the March 1984 tests (using 2 layers of rebar). However, a comparison of those results (including bolt deflections) indicates that the amount of rebar is not a significant factor. See also Tr. 6495-6500 wherein the cognizant Staff witness concurs with this assessment.

III. ABILITY TO RESIST AXIAL TORSION

- Q. Are you familiar with the issue regarding the ability to resist axial torsion?

A. Yes. This issue refers to the concern by CASE of the ability of the Richmond assembly (including the threaded rod) to resist "axial" torsion. In the Board's Memorandum and Order of December 28, 1983 at 62, the Board states that this concern is important because

"The Richmond was tested without being connected to a steel member that could induce torsion into the bolt. Consequently, the safety of the Richmond depends in part on the test described in subsection 1., [8] above, and in part on the engineering analysis of the effects of torsion on the bolt."

The Board concurred with CASE's view that the Applicants' manner of computing the tension force in the bolt of the Richmond insert assembly resulting from torsion in the tube steel is incorrect. Id.

Q. Describe Applicants' method of computing the torsion forces in the bolt.

A. In computing the torsion force in the bolt of a Richmond insert, the formula $T = Fd$ is used; where T = the torsion applied to the steel tube (see Figures 1 and 2 of Attachment D), F = the tension in the bolt, and d = the distance from the bolt to the force acting on the washer. The Board believed that Applicants were using the distance d as equal to $2/3$ of the one half of the width of the washer. See December 28, 1983 Memorandum and Order at 62-66.

⁸ This quote refers to the March 1983 test required by the SIT, completed by Applicants, and discussed above.

Applicants, in general, did not use this distance, but instead relied on predeveloped charts which use the distance from the bolt centerline to the centroid of a triangular compressive load distribution, offset from the bolt centerline. When configurations were encountered that are not covered by the predeveloped chart, and for designs performed prior to the development of the charts, Applicants did use the distance questioned by the Board, i.e., $2/3$ of the distance between the center of the bolt and the edge of the washer. The distance derived from this calculation is always smaller than that which would be obtained from the predeveloped charts, which is the distance from the centerline of the bolt to the centroid of the triangular compressive load distribution defined between the neutral axis and the edge of the washer. (See Attachment D.)

Since the distances from the charts predeveloped would result in smaller calculated tension in the bolt, we have chosen to focus our discussion on the effects of using this distance (i.e., that obtained from the predeveloped charts) in order to determine whether it accurately reflects the appropriate load distribution.

To illustrate why the Board might be confused as to what distances were used, we will make use of a similar figure (Figure 1 of Attachment D) to that utilized by the Board in its Memorandum and Order of December 28 at 77. The major difference between Figure 1 and the Board's figure

(which is included as Figure 2 of Attachment D) is in the meaning of the distance d_2 . This is the distance the Board believes Applicants used in the formula $T=Fd$. As shown in Figure 2 of Attachment D that distance is equal to $2/3$ of the washer half width because it is shown as starting from the center of the bolt.

Applicants generally have used the distance d'_2 from figure 1 of Attachment D, which represents the distance between the centerline of the bolt and the centroid of a triangular compressive stress distribution defined between the location of the neutral axis of bending and the edge of the washer. This axis is not located in the center of the bolt but it is shifted toward the edge of the washer placed in compression by the applied torsion. The location of the neutral axis and the tension in the bolt can be derived by solving the static equilibrium and strain compatibility equations. Such a solution is provided in Attachment D, where it is shown that d_2 is generally greater than d'_2 . This clarifies the circumstances which may have confused the Board. The solution for d'_2 provided in Attachment D is correct only if the equation expressing strain compatibility between the concrete and the bolt is valid. While that equation is valid if the problem were truly two dimensional, and is generally employed for solving problems of this kind (see CASE Exhibit 903, Excerpts from Blodgett's Column Base Plates), one cannot say with certainty whether the same form

would apply in the three dimensional problem which is present in the field. Because there is no preload (other than snug tightness) of the bolt and hence, no continuity between the tube steel, the bolt, the lower washer and the concrete, the distribution of strains between the bolt and the concrete is a tri-dimensional complex pattern.

Q. Had Applicants performed any additional analysis to evaluate this complex situation?

A. Yes. To study this pattern Applicants performed detailed finite element analyses utilizing the STARDYNE computer program. A description of the model and results of the analyses is given in Attachments E1 and E2. The results of the analyses indicate that the formulas used by Applicants as described above did not precisely model the resulting forces. The formulas used by Applicants resulted in a calculated force that was low for all but six supports⁹ by as much as 25 percent. (As noted later in this Affidavit, the finite element analyses refined this calculation and only predicted an 18 percent increase; in addition, because of conservatism in the methodology and process used, in all cases allowables would not have been exceeded.)

Q. What did the results of the finite element analyses show?

⁹ There are six 4 x 4 x 1/2 tube steel sections loaded primarily in torsion or shear for which this effect would result in a calculated 33 percent increase. This increase has been factored into the interaction formulas in Table 1 (attached) and has been found to be acceptable for the six supports.

A. The results of the finite element analyses showed the following:

- a) The transfer of moment (torque) into the couple which results in bolt tension and concrete compression occurs at the tangent point between the tube and the washer. In this respect Mr. Doyle (and the Board) were correct. However, due to the stiffness of the steel, the transfer is along a line and is not spread over an area.
- b) The compressive force distribution in the concrete is reasonably linear and extends to the edge of the washer. Here, Applicants were right as explained in e) below.
- c) The quasi-linear force distribution in the concrete, however, is not the same at different locations parallel to, but away from the line drawn from the bolt centerline to the edge of the washer (this is due to tri-dimensional effects) and this is what causes the difference between the original approach used for design and the present results.

The centroid of the triangular distribution existing in the center of the washer (line between center of bolt and edge of washer) coincides vertically with the tangent point of the tube steel and the washer, i.e., the neutral axis adjusts accordingly.

- d) The increase in bolt tension for the worst configuration is less than 25 percent for bolt holes located along the tube steel centerline (see note 9) and this can be calculated by using the expression $T = Pd_4$ where d_4 is the distance between the bolt centerline and the tangent point of the tube steel and the washer.
- e) Applicants ran a sensitivity study and the stiffness of the concrete was varied. For the stiffness existing in the field, the distribution of compressive stresses is essentially linear and extends to the washer as shown in Attachment E2. As the stiffness of the concrete is decreased, the distribution of compressive forces in the concrete becomes non-linear, with the peak of the distribution coinciding vertically with the tangent point between the tube and the washer.
- f) Although not raised as an issue in this case, the finite element model was also executed for the cases in which the bolt holes are offset from the centerline of the tube steel. The offset in the model was equal to the maximum value permitted by the design criteria. This was done to assure ourselves that the largest possible increase in

tension over that computed initially would be determined. Applicants could have used the same method outlined in d) above, i.e., using the lever arm defined as the distance between the bolt centerline and the tangent point of tube steel to washer, to compute the increase in tension on the bolt for offset bolt holes. However, the finite element analyses indicate that this coupling method is not applicable for the bounding eccentricity (which is for 4" x 4" tube steel, 3/4 inch from the center or 1/2 inch from the tangent point of tube steel and washer) which is the worst case that exists in the field.

- g) The finite element analyses discussed in f) above shows that the torsion does not result in a concrete compression/bolt tension couple as discussed above, but rather results in a shear couple at the top and bottom of the bolt which puts the bolt in bending.

Q. Is there an adverse effect on the safety of the plant from these results?

A. No. As discussed below, this will result in no adverse effect on the safety of the plant.

Table 1 (attached) lists (Unit 1 and Common) supports using tube steel with Richmond inserts which are safety related and which may be primarily loaded in torsion or shear. This table also lists the existing eccentricities and the loads for the inserts. It is evident that the preponderant number of supports (90%) have tube steel connected to Richmond inserts at the centerline of the tube steel (zero offset) or with small eccentricities. Cases of extreme eccentricities are few (only in about 18 cases out of the 102 cases of 4" x 4" tube steel (mostly loaded in torsion or shear) do eccentricities equal to or exceed 3/8 inch). For the other 53 supports loaded primarily in torsion or shear, only three have offsets equal to or in

excess of one inch (one inch in six and eight inch TS would give a comparable effect as the 3/8 inch in the four inch TS).

For these, the maximum possible underestimation of the tension resulting in the bolt is about 25 percent. (See note 9.) The finite element analyses which will be discussed later actually indicate that the maximum experienced increase is only 18 percent. This 25 percent corresponds to the difference between the proper lever arm, i.e., that between the bolt centerline and the tangent point of tube steel to washer, and that used in design for the most common 4" x 4" tube steel (thickness = 3/8 inch). Other tube steel dimensions will have lower differences. (See note 9.) The 25% increase (and the 33% increase for the 4"x 4" x 1/2" tube steel cases) can be accommodated by the supports.

In the process of performing the finite element analyses, described in Attachment E, Applicants noted that when it is assumed that no clearance exists between the tube steel and the bolt, a shear couple is created which places the bolt in bending. The effect becomes pronounced when the bolt holes are offset to their largest values. The prior manual or chart methods of analyses cannot account for the bending effect. To investigate the possible adverse effects on the connections Applicants developed a screening

criterion, based on a very conservative analysis, by which we could judge which particular supports require closer scrutiny.

This criterion requires that any connection where either the insert interaction exceeds unity or the bolt interaction equation exceeds 1.75 must be listed as a candidate for further evaluation. The factor of 1.75 for the bolt derives from two factors, each having a value of 1.33, which represent, respectively, the difference between the bolt bending stresses predicted by finite element analyses and those predicted by simple flexure manual calculations (the latter are 33 percent higher, as indicated in Attachment E), and the difference between values of $.75 F_y$ (the allowable bending stress) and F_y (where F_y is yield strength of bolt material). For establishment of the criterion, Applicants allow the outer fiber stresses of the bolt to reach yield, because the manual method of analysis employed to compute such stresses has been shown by the tests discussed in Attachment F to be extremely conservative.

The factors of safety inherent in the methods of calculation employed to establish the interaction ratios needed for the criterion are shown in Table 1 of Attachment F (method D) and are shown to be in excess of 10. The method of computation of the interactions is summarized below.

A portion of the torsional moment is applied to the bolt as a bending moment, which accounts for the internally created shear couple. Depending on the offset of the bolt hole, different fractions of this moment are inputted as direct bending moment of the bolt. For any offset exceeding 1/4 inch, all the moment is inputted as bending moment of the bolt. Even with zero offset, 38.4 percent of the external moment for 1-1/2 inch bolt (17 percent for the 1 inch bolt) is applied to the bolt as a bending moment.

The moment in the bolt induced by the shear is determined by multiplying the shear value by the distance from the center of the tube steel to the concrete and multiplying this times 0.58 for 1-1/2 inch bolts with no offset (or 0.72 for 1 inch bolts with no offset, or 1.0 for bolts with offset).¹⁰ Any fraction of the moments not inputted into the bolt as bending is coupled out into bolt tension as described for the traditional method. The Board

¹⁰ The fractions of the moments (where these fractions are 0.58, 0.72 and 1.0 for 1-1/2 inches with no offset, 1 inch with no offset and 1 inch with offset, respectively) that are assumed to go into bending are extrapolated from the recent worst case shear finite element analyses conducted on a single size tube steel ("TS") (4" x 4" x 3/8") and prior analyses (also conducted on 4" x 4" TS) performed in September of 1982. (SIT Report at 21.) Since none of these analyses were conducted at intermediate offsets, a linear distribution of the fraction of external moment going into the bolt as bending is assumed from zero offset to an offset of 1/4 inch. Above 1/4 inch offset all the external moment is assumed to go into bending the bolt. Also, for any offset all of the bending due to shear is assumed to go into the bolt.

should recall that in the traditional method of analyses discussed previously, all of this moment would be coupled out as tension in the bolt. Any external pull is added to this tension to give the total tension. The resulting tension, applied shear, and bolt bending are used in the following bolt interaction equation:

$$(T/T_A)^2 + (S/S_A)^2 + (M_b/M_{ba}) = \text{bolt interaction ratio}$$

where M_{ba} is the allowable bolt bending moment as computed from $M_{ba} c/I = 0.75 F_y$, T_A is the allowable bolt tension and S_A is the allowable bolt shear. The tension (T) equals the applied external tension plus any coupled-out tension resulting from torsion. The shear (S) is the applied external shear, and M_b (the applied bolt bending moment), has been defined above. The bending moment in the bolt is converted to a couple within the bolt (moment arm = effective diameter of the bolt).

The total pull of the insert, T_{IP} , defined as the equivalent total axial load, is calculated by adding the tension component of the bolt internal couple to the tension, T, calculated above. This total insert pull and the applied shear are used in the insert interaction equation, noted below,

$$\frac{T_{IP}}{T_{AI}}^{4/3} + \frac{S}{S_{AI}}^{4/3} = \text{insert interaction}$$

where T_{AI} is the allowable insert tension and S_{AI} is the allowable insert shear, T_{IP} is the total insert pull and S is the shear on the insert.

The manner in which these interaction ratios are computed is based on very conservative assumptions (see e.g., note 10), which were not borne out by the testing noted in Attachment F (e.g., the tests indicate that larger offsets are needed for these limiting conditions to be valid and that even at the largest offset not all of the moment goes into bending). For the larger tube steel sizes (i.e., greater than 4" x 4") the conservatism is compounded since the same percentages were used whereas the effect of the offset would be progressively smaller.

Table 1 (attached) summarizes the results of the evaluation of the interaction ratios for the safety related supports which can experience loads primarily in torsion. From Table 1 (attached) there are a total of 12 supports which exceeded the interaction ratio. These mostly fall in the following categories:

- (a) tube steel connections with relatively large offsets, and

(b) tube steel connections with smaller or zero offsets which employ 1 inch bolts, which by virtue of the small section modulus of the bolt are less capable of withstanding bending loads.

Although Applicants are concerned with the conservatively calculated bending stresses in the bolts, from the results of testing noted below, there is no safety concern with these connections.

Of the tests reported in Attachment F, the most adverse test is the torsional test of the 4" x 4" x 3/8" TS insert with the 3/4 inch offset which indicated failure (or near failure) at approximately 10,600 lbs (applied 2 inches above the top of the tube steel). The configuration of this test is designed to encompass many of the supports listed in Table 1 (attached). If the 4" x 4" x 3/8" connection with a 1-1/2 inch bolt having the highest torsion and shear is examined against the test results the following is noted. This support, CT-1-053-408-C62R, is computed to exceed the interaction ratio criterion when subject to a shear load of 2.479 kips and a torsion of 9.249 in-kips, with no offset. The test conducted for the 4" x 4" x 3/8" tube steel with a 3/4 inch offset (which is worse than that of the related support) loads the connection in torsion and shear. When the shear equals 3 kips, the corresponding torsion is 21 in-kips. At this loading condition, the measured deflection of the assembly is 0.05 inches, which is 6 percent of the

ultimate deflection. The factor of safety to failure for the support (load = 2.479 kips shear and 9.249 in-kips torsion) is greater than 4 based on the test results. Thus, even though the interaction ratio criterion indicates that the worst case support, CT-1-053-408-C62R, may be suspect, the test shows that there is no safety concern, and that an adequate margin of safety exists.

Applicants recognize that the criterion and method employed to determine whether the bolts can accept the loads in these instances is not covered by the Code. The Code does not provide for such eventuality, as it assumes bolts to be loaded in shear and tension only. The bolts can indeed accept the shear loads, but tension has no real meaning when greatly offset holes are present. As is evident from Attachment F and also the finite element analysis of Attachment E, the shear couple generated in such instances gives rise to a combination of bending, tension and shear of the bolt, for which the Code makes no provision. The tests support the conservatism of the chosen approach. (It should also be noted that from the test results shown in Attachment F, one can verify that tube steel deformations for the applied loads are low.)

IV. Method Used To Analyze Connections¹¹


- Q. Have you reviewed the issue regarding methods used to analyze connections?
- A. Yes. In Section VIII of CASE's Findings, Messrs. Walsh and Doyle expressed concerns over the methods used to analyze the connections of the bolts, tube steel and Richmond inserts. Specifically, this concern focuses on the acceptability of release of all moments except for the torsional moment (M_x).

CASE agrees that the moment in the tube (M_y) about the axis of the bolt cannot develop, but they state that the other moment (M_z) (which would tend to produce prying action, if any), should either be considered whenever the moment which produces torsion (M_x) is considered, or both M_x and M_z should be released. CASE states further at VIII-6 that "the ability to rotate about the local Z axis is inhibited; therefore, prying (moment coupling) exists." (Refer to Figure 1 for an explanation of the coordinates and moments.)

¹¹ In the area, CASE's concern regarding the method selected by Applicants to react the shears is addressed in the preceding discussion of the ability to resist axial torsion.

FIGURE 1

EXPLANATION OF COORDINATES & MOMENTS



To examine the validity of this concern we have utilized a finite element analysis which employs the same model and method as the analyses described in Attachments E1 and E2, and which examines the behavior of the joints under the combined influence of axial (parallel to the insert bolt, M_z) and torsional loads or purely axial load. The purely torsional load was addressed separately via another finite element analysis, referred to previously. Clearly for single tubes loaded in torsion, the restraint of torsional moment is required for stability. Similarly, for single tubes loaded torsionally and axially, the axial displacement resulting from the maximum permissible axial load in the tube is insufficient to prevent the torsion constraint as discussed below. Moreover, the single tubes are all lightly loaded, further pointing to the correctness of modelling the torsional moment constraint. The resistance of the attachment assembly under pure torsional loading was demonstrated to develop bearing between the tube and upper shim plate solely along the line of tangency at the corner of the tube. The couple between the bearing area and the bolt tension equals the applied torsional moment; therefore, the prying action in the bolt can be calculated directly.

due to bolt elongation (along the Y direction) is sufficient to cause loss of contact with the washer. Thus, there is no prying action. For pure axial loads, i.e. loads applied to the tube steel between Richmond inserts in the y direction, there is no prying action and their release of the moment about the Z axis is the correct way to model the joint.

A parametric study of the loading was performed to analyze the effect of bending moment M_z on the prying action which occurs due to the torsional load. For the study, a 4 x 4 x 3/8 inch tube with 1-1/2 inch diameter inserts located 20 inches on center was analyzed.

The bending moment is introduced by the addition of an axial load at the center of the attachment assembly.

Two parameters were analyzed:

- a. Variable applied bending load with constant torsional load.
- b. Variable torsional load with constant bending load.

Analyses were performed for the load cases shown below in Table E. Additional data presented include the fixed end moment ("FEM") calculated for the applied pull load had the connection been modelled as fixed with respect to the M_z in STRUDL, and the ratio of the FEM to the applied torsional load ("FEM/Torsion").

TABLE E

LOADING NUMBER	TORSIONAL LOAD (in-lbs.)	AXIAL LOAD (lbs.)	FEM (in-lbs.)	FEM/Torsion
1	4000	2000	5,000	1.25
2	4000	8000	25,000	5.0
3	4000	20000	50,000	12.5
4	4000	40000	100,000	25.0
5	1000	40000	100,000	100.0
6	0	40000	0	0

Each load case was analyzed to identify the mode of resistance of the assembly. Results for the first five analyses showed the area of bearing between the structural tube and the top shim plate to be limited to the line along the tangent point of the tube corner. Any bending resistance is developed by the eccentricity due to translation of the torsional resistance toward the end of the tube. The sixth analysis showed that no bending resistance was developed in the absence of a torsional moment.

Table F summarizes the results for each load case. Information tabulated includes the following items:

- a. Loading-torsion (in-lbs.); pull (lbs.)
- b. Expected bolt reaction neglecting bending in the bolt proper (lbs.)¹²

¹² In computing the bolt reaction, the axial load was added to the tension computed from the torsion by the point-of-tangency method.

- c. Bolt reaction from analysis (lbs.)
- d. Maximum possible bending resistance with torsional loading governing prying action (in-lbs.)
- e. Bending resistance from analysis (in-lbs.)

TABLE F

Loading No.	Loading Torsion	Pull	Expected Bolt Load	Actual Bolt Reaction	Max Bending ¹³ Resistance	Actual Bending Resistance
1	4000	2000	2600	2600	3200	1618
2	4000	8000	5600	5600	3200	2684
3	4000	20000	11600	11500	3200	2966
4	4000	40000	21600	21400	3200	2886
5	1000	40000	20400	20300	800	600
6	0	40000	20000	20001	0	0

The flexibility of the connection under bending is due to the elongation of the bolt from the tensile loads.

Loading No. 6 demonstrates that there is no bearing between the tube and the washer plate if torsion is not present.

¹³ This moment resistance is established by assuming (from finite element analysis) that the reaction to the combined torsion and axial load (which results in the M_z moment) occurs at the intersection of the line of tangency and the edge of the washer (point C of Figure 1). The distance between that point and the center of the bolt is 2 inches in the x direction (M_z lever arm). For example, the reaction due to the applied torsion at that point is 1600 lbs. for a 4000 in-lb. torsion (this is computed from $\frac{4000}{2(1.25)}$). Thus, the resistance to the

moment about the z axis due to the torsion reaction for this case is 3200 in-lbs. No increase in bolt tension would occur until this resistance is exceeded as a result of the pull. However, when the actual bending resistance (obtained from the finite element analyses which considered both torsion and bending (M_z)) is compared to the max-bending resistance due to pure torsion, it is seen that the actual value is always lower, indicating no prying action from the bending.

Based on the results of this study, it is evident that any additional bolt tension need only be considered when torsional loads are present. The increased tension can be calculated directly from the ratio of the torsion and distance from the bolt centerline to the tangent line of the corner of the tube. It is also evident that modelling the joint with the M_z moment released is a more correct manner than modelling it as fixed because of the low bending resistance of the joint. Applicants recognize, and calculations demonstrate, that modelling of the joints as pinned instead of fixed would result in stresses and deflections of the member steel tubes which are higher than those which would be calculated on the basis of fixed connections. On the other hand, fixity of the connection results in higher loads on the inserts. Analyses indicate that the percentage increase in member loads resulting from releasing all moments is not nearly as large as the decrease in load of the insert. Design of the connection with the assumption of a M_z moment constraint produces conservative loads for the Richmond inserts, which are generally the limiting factors, while producing loads on member steel which are minimally unconservative. Table G, below, shows the M_z moment carrying capacity of the lightest tube steel section for large bore piping and of the 1-1/2 inch insert connection based on the equation

M_{max} Tube Steel = $.6 F_y$ x Section Modulus; Insert M_{max} = Allowable Tension x Lever Arm from bolt centerline to tangency point.

TABLE G

TS Size	Section Modulus	Tube Steel M_{max} (in-kips)	Insert M_{max} (in-kips)
4x4x1/4	4.11	92.22	42.16
6x6x1/4	10.1	226.64	84.33
8x8x1/4	18.8	421.87	112.44
10x10x1/4	30.1	675.44	140.55

This shows that the insert is the limiting factor by at least a factor of 2. The difference in the bending moment between a member with pinned ends and a member with fixed ends is less than 2. Therefore, if a support was modelled with M_z fixed, releasing M_z would lower the insert loads, increase the tube steel bending moment, but not overstress the tube steel.

Prior to beginning the as-built program, NPSI began analyzing the joints as pinned. If the designer was not sure whether the pinned model was correct he would check if there was sufficient elongation in the bolt to allow the rotation of the tube steel. The use of the pinned assumption is normal structural design practice. In fact, the 8th Ed. AISC Specification, paragraph 1.15.4, states that inelastic action in the connection is permitted to accommodate end rotations.

PSE leaves it to the designers' judgment to decide whether the moment should be released and, therefore, has not always reanalyzed the joints during the as-built program as pinned. PSE has in some cases still retained constraint on the M_z moment. Even though the finite element analyses indicate that this is an appropriate modelling assumption, we would like to place in perspective the effect of this assumption on the steel member stresses.

Applicants have reanalyzed several support configurations selected at random assuming that all moments would be released. Table 2 (attached) provides a comparison between the maximum stresses and deflections of the members calculated with and without the constrained moment. Also shown in this table are the margins to allowable loads which exist. As can be readily seen, adequate margins exist, even with the fully released moments. As a final point, the effect of modelling on the support stiffness should also be addressed.

CASE contends that the difference in modelling can result in substantially different stiffnesses, and hence, invalidate the assumption of generic stiffness being applicable to the piping analysis. Applicants have addressed the issue of generic versus actual stiffnesses under a separate affidavit, see Applicants' Motion for Summary Disposition Regarding Use of Generic Stiffnesses Instead of Actual Stiffnesses In Piping Analysis, filed on

May 21, 1984. However, it is important to state here that significant effects from differences in stiffnesses do not occur unless the differences between adjacent supports or groups of supports are fairly large. As seen from Table 2 (attached), the difference in stiffness is not great enough to have a significant impact on the piping analyses.

V. Bending Moments

Q. Are you familiar with the issue of bending moments?

A. Yes. In section VIII of CASE's Findings, CASE is concerned with allegedly high bending moments in the bolt resulting from the imposition of a shear force on the bolt offset from the concrete surface by the use of a one-inch washer between the concrete and the support steel.

Bending of the bolt is not considered by the ASME Code, because in conventional bolt connections, bending is not significant. In reality, however, bending can occur. This problem was addressed by the SIT¹⁴ which had indicated that Applicants' preliminary calculations showed the bending moments to be insignificant in all but one of 60 cases reviewed. The NRC in the same report requested that the total stress (including the bending stress) in the bolts should be evaluated to assure that the value for allowable stress has not been exceeded.

¹⁴ SIT Report at 21.

There are two possible ways for the joint to react to the bending moment and, therefore, two ways to analyze them. One way is to compute the increased tension in the bolt by the same method as that used for the applied torsion moment (only now using the lever arm from the center of the bolt to the point of tangency). This is not an entirely correct manner because the bending moment would also be reacted by a couple internal to the bolt. This approach would then be an approximate approach, perhaps non-conservative, which would resolve the bending moment into an increased tension to be included in the shear-tension interaction formula of the Code. The second, conservative approach is to compute the bending stresses from the Mc/I formula or finite element analyses, then add the bending stress ratio-to-the-allowable (conservatively assumed as $0.75 F_y$ where F_y is the yield stress) to the Code interaction formula in linear fashion. As discussed previously in Section III (Ability To Resist Axial Torsion), Applicants have used the latter approach in evaluating the supports of Table 1 (attached) which are highly loaded in shear (which include those among the 60 supports mentioned by the SIT). The results of these analyses are set forth in Table 1 (attached), and, as discussed in Section III, reflect that due to the conservatism of the calculational methodology bending does not present a safety concern with these connections.

The results of tests reported in Attachment F reinforce Applicants conclusion in this regard, (i.e., that deflection of the supports at the design loads are very small regardless of whether the load is applied torsionally or as a shear, and that ample margin exists.

It should be further stated that about fifty percent of the bending moment in the bolt (from shear loading) is contributed by the shear at the tube steel flange next to the concrete. The shear tests conducted in March 1983 without tube steel (but with the washer) would also have contributed a bending moment to the bolt, and hence, those results provide corroboration that there is ample margin against failure.

VI. Sharing of Shear Loads

- Q. Are you familiar with the issue regarding sharing of shear loads?
- A. Yes. CASE's allegations in this regard are concerned with the sharing of the shear load among all of the bolts in a particular support. CASE alleges that only half or fewer of the bolts would accept the shear and would exceed allowable values before the remainder take up the load because of the presence of oversized bolt holes. We believe that their concern is not valid. Since this concern is common to all connections, not just to Richmond inserts, we have chosen to discuss it more fully in a separate Affidavit and Motion for

Summary Disposition Regarding the Effects of Gaps on Structural Behavior Under Seismic Loading Conditions filed in this proceeding on May 18, 1984.

VI. Additional Matters

Q. Does this complete your testimony on matters relating to Richmond inserts?


A. Almost. As a final point, we would like to address the concern (raised on VIII-11 of CASE findings) that Applicants failed to consider the A-307 bolt in their calculations submitted as Applicants' Exhibit 142D.

Applicants did not fail to consider the A-307 bolt; they purposely did not include the strength of the A-307 (A-36) bolt because the purpose of the analysis was to demonstrate that even the stiffest anchorage possible would considerably relieve the thermal expansion stresses resulting from LOCA and that the resultant load on the anchor would be considerably smaller than that computed for a fully restrained structural member. This was the purpose of Applicants' Exhibit 142D. It should be clear to everyone that the highest load on the anchorage system results from assuming the least flexible member of that system. If a high strength bolt were used for the Richmond insert, the least flexible member may or may not be the insert. However, both the test data obtained from the manufacturer and that obtained by Applicants (Attachment B to this


testimony) certainly indicate that the failure occurs in the bolt rather than the insert, pointing to the latter as being the stiffer and stronger member of the anchorage system. Thus, use of test data acquired via high strength bolts is appropriate if one wishes to determine the maximum load on the Richmond anchor, so that this load can be compared against the insert allowable. This, of course, was not the purpose of Applicants' Exhibit 142D.

Nevertheless, just to make the obvious point, Applicants recognized that A-36 rods are more flexible than high strength bolts, and that they have lower allowable values than the Richmond inserts, i.e., 17 kips instead of 25 kips. Applicants, however, also recognized that the thermal expansion load that would occur had an A-36 rod been used, is lower than that calculated for the high strength bolt. This load would then be the one that should be compared against the allowable load for the A-307 bolt. To put this concern in perspective, the thermal expansion load that would have resulted from the use of an A-307 bolt is seen from Figure 2. Also shown in this figure is the load computed for a high strength bolt. Figure 2 is developed using the March 1983 and 1984 test data (Attachment B) using the methodology employed in Applicants' Exhibit 142D.

FIGURE 2




The load resulting from the thermal expansion for the stiffest connection employing A-36 threaded rod is 5.0 kips. This load is below the allowable 17 kips for the A-307 bolt. When the maximum allowable mechanical load (17.7 kips) is added to the thermal load (per procedure of Exhibit 142D), the resulting deflection would be 0.4 inch. The ultimate deflection is about .95. Thus, there is a margin of safety of 2.4. The ultimate load is approximately 61 kips; hence, the safety factor on a load base is also 2.7. To finish this argument, it is appropriate to again place the purpose of Applicants' Exhibit 142D in perspective. Its purpose was to demonstrate the self-limiting nature of the thermal expansion load and why it need not be considered since anchorage slippages are minute with respect to the ultimate slippage capacity.




Robert C. Iotti


Sworn to before me this 1st day of June 1984.


Notary Public


My Commission Expires February 14, 1986


John C. Finneran, Jr.


Sworn to before me this 1st day of June 1984.


Notary Public

My Commission Expires February 14, 1986


R. Peter Deubler

Sworn to before me this 1st day of June 1984.


Notary Public

My Commission Expires February 14, 1986

LIST OF ATTACHMENTS

I. Documents

- A. Test Report - Shear Tests of Richmond Inserts - March 1983
- B. Test Report - Shear and Tension Tests of Richmond Inserts - April 1984
- C. Combined Shear and Tension Test Results Summary - Shear/Tension Interaction Curve
- D. Original Design Approach - Three Equation Method
- E. Finite Element Analyses
 - E1 - Finite Element Model
 - E2 - Finite Element Results
 - E3 - Finite Element Model and Results for Bolt Bending
- F. Test Results for Inserts and Tube Steel Loaded in Shear and Torsion
- G. Qualification Statement of Ray Peter Deubler

II. Tables

- 1. Richmond Inserts Subject to Torsion
- 2. Tube Steel and Richmond Inserts Comparison of Results Obtained With STRUDL With and Without Releasing M_2 .

ATTACHMENT A

TEST REPORT

SHEAR TESTS

ON

RICHMOND 1 1/2-INCH TYPE EC-6W INSERTS

MARCH 30, 1983

Prepared by

J.C. Gilbreth, P.E.

J.C. Gilbreth
Civil Engineer

Approved by

R.M. Kissinger, P.E.

R.M. Kissinger
Project Civil Engineer

TABLE OF CONTENTS

1.0 REFERENCES

2.0 GENERAL

2.1 PURPOSE AND SCOPE

2.2 RESPONSIBILITY

2.3 TEST APPARATUS

3.0 PROCEDURE

4.0 RESULTS

5.0 CONCLUSIONS

6.0 APPENDICES

APPENDIX 1 - - DRAWING NO. FSC-00464, SHT. 1
- - CONCRETE COMPRESSIVE TEST REPORT

APPENDIX 2 - - TEST DATA SHEETS

APPENDIX 3 - - LOAD-DEFLECTION CURVES

TEST REPORT

SHEAR TESTS

ON

RICHMOND 1 1/2-INCH TYPE EC-6W INSERTS

1.0 REFERENCES

1-A CP-EP-13.0 Test Control

1-B CP-EI-13.0-8 1 1/2" Richmond Insert Shear Tests

2.0 GENERAL

2.1 PURPOSE AND SCOPE

These tests were performed to determine the characteristics of Richmond 1 1/2-Inch Type EC-6W Inserts when installed in concrete representative of that used in the power block structures at CPSES and subjected to shear-type loading. The strength, deflections, and type of deformations produced by this loading were the qualities to be determined. This series of tests employed only 1 1/2"-Inch Type EC-6W Inserts subjected to shear loads.

2.2 RESPONSIBILITY

The tests were performed under the direction of the CP Project Civil Engineer. Witnesses to the tests were: A Nuclear Regulatory Commission (NRC) Representative from the Arlington, Texas Regional Office, the NRC Inspector stationed at CPSES, a TUSI site Quality Assurance representative, and other site engineering personnel.

2.3 TEST APPARATUS

The arrangement and details of the test apparatus are shown on Drawing No. FSC-00464, Sheet 1, included in Appendix 1 to this report. The insert specimens tested were taken at random from the Constructor's stock on site and were; therefore, representative of those installed in the plant structures. They were placed in a thick concrete slab cast specifically for these tests and which was composed of materials and reinforcement similar to those elements of the plant buildings. This is "4000-pound concrete" (28-day strength). The laboratory test report on the concrete of which this slab is composed is included here in Appendix 1.

An apparatus for applying shear loads to the specimens was designed and built on site. This facility employed a 60-ton capacity manually operated hydraulic ram whose thrust against a crosshead was transmitted by tension rods to a 1 1/2-inch thick shear plate bolted to the insert specimen. Base reaction of the ram was transmitted through a structural steel grillage to the outer face of the concrete slab. Ram thrust was determined by multiplying the fluid pressure (PSI), as indicated by a gauge on the pump, by a number equal to the ram piston area in square inches. Deflections were measured by a dial indicator mounted on a remotely anchored bracket and with its spring-loaded probe in contact with the specimen bolt head or bottom nut where threaded rods were used. These instruments bore valid stickers showing them to be currently in calibration.

3.0 PROCEDURE

In performance of the tests, inserts were cleaned of concrete mortar and other trash that would affect bolt thread engagement. The shear plate was attached to the specimen insert by a suitable length bolt or threaded rod of type shown on the test data sheets, Appendix 2. A new and different bolt was used for each insert. These fasteners were tightened "snug tight". On three specimens the shear plate was attached in direct contact with the top of the insert. On six other specimens a 1-inch thick plate was inserted between the shear plate and the insert, representing the "washer" used frequently at this location in pipe hanger installation. Shear loads were applied by the ram by operation of the manual pump. As the load increased from zero (0), indications of fluid pressure (later converted to load) and bolt head deflection were read at regular intervals. These intervals were at 400 PSI on the pressure gauge, corresponding to 5300 pounds thrust. Load application on each specimen was halted before failure occurred and when the load had reached a size considered to be sufficient in comparison with the design load values. At this point in each test, the NRC Representative indicated his concurrence with this consideration. After this, the load was removed, the apparatus detached, and observation was made of the condition of the specimen.

4.0 RESULTS

As can be seen on the test data sheets, the maximum load applied to specimens on which ASTM A490 bolts were used ranged from 88,110 lb. to 95,400 lb.. The bolts could be seen, after removal from the insert, to be slightly bent. By measuring the distance of the bolt tip from a line perpendicular to the bolt head these deflections were approximately as follows:

<u>Fastener Type</u>	<u>Specimen No.</u>	<u>Bolt Length</u>	<u>Deflection of Tip</u>
A-490	1	4 1/2-in.	0.0 in.
A-490	2	5 1/2 in.	0.05 in.
A-490	3	5 1/2 in.	0.10 in.
A-490	4	4 1/2 in.	0.05 in.
A-490	5	5 1/2 in.	0.10 in.
A-490	6	4 1/2 in.	0.0 in.

Other than these deformations, no bolt showed signs of incipient failure.

Loading of the three specimens employing a double-nutted SA-36 threaded rod for attaching the shear plate and including the 1-inch washer plate produced a reverse curve in the threaded rod. The offset between the approximately parallel ends of each rod was approximately as follows:

<u>Specimen No.</u>	<u>Offset</u>
7	0.4 in.
8	.4 in.
9	.4 in.

The fact that the end portions of rods were not truly parallel accounts for the difference in deflection measured at the bottom nut on the rods. Although these deflections were experienced, there was no sign of imminent failure of either the threaded rod, the insert, or the concrete.

There was small spalling of concrete around the top of some inserts. This allowed the top of insert to deflect laterally and in the case of Specimen No. 1 to deform to a small extent. However, in no part of any test specimen did breakage or complete failure appear to be imminent. In each case at the time operation of the hydraulic pump was halted, the applied load was increasing, showing that neither the insert nor fastener had reached its maximum load carrying capability.

The factor of safety for each specimen based on these maximum applied loads is shown in the following table.

FACTORS OF SAFETY

BASED ON

MAXIMUM APPLIED LOAD

<i>Fastener</i>	<i>Specimen Number</i>	<i>Maximum Applied Shear Load (Kips)</i>	<i>Factor of Safety</i> $F.S. = \frac{\text{Max. Applied Load}}{\text{Design Allowable Ld.}}$
<i>A-490 Bolt w/ 1" Shim #</i>	<i>1</i>	<i>88.1 *</i>	$88.1/26.51 = 3.32$
	<i>3</i>	<i>90.1</i>	$90.1/26.51 = 3.40$
	<i>5</i>	<i>95.4</i>	$95.4/26.51 = 3.60$
<i>A-490 Bolt w/ 6 1" Shim #</i>	<i>2</i>	<i>95.4</i>	$95.4/26.51 = 3.60$
	<i>4</i>	<i>95.4</i>	$95.4/26.51 = 3.60$
	<i>6</i>	<i>90.1</i>	$90.1/26.51 = 3.40$
<i>SA-36 Threaded Rod w/ 1" Shim #</i>	<i>7</i>	<i>58.3</i>	$58.3/17.67 = 3.30$
	<i>8</i>	<i>63.6</i>	$63.6/17.67 = 3.60$
	<i>9</i>	<i>63.6</i>	$63.6/17.67 = 3.60$

* Load halted due to dial indicator for deflection having reached its limit of travel.

5.0 CONCLUSION

These test results show that the performance capabilities of the Richmond Insert in shear exceed the design allowable by a ratio of more than 3 to 1. Thus, a minimum factor of safety of 3 is indicated. The test results for the specimens with the 1" thick washer are comparable to the test results for the specimens without the washer. This indicates that the presence of the washer had little effect on the performance of the bolt or the Richmond Insert. If additional bending stresses are introduced into the bolt as a result of the presence of the 1" thick washer, the test results show that it is not significant enough to distinguish the difference.

Based on this test, the design allowables for shear loading are acceptable for use without further investigation or additional calculations.

APPENDIX 1

MONCHE PEAK STEAM ELECTRIC STATION
 REPORT ON COMPRESSIVE TESTS OF CONCRETE
 PROCEDURE QC 291.1-41

NOTE:
 017-9840-001
 (Test Block)

DATE 2-11-83 APP. - 1
 POUR NO. 505 CRT.
 CYL. SET NO. 2315

MIX	COMPLETE DATA AS APPLICABLE FROM BATCH TESTS	WATER ADJ.	F.A. 6120 LBS.	H ₂ O FA. 120 LBS.	C.A. 8460 LBS.	H ₂ O C.A. 0 LBS.	TOTAL WATER/BATCH 1188 LBS.	TYPE OF CURING M & W
	CEMENT / CU. YD. 3157 LBS.	H ₂ O ADDED 4 GAL.	H ₂ O/CEMENT RATIO .376	AIR CU. YD. 11.6 1/2 OZ.	TOTAL H ₂ O 58 1/2 OZ.	SPECIFIED DESIGN STRENGTH 4000 PSI	23 DAYS	
MATERIALS	BRAND OF CEMENT G H	TYPE OF CEMENT II	BRAND OF AIR ENTRAINING ADMIXTURE TMB VR	BRAND OF WATER REDUCING ADMIXTURE II	MAX SIZE C.A. 3/4			
	SOURCE C.A. TX Cleburne	SP. GR. C.A. 2.63	SOURCE F.A. TX Cleburne	SP. GR. F.A. 2.63	FINESS MODULUS F.A. 2.51			

SAMPLING	TYPE OF MIXING Plant 1	BATCH LOAD 5 C.Y.	TICKET NO. 62256	SAMPLE TAKEN AT: <input type="checkbox"/> CENTRAL MIXER <input type="checkbox"/> FORMS <input checked="" type="checkbox"/> POINT OF DISCHARGE				
	METHOD OF PLACING <input checked="" type="checkbox"/> PUMP <input type="checkbox"/> BUCKET	<input type="checkbox"/> BULKIES <input type="checkbox"/> BELT <input type="checkbox"/> CHUTE	DATE SAMPLED 2-11-83	HOUR 1957 AM	WEATHER Clear	AIR TEMP. 50 °F	CONC. TEMP. 64 °F	SLUMP 3 3/4 IN.
	TIME OF MIXING AT CENTRAL PLANT 70 mins	UNIT WT. CU. FT. 144.56 LBS.	MIX ID. 132	SPECIMEN TAKEN BY OSBORNE	SPECIMEN CAST BY RG-IAS	AIR 5.2%		

TESTS	CYLINDER ID.	AGE	MEASURED DIA. IN.	AVG. DIA. IN.	DATE CAPPED	CAPPED BY	TIME TESTED	DATE TESTED	MAX. LOAD LB.	COMPRESSIVE STRENGTH	CAP CHECKED BY	CYLINDER TESTED BY	TYPE OF BREAK
	2315A	7	6.010	6.006	2-13-83	JD	0723	2-13-83	94500	3340	JD	JD	Reg
	2315B	7	6.002	6.007	2-13-83	JD	0730	2-13-83	95500	3370	JD	JD	Reg
	2315C	23	6.014	6.009	3-9-83	JD	0706	3-11-83	159,000	5610	R.G.	R.G.	REG.
	2315D	23	6.011	6.012	3-9-83	JD	0702	3-11-83	158,000	5570	R.G.	R.G.	REG.
	2315E	23	6.013	6.009	3-9-83	JD	0658	3-11-83	172,000	4650	R.G.	R.G.	REG.
	2315F	23	6.013	6.005	3-9-83	JD	0655	3-11-83	179,500	4570	R.G.	R.G.	REG.
	NA												
	NA												

DATE & TIME STRIPPED: 2-12-83 1230
 REMARKS:

CURING CONTROL TEST RESULTS
 FOR 28 DAY BREAK

LABORATORY CURED CYLINDER(S)	FIELD CURED CYLINDERS
STRENGTH (P.S.I.) <u>5610</u> (C)	STRENGTH (P.S.I.) <u>4650</u> (D)
<u>5570</u> (D)	<u>4570</u> (D)
1. (C)+(D) ÷ 2 = <u>0.82</u> *	2. (D)+(D) ÷ 2 = <u>4610</u> *

* NOTE: (1) ABOVE MUST BE EQUAL TO OR GREATER THAN 0.85; OR (2) ABOVE NEED NOT EXCEED THE DESIGN STRENGTH BY MORE THAN 500 PSI; EVEN THOUGH THE 0.85 CRITERION IS NOT MET.

MATERIALS TEST REPORT NO. ATE-1392
 COMPRESSION MACHINE NO. ATE-3031
 CURING MOLD NO. A101-4102

7 DAY PREPARED BY JD CHECKED BY IAS
 28 DAY PREPARED BY R.G. CHECKED BY IAS

FOR INFORMATION ONLY!

Joe Logan
 TUGCO LAB SUPERVISOR

NOTE:
017-9840-001
(Test Block)

DATE 2-11-83
POUR NO. See last
CYL. SET NO 2315

MANCHE PEAK STEAM ELECTRIC STATION
REPORT ON COMPRESSIVE TESTS OF CONCRETE
PROCEDURE Q1211.1-47

MIX	COMPLETE DATA AS APPLICABLE FROM BATCH TICKET	(c) MOIST AGGR	F.A.	H ₂ O FA	C.A.	H ₂ O C.A.	TOTAL WATER/BATCH	TYPE OF CURING
	CEMENT / CU. YD.	H ₂ O ADDED	H ₂ O/CEMENT RATIO	AIR CU YD	TOTAL AIR	SPECIFIED DESIGN STRENGTH		
3:57 LBS.		4 GAL.	1.376	11.6 OZ.	58 1/2 OZ.	4000 PSI	28	DAYS
MATERIALS	BRAND OF CEMENT	TYPE OF CEMENT	BRAND OF AIR ENTRAINING ADMIXTURE	BRAND OF WATER REDUCING ADMIXTURE	MAX SIZE C.A.			
	SOURCE C.A.	SP GR. C.A.	SOURCE F.A.	SP GR. F.A.	FINENESS MOODULES F.A.			
G-H		II	MBYR	N/A	3/4			
Tri-Clean		2.63	Tri-Clean	2.63	2.51			

SAMPLING	TYPE OF MIXING	BATCH LOAD	TICKET NO.	SAMPLE TAKEN AT:					
	Plant 1	5 C.Y.	62256	<input type="checkbox"/> CENTRAL MIXER	<input type="checkbox"/> FORMS	<input checked="" type="checkbox"/> POINT OF DISCHARGE			
	METHOD OF PLACING	<input checked="" type="checkbox"/> PUMP	<input type="checkbox"/> BUCKET	DATE SAMPLED	HOUR	WEATHER	AIR TEMP.	CONC. TEMP.	SLUMP
<input type="checkbox"/> BUGGIES <input type="checkbox"/> BELT <input type="checkbox"/> CHUTE				2-11-83	1957 ^{AM}	Clear	50 °F	64 °F	3 3/4 IN.
TIME OF MIXING AT CENTRAL PLANT		UNIT WT. CU. FT.	MIX I.D.	SPECIMEN TAKEN BY	SPECIMEN CAST BY	AIR			
70 Revs		144.56 LBS.	132	OSBORNE	R.G.-IAS	5.2%			

TESTS	CYLINDER ID	AGE	MEASURED DIA. IN.	AVG. DIA. IN.	DATE CAPPED	CAPPED BY	TIME TESTED	DATE TESTED	MAX. LOAD LB.	COMPRESSIVE STRENGTH	CAP CHECKED BY	CYLINDER TESTED BY	TYPE OF BREAK
	NA												1
	NA												2
	NA												2
	NA												2
	2315	3	6.008 6.013	6.011	2-14-83	IAS	6:59 ^{PM}	2-14-83	55500	1960	IAS	IAS	R.G.
	2315	4	6.012 6.014	6.003	2-15-83	(P)	6:59 ^{PM}	2-15-83	64,500	2280	(P)	(P)	Key
	2315	5	6.009 5.915	6.002	2-16-83	(JW)	6:59 ^{PM}	2-16-83	67,000	2370	R.G.	R.G.	R.G.
	NA												1
DATE & TIME STRIPPED		REMARKS											
2-12-83 1230													

CURING CONTROL TEST RESULTS
FOR 28 DAY BREAK

LABORATORY CURED CYLINDER(S)	FIELD CURED CYLINDER(S)
STRENGTH (P.S.I.) <u>NA</u> (c)	STRENGTH (P.S.I.) <u>NA</u> (d)
<u>1</u> (d)	<u>1</u> (d)
1. (a) + (c) + (d) = <u>1</u> *	2. (a) + (b) + 2 = <u>1</u> *

*NOTE: (1) ABOVE MUST BE EQUAL TO OR GREATER THAN 0.85; OR (2) ABOVE NEED NOT EXCEED THE DESIGN STRENGTH BY MORE THAN 500 PSI EVEN THOUGH THE 0.85 CRITERION IS NOT MET.

WALVE METER OR CALIBERS NO. MTE-1392
COMPRESSION MACHINE NO. MTE-3031
CAPPING MOLD NO. L-111-L102

3 DAY PREPARED BY IAS CHECKED BY (P)
4 DAY PREPARED BY (P) CHECKED BY IAS
5 DAY PREPARED BY R.G. CHECKED BY IAS

28-DAY COUNTERS COMMENTS (IF APPLICABLE)

FOR INFORMATION ONLY!

Don Scoppa
TUGCO LAB SUPERVISOR

APPENDIX 2

TEST DATA SHEETS

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 1

DATE 22 March 83

BOLT SPEC: A-490

W/SHIM PL.

W/O SHIM PL.

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS.)	NOTES - FAILURE MODE
0.100	600		
.42	800		
.84	1200		
.023	400	5,300	
0.041	800	10,600	
.055	1200	15,900	
.083	1600	21,200	
.105	2000	26,500	
.138	2400	31,800	
.168	2800	37,100	
.200	3200	42,400	
.230	3600	47,700	
.270	4000	53,000	
.306	4400	58,300	Started Yield - Jack had started due probably to pump failure.
.360	4800	63,600	
.452	5200	68,900	
.530	5600	74,200	
.613	6000	79,500	
.877	6400	84,800	
1.000	6600	88,110	Insert bent over - failure occurred on tension side

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25

JACK: EQUIPMENT NUMBER RCH 606

PRESSURE GAUGE: M&TE NUMBER 1821

DUE DATE: 9 June '83

DIAL GAUGE: M&TE NUMBER 2094

DUE DATE: 20 June '83

PERFORMED BY:

WITNESSED BY:

Joe Wilford
DATE 22 March 83

Victor [Signature]
QA REPRESENTATIVE DATE 3-22-83

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 2

DATE 22 March '83

BOLT SPEC: A-490

W/SHIM PL. _____

W/O SHIM PL.

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS.)	NOTES - FAILURE MODE
.010	400	5,300	
.028	800	10,600	
.062	1200	15,900	
.094	1600	21,200	
.130	2000	26,500	
.172	2400	31,800	
.214	2800	37,100	
.254	3200	42,400	
.285	3600	47,700	
.306	4000	53,000	
.326	4400	58,300	
.348	4800	63,600	
.371	5200	68,900	
.400	5600	74,200	
.434	6000	79,500	
.472	6400	84,800	
.513	6800	90,100	
.560	7200	95,400	Concrete failed - cone type - Spall in flexure - Prying action. Spall: - approx 7" diam.

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25

JACK: EQUIPMENT NUMBER RC14 606

PRESSURE GAUGE: M&TE NUMBER 1821

DUE DATE: 9 June '83

DIAL GAUGE: M&TE NUMBER 2094

DUE DATE: 20 June '83

PERFORMED BY:

WITNESSED BY:

Joe Habicht
DATE 3-22-83

Victor T. Dennis
QA REPRESENTATIVE DATE 3-22-83

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 3DATE 22 March 83BOLT SPEC: A-490W/SHIM PL. W/O SHIM PL.

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS.)	NOTES - FAILURE MODE
.018	400	5,300	
.053	800	10,600	
.085	1200	15,900	
.130	1600	21,200	
.145	2000	26,500	
.175	2400	31,800	
.207	2800	37,100	
.248	3200	42,400	
.304	3600	47,700	
.365	4000	53,000	
.417	4400	58,300	
.463	4800	63,600	
.508	5200	68,900	
.559	5600	74,200	Concrete started spall
.612	6000	79,500	
.668	6400	84,800	
.725	6800	90,100	
			Concrete spalled around upper part of insert permitting lateral deflection of insert.

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25JACK: EQUIPMENT NUMBER RCH 606PRESSURE GAUGE: M&TE NUMBER 1821DUE DATE: 9 June 83DIAL GAUGE: M&TE NUMBER 2094DUE DATE: 20 June 83

PERFORMED BY:

WITNESSED BY:

Joe Gilbert 3-22-83
DATE

James McQuinn 3-22-83
QA REPRESENTATIVE DATE

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 4DATE 22 June 83BOLT SPEC: A-490

W/SHIM PL. _____

W/O SHIM PL.

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS).	NOTES - FAILURE MODE
0.004	400	5,300	
.019	800	10,600	
.043	1200	15,900	
.070	1600	21,200	
.100	2000	26,500	
.132	2400	31,800	
.165	2800	37,100	
.198	3200	42,400	
.249	3600	47,700	
.308	4000	53,000	
.380	4400	58,300	
.448	4800	63,600	
.511	5200	68,900	
.536	5600	74,200	Concrete spalled at edge of
.571	6000	79,500	slab at jack end of rods.
.604	6400	84,800	
.646	6800	90,100	
.688	7200	95,400	
			Concrete spalled @ insert allowing
			lateral deflection of specimen at top

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25JACK: EQUIPMENT NUMBER RCH 600PRESSURE GAUGE: M&TE NUMBER 1821DUE DATE: 9 June 83DIAL GAUGE: M&TE NUMBER 2094DUE DATE: 20 June 83

PERFORMED BY:

WITNESSED BY:

3-22-83
DATE

3-22-83
QA REPRESENTATIVE DATE

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 5DATE 22 June '83BOLT SPEC: A-490W/SHIM PL. W/O SHIM PL. At 1/4

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS).	NOTES - FAILURE MODE
.013	400	5,300	
.052	800	10,600	
.091	1200	15,900	
.132	1600	21,200	
.180	2000	26,500	
.220	2400	31,800	
.265	2800	37,100	
.303	3200	42,400	
.336	3600	47,700	
.365	4000	53,000	
.391	4400	58,300	
.415	4800	63,600	
.444	5200	68,900	
.479	5600	74,200	Concrete spalled slightly at edge of slab under jack support
.509	6000	79,500	
.538	6400	84,800	
.570	6800	90,100	
.616	7200	95,400	Failed by local spalling of concrete at insert permitting lateral movement of insert.

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25JACK: EQUIPMENT NUMBER RCH 606PRESSURE GAUGE: M&TE NUMBER 1821DUE DATE: 9 June '83DIAL GAUGE: M&TE NUMBER 2094DUE DATE: 20 June '83

PERFORMED BY:

WITNESSED BY:

J. C. Vilheth 3-22-'83
DATE

W. J. ... 3-22-'83
QA REPRESENTATIVE DATE

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 6DATE 22 March '83BOLT SPEC: A-470

W/SHIM PL. _____

W/O SHIM PL.

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS.)	NOTES - FAILURE MODE
.034	400	5,300	
.067	800	10,600	
.099	1200	15,900	
.134	1600	21,200	
.173	2000	26,500	
.225	2400	31,800	
.284	2800	37,100	
.352	3200	42,400	
.407	3600	47,700	
.442	4000	53,000	
.490	4400	58,300	
.624	4800	63,600	
.674	5200	68,900	Concrete spalls at upper edge of
.725	5600	74,200	slat at jack end of rods
.765	6000	79,500	
.809	6400	84,800	
.855	6800	90,100	
			Concrete spalls locally
			around insert - allowing
			lateral deflection of upper
			part of insert

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25JACK: EQUIPMENT NUMBER RC17 000PRESSURE GAUGE: M&TE NUMBER 1821DUE DATE: 9 June '83DIAL GAUGE: M&TE NUMBER 2094DUE DATE: 20 June '83

PERFORMED BY:

WITNESSED BY:

J. J. Libeth 3-22-83
DATE

W. J. [Signature] 3-22-83
QA REPRESENTATIVE DATE

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 7

DATE 22 March 83

BOLT SPEC: S A 36 Rod

W/SHIM PL.

W/O SHIM PL. KCH

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS).	NOTES - FAILURE MODE
0.081	400	5,300	
.272	800	10,600	
.400	1200	15,900	
.483	1600	21,200	
.516	2000	26,500	
.568	2400	31,800	
.465	2800	37,100	
.732	3200	42,400	
.811	3600	47,700	
.883	4000	53,000	
-	4400	58,300	Dial gauge bottomed out
			all discernable deflections were a formation of bolt

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25

JACK: EQUIPMENT NUMBER KCH 606

PRESSURE GAUGE: M&TE NUMBER 1821

DUE DATE: 9 June '83

DIAL GAUGE: M&TE NUMBER 2094

DUE DATE: 20 June '83

PERFORMED BY:
J. C. Gilbert


WITNESSED BY:

3-22-83
DATE

1/2 Peter M. J. 3-22-83
QA REPRESENTATIVE DATE

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 8DATE 22 March 83BOLT SPEC: SA 30 RodW/SHIM PL. W/O SHIM PL.

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS.)	NOTES - FAILURE MODE
0.029	400	5,300	
.190	800	10,600	
.345	1200	15,900	
.408	1600	21,200	
.457	2000	26,500	
.526	2400	31,800	
.618	2800	37,100	
.698	3200	42,400	
.745	3600	47,700	
.815	4000	53,000	
.890	4400	58,300	Slight spalling of concrete
.992	4800	63,600	but practically all deformations were in the bolt, it being deformed then:
			

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25JACK: EQUIPMENT NUMBER RCH 606PRESSURE GAUGE: M&TE NUMBER 1821DUE DATE: 9 June '83DIAL GAUGE: M&TE NUMBER 2094DUE DATE: 20 June '83

PERFORMED BY:

WITNESSED BY:

J. C. Hibbert3-22-83
DATEV. M. De... 3-27-83
QA REPRESENTATIVE DATE

RICHMOND 1-1/2-INCH TYPE EC-6W INSERTS
SHEAR TESTS
REFERENCE: CP-EI-13.0-8

SPECIMEN NUMBER: 9

DATE 22 March 83

BOLT SPEC: SA-36 Rod

W/SHIM PL.

W/O SHIM PL.

DEFLECTION (IN.)	GAUGE PRESSURE (P.S.I.)	JACK* THRUST (LBS.)	NOTES - FAILURE MODE
.027	400	5,300	
.071	800	10,600	
.120	1200	15,900	
.179	1600	21,200	
.225	2000	26,500	
.266	2400	31,800	
.340	2800	37,100	
.440	3200	42,400	
.526	3600	47,700	
.609	4000	53,000	
.698	4400	58,300	
.821	4800	63,600	
			all deflection was result of deformation of bolt. No sign of failure of bolt, only deformation.

*JACK THRUST EQUAL SHEAR LOAD ON INSERT.

JACK THRUST (LBS) = GAUGE PRESSURE (P.S.I.) TIMES 13.25

JACK: EQUIPMENT NUMBER RCH 606

PRESSURE GAUGE: M&TE NUMBER 1821

DUE DATE: 9 June 83

DIAL GAUGE: M&TE NUMBER 2094

DUE DATE: 20 June 83

PERFORMED BY:

WITNESSED BY:


G.C. Gilketh

3-22-83
DATE

V. J. ...
3-22-83
QA REPRESENTATIVE DATE

APPENDIX 3


LOAD-DEFLECTION CURVES





LOAD - DEFLECTION CURVES

SHOP BILL

ASSEMBLY NO.	SHAPE	SIZE	QUANTITY	NOTES - SPECS
A	One Assy. Group	Two Assy. Groups		
B	One Assy. Group	One Assy. Group		
C	One Assy. Group	One Assy. Group		
D	One Assy. Group	One Assy. Group		
E	One Assy. Group	One Assy. Group		
F	One Assy. Group	One Assy. Group		
G	One Assy. Group	One Assy. Group		
H	One Assy. Group	One Assy. Group		
I	One Assy. Group	One Assy. Group		
J	One Assy. Group	One Assy. Group		
K	One Assy. Group	One Assy. Group		
L	One Assy. Group	One Assy. Group		
M	One Assy. Group	One Assy. Group		
N	One Assy. Group	One Assy. Group		
O	One Assy. Group	One Assy. Group		
P	One Assy. Group	One Assy. Group		
Q	One Assy. Group	One Assy. Group		
R	One Assy. Group	One Assy. Group		
S	One Assy. Group	One Assy. Group		
T	One Assy. Group	One Assy. Group		
U	One Assy. Group	One Assy. Group		
V	One Assy. Group	One Assy. Group		
W	One Assy. Group	One Assy. Group		
X	One Assy. Group	One Assy. Group		
Y	One Assy. Group	One Assy. Group		
Z	One Assy. Group	One Assy. Group		




GENERAL ASSEMBLY








TYPICAL SECTION

A SPECIMEN INSTALLATION



ASSEMBLY B - DETAILS






This is a temporary facility, non-safety-related.



Brown & Root, Inc. Houston, Texas Brown & Root, Inc. Houston, Texas		
PROJECT NO. DRAWING NO. DATE	SPECIMEN NO. DATE TESTED TEST RESULTS	CLIENT PROJECT NAME PROJECT LOCATION
TEXAS UTILITIES SERVICES, INC. C.P.S.S. - GLEN ROSE, TEXAS		

SHOP BILL

ASSEMBLY NO.	SHAPE	LENGTH FT IN	NOTES - SPECS
A	One Assembly Shown - 7mm Assembly Shown	11 1/2	One Assembly Shown - 7mm Assembly Shown
B	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
C	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
D	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
E	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
F	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
G	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
H	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
I	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
J	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
K	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
L	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
M	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
N	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
O	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
P	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
Q	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
R	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
S	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
T	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
U	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
V	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
W	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
X	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
Y	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown
Z	One Assembly Shown - One Assembly Shown	11 1/2	One Assembly Shown - One Assembly Shown



This is a temporary facility, non-safely related

Brown & Root, Inc.
CORPORATE OFFICE: HOUSTON, TEXAS
TELEPHONE: 435-1111
FACSIMILE: 435-1111

TEXAS UTILITIES SERVICES, INC.
1111 RICHMOND STREET, HOUSTON, TEXAS 77002

PROJECT: C.P.S.E. GLEN ROSE, TEXAS

DATE: 10/15/83
SCALE: 1/2" = 1'-0"

APPROVED: [Signature]
DATE: 10/15/83

REVISIONS:
1. Issue for Construction
2. Issue for Construction

NOTES:
1. Use B.F.R. WDS 10048
2. No paint required on this structure

CONTINUED ON NEXT SHEET


ATTACHMENT B

TEST REPORT

SHEAR AND TENSION LOADING
OF
RICHMOND INSERTS
1 1/2-INCH TYPE EC-6W
1-INCH TYPE EC-2W


APRIL 19, 1984

Prepared by



S.G. McBee
Civil Engineer

Approved by



R.M. Kissinger, P.E.
Project Civil Engineer

TABLE OF CONTENTS

1.0 REFERENCES

2.0 GENERAL

2.1 DEFINITIONS

2.2 PURPOSE AND SCOPE

2.3 RESPONSIBILITY

2.4 TEST APPARATUS

2.4.1 EMBEDMENTS

2.4.2 SHEAR TEST APPARATUS

2.4.3 TENSION TEST APPARATUS

2.4.4 COMBINED SHEAR AND TENSION TEST APPARATUS

3.0 TEST PROCEDURE

4.0 RESULTS

4.1 1 1/2-INCH RICHMOND INSERTS

4.1.1 SHEAR TESTS

4.1.2 TENSION TESTS

4.1.3 COMBINED SHEAR AND TENSION TESTS

4.2 1-INCH RICHMOND INSERTS

4.2.1 SHEAR TESTS

4.2.2 TENSION TESTS

4.2.3 COMBINED SHEAR AND TENSION TESTS

5.0 CONCLUSIONS

TABLE OF CONTENTS (Cont.)

6.0 APPENDICES

APPENDIX 1 - DRAWING NO. FSC-00464 SHT. 1, 2 & 3

APPENDIX 2 - CONCRETE COMPRESSIVE TEST REPORT
TEST DATA SHEETS

APPENDIX 3 - LOAD-DEFLECTION CURVES

APPENDIX 4 - PICTURES OF ACTUAL TEST APPARATUS

TEST REPORT

SHEAR AND TENSION LOADING
OF
RICHMOND INSERTS
1 1/2-INCH TYPE EC-6W
AND
1-INCH TYPE EC-2W

1.0 REFERENCES

- A CP-EP-13.0 Test Control
- B CP-EI-13.0-13 1 1/2" and 1" Richmond Insert Shear and Tension Tests

2.0 GENERAL

2.1 DEFINITIONS

Ultimate Load - The load applied to the specimen which caused a physical rupture of the specimen.

Failure Load - The load applied to the specimen beyond which, deflections increased considerably without substantial increase in the applied load.

2.2 PURPOSE AND SCOPE

These tests were performed to determine the characteristics of 1 1/2-Inch Type EC-6W and 1-Inch Type EC-2W Richmond Inserts when installed in concrete representative of that used in the power block structures at CPSES. The test specimens were subjected to shear, tension, and combined shear and tension loadings. The strength, deflections, and type of deformations produced by these loadings were the qualities to be determined.

2.3 RESPONSIBILITY

The tests were performed under the direction of the CP Project Civil Engineer. Witnesses to the tests were: A TUGCO site Quality Assurance representative and other site engineering personnel.

2.4 TEST APPARATUS

2.4.1 CONCRETE SLAB & EMBEDMENTS

The arrangement and details of the test apparatus are shown on Drawing No. FSC-00464, Sheet 1, 2 and 3, which are included in Appendix 1 to this report. (Note that only MK C-14, C-15, C-16 and Assembly 'D' on Sheet 1 were used in this test.)


The insert specimens tested were taken at random from the Constructor's stock on site and therefore, were representative of those installed in the plant structures. They were placed in a concrete slab cast specifically for these tests and which was composed of materials and reinforcement similar to those elements of the plant buildings. The concrete used was based on having a minimum design strength of 4000 pounds per square inch at 28 days. The laboratory test report on the concrete of which this slab is composed is included here in Appendix *X.2.* ^{6/11/94} _{mas}

2.4.2 SHEAR TEST APPARATUS

An apparatus for applying shear loads to the specimens was designed and built on site. This facility employed a 60-ton capacity, manually operated hydraulic ram whose thrust against a cross head was transmitted by tension rods to a 1 1/2-inch thick shear plate bolted to the insert specimen. The base reaction of the jack was transmitted through a structural steel "bridge" to the outer face of the concrete test slab. This arrangement, as shown in Appendix 1, provided a horizontal shear load on the vertically positioned insert without producing secondary or reactive concrete stresses in the vicinity of the specimen. Ram thrust was determined by multiplying the fluid pressure (PSI), as indicated by a calibrated gauge on the pump, by a number equal to the ram piston area in square inches. Deflections were measured by a calibrated dial indicator mounted on a remotely anchored bracket and with its spring loaded probe in contact with a lug welded to the shear plate directly behind the bolt head or threaded rod.

2.4.3 TENSION TEST APPARATUS

An apparatus for applying tension loads to the specimens was also designed and built on site. This facility employed a 60-ton capacity, manually operated hydraulic ram which serves as an end loading on a built-up steel beam. The other end of the beam was bearing against a well-supported round bar which served as a fulcrum and provided the other end reaction of the beam when the jack was operated to load the specimen. A threaded rod protruded through the beam at mid-span, through a nut and bearing plate on the beam with the opposite end threaded into the Richmond Insert. This arrangement caused the load on the rod to be equal to twice the force applied to the jack. Location of the base plates for the reactions of the beam provided clearance from the insert of at least 4 times the overall insert height; i.e., at least 39 1/2 inches for the 1 1/2 inch inserts and 23 inches for the 1 inch inserts. Ram thrust was determined by multiplying the fluid pressure (PSI), as indicated by a calibrated gauge on the pump, by a number equal to the ram piston area in square inches. Deflections were measured by a calibrated dial indicator mounted on a remotely anchored bracket and with its spring loaded probe in contact with a bracket which was securely clamped to the nut on the threaded rod, as shown in the sketch below.



2.4.4 COMBINED SHEAR AND TENSION TEST

The apparatus for the combined shear and tension test utilized the same equipment as that used on the individual shear and tension tests. For the shear portion, the equipment was set up identically to the individual shear test. For the tension portion, the equipment was arranged in a slightly different fashion. The hydraulic ram was not placed under the end of the beam, but instead, on the center of the beam on top. The ram thrust was applied directly to the threaded rod, which passed through the center of the ram, by means of a plate which was placed on top of the ram. The base reaction was resisted by the tension beam, loading which was supported by two wide flange stands at sufficient distance from the insert so as not to induce secondary or reactive concrete stresses in the vicinity of the specimen. This arrangement caused the load on the rod to be equal to the ram thrust. Both rams (one applying tension and one applying shear) were operated by a single hand pump with a calibrated pressure gauge. In this fashion, the shear and tension loads applied to the test specimen would be equal at all times.

3.0 TEST PROCEDURE

In performance of all of the tests, inserts were cleaned of concrete mortar and other trash that would affect bolt thread engagement. A new bolt (A-490) or threaded rod (SA-193 Grade B7) was used for each insert. The fasteners were all tightened "snug tight". The application of all loads was applied by the ram by operation of the manual hydraulic pump. As the load increased from zero (0), indications of fluid pressure (later converted to load) and simultaneous bolt head deflection were read at regular intervals. These intervals were at 400 PSI on the pressure gauge, corresponding to 5300 pounds thrust with the exception of the direct tension tests. On the direct tension test, these intervals were at 200 PSI on the pressure gauge, which also corresponded to 5300 pounds thrust on the specimen due to the configuration used. The load as indicated by these gauge pressures was maintained as constant as possible for a period of two (2) minutes. At the end of this time period, the deflection was again observed and noted. Load application on each specimen was carried out until ultimate failure of the specimen occurred (except specimen no. 1, which was tested in shear). At this point, observations were made of the condition of the specimens and the failure mode.

4.0 RESULTS

4.1 1 1/2-INCH RICHMOND INSERTS

4.1.1 SHEAR TESTS

As can be seen on the test data sheets, the ultimate load applied to the specimens ranged from 90,100 lbs. to 106,000 lbs.. The failure loads ranged from 84,800 lbs. to 106,000 lbs.. All bolts sheared abruptly (except specimen #1; test was halted prior to ultimate failure), with minor spalling of the concrete on the compression side of the Richmond Insert. All five (5) specimens were utilizing A-~~9~~₄90 bolts.

<u>SPECIMEN NO.</u>	<u>ULTIMATE LOAD (lbs)</u>	<u>FAILURE LOAD (lbs)</u>
1	90,100	84,800
2	95,400	90,100
3	95,400	90,100
4	106,000	100,700
5	106,000	106,000
Average	98,580	94,340

Using the allowable insert loads given in specification 2323-SS-30 for 1 1/2-inch Richmond Inserts, the factor of safety is determined.

Allowable Shear = 27.0^k

Factor of Safety (F.S.) = $\frac{\text{Average Failure Ld.}}{\text{Design Allowable Ld.}}$

<u>SPECIMEN NO.'s</u>	<u>AVERAGE FAILURE LOAD (k)</u>	<u>FACTOR OF SAFETY</u>
1 thru 5	94.34	$\frac{94.34}{27.0} = 3.49$

4.1.2 TENSION TESTS

The ultimate load applied to the tension test specimens ranged from 87,650 lbs. to 114,150 lbs.. The failure loads ranged from 87,650 lbs. to 108,850 lbs.. The failure mode for specimens 11 and 12 was by stripping the threads between the threaded rod and the Richmond Insert. Specimen 13 failed in the Richmond Insert by a failure of the welds between the axial strut rods to the upper threaded coil. Specimens 14 and 15 failed by concrete shear cone failures. All specimens were utilizing SA-193 Grade B7 threaded material.

<u>SPECIMEN NO.</u>	<u>ULTIMATE LOAD</u>	<u>FAILURE LOAD</u>
11	106,200	103,550
12	114,150	108,850
13	114,150	108,850
14	87,650	87,650
15	100,900	100,900
Average	104,610	101,960

Allowable Tension = 31.3k

Factor of Safety (F.S.) = $\frac{\text{Average Failure Ld.}}{\text{Design Allowable Ld.}}$

<u>SPECIMEN NO.'s</u>	<u>AVERAGE FAILURE LOAD (k)</u>	<u>FACTOR OF SAFETY</u>
11 thru 15	101.96	101.96/31.3 = 3.26

4.1.3 COMBINED SHEAR AND TENSION TESTS

The shear and tension loads applied to the specimens under this loading condition are equal and the ultimate loads ranged from 60,950 lbs. to 68,900 lbs.. The failure loads ranged from 58,300 lbs. to 67,575 lbs.. Specimens 6 through 9 failed by an abrupt shearing of the threaded rod. There was some deformation of the rod in bending at the shear zone (ranging for 20° to 45° bend). Upper insert washer moved from 1/2 inch to 3/4 inch with some concrete spalling on the compression side of the insert. Specimen 10 failed by stripping the threads between the threaded rod and the insert. This failure lifted the upper insert washer from the struts, but the insert remained in place.

<u>SPECIMEN NO.</u>	<u>ULTIMATE LOAD (lbs)</u>	<u>FAILURE LOAD (lbs)</u>
6	68,900	67,575
7	67,575	67,575
8	60,950	58,300
9	61,613	61,613
10	64,925	62,275
Average	64,793	63,468

Allowable Tension = 31.3k

Allowable Shear = 27.0k

Factor of Safety (F.S.)

$$\left(\frac{\text{Average Failure Tension}}{\text{Design Allowable Tension} \times \text{F.S.}} \right)^{4/3} + \left(\frac{\text{Average Failure Shear}}{\text{Design Allowable Shear} \times \text{F.S.}} \right)^{4/3} = 1.0$$

<u>SPECIMEN NO's.</u>	<u>TENSION AND SHEAR AVERAGE FAILURE LOAD (k)</u>	<u>FACTOR OF SAFETY</u>
6 thru 10	63.47	$\left(\frac{63.47}{31.3 \times \text{F.S.}} \right)^{4/3} + \left(\frac{63.47}{27.0 \times \text{F.S.}} \right)^{4/3} = 1.0$ <p style="text-align: center;">F.S. = 3.63</p>

4.2 1-INCH RICHMOND INSERTS

4.2.1 SHEAR TESTS

From the test data sheets, the ultimate load applied to the specimens ranged from 39,750 lbs. to 50,350 lbs.. The failure loads ranged from 37,100 lbs. to 42,400 lbs.. Specimens 16 thru 19 failed by shear failure of the A-490 bolt. The top portion of the inserts deflected from 1/8 inch to 7/8 inch with some spalling on the compression side of the insert. Specimen 16 showed some rotation of the top of the insert. Specimen 17 and 18 showed no apparent sign of rotation. Specimen 19 failed by breaking the weld between the upper coil and the struts. The bolt then failed in bending after rotating with the upper portion of the coil. Specimen 20 failed by crushing the concrete on the compression side of the insert. The insert then rotated intact and the bolt ultimately failed in bending.

<u>SPECIMEN NO.</u>	<u>ULTIMATE LOAD (lbs)</u>	<u>FAILURE LOAD (lbs)</u>
16	46,375	42,400
17	43,060	37,100
18	50,350	42,400
19	46,375	42,400
20	39,750	37,100
Average	45,182	40,280

Allowable Shear = 11.5k

$$\text{Factor of Safety (F.S.)} = \frac{\text{Average Failure Ld.}}{\text{Design Allowable Ld.}}$$

<u>SPECIMEN NO's.</u>	<u>Average Failure Load (k)</u>	<u>Factor of Safety</u>
16 thru 20	40.28	40.28/11.5 = 3.50

4.2.2 TENSION TESTS

The ultimate load applied to the specimens ranged from 41,270 lbs. to 43,920 lbs.. The failure loads ranged from 39,950 lbs. to 43,920 lbs.. Specimens 26, 28 and 29 failed by concrete shear cone failure. Specimens 27 and 30 failed by Richmond Insert failure. The inserts failed by a failure of the welds between the struts and the lower coil. There was some surface spalling associated with these failures.

<u>SPECIMEN NO.</u>	<u>ULTIMATE LOAD (lbs)</u>	<u>FAILURE LOAD (lbs)</u>
26	42,600	42,600
27	43,920	43,920
28	42,600	39,950
29	42,600	39,950
30	41,270	39,950
Average	42,598	41,276

Allowable Tension = 11.5k

Factor of Safety (F.S.) = $\frac{\text{Average Failure Ld.}}{\text{Design Allowable Ld.}}$

<u>SPECIMEN NO's.</u>	<u>AVERAGE FAILURE LOAD (k)</u>	<u>FACTOR OF SAFETY</u>
26 thru 30	41.276	41.276/11.5 = 3.59

4.2.3 COMBINED SHEAR AND TENSION TESTS

The shear and tension loads applied to the specimens under this loading condition are equal and the ultimate loads ranged from 27,825 lbs. to 30,475 lbs.. The failure loads ranged from 27,825 to 29,150 lbs.. Specimens 21 thru 25 failed abruptly due to shear failure of the threaded rod. All inserts remained intact with only surface spalling of the concrete.

<u>SPECIMEN NO.</u>	<u>ULTIMATE LOAD (lbs)</u>	<u>FAILURE LOAD (lbs)</u>
21	27,825	27,825
22	29,150	29,150
23	30,475	29,150
24	29,150	27,825
25	28,487	27,825
Average	29,017	28,355

Allowable Tension = 11.5k

Allowable Shear = 11.5k

Factor of Safety (F.S.)

$$\left(\frac{\text{Average Failure Tension}}{\text{Design Allowable Tension} \times \text{F.S.}} \right)^{4/3} + \left(\frac{\text{Average Failure Shear}}{\text{Design Allowable Shear} \times \text{F.S.}} \right)^{4/3} = 1.0$$

<u>SPECIMEN NO's</u>	<u>TENSION AND SHEAR AVERAGE FAILURE LOAD (k)</u>	<u>FACTOR OF SAFETY</u>
21 thru 25	28,355	$\left(\frac{28.36}{11.5 \times \text{F.S.}} \right)^{4/3} + \left(\frac{28.36}{11.5 \times \text{F.S.}} \right)^{4/3} = 1.0$ F.S. = 4.15


5.0 CONCLUSIONS

These test results show that the performance capabilities of the 1 1/2-inch type EC-6W and the 1-inch type EC-2W Richmond Inserts in shear, tension and combined shear and tension exceed the design allowable by a ratio of more than 3 to 1. These conclusions are valid for the design allowables shown in Specification 2323-SS-30, based on a spacing of the Richmond Inserts such that a full shear cone can develop.

Based on this test, the design allowables for shear, tension and combined shear and tension are acceptable for use without further investigation or additional calculations. Richmond's recommendation of a minimum safety factor of 3 has been complied with.

APPENDIX 1

DRAWING NO. FSC-00464 SHT. 1, 2 & 3




ITEM	QTY	DESCRIPTION	UNIT	REMARKS
1	1	Richmond Insert Shear Test Specimen	EA	
2	1	Richmond Insert Shear Test Specimen	EA	
3	1	Richmond Insert Shear Test Specimen	EA	
4	1	Richmond Insert Shear Test Specimen	EA	
5	1	Richmond Insert Shear Test Specimen	EA	
6	1	Richmond Insert Shear Test Specimen	EA	
7	1	Richmond Insert Shear Test Specimen	EA	
8	1	Richmond Insert Shear Test Specimen	EA	
9	1	Richmond Insert Shear Test Specimen	EA	
10	1	Richmond Insert Shear Test Specimen	EA	
11	1	Richmond Insert Shear Test Specimen	EA	
12	1	Richmond Insert Shear Test Specimen	EA	
13	1	Richmond Insert Shear Test Specimen	EA	
14	1	Richmond Insert Shear Test Specimen	EA	
15	1	Richmond Insert Shear Test Specimen	EA	
16	1	Richmond Insert Shear Test Specimen	EA	
17	1	Richmond Insert Shear Test Specimen	EA	
18	1	Richmond Insert Shear Test Specimen	EA	
19	1	Richmond Insert Shear Test Specimen	EA	
20	1	Richmond Insert Shear Test Specimen	EA	
21	1	Richmond Insert Shear Test Specimen	EA	
22	1	Richmond Insert Shear Test Specimen	EA	
23	1	Richmond Insert Shear Test Specimen	EA	
24	1	Richmond Insert Shear Test Specimen	EA	
25	1	Richmond Insert Shear Test Specimen	EA	
26	1	Richmond Insert Shear Test Specimen	EA	
27	1	Richmond Insert Shear Test Specimen	EA	
28	1	Richmond Insert Shear Test Specimen	EA	
29	1	Richmond Insert Shear Test Specimen	EA	
30	1	Richmond Insert Shear Test Specimen	EA	
31	1	Richmond Insert Shear Test Specimen	EA	
32	1	Richmond Insert Shear Test Specimen	EA	
33	1	Richmond Insert Shear Test Specimen	EA	
34	1	Richmond Insert Shear Test Specimen	EA	
35	1	Richmond Insert Shear Test Specimen	EA	
36	1	Richmond Insert Shear Test Specimen	EA	
37	1	Richmond Insert Shear Test Specimen	EA	
38	1	Richmond Insert Shear Test Specimen	EA	
39	1	Richmond Insert Shear Test Specimen	EA	
40	1	Richmond Insert Shear Test Specimen	EA	
41	1	Richmond Insert Shear Test Specimen	EA	
42	1	Richmond Insert Shear Test Specimen	EA	
43	1	Richmond Insert Shear Test Specimen	EA	
44	1	Richmond Insert Shear Test Specimen	EA	
45	1	Richmond Insert Shear Test Specimen	EA	
46	1	Richmond Insert Shear Test Specimen	EA	
47	1	Richmond Insert Shear Test Specimen	EA	
48	1	Richmond Insert Shear Test Specimen	EA	
49	1	Richmond Insert Shear Test Specimen	EA	
50	1	Richmond Insert Shear Test Specimen	EA	

FOR OFFICE AND ENGINEERING USE ONLY

TITLE: RICHMOND INSERT SHEAR TEST SPECIMEN INSTALLATION APPARATUS DRAWN BY: [Blank] CHECKED BY: [Blank] DESIGNED BY: [Blank] DATE: [Blank]	PROJECT NO.: [Blank] SHEET NO.: [Blank] OF [Blank]	COMPANY: BROWN & ROOT, INC. ADDRESS: [Blank] CITY: [Blank] STATE: [Blank]	CLIENT: TEXAS UTILITIES SERVICES, INC. ADDRESS: [Blank] CITY: GULF BROSSE, TEXAS
--	---	---	--

1. Use of this drawing is limited to the structure shown.
 2. No other reproduction or use is permitted.

FOR OFFICE AND
CONFERRING USE ONLY



SHOP BILL

DATE: 11/15/54
BY: J. R. BROWN
FOR: RICHMOND INERT TESTS

APPROVED BY: J. R. BROWN

SECTION: 101-100

REVISIONS:

NO.	DESCRIPTION	DATE
1	ASSEMBLY - 101-100	11/15/54
2	ASSEMBLY - 101-100	11/15/54
3	ASSEMBLY - 101-100	11/15/54
4	ASSEMBLY - 101-100	11/15/54
5	ASSEMBLY - 101-100	11/15/54


Brown & Root, Inc.
101-100

Richmond Installation (Apparatus)
Texas Utilities Services, Inc.
CP 111 - GUN ROSE, TEXAS


FSC - 00184
REV. 2-54

ENGINEERING


SEE SHEAR ASSEMBLY
DRAWING FOR DIMENSIONS, USE




PLAN VIEW
RICHMOND INSERT - TENSION TEST




ELEVATION VIEW



PLAN VIEW - RICHMOND INSERT - COMBINED TENSION & SHEAR TEST



ELEVATION VIEW



6081 1/2"
PLAN VIEW

THIS INSTALLATION IS NON SAFETY RELATED - (NHS)

ALL DIMENSIONS UNLESS SPECIFIED TO SPEC. AS SHOWN ON DRAWING TO BE IN ACCORDANCE WITH AISC AND AIA

Brown & Root, Inc.



DESIGNED BY: B. J. BROWN
DATE: 11/14/54
SCALE: NTS

APPROVED: *[Signature]*

REFERENCE DRAWING

CLIENT: RICHMOND INSERT TESTS
TENSION AND TENSION & SHEAR COMBINED
NAME OF COMPANY: TEXAS UTILITIES SERVICES, INC.
ADDRESS: C.P.S.E.S. GLEN ROSE, TEXAS

CONTRACT NO: 24110
DRAWING NO: E.P.C.-00142
SHEET: 3 OF 5

APPENDIX 2

CONCRETE COMPRESSIVE TEST REPORT

COMANCHE PEAK SES

PORT ON COMPRESSIVE TESTS OF CONCRETE
 OCEURE QT-9P-161-41

2-29-84
 POUR NO 017-9834-001
 CYL. SET NO 2473
 (TEST BLOCK)

MIX	COMPLETE DATA AS APPLICABLE FROM BATCH TICKET	(g) MOIST AGGR	FA	H ₂ O FA	CA	H ₂ O CA	TOTAL WATER/BATCH	TYPE OF CURING
	CEMENT / CU YD							
MATERIALS	BRAND OF CEMENT	TYPE OF CEMENT	BRAND OF AIR ENTRAINING ADMIXTURE		BRAND OF WATER REDUCING ADMIXTURE		MAX SIZE CA.	
	SOURCE CA	SP GR CA	SOURCE FA		SP GR FA		FINENESS MODULES FA	
SAMPLING	TYPE OF MIXING	BATCH LOAD	TICKET NO.	SAMPLE TAKEN AT:				
	METHOD OF PLACING		DATE SAMPLED	HOUR	WEATHER	AIR TEMP.	CONC. TEMP.	SLUMP
	TIME OF MIXING AT CENTRAL PLANT	UNIT WT. CU. FT	MIX ID.	SPECIMEN TAKEN BY		SPECIMEN CAST BY		AIR

CYLINDER ID.	AGE	MEASURED DIA IN.	AVG. DIA. IN.	DATE CAPPED	CAPPED BY	TIME TESTED	DATE TESTED	MAX. LOAD LB.	COMPRESSIVE STRENGTH	CAP CHECKED BY	CYLINDER TESTED BY	TYPE OF BREAK
2473A	7	5.980	5.990	3-6-84	DW	0710	3-7-84	116000	4120	UC	UC	Reg
2473B	7	6.001	6.001	3-6-84	DW	0704	3-7-84	119000	4210	UC	UC	Reg
2473C	28	6.002	6.000	3-23-84	DW	0702	3-28-84	153500	5430	UC	UC	Reg
2473D	28	6.000	6.008	3-23-84	DW	0648	3-28-84	155500	5490	UC	UC	Reg
2473E	28	6.001	6.002	3-23-84	DW	0659	3-28-84	139500	4930	UC	UC	Reg
2473F	28	6.016	6.004	3-23-84	DW	0656	3-28-84	141000	4920	UC	UC	Reg
NA												
NA												

DATE & TIME STRIPPED: 3-1-84 9:15 AM
 REMARKS:

CURING CONTROL TEST RESULTS FOR 28 DAY BREAK

LABORATORY CURED CYLINDER(S)	FIELD CURED CYLINDER(S)
STRENGTH (P.S.I.) <u>5430</u> (C)	STRENGTH (P.S.I.) <u>4930</u> (D)
<u>5490</u> (D)	<u>4920</u> (D)
1. (C)+(D) = (C)+(D) = <u>0.91</u> *	2. (D)+(D) + 2 = <u>4955</u> *

* NOTE: (1) ABOVE MUST BE EQUAL TO OR GREATER THAN 0.85; OR (2) ABOVE NEED NOT EXCEED THE DESIGN STRENGTH BY MORE THAN 500 PSI; EVEN THOUGH THE 0.85 CRITERION IS NOT MET

MICROMETER OR CALIPERS NO. M2-T6 1392
 COMPRESSION MACHINE NO. M&T 3071
 CAPPING MOLD NO. W-101 & 1-102

7 DAY PREPARED BY UC CHECKED BY IAS
 28 DAY PREPARED BY UC CHECKED BY IAS

(IGN ENGINEERS COMMENTS (IF APPLICABLE))

[Signature]
 TUGCO

APPENDIX 2

TEST DATA SHEETS

COMANCHE PEAK SES

SHEAR TESTS

RICHMOND $1\frac{1}{2}$ -INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0- \approx 13 gca

Specimen Number: 1 Bolt Spec: A-490 Date: 3 Apr '84

(First insert @ west end of conc. slab)

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs.)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
0.003	0.003	400	5300	
.032	.035	800	10600	
.060	.060	1200	15900	
.076	.079	1600	21200	
.095	.098	2000	26500	
.111	.116	2400	31800	
.128	.132	2800	37100	
.144	.150	3200	42400	
.160	.167	3600	47700	
.178	.185	4000	53000	
.196	.206	4400	58300	
.220	.233	4800	63600	
.250	.264	5200	68900	
.277	.297	5600	74200	
.304	.328	6000	79500	Bolt deformed.
.380	.429	6400	84800	Crushing of concrete was
.510	1.125	6800	90100	principal failure. No increase
				in load with increased deflec-
				tion. Did not load to destruction
				Burned off bolthead for removal. Insert stayed fast
				in concrete

* Jack Thrust equal Shear Load on Insert.
 Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25

Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355

Dial Gauge:.....M & TE Number 2949

Due Date: 16 Apr 84

Due Date: 29 June 84

Performed By:

Witnessed By:

J. C. Gilbert 3 April 84
 Name Date

Allen Britz 4-3-84
 QA Representative Date

COMANCHE PEAK SES
SHEAR TESTS

RICHMOND $1\frac{1}{2}$ - INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0-~~18~~ 18 jch

Specimen Number: 2
(2nd from west end)

Bolt Spec: A-490

Date: 4 April 84

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs.)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
.002	0.002	400	5,300	
.021	.022	800	10,600	
.034	.036	1200	15,900	
.049	.051	1600	21,200	
.063	.066	2000	26,500	
.080	.083	2400	31,800	
.096	.102	2800	37,100	
.115	.121	3200	42,400	
.133	.142	3600	47,700	
.157	.166	4000	53,000	
.180	.192	4400	58,300	
.208	.217	4800	63,600	
.237	.247	5200	68,900	
.263	.276	5600	74,200	
.293	.314	6000	79,500	
.338	.370	6400	84,800	
.480	.555	6800	90,100	
.770	1.110	7200	95,400	Bolt sheared abruptly. Concrete spalled on compression side of insert. Approx $1\frac{1}{2}$ " deep, running out to zero @ 7" away. Spall approx 6" wide near insert.

* Jack Thrust equal Shear Load on Insert.
Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25
Jack:.....Equipment Number RCH 606
Pressure Gauge: M & TE Number 27472355 Due Date: 16 Apr 84
Dial Gauge:.....M & TE Number 2949 Due Date: 29 Jun 84



Insert top deflected 7/8"

Performed By:

Witnessed By:

J. C. Gilbreth 4 April 84
Name Date

Robert A. [Signature] 4-4-84
QA Representative Date

COMANCHE PEAK SES

SHEAR TESTS

RICHMOND 1 1/2-INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0-~~X~~ 13 *per*

Specimen Number: 3

Bolt Spec: A-490

Date: 4 April 84

(3rd from West End)

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs.)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
.000	.000	400	5300	
.002	.002	800	10600	
.003	.003	1200	15900	
.006	.007	1600	21200	
.012	.018	2000	26500	
.032	.036	2400	31800	
.049	.052	2800	37100	
.067	.069	3200	42400	
.078	.083	3600	47700	
.096	.107	4000	53000	
.126	.131	4400	58300	
.144	.154	4800	63600	
.174	.182	5200	68900	
.206	.218	5600	74200	
.242	.259	6000	79500	
.283	.315	6400	84800	
.365	.399	6800	90100	
.540	(1.2)	7200	95400	Bolt sheared abruptly. Concrete spalled 1" deep @ insert, tapering to zero depth @ 5" out (on compression side of insert). Insert deformed where visible (ins, 12). Insert seemingly intact where still in concrete.

* Jack Thrust equal Shear Load on Insert.

Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25

Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355

Dial Gauge:.....M & TE Number 2949

Due Date: 16 Apr 84

Due Date: 29 Jun 84

Insert top deflected abt 5/8"

Performed By:

Witnessed By:

J. C. Gillett 4 April 84
Name Date

Arthur Pitroch 4-4-84
QA Representative Date

COMANCHE PEAK SES

SHEAR TESTS

RICHMOND 1 1/2-INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0-~~X~~13 *per*

Specimen Number: 4

Bolt Spec: A-490

Date: 4 April '84

(4th from West End)

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs.)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
.0005	.0005	400	5,300	
.003	.003	800	10,600	
.012	.013	1200	15,900	
.024	.026	1600	21,200	
.035	.038	2000	26,500	
.047	.048	2400	31,800	
.058	.059	2800	37,100	
.067	.070	3200	42,400	
.078	.081	3600	47,700	
.089	.094	4000	53,000	
.102	.1	4400		accidental opening of valve - Good return
.107	.109	4800	58,300	
.116	.120	4800	63,600	
.128	.133	5200	68,900	
.142	.146	5600	74,200	
.156	.164	6000	79,500	
.173	.181	6400	84,800	
.292	.303	6800	90,100	
.315	.333	7200	95,400	
.360	.389	7600	100,700	
.530		8000	106,000	Bolt sheared abruptly. Concrete spalled.

* Jack Thrust equal Shear Load on Insert. *1" deep @ insert to 0" @ 4" out. spall 8" wide*

Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25


Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355

Dial Gauge:.....M & TE Number 2949

Due Date: 16 Apr 84

Due Date: 29 Jun 84



Insert deflected about 1/4"

Performed By:

Witnessed By:

J.C. Nilrott 4 April 84
Name Date

Andrew Ritzsch 4-4-84
QA Representative Date

COMANCHE PEAK SES
SHEAR TESTS

RICHMOND 1/2-INCH, TYPE INSERT

Reference: CP-EI-13.0-~~8~~12904


Specimen Number: 5
(5th from West End)

Bolt Spec: A-490

Date: 4 April 84

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs.)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
0.002	0.002	400	5300	
.004	.005	800	10600	
.013	.015	1200	15900	
.035	.037	1600	21200	
.057	.063	2000	26500	
.090	.094	2400	31800	
.117	.124	2800	37100	
.150	.157	3300	42400	
.176	.183	3600	47700	
.200	.209	4000	53000	
.223	.236	4400	58300	
.248	.261	4800	63600	
.276	.295	5200	68900	
.307	.322	5600	74200	
.338	.356	6000	79500	
.370	.389	6400	84800	
.408	.428	6800	90100	
.447	.479	7200	95400	
.506	.556	7600	100700	
.585		8000	106000	Bolt sheared abruptly. Concrete spalled 1.1" @ Break { 1" deep @ insert to 0" @ 4" out, 6" wide

* Jack Thrust equal Shear Load on Insert.

Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25 *thru: *

Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355

Dial Gauge:.....M & TE Number 2949

Due Date: 16 Apr '84

Due Date: 29 Jun '84

Insert top deflection 3/8"

Performed By:

Witnessed By:

L.C. Gilketh 4 Apr 84
Name Date

Andrew Pitzyk 4-4-84
QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond $1\frac{1}{2}$ -Inch, Type AC-GW Insert
 Reference: CP-EI-13.0 ~~13.0M~~

Specimen Number: 6 (6th from west)

Inserted Load Rod: A-193

Date: 10 April 84

Common	SHEAR				TENSION				Notes - Failure Mode		
	Gauge Press. (PSI)	1-* Jack Thrust (Lb.)	Deflection (Inch)		Gauge Press. (PSI)	2-* Jack Thrust (Lb.)	** Net Jack Thrust (Lb.)	*** Insert Load (Lb.)		Deflection (Inch)	
			Init.	After 2-Min.						Init.	After 2-Min.
400	5300	0.007	0.007		5300			0.0015	0.0015		
800	10600	.023	.024		10600			.005	.005		
1200	15900	.091	.042		15900			.0095	.0105		
1600	21200	.062	.064		21200			.018	.019		
2000	26500	.088	.095		26500			.031	.034		
2400	31800	.146	.153		31800			.046	.048		
2800	37100	.192	.199	N/A	37100	N/A	N/A	.054	.056		
3200	42400	.236	.246		42400			.062	.0635		
3600	47700	.290	.304		47700			.0715	.074		
4000	53000	.339	.382		53000			.083	.087		
4250	56313	.420			56313						
4300	56975	.460			56975						
4400	58300	.475	.559		58500			.115	.139		
4500	59625	.55			59625						
4800	60950	.630			60950						

- 1-* Jack Thrust = Shear Load on Insert.
- 1-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x $\frac{13.25}{1}$ for Shear Load.
- 2-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x $\frac{13.25}{2}$ for Tension Load.
- Total Wt. of Tension Load Beam = NA Lb.
- ** Net Jack Thrust = Total Thrust Minus $\frac{1}{2}$ Wt. of Beam.
- *** Insert Load = Net Jack Thrust x $\frac{1}{2}$

Shear Apparatus: Jack---Equipment No: RCH 606
 Pressure Gauge-M&TE No: 2355 Due Date: 16 Apr 84
 Dial Gauge-M&TE No: 2949 Due Date: 29 Jun 84
 Tension Apparatus: Jack-Equipment No: RCH 603T
 Pressure Gauge-M&TE No: 2776 Due Date: _____
 Dial Gauge-M&TE No: 2094 Due Date: 18 Jun 84

Performed By: J. C. Hilbert 4-10-84
 Name Date

Witnessed By: Andrew P. [Signature] 4-10-84
 QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond $\frac{1}{2}$ -Inch, Type EC-GIV Insert
 Reference: CP-EI-13.0 \rightarrow 132c4

Specimen Number: 6 (P. 2 of 2)

Inserted Load Rod: A-193

Date: 10 April '84

Gauge Press. (PSI)	SHEAR			TENSION						Notes - Failure Mode
	1-* Jack Thrust (Lb.)	Deflection (Inch)		Gauge Press. (PSI)	2-* Jack Thrust (Lb.)	** Net Jack Thrust (Lb.)	*** Insert Load (Lb.)	Deflection (Inch)		
		Init.	After 2-Min.					Init.	After 2-Min.	
4800	63600	.750	.808		63600			.164	.167	
5000	66250	.820			66250					
5100	67575	.910			67575					
5200	68900	1.010			68900	N/A		0.186		
5100	67575			N/A	67575	N/A	N/A			Abrupt shearing of Rod. Rod deformed in bending @ shear plane, carrying insert washer some $\frac{1}{2}$ " horizontally.

- 1-* Jack Thrust - Shear Load on Insert.
- 1-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x $\frac{13.25}{1}$ for Shear Load.
- 2-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x $\frac{13.25}{1}$ for Tension Load.
- Total Wt. of Tension Load Beam = $\frac{N/A}{1}$ Lb.
- ** Net Jack Thrust = Total Thrust Minus $\frac{1}{2}$ Wt. of Beam.
- *** Insert Load = Net Jack Thrust $\times 2$. 204

Shear Apparatus: Jack---Equipment No: RCH 606
 Pressure Gauge-M&TE No: 2355 Due Date: 16 Apr '84
 Dial Gauge-M&TE No: 2949 Due Date: 29 Apr '84
 Tension Apparatus: Jack-Equipment No: RCH 6037
 Pressure Gauge-M&TE No: Same Due Date:
 Dial Gauge-M&TE No: 2094 Due Date: 18 Apr '84

Performed By: J. C. Gillett 4-10-84
 Name Date

Witnessed By: Alan Dietz 4-10-84
 QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond 1/2-Inch, Type ^{EC-CW} Insert
 Reference: CP-EI-13.0-9-1390A

Specimen Number: 7 (7th from west end)

Inserted Load Rod: A-193

Date: 11 April '84

Comments	SHEAR				TENSION					Notes - Failure Mode	
	Gauge Press. (PSI)	Jack Thrust (Lb.)	Deflection (Inch)		Gauge Press. (PSI)	Jack Thrust (Lb.)	Net Jack Thrust (Lb.)	Insert Load (Lb.)	Deflection (Inch)		
			Init.	After 2-Min.					Init.		After 2-Min.
	400	5300	0.000	0.000		5300			0.000	0.000	
	800	10600	.009	.000		10600			.003	.003	
	1200	15900	.023	.026		15900			.012	.012	
	1600	21200	.041	.043		21200			.022	.023	
	2000	26500	.070	.075		26500			.039	.043	
	2400	31800	.125	.133		31800			.063	.065	
	2800	37100	.179	.182		37100			.084	.086	
	3200	42400	.227	.236		42400			.102	.104	
	3600	47700	.277	.297	N/A	47700	N/A	N/A	.117	.121	
	4000	53000	.305	.371		53000			.135	.140	
	4400	58300	.350	.449		58300			.165	.179	
	4600	60950	.58			60950			.195		
	4700	62275	.770			62275			.210		Vert. deflection sensor reversed direction due to fouling of bracket with bending rod.
	4800	63600	.802	.846		63600			.206	.198	Rod failed in shear. Top of insert deflected horizontally some 5/8". Rod distorted to some 30° from vert @ shear zone.
	4950	65588	.870			65588					Concrete spalled slightly around insert
	5000	66250	.900			66250					break! insert intact
	5050	66913	1.15			66913					
	5100	67575	1.200	1.30		67575					

1* Jack Thrust = Shear Load on Insert.

1* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Shear Load.

2* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Tension Load.

Total Wt. of Tension Load Beam = N/A Lb.

** Net Jack Thrust = Total Thrust Minus 1/2 Wt. of Beam.

*** Insert Load = Net Jack Thrust x 2 = 204

Shear Apparatus: Jack---Equipment No: RCM 606

Pressure Gauge-M&TE No: 2355 Due Date: 16 Jun 84

Dial Gauge-M&TE No: 2949 Due Date: 29 Jun 84

Tension Apparatus: Jack-Equipment No: RCM 603T

Pressure Gauge-M&TE No: Same Due Date:

Dial Gauge-M&TE No: 2094 Due Date: 18 Jun 84

Performed By: J. C. Helbeth, 4-11-84
 Name Date

Witnessed By: Andrew Chittenden 4-11-84
 QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond $\frac{1}{2}$ -Inch, Type EC-6W Insert
 Reference: CP-EI-13.0-#13918

Specimen Number: 8 (8th from west end)

Inserted Load Rod: A-193

Date: 11 April '84

Comments	SHEAR				TENSION				Notes - Failure Mode		
	Gauge Press. (PSI)	Jack Thrust (Lb.)	Deflection (Inch)		Gauge Press. (PSI)	Jack Thrust (Lb.)	Net Jack Thrust (Lb.)	Insert Load (Lb.)		Deflection (Inch)	
			Init.	After 2-Min.						Init.	After 2-Min.
	400	5380	0.000	0.000		5300			0.000	0.000	
	800	10600	.021	.021		10600			.001	.001	
	1200	15900	.046	.047		15900			.0035	.0045	
	1600	21200	.064	.068		21200			.008	.009	
	2000	26500	.081	.088		26500			.012	.013	
	2400	31800	.096	.104		31800			.018	.019	
	2800	37100	.112	.120		37100			.024	.025	
	3200	42400	.128	.136		42400			.030	.031	
	3600	47700	.144	.152		47700			.036	.037	
	4000	53000	.160	.168	N/A	53000	N/A	N/A	.042	.043	
	4400	58300	.176	.184		58300			.048	.049	
	4800	63600	.192	.200		63600			.054	.055	
	5200	68900	.208	.216		68900			.060	.061	
	5600	74200	.224	.232		74200			.066	.067	
	6000	79500	.240	.248		79500			.072	.073	
	6400	84800	.256	.264		84800			.078	.079	
	6800	90100	.272	.280		90100			.084	.085	
	7200	95400	.288	.296		95400			.090	.091	
	7600	100700	.304	.312		100700			.096	.097	
	8000	106000	.320	.328		106000			.102	.103	
	8400	111300	.336	.344		111300			.108	.109	
	8800	116600	.352	.360		116600			.114	.115	
	9200	121900	.368	.376		121900			.120	.121	
	9600	127200	.384	.392		127200			.126	.127	
	10000	132500	.400	.408		132500			.132	.133	
	10400	137800	.416	.424		137800			.138	.139	
	10800	143100	.432	.440		143100			.144	.145	
	11200	148400	.448	.456		148400			.150	.151	
	11600	153700	.464	.472		153700			.156	.157	
	12000	159000	.480	.488		159000			.162	.163	
	12400	164300	.496	.504		164300			.168	.169	
	12800	169600	.512	.520		169600			.174	.175	
	13200	174900	.528	.536		174900			.180	.181	
	13600	180200	.544	.552		180200			.186	.187	
	14000	185500	.560	.568		185500			.192	.193	
	14400	190800	.576	.584		190800			.198	.199	
	14800	196100	.592	.600		196100			.204	.205	
	15200	201400	.608	.616		201400			.210	.211	
	15600	206700	.624	.632		206700			.216	.217	
	16000	212000	.640	.648		212000			.222	.223	
	16400	217300	.656	.664		217300			.228	.229	
	16800	222600	.672	.680		222600			.234	.235	
	17200	227900	.688	.696		227900			.240	.241	
	17600	233200	.704	.712		233200			.246	.247	
	18000	238500	.720	.728		238500			.252	.253	
	18400	243800	.736	.744		243800			.258	.259	
	18800	249100	.752	.760		249100			.264	.265	
	19200	254400	.768	.776		254400			.270	.271	
	19600	259700	.784	.792		259700			.276	.277	
	20000	265000	.800	.808		265000			.282	.283	
	20400	270300	.816	.824		270300			.288	.289	
	20800	275600	.832	.840		275600			.294	.295	
	21200	280900	.848	.856		280900			.300	.301	
	21600	286200	.864	.872		286200			.306	.307	
	22000	291500	.880	.888		291500			.312	.313	
	22400	296800	.896	.904		296800			.318	.319	
	22800	302100	.912	.920		302100			.324	.325	
	23200	307400	.928	.936		307400			.330	.331	
	23600	312700	.944	.952		312700			.336	.337	
	24000	318000	.960	.968		318000			.342	.343	
	24400	323300	.976	.984		323300			.348	.349	
	24800	328600	.992	1.000		328600			.354	.355	
	25200	333900	1.008	1.016		333900			.360	.361	
	25600	339200	1.024	1.032		339200			.366	.367	
	26000	344500	1.040	1.048		344500			.372	.373	
	26400	349800	1.056	1.064		349800			.378	.379	
	26800	355100	1.072	1.080		355100			.384	.385	
	27200	360400	1.088	1.096		360400			.390	.391	
	27600	365700	1.104	1.112		365700			.396	.397	
	28000	371000	1.120	1.128		371000			.402	.403	
	28400	376300	1.136	1.144		376300			.408	.409	
	28800	381600	1.152	1.160		381600			.414	.415	
	29200	386900	1.168	1.176		386900			.420	.421	
	29600	392200	1.184	1.192		392200			.426	.427	
	30000	397500	1.200	1.208		397500			.432	.433	
	30400	402800	1.216	1.224		402800			.438	.439	
	30800	408100	1.232	1.240		408100			.444	.445	
	31200	413400	1.248	1.256		413400			.450	.451	
	31600	418700	1.264	1.272		418700			.456	.457	
	32000	424000	1.280	1.288		424000			.462	.463	
	32400	429300	1.296	1.304		429300			.468	.469	
	32800	434600	1.312	1.320		434600			.474	.475	
	33200	439900	1.328	1.336		439900			.480	.481	
	33600	445200	1.344	1.352		445200			.486	.487	
	34000	450500	1.360	1.368		450500			.492	.493	
	34400	455800	1.376	1.384		455800			.498	.499	
	34800	461100	1.392	1.400		461100			.504	.505	
	35200	466400	1.408	1.416		466400			.510	.511	
	35600	471700	1.424	1.432		471700			.516	.517	
	36000	477000	1.440	1.448		477000			.522	.523	
	36400	482300	1.456	1.464		482300			.528	.529	
	36800	487600	1.472	1.480		487600			.534	.535	
	37200	492900	1.488	1.496		492900			.540	.541	
	37600	498200	1.504	1.512		498200			.546	.547	
	38000	503500	1.520	1.528		503500			.552	.553	
	38400	508800	1.536	1.544		508800			.558	.559	
	38800	514100	1.552	1.560		514100			.564	.565	
	39200	519400	1.568	1.576		519400			.570	.571	
	39600	524700	1.584	1.592		524700			.576	.577	
	40000	530000	1.600	1.608		530000			.582	.583	
	40400	535300	1.616	1.624		535300			.588	.589	
	40800	540600	1.632	1.640		540600			.594	.595	
	41200	545900	1.648	1.656		545900			.600	.601	
	41600	551200	1.664	1.672		551200			.606	.607	
	42000	556500	1.680	1.688		556500			.612	.613	
	42400	561800	1.696	1.704		561800			.618	.619	
	42800	567100	1.712	1.720		567100			.624	.625	
	43200	572400	1.728	1.736		572400			.630	.631	
	43600	577700	1.744	1.752		577700			.636	.637	
	44000	583000	1.760	1.768		583000			.642	.643	
	44400	588300	1.776	1.784		588300			.648	.649	
	44800	593600	1.792	1.800		593600			.654	.655	
	45200	598900	1.808	1.816		598900			.660	.661	
	45600	604200	1.824								

96 124
45 174

COMANCHE PEAK SES
COMBINED SHEAR & TENSION TESTS
Richmond $1\frac{1}{2}$ -inch, Type EC-6W Insert
Reference: CP-EI-13.0-13, 13.04

Specimen Number: 9 (93 from west end)

Inserted Load Rod: A-193

Date: 11 April '84

Comments	SHEAR				TENSION					Notes - Failure Mode	
	Gauge Press. (PSI)	Jack Thrust (Lb.)	Deflection (Inch)		Gauge Press. (PSI)	2-* Jack Thrust (Lb.)	** Net Jack Thrust (Lb.)	*** Insert Load (Lb.)	Deflection (Inch)		
			Init.	After 2-Min.					Init.		After 2-Min.
	400	5300	0.000	0.000		5300			0.000	0.000	
	800	10600	.002	.002		10600			.000	.000	
	1200	15900	.002	.022		15900			.002	.003	
	1600	21200	.042	.047		21200			.005	.008	
	2000	26500	.073	.080		26500			.016	.018	
	2400	31800	.133	.143		31800			.037	.041	
	2800	37100	.200	.211		37100			.066	.067	
	3200	42400	.277	.283		42400			.092	.098	
	3600	47700	.311	.330		47700			.122	.133	
	4000	53000	.392	.376		53000			.163	.179	
	4400	58300	.490	.436		58300			.215	.236	
	4600	60950	.720		N/A	60950	N/A	N/A	.30		Dial gauges removed to prevent damage.
	4650	61613	.77			61613					
	3500	46375				46375					Break! shear failure of rod. Rod shear zone rotated about 45°. Struts on comp. & tension sides of insert broke loose from washer @ welds. Washer moved $\frac{3}{4}$ " horizontally. Insert below washer appeared to be intact but threaded coil slightly distorted. Conc. spalled $1\frac{1}{2}$ " x $6\frac{1}{2}$ " on comp. side.

- 1-* Jack Thrust = Shear Load on Insert.
- 1-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Shear Load.
- 2-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Tension Load.
- Total Wt. of Tension Load Beam = N/A lb.
- ** Net Jack Thrust = Total Thrust Minus $1/2$ Wt. of Beam.
- *** Insert Load = Net Jack Thrust x t .

Shear Apparatus: Jack---Equipment No: RCH 606
 Pressure Gauge-M&TE No: 2355 Due Date: 16 Apr '84
 Dial Gauge-M&TE No: 2949 Due Date: 29 Jun '84
 Tension Apparatus: Jack-Equipment No: RCH 603T
 Pressure Gauge-M&TE No: 5322 Due Date: _____
 Dial Gauge-M&TE No: 2094 Due Date: 18 Jun '84

Performed By: J. C. Gilbrink 4-11-84
 Name Date

Witnessed By: Alan Prutz 4-11-84
 QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond $1\frac{1}{2}$ - Inch, Type EC-GW Insert
 Reference: CP-EI-13.0-4 13y68

Specimen Number: 10 (10th from west end) Inserted Load Rod: A-193

Date: 11 April '84

Comments	SHEAR				TENSION				Notes - Failure Mode		
	Gauge Press. (PSI)	1-* Jack Thrust (Lb.)	Deflection (Inch)		Gauge Press. (PSI)	2-* Jack Thrust (Lb.)	** Net Jack Thrust (Lb.)	*** Insert Load (Lb.)		Deflection (Inch)	
			Init.	After 2-Min.						Init.	After 2-Min.
	400	5300	0.000	0.000		5300			0.000	0.000	
	800	10600	.000	.000		10600			.000	.000	
	1200	15900	.005	.006		15900			.001	.001	
	1600	21200	.006	.008		21200			.002	.003	
	2000	26500	.007	.007		26500			.002	.003	
	2400	31800	.008	.007		31800			.002	.003	
	2800	37100	.009	.007		37100			.002	.003	
	3200	42400	.009	.007		42400			.002	.003	
	3600	47700	.009	.007		47700			.002	.003	
	4000	53000	.009	.007		53000			.002	.003	
	4400	58300	.009	.007		58300			.002	.003	
	4600	60950	.270		N/A	60950	N/A	N/A			
	4700	62275	.310			62275					
	4800	63600	.315			63600			.165		
	4800	63600	.550			63600					
	4900	63600	.600	.625		63600			.230	.245	Threads stripped. Lifted insert washer loose from struts. Insert remained in place.
	4900	64925				64925					
	4										

- 1-* Jack Thrust = Shear Load on Insert.
 1-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Shear Load.
 2-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Tension Load.
 Total Wt. of Tension Load Beam = N/A Lb.
 ** Net Jack Thrust = Total Thrust Minus $1/2$ Wt. of Beam.
 *** Insert Load = Net Jack Thrust $\times 2$. 904

Shear Apparatus: Jack---Equipment No: RCH 606
 Pressure Gauge-M&T No: 2353 Due Date: 16 Apr '84
 Dial Gauge-M&T No: 2949 Due Date: 29 Jun '84
 Tension Apparatus: Jack-Equipment No: RCH 603T
 Pressure Gauge-M&T No: same Due Date:
 Dial Gauge-M&T No: 2094 Due Date: 18 Jun '84

Performed By: J.C. Gilbert 4-11-84
 Name Date

Witnessed By: Andrew Dickson 4-11-84
 A Representative Date

COMANCHE PEAK SES
TENSION TESTS

RICHMOND 1/2-INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0-~~13~~₁₃

Specimen Number: 11 Load Rod Spec: A-193 Date: 5 Apr 84
(11th from west, 5th from east)

GAUGE PRESS. (S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2650	1425	2850	0.000	0.000	
400	5300	4075	8150	0.000	0.000	
600	7950	6725	13450	.000	.000	
800	10600	9375	18750	.001	.001	
1000	13250	12025	24050	.003	.0035	
1200	15900	14675	29350	.005	.006	
1400	18550	17325	34650	.009	.011	
1600	21200	19975	39950	.013	.015	
1800	23850	22625	43250	.0155	.017	
2000	26500	25275	50550	.0195	.020	
2200	29150	27925	55850	.022	.023	
2400	31800	30575	61150	.027	.028	
2600	34450	33225	66450	.032	.035	
2800	37100	35875	71750	.073	.078	
3000	39750	38525	77050	.096	.099	
3200	42400	41175	82350	.103	.1055	
3400	45050	43825	87650	.109	.111	
3600	47700	46475	92950	.123	.123	
3800	50350	49125	98250	.138	.148	
4000	53000	51775	103550	.190	.214	
4100	100000 54325	53100	106,200			Abrupt failure of threads (insert and rod). Thread engagement was "full". Threads on both rod & insert were stripped. Concrete spalled to about 12" depth, 18" x 15" cover concrete only. Rebar not exposed.

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25
 Total Weight of Load Beam = 2450
 ** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. (1/2 wt. of bin. = 1225#)
 *** Insert Load = Net Jack Thrust x 2.

By dynamometer
No M & TE # 1432
due Apr. 17, '84

Jack: Equipment Number RCM 606
 Pressure Gauge: M & TE Number 2355 Due Date: 16 Apr 84
 Dial Gauge: M & TE Number 2949 Due Date: 29 Jun '84

Performed By: J.C. Hilbert 5 apr '84
 Witnessed By: Andrew Puetzke 4-5-84
 Name Date QA Representative Date

COMANCHE PEAK SES
TENSION TESTS

RICHMOND $\frac{1}{2}$ -INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0-~~2~~ 13.04

Specimen Number: 12 Load Rod Spec: A-193 Date: 5 April '84
(12 from West, 4th from East)

GAUGE PRESS. P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2650	1425	2850	0.000	0.000	
400	5300	4075	8150	0.000	.000	
600	7950	6725	13450	.000	.000	
800	10600	9375	18750	.0015	.002	
1000	13250	12025	24050	.0035	.0055	
1200	15900	14675	29350	.007	.008	
1400	18550	17325	34650	.009	.010	
1600	21200	19975	39950	.0115	.012	
1800	23850	22625	43250	.014	.0145	
2000	26500	25275	50550	.017	.0175	
2200	29150	27925	55850	.0195	.020	
2400	31800	30575	61150	.022	.0225	
2600	34450	33225	66450	.0245	.0265	
2800	37100	35875	71750	.028	.0295	
3000	39750	38525	77050	.032	.034	
3200	42400	41175	82350	.036	.037	
3400	45050	43825	87650	.040	.043	
3600	47700	46475	92950	.048	.051	
3800	50350	49125	98250	.057	.0625	
4000	53000	51775	103550	.070	.075	
4200	55650	54425	108850	.084	.092	
4400	58300	57075	114150	.120		Failure by stripped threads, Rod to insert. Thread engagement was "full" stripped length was 3". Concrete surface spalled in 18" dia. area. Spalling apparently result of impact when threads stripped. This failure was abrupt. Max. depth of surface spall was 1". Did not expose rebar.

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25
Total Weight of Load Beam = 2450

** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. ($\frac{1}{2}$ Wt. = 1225#)

*** Insert Load = Net Jack Thrust x 2.
Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355 Due Date: 16 Apr '84

Dial Gauge: M & TE Number 2949 Due Date: 29 Jun '84

Performed By:

Witnessed By:

J. C. Helbert 5 apr 84
Name Date

Andrew P. ... 9-5-84
QA Representative Date

COMANCHE PEAK CES
TENSION TESTS

RICHMOND $\frac{1}{2}$ -INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0-~~13~~ 13 ~~13~~

Specimen Number: 13 Load Rod Spec: A-193 Date: 5 Apr 84
(13th from west, 3rd from east)

GAUGE PRESS. P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2650	1725	2850	0.000	0.000	
400	5300	4075	8150	0.000	0.000	
600	7950	6725	13450	0.000	0.000	
800	10600	9375	18750	0.000	0.000	
1000	13250	12025	24050	0.001	0.001	
1200	15900	14675	29350	.001	.001	
1400	18550	17325	34650	.0015	.0015	
1600	21200	19975	39950	.003	.004	
1800	23850	22625	43250	.0045	.0045	
2000	26500	25275	50550	.0055	.007	
2200	29150	27925	55850	.0075	.008	
2400	31800	30575	61150	.009	.010	
2600	34450	33225	66450	.011	.012	
2800	37100	35875	71750	.0135	.015	
3000	39750	38525	77050	.0175	.0185	
3200	42400	41175	82350	.021	.023	
3400	45050	43825	87650	.0255	.0285	
3600	47700	46475	92950	.033	.0385	
3800	50350	49125	98250	.045	.051	
4000	53000	51775	103550	.059	.063	
4200	55650	54425	108850	.074	.080	
4400	58300	57075	114150			Concrete failed
						on surface in area some 18" x 18"
						structural failure that allowed this was
						failure of the weld connecting the
						axial strut rods to the threaded coil.
						This permitted surface spalling of the
						concrete. However there was no discern-
						able sign of a cone failure in the concrete.
						Concrete visible @ rebar depth looked intact
						and there was no sound like a void when
						tapped with a metal object.

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25
Total Weight of Load Beam = 2450

** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. ($\frac{1}{2}$ wt. = 1225#)

*** Insert Load = Net Jack Thrust x 2.
Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355 Due Date: 16 Apr 84

Dial Gauge: M & TE Number 2949 Due Date: 29 Jun 84

Performed By:

Witnessed By:

J.C. Helbert 5 Apr 84
Name Date

Andrew Rietzke 4.5.84
QA Representative Date

COMANCHE PEAK SES
TENSION TESTS

RICHMOND 1 1/2-INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0-~~13~~ 13 PCN

Specimen Number: 14 Load Rod Spec: A-193 Date: 5 Apr 84

(14th from West End, 2nd from East)

GAUGE PRESS. (P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2650	1425	2850	0.000	0.000	
400	5300	4075	8150	0.001	0.001	
600	7950	6725	13450	.0015	.0015	
800	10600	9375	18750	.002	.002	
1000	13250	12025	24050	.004	.004	
1200	15900	14675	29350	.004	.005	
1400	18550	17325	34650	.008	.005	
1600	21200	19975	39950	.0095	.0095	
1800	23850	22625	45250	.010	.010	
2000	26500	25275	50550	.010	.010	
2200	29150	27925	55850	.010	.010	
2400	31800	30575	61150	.012	.012	
2600	34450	33225	66450	.0135	.014	
2800	37100	35875	71750	.016	.0165	
3000	39750	38525	77050	.018	.019	
3200	42400	41175	82350	.020	.024	
3400	45050	43825	87650	.028	.055	Concrete failed
3600						shear cone type failure. Depth of cone equal full depth of insert. Top of cone limited in size by rebars (@ 10" E.W.) After initial failure, rebars lifted cover concrete, fracturing in area about 3' x 5', the long dimen. corresponding to the direction of upper layer of rebar.

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25

Total Weight of Load Beam = 2450

** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. (1/2 WB = 1225)

*** Insert Load = Net Jack Thrust x 2.

Jack:.....Equipment Number PCN 606

Pressure Gauge: M & TE Number 2355

Due Date: 10 Apr '84

Dial Gauge: M & TE Number 2949

Due Date: 29 Jun '84

Performed By:

Witnessed By:

J.C. Gilbert 5 April 84

Andrew Ritzel 4-5-84

Name

Date

QA Representative

Date

COMANCHE PEAK SES
TENSION TESTS

RICHMOND $\frac{1}{2}$ -INCH, TYPE EC-6W INSERT

Reference: CP-EI-13.0 $\frac{1}{3}$ inch

Specimen Number: 15
(15th from West end - 1st on East End)

Load Rod Spec: A-193

Date: 4 April '84

GAUGE PRESS. (P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2650	1925	2850	0.000	0.000	
400	5300	4075	8150	0.000	0.000	
600	7950	6725	13450	0.001	0.001	
800	10600	9375	18750	0.003	0.003	
1000	13250	12025	24050	0.004	0.006	
1200	15900	14675	29350	.008	.008	
1400	18550	17325	34650	.009	.010	
1600	21200	19975	39950	.010	.012	
1800	23850	22625	45250	.013	.015	
2000	26500	25275	50550	.017	.0195	
2200	29150	27925	55850	.021	.024	
2400	31800	30575	61150	.026	.027	
2600	34450	33225	66450	.028	.031	
2800	37100	35875	71750	.034	.036	
3000	39750	38525	77050	.038	.040	
3200	42400	41175	82350	.041	.042	
3400	45050	43825	87650	.049	.053	
3600	47700	46475	92950	.058	.065	
3800	50350	49125	98250	.069	.081	
3900	51,675	50,450	100,900	.70		Concrete failed,
						shear cone type, limited test in area by
						rebar pattern. Concrete out above rebar
						spalled in oval 3' x 4', cone below cone.
						Cone about 10" dia at top. depth = insert
						height dimension top of conc. to offset
						in vertical rods of insert, (abt. 6")

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x $\frac{13.25}{1}$ (By dynamometer No. M & TE 1432)
 Total Weight of Load Beam = 2450 Lb. (-2 = 1225) --- due Apr 17, '84

** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam.

*** Insert Load = Net Jack Thrust x 2.
 Jack:.....Equipment Number RCH 666

Pressure Gauge: M & TE Number 2355 Due Date: 16 Apr 84

Dial Gauge: M & TE Number 2999 Due Date: 29 Jun 84

Performed By: J. C. Gilbreth 4 Apr 84
 Name Date

Witnessed By: Andrew Britz 4-4-84
 QA Representative Date

COMANCHE PEAK SES
SHEAR TESTS

RICHMOND / -INCH, TYPE EC-2W INSERT

Reference: CP-EI-13.0-~~X~~13.204

Specimen Number: 16
(1st on West end)

Bolt Spec: A-192 490 Date: 6 April '84

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs.)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
0.000	0.000	400	5,300	
.001	.001	800	10,600	
.0195	.021	1200	15,900	
.042	.044	1600	21,200	
.062	.0655	2000	26,500	
.085	.091	2400	31,800	
.112	.123	2800	37,100	
.152	.170	3200	42,400	
.22		3500-3600	46,375	Failure of bolt in shear.
<p>Insert top deflected 7/8" by crushing of upper portion of concrete. Within this yield pattern, the top of insert rotated a few degrees.</p>				

* Jack Thrust equal Shear Load on Insert.

Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25

Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355

Dial Gauge:.....M & TE Number 2749

Due Date: 16 Apr '84

Due Date: 29 Jun '84

Performed By:

Witnessed By:

J. C. Hilbath, 6 April '84
Name Date

Andrew Ritzel 4-6-84
QA Representative Date

COMANCHE PEAK SES
SHEAR TESTS

RICHMOND 1 -INCH, TYPE EC-2W INSERT

Reference: CP-EI-13.0-~~X~~ 13 gch

Specimen Number: 17

~~Bolt~~ Bolt Spec: A-490
~~Bolt~~ Bolt

Date: 6 Apr '84

(2nd fr West End)

DEFLECTION (IN.)		Jack GAUGE PRESSURE THRUST (Lbs)	Gauge JACK * THRUST Pressure (PSI)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
0.000	0.000	5300	400	
.020	.020	10,600	800	
.037	.039	15,900	1200	
.060	.0645	21,200	1600	
.087	.093	26,500	2000	
.127	.129	31,800	2400	
.166	.186	37,100	2800	
.313	.332	42,400	3200	
.	.	43,060	3250	Failure by bolt shear Insert deflected horizontally 3/8", being permitted by crushing failure of concrete. No apparent rotation of top of insert.

* Jack Thrust equal Shear Load on Insert.

Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25

Jack:.....Equipment Number RCM 606

Pressure Gauge: M & TE Number 2355

Dial Gauge:.....M & TE Number 2949

Due Date: 16 Apr '84

Due Date: 29 Jun '84

Performed By:

Witnessed By:

J C Gilbert 6 apr '84
Name Date

Adrian Pietroni 4-6-84
QA Representative Date

COMANCHE PEAK SES
SHEAR TESTS

RICHMOND 1 -INCH, TYPE EC-2W INSERT

Reference: CP-EI-13.0-~~X~~¹³YC~~4~~

Specimen Number: 18

Bolt Spec: A-490

Date: 6 Apr '84

(3rd from west end)

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
0.000	0.000	400	5300	
.003	.004	800	10600	
.023	.0245	1200	15900	
.042	.045	1600	21200	
.060	.063	2000	26500	
.080	.085	2400	31800	
.104	.109	2800	37100	
.156	.148	3200	42400	
.200	.332	3600	47700	
.400		3800	50350	Failure by bolt shear. Insert top deflected about 1/8", no apparent rotation of insert. Top of concrete crushed (spalled) about 2" in front of insert. The insert washer sheared off from the struts, thus the 1/8" deflection was after this shear failure. Coils & struts did not move.

* Jack Thrust equal Shear Load on Insert.

Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25

Jack:.....Equipment Number RCM 606

Pressure Gauge: M & TE Number 2355

Dial Gauge:.....M & TE Number 2949

Due Date: 16 Apr '84

Due Date: 29 Jun '84

Performed By:

Witnessed By:

J.C. Gilbert, 6 Apr '84
Name Date

Richard Ritzel, 4-6-84
QA Representative Date

COMANCHE PEAK SES
SHEAR TESTS

RICHMOND / -INCH, TYPE EC-2W INSERT

Reference: CP-EI-13.0-~~X~~¹³ 224

Specimen Number: 19

Bolt Spec: A-490

Date: 9 Apr '84

(4th from west end)

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs.)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
0.004	0.0035	400	5300	
.036	.036	800	10600	
.059	.0605	1200	15900	
.080	.081	1600	21200	
.098	.099	2000	26500	
.122	.127	2400	31800	
.147	.155	2800	37100	
.190	.2225	3200	42400	
		3600		
.270		3500	46375	Insert failed by breaking weld between upper coil and struts. Bolt failed after rotating with the engaged upper coil thru several degrees. The bolt failed in bending with a lesser load than the 46375 lb.

* Jack Thrust equal Shear Load on Insert.
 Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25
 Jack:.....Equipment Number RC14 606
 Pressure Gauge: M & TE Number 2355
 Dial Gauge:.....M & TE Number 2949

Due Date: 16 Apr '84
 Due Date: 29 JUN '84

Performed By:

Witnessed By:

J. C. Gillett 9 Apr '84
 Name Date

Andrew Ritzke 4-9-84
 QA Representative Date

COMANCHE PEAK SES
SHEAR TESTS

EC-2W

RICHMOND 1-INCH, TYPE INSERT

Reference: CP-EI-13.0-~~13~~13904

Specimen Number: 20

Bolt Spec: A-490

Date: 9 Apr 84

(5th from West End)

DEFLECTION (IN.)		GAUGE PRESSURE (P.S.I.)	JACK * THRUST (Lbs.)	NOTES-FAILURE MODE
INITIAL	AFTER 2-MIN.			
0.002	0.007	400		} Slack not out of apparatus
		800		
0.004	0.008	400		
0.008	0.008	800		
		1200		
0.003	0.003	900	5300	
.025	.032	800	10600	
.046	.096	1200	15900	
.063	.064	1600	21200	
.085	.087	2000	26500	
.115	0.122	2400	31800	
.154	.173	2800	37100	
.270		3200 3000	39,750	Concrete crushed. insert remained intact but upper portion rotated thru a few degrees. Deflection of upper part of insert (washer) 3/8". Bolt broke in bending at lower load than the max 39,750. Rotation caused conc spall to lift on tension side 1/2" deep, tapering to zero 10" back. Spall total 12" dia (I)

* Jack Thrust equal Shear Load on Insert.
 Jack Thrust (Lbs.) = Gauge Pressure (PSI) x 13.25
 Jack:.....Equipment Number RCH 606
 Pressure Gauge: M & TE Number 2355
 Dial Gauge:.....M & TE Number 2949

Due Date: 16 Apr '84
 Due Date: 29 Jun '84

Performed By:

Witnessed By:

J. C. Gilbert 9 Apr '84
 Name Date

Adrian Pietryk 4-9-84
 QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond 1 -Inch, Type EC-2W Insert
 Reference: CP-EI-13.0-5/13/84

Specimen Number: 21 (6th from West Ex) Inserted Load Rod: A-193

Date: 9 Apr 84

Gauge Press. (PSI)	SHEAR		TENSION					Notes - Failure Mode
	1-* Jack Thrust (Lb.)	Deflection (Inch) Init. After 2-Min.	Gauge Press. (PSI)	2-* Jack Thrust (Lb.)	** Net Jack Thrust (Lb.)	*** Insert Load (Lb.)	Deflection (Inch) Init. After 2-Min.	
400	5300	0.000 0.000		5300			0.000 0.000	
800	10600	.001 .001		10600			.000 .000	
1200	15900	.065 .061		15900			.022 .0225	
1600	21200	.173 .183		21200			.049 .0525	
2000	26500	.330 .370		26100			.111 .134	
2400	27825	.400		27825			.15	
			N/A		N/A	N/A		Sound of a weld breaking. ^{Rod} rod sheared @ 239 = 900 < 11,925#. Insert washer deflected laterally 3/8". Some bending of rod but fractured surface indicated a shear break. Top of insert rotated thru Concrete spalled all around @ about 12" dia. 1 1/2" deep @ insert, zero depth @ edge

- 1-* Jack Thrust = Shear Load on Insert.
- 1-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Shear Load.
- 2-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Tension Load.
- Total Wt. of Tension Load Beam = N/A Lb.
- ** Net Jack Thrust = Total Thrust Minus 1/2 Wt. of Beam
- *** Insert Load = Net Jack Thrust ÷ 2

Shear Apparatus: Jack---Equipment No: RCH 606
 Pressure Gauge-M&TE No: 2355 Due Date: 16 Apr 84
 Dial Gauge-M&TE No: 2949 Due Date: 29 Jun 84
 Tension Apparatus: Jack-Equipment No: RCH 603T
 Pressure Gauge-M&TE No: 5000 Due Date:
 Dial Gauge-M&TE No: 2450 2092 Due Date: 18 Jun 84

Performed By: J.C. Hillkott 9 April 84
 Name Date

Witnessed By: Andrew Dickson 4-9-84
 QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond 1 - Inch, Type ^{EC-2W} Insert
 Reference: CP-EI-13.0-~~13.0~~^{13.0W}

Specimen Number: 22 (7th from West)

Inserted Load Rod: A-193

Date: 9 April '84

Comments	SHEAR				TENSION				Notes - Failure Mode		
	Gauge Press. (PSI)	1-* Jack Thrust (lb.)	Deflection (Inch)		Gauge Press. (PSI)	2-* Jack Thrust (lb.)	** Net Jack Thrust (lb.)	*** Insert Load (lb.)		Deflection (Inch)	
			Init.	After 2-Min.						Init.	After 2-Min.
	400	10,600	0.002	0.004		5300			0.001	0.001	
	800	10,600	.037	.038		10,600			.013	.014	
	1200	15,900	.105	.109		15,900			.0255	.026	
	1600	21,200	.196	.205		21,200			.055	.058	
	2000	26,500	.342	.428		26,500			.115	.145	
	2200	29,150	.52			29,150			.16		
	1800	23,850			N/A	23,850	N/A	N/A			
	1500	19,875				19,875					

~~Water bucket~~ sharp noise. Cause unknown
 Rod sheared. Rod had rotated @ shear line thru approx. 20° when broke.
 Concrete spalled approx 15" diameter, being 12" on tension side & 3" on comp. (toward shear jack) side. 2" deep @ insert.
 Insert remained intact.

- 1-* Jack Thrust = Shear Load on Insert.
- 1-* Jack Thrust (lb.) = Gauge Pressure (PSI) x 19.25 for Shear Load.
- 2-* Jack Thrust (lb.) = Gauge Pressure (PSI) x 13.25 for Tension Load.
- Total Wt. of Tension Load Beam = N/A lb.
- ~~Net Jack Thrust = Total Thrust minus 1/2 Wt. of Beam.~~
- *** Insert Load = ~~Net Jack Thrust~~ x 2 = 926

Shear Apparatus: Jack---Equipment No: RCH 606
 Pressure Gauge-M&TE No: 2955 Due Date: 16 Apr 84
 Dial Gauge-M&TE No: 2949 Due Date: 29 Jun 84
 Tension Apparatus: Jack-Equipment No: RCH 603T
 Pressure Gauge-M&TE No: Same Due Date: _____
 Dial Gauge-M&TE No: 2094 Due Date: 18 Jun 84

Performed By: J. C. Hilbath 9 Apr '84
 Name Date

Witnessed By: John Ritzke 4-9-84
 QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond / -Inch, Type ^{EC-2W} Insert
 Reference: CP-EI-13.0-5004

Specimen Number: 24 (9th from west end)

Inserted Load Rod: A-193

Date: 10 April '84

Common	SHEAR				TENSION					Notes - Failure Mode	
	Gauge Press. (PSI)	1-* Jack Thrust (Lb.)	Deflection (Inch)		Gauge Press. (PSI)	2-* Jack Thrust (Lb.)	** Net Jack Thrust (Lb.)	*** Insert Load (Lb.)	Deflection (Inch)		
			Init.	After 2-Min.					Init.		After 2-Min.
	400	5,300	0.001	0.001		5,300			0.002	0.002	
	800	10,600	.008	.008		10,600			.0065	.0065	
	1200	15,900	.060	.070		15,900			.027	.030	
	1600	21,200	.153	.171		21,200			.062	.069	
	2000	26,500	.325	.390		26,500			.135	.159	
	2100	27,825	.400			27,825			.17		Rapid yielding began.
	2100	27,825	.500		N/A	27,825	N/A	N/A	.20		
	2200	28,150	.540			29,150			.227		
	2200	29,150	.700			29,150			.227		
	2000	26,500				26,500					Break. Abrupt shear failure of rod. Some 1/8" horizontal deflection of top of insert permitted by rotation crushing of concrete and ^{deflection} distortion of upper coil of insert. Concrete soaked 2" deep in tension. Visible 2" of insert seen to have tilted 5°(±). Insert intact

- 1-* Jack Thrust = Shear Load on Insert.
- 1-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x $\frac{13.25}{100}$ for Shear Load.
- 2-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x $\frac{13.25}{100}$ for Tension Load.
- Total Wt. of Tension Load Beam = $\frac{N/A}{Lb.}$
- ** ~~Net Jack Thrust = Total Thrust minus 1/2 Wt. of Beam.~~
- *** Insert Load = ~~Net Jack Thrust x 2~~ $\frac{Side}{}$

Shear Apparatus: Jack---Equipment No: RCH 506
 Pressure Gauge-M&T No: 2355 Due Date: 16 Apr '84
 Dial Gauge-M&T No: 2949 Due Date: 29 Jun '84
 Tension Apparatus: Jack-Equipment No: RCH 603T
 Pressure Gauge-M&T No: same Due Date:
 Dial Gauge-M&T No: 2094 Due Date: 18 Jun '84

Performed By: J. C. Gilbert, 10 April '84
 Name Date

Witnessed By: Adrian Peltz 4-10-84
 QA Representative Date

COMANCHE PEAK SES
 COMBINED SHEAR & TENSION TESTS
 Richmond 1 -Inch, Type ^{EC-2W} Insert
 Reference: CP-EI-13.0-~~3804~~

Specimen Number: 25 (10th from West End) Inserted Load Rod: A-193

Date: 10 April '84

Comments	SHEAR				TENSION				Notes - Failure Mode		
	Gauge Press. (PSI)	Jack Thrust (Lb.)	Deflection (Inch)		Gauge Press. (PSI)	2-* Jack Thrust (Lb.)	** Net Jack Thrust (Lb.)	*** Insert Load (Lb.)		Deflection (Inch)	
			Init.	After 2-Min.						Init.	After 2-Min.
	400	5300	0.0015	0.0015		5300			0.000	0.000	
	800	10600	0.026	0.028		10600			0.0025	0.004	
	1200	15900	.115	.122		15900			-0.005		
	1600	21200	.217	.229		21200			.006	.010	
	2000	26500	.260	.304		26500			.049	.063	
	2100	27825	.320			27825			.070		
	2150	28987	.400		N/A	28467	N/A	N/A	.080		Abrupt break. Insert deflected 1/2" (-). Rod failed in shear.

- 1-* Jack Thrust = Shear Load on Insert.
- 1-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 19.25 for Shear Load.
- 2-* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25 for Tension Load.
- Total Wt. of Tension Load Beam = N/A Lb.
- ** Net Jack Thrust = Total Thrust Minus 1/2 Wt. of Beam = 304
- *** Insert Load = Net Jack Thrust - 2.

Shear Apparatus: Jack---Equipment No: RCH 606
 Pressure Gauge-M&TE No: 2355 Due Date: 16 Apr '84
 Dial Gauge-M&TE No: 2949 Due Date: 29 Jun '84
 Tension Apparatus: Jack-Equipment No: RCH 603T
 Pressure Gauge-M&TE No: Same Due Date: _____
 Dial Gauge-M&TE No: 2094 Due Date: 18 Jun '84

Performed By: J. C. Gilbeth 10 April 84
 Name Date

Witnessed By: [Signature] 4-10-84
 QA Representative Date

COMMACHE PEAK SES
TENSION TESTS

RICHMOND 1 -INCH, TYPE EC-2W INSERT

Reference: CP-EI-13.0-~~13~~ 13904

Specimen Number: 26 Load Rod Spec: A-193 Date: 6 Apr '84
~~11th~~ 11th from west end, 5th from east

GAUGE PRESS. P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2650	1425	2850	0.000	0.000	
400	5300	4075	8150	.003	.003	
600	7950	6725	13450	.007	.0075	
800	10600	9375	18750	.012	.0125	
1000	13250	12025	24050	.0175	.019	
1200	15900	14675	29350	.037	.038	
1400	18550	17325	34650	.070	.070	
1600	21200	19975	39950	.098	.105	
1700	22525	21300	42600	.134		Failure.
						insert remained intact. Shear cone type failure of concrete. Insert was located near center between E-W & N-S re-bars. Cone was restricted somewhat by 4-bars, 2-each way. Some lifting force on bars caused concrete to spall 3-ft. ea. side of insert. Shear cone depth = full height of insert less 3/4" @ bottom.

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25
 Total Weight of Load Beam = 2450

** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. ($\frac{1}{2}$ wt. = 1225/16)

*** Insert Load = Net Jack Thrust x 2.
 Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355 Due Date: 16 Apr '84

Dial Gauge: M & TE Number 2949 Due Date: 29 Jun '84

Performed By:

Witnessed By:

J. B. Gilketh 6 Apr '84
 Name Date

Robert Dietzke 4-6-84
 QA Representative Date

COMANCHE PEAK SES
TENSION TESTS

RICHMOND / -INCH, TYPE EC-2W INSERT

Reference: CP-EI-13.0 ~~13.0~~ 13.25

Specimen Number: 27

Load Rod Spec: A-193

Date: 6 Apr '84

~~12th from West End,~~ 4th from east

GAUGE PRESS. P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2650	1425	2850	0.000	0.000	
400	5300	4075	8150	.000	.000	
600	7950	6725	13450	.000	.000	
800	10600	9375	18750	.0005	.0005	
1000	13250	12025	24050	.0065	.0075	
1200	15900	14675	29350	.0165	.0175	
1400	18550	17325	34650	.050	.056	
1600	21200	19975	39950	.089-060	.098	
1800 1750				.146		Failure
2000	23188	21960	43920			
			Failure occurred by failure of the insert. Weld between lower coil and vertical struts broke. Threaded, upper, coil came out and carried the two struts w/it. Concrete spalled an oval area about 1.5' x 2.25' max depth 2" @ insert. Exposed one rebar located 3" o.c. from insert. Rebar not disturbed. Only concrete cover removed.			

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25
Total Weight of Load Beam = 2450

** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. ($\frac{1}{2}$ Wt. = 1225)

*** Insert Load = Net Jack Thrust x 2.
Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355 Due Date: 16 Apr '84

Dial Gauge: M & TE Number 2949 Due Date: 29 Jun '84

Performed By:
J. C. Silbeth 6 Apr '84
Name Date

Witnessed By:
Adrian Ritzel 4-6-84
QA Representative Date

COMANCHE PEAK
TENSION TESTS

RICHMOND 1-INCH, TYPE EC-2W INSERT

Reference: CP-EI-13.0-~~13~~ 13 RCY

Specimen Number: 28
(3rd from east end)

Load Rod Spec: A-193

Date: 10 April '84

GAUGE PRESS. (P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2650	1425	2850	0.000	0.000	
400	5300	4075	8150	.000	.000	
600	7950	6725	13450	.000	.000	
800	10600	9375	18750	.002	.002	
1000	13250	12025	24050	.004	.005	
1200	15900	14675	29350	.009	.010	
1400	18550	17325	34650	.015	.029	
1500 1550	20538	19313	38624	.055	-	
1600	21200	19975	39950	.067	.082	
1700 2000	22525	21300	42600	.15		Concrete shear
2200						cone failure. Insert and rod remained intact. Cone height equal insert height. Size of cone top limited by rebar height mat. Rebars lifted with cone and lifted area 45 x 3.5'. Rebars @ 9" o.c. E.W.
2400						
2600						

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25
Total Weight of Load Beam = 2450

** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. ($\frac{1}{2}$ wt. = 1225 Lb)

*** Insert Load = Net Jack Thrust x 2.
Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355

Due Date: 16 Apr '84

Dial Gauge: M & TE Number 2049

Due Date: 18 Jun '84

Performed By:

Witnessed By:

D.C. Gilbert 4-10-84
Name Date

Andrew Pictor 4-10-84
QA Representative Date

COMANCHE PEAK SES
TENSION TESTS

EC-2W

RICHMOND 1 -INCH, TYPE INSERT

Reference: CP-EI-13.0 ~~13~~ ²²⁴

Specimen Number: 29 Load Rod Spec: A-193 Date: 5 April '84
(2nd from East, 14th fr. West)

GAUGE PRESS. (P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODE
				INIT.	AFTER 2-MIN.	
200	2450	1425	2850	0.000	0.000	
400	5300	4075	8150	.005	.005	
600	7750	6725	13450	.009	.009	
800	10600	9375	18750	.0145	.015	
1000	13250	12025	24050	.021	.022	
1200	15900	14675	29350	.033	.037	
1400	18550	17325	34650	.101	.104	
1600	21200	19975	39950	.135	.1455	
1800						
2000						
1700	22525	21300	42,600			concrete failed by the load on insert lifting the rebar mat. An area some 3.5' x 6.0' failed in this manner then insert pulled out, taking a small cone with it. Top rebar was placed in contact with insert, thus contributing to the cause of this large area concrete failure.

- * Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25
Total Weight of Load Beam = 2450
- ** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. ($\frac{1}{2} WT. = 1225$)
- *** Insert Load = Net Jack Thrust x 2.
Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355 Due Date: 16 Apr '84
Dial Gauge: M & TE Number 2949 Due Date: 29 Jun '84

Performed By: J.P. Lubett Date: 5 April '84
Witnessed By: Andrew Pietryk Date: 4-5-84
QA Representative Date

COMANCHE PEAK SES
TENSION TESTS

EC-2W
RICHMOND 1 -INCH, TYPE INSERT

Reference: CP-EI-13.0-~~F224~~

Specimen Number: 30

Load Rod Spec: A-193

Date: 5 April '84

(1st on 6-st end)

GAUGE PRESS. (P.S.I.)	* JACK THRUST (Lb.)	** NET JACK THRUST (Lb.)	*** INSERT LOAD (Lb.)	DEFLECTION (IN.)		NOTES-FAILURE MODF
				INIT.	AFTER 2-MIN.	
500				0.000	0.000	
400				.000	.000	
500				.000	 	
200	2650	1425	2850	0.000	0.000	
400	5300	4075	8150	0.000	.000	
600	7950	6725	13450	.001	.001	
800	10600	9375	18750	.005	.006	
1000	13250	12025	24050	.019	.021	
1200	15900	14675	29350	.047	.049	
1400	18550	17325	34650	0.106	.109	
1600	21200	19975	39950	.153	.174	
1800						
2000	21860	20635	41270	.250		Load peaked out.
1650						Insert failed by breaking weld between lower coil and vertical struts. Upper (threaded coil) came out w/rod, also struts came out. Top concrete spalled abt 18" diam. surface spall only. Rebar not (6" lgh) exposed. by removal of cover. Bar not deformed. Concrete

* Jack Thrust (Lb.) = Gauge Pressure (PSI) x 13.25

Total Weight of Load Beam = 2450

** Net Jack Thrust = Total Thrust Minus 1/2 Weight of Beam. ($\frac{1}{2}$ WT. = 1225)

*** Insert Load = Net Jack Thrust x 2.

Jack:.....Equipment Number RCH 606

Pressure Gauge: M & TE Number 2355 Due Date: 16 Apr '84

Dial Gauge: M & TE Number 2949 Due Date: 29 Jun '84


Performed By:
J C Gilbott 5 Apr 84
Name Date

Witnessed By:
Andrew Pietryk 4-5-84
QA Representative Date

APPENDIX 3

LOAD-DEFLECTION CURVES


LOAD-DEFLECTION CURVES 1/2-INCH TYPE EC-6W, SHEAR TEST




COMBINED SHEAR & TENSION TEST CHART

RICHMOND 1 1/2 INCH, TYPE EC-6W INSERT

SPECIMAN No. 6




1 1/2 INCH, TYPE EC-6W
SPECIMEN # 7




DEFLECTION - INCHES

COMBINED SHEAR & TENSION TEST CURVES
 1½ INCH, TYPE EC-6W
 SPECIMEN # 8



DEFLECTION - INCHES

LOAD DEFLECTION CURVES FOR 1 1/2" TYPE EC-6W
RICHMOND INSEAT




NOTES: AT EVERY GIVEN LOAD,
TENSION & SHEAR WERE AP-
PLIED SIMULTANEOUSLY.

LEGEND
 ——— INITIAL DEFLECTION
 - - - DEFLECTION @ 2 MIN.
 O SPECIMEN NO.

DEFLECTION - INCHES

LOAD-DEFLECTION CURVES FOR 1 1/2" Ø 171" EC-6W
RICHMOND INSERT




NOTES: AT EVERY GIVEN
LOAD, TENSION & SHEAR
WERE APPLIED SIMULTAN-
EOUSLY.

LEGEND

- INITIAL DEFLECTION
- - - DEFLECTION @ 2 MIN
- SPECIMEN NO.
- * THREADS STRIPPED


DEFLECTION - INCHES

LOAD-DEFLECTION CURVES 1 1/2-INCH TYPE EC-6W, TENSION TEST




LOAD-DEFLECTION CURVES


1-INCH TYPE EC-2W SHEAR TEST




COMBINED SHEAR & TENSION CHART
 RICHMOND 1 INCH, TYPE EC-2W INSERT
 SPECIMEN No. 21




COMBINED SHEAR & TENSION CHART
RICHMOND 1 INCH, TYPE EC-2W INSERT
SPECIMAN No. 22



COMBINED SHEAR & TENSION TEST CURVES
1 INCH, TYPE EC-2W
SPECIMEN #23




LOAD DEFLECTION CURVES FOR 1" ϕ TYPE EC-2W RICHMOND INSERT




DEFLECTION - INCHES

LOAD - DEFLECTION CURVE
 1-INCH TYPE EC-2W
 COMBINED SHEAR AND TENSION



LOAD-DEFLECTION CURVES

1-INCH TYPE EC-2W TENSION TEST




APPENDIX 4

PICTURES OF ACTUAL TEST APPARATUS


SHEAR TEST



TEST APPARATUS




DIAL INDICATOR ARRANGEMENT




TYPICAL SHEAR FAILURE


TENSION TEST



TEST APPARATUS




DIAL INDICATOR ARRANGEMENT




CONCRETE SHEAR ZONE FAILURE


COMBINED SHEAR AND TENSION
TEST




TEST APPARATUS




TEST APPARATUS




DIAL INDICATOR ARRANGEMENT




$1\frac{1}{2}$ -INCH SPECIMEN JUST PRIOR TO FAILURE



$1\frac{1}{2}$ -INCH SPECIMEN AT FAILURE




1 1/2 - INCH FAILED SPECIMEN



TYPICAL FAILURE

ATTACHMENT C

COMBINED SHEAR AND TENSION TEST SUMMARY



ATTACHMENT D

ORIGINAL DESIGN APPROACH AND COMPARISON
WITH MEMORANDUM AND ORDER

When a Richmond insert assembly (tube steel, washers, bolt and insert) is subjected to a torsion in the tube steel, T , the additional tension P resulting in the bolt is computed (original design) as follows assuming that the bolt is originally tensioned to a value equal to Q . Equilibrium equations (for symbols refer to Figure D-1)

$$\sum F = 0 \quad Q = P - C$$

The force Q can also be written as $f_s A_b$ where f_s is the stress in the bolt and A_b the bolt effective cross sectional area. Similarly the force C which acts at the distance of d_3 from the neutral axis can be written as $3f_c \frac{b d_3}{4}$ where $\frac{f_c}{2}$ is the average compressive stress of the concrete (for a triangular distribution), b is the width of the washer and $3/2 d_3$ is the distance from the neutral axis to the edge of the washer (d_3 is the distance between the neutral axis and the centroid of the triangle which is at $2/3$ of its base). Thus

$$P = f_s A_b + \frac{3}{4} f_c b d_3 \quad (1)$$

$$\sum M = 0 \quad T = C d_2 = C \left(\frac{b}{2} - \frac{d_3}{2} \right) = \frac{3}{4} f_c b d_3 \left(\frac{b}{2} - \frac{d_3}{2} \right) \quad (2)$$

The third equation employed is strain compatibility between the concrete and the bolt (note that this assumes that the distribution of stresses in the concrete is uniform and equal to that shown at all locations across the washer plate

$$\frac{\epsilon_c}{3/2 d_3} = \frac{\epsilon_s}{b/2 - 3/2 d_3} ; \frac{f_c / E_c}{3/2 d_3} = \frac{f_s / E_s}{b/2 - 3/2 d_3}$$

Where E_c and E_s are the concrete and steel (bolt) moduli of elasticity. This leads, using $n = E_s / E_c$ to:

$$\frac{n f_c}{3/2 d_3} = \frac{f_s}{b/2 - 3/2 d_3} \quad (3)$$

If one then replaces $\frac{3}{2} d_3$ (the distance from the neutral axis to the edge of the washer) with X , and substitutes (1) and (2) into (3), the following equation is obtained.

$$\frac{Q b X^3}{3} - \left(\frac{Q b^2}{2} + b T \right) X^2 - 2 n T A_b X + n T b A_b = 0 \quad (4)$$

Equation (4) is a cubic equation in X , which when solved yields the value of X and hence the location of the neutral axis. Once that value is known, the solution for the additional tension in the bolt can be solved from equation (1) recalling that $X = \frac{3}{2} d_3$.

For the particular instance in which the bolt is subject to no preset tension, but the tube steel is subject to torsion, i.e. $Q=0$, equation (4) reduces to

$$X^2 + \frac{2n}{b} A_b X - n A_b = 0 \quad (5)$$

which can be solved for X, and yields

$$X = A_b \frac{n}{b} \left(-1 \pm \sqrt{1 + \frac{b^2}{nA_b}} \right) \quad (6)$$

Only one of the roots of equation (6) is appropriate. The solutions for X were tabulated by NPSI in their design methods and the tables were employed to compute the resulting bolt tension. For instance for $E_s/E_c = 8$ and a 4 x 4 tube steel ($b=4$) with a bolt having an effective area of 0.606 in (1-inch bolt) one would obtain

$$X = 1.301 \text{ (or } -3.726) \text{ inches}$$

This means that the neutral axis is shifted from the bolt centerline 0.699 inches in the direction of the applied torsion.

Another interesting fact about equation (6) is that the location of the neutral axis is independent of the applied torsion. If there had been continuity between the bolt, the washer and the concrete (as for instance in an embedded plate with welding between the washer and the plate) the condition that the neutral axis is purely dependent on the moduli of elasticity of steel and concrete would probably be satisfied. In retrospect, after the Board's Order, it was this result that led us to suspect the validity of the strain compatibility equation and the development of the finite element model solution.


The difference brought about by the finite element analysis is best explained by the following: in the original design calculation, the computation of the tension in the bolt by

equation (1) is entirely equivalent to taking a lever arm from the center of the bolt to the centroid of the triangular compressive stress distribution in the concrete. This can be verified by noting that with the assumptions made in equation (1), (2) and (3), that centroid occurs at a distance $(\frac{b}{2} - \frac{x}{3}) = d_2$

From equation (2) and equation (1) we can write $\frac{3}{4} f_c b d_3 = f_s A_b + P$
and $T = (f_s A_b - P)(\frac{b}{2} - \frac{d_3}{2})$ But $x = \frac{3}{2} d_3$, thus $T = (f_s A_b + P) d_2$

Hence for the case in which $Q = f_s A_b = 0$ we have $T = P d_2$

This is what Applicant had used. What the finite element analysis indicated is that the correct formula should be $T = P d_4$, where d_4 is the distance from the bolt to the point of tangency between the tube steel and the washer.



Neutral Axis












Figure 1 (Original Design Assumptions)

Figure 2 (from Memo of Order at 77)

ATTACHMENT E-2
RICHMOND INSERT - TUBE STEEL ASSEMBLY

FINITE ELEMENT ANALYSIS

- A. Analysis of Richmond Insert Assembly
Ts 4 x 4 x 3/8 Tube with 1 1/2" Dia. Bolt - Radius = 2t
Eccentricity = 0"

INTRODUCTION

Ts 4 x 4 x 3/8 with 1 1/2" Dia. Bolt is used for the analysis because, except for a few 1/2" thick tubes Ts 4 x 4 x 3/8 represents the worst condition with respect to torsion.

A Richmond insert assembly was modeled with a 1 1/2" dia. Bolt at the center line of assembly as shown in Figure E-2. The purpose of this model is to study the behavior of the assembly and also concrete reactions for various loading conditions.

The analysis is performed using 'STARDYNE' computer program.

FINITE ELEMENT MODEL

A finite element model consisting of a Ts 4 x 4 x 3/8 tube with two inserts is used. The spacing between the two inserts is taken to be 20" and the tube is modeled with an outer radius of $2t$ ($= 3/4"$).

Advantage is taken of the symmetric nature of the geometry and loading. Therefore, only half of the complete geometry is used. However, proper boundary conditions are enforced in the plane of the symmetry. The tube and the two 1" washer plates are modeled using either triangular or quadrilateral plate elements. The model is shown in Figure E-1, (a) through (f). The concrete reactions are obtained from the 'SPRING' subprogram of 'STARDYNE' which uses non-linear springs. The spring constant for concrete is calculated based on the theory of elastic half space. These ground springs are tied to the '3000' series nodes and are shown on E-1 (d). This drawing also shows the rigid beams that connect from the center line of the top washer plate to the surface of the tube steel given by '1000' series beams and from the center line of the top washer to the concrete surface by '2000' series beams. Rigid beams numbering B-1 to B-99 extend from the center line of top of tube and are shown on E-1 (c). The top, bottom and sides of the tube are modeled with triangular or quadrilateral plate elements and are shown on E-1 (a) and E-1 (b). The bolt is modeled by using beam elements. But in practice the bolt will behave

differently because of its very small span to depth ratio. This is discussed in Attachment E-3. The interface between the top of tube and top washer plate is modeled in such a way that only compression is transferred. If any rigid beam in this interface is found to carry tension, they are softened and removed so as not to transfer any tensile load. This is an iterative process and is used to obtain the final solution. The three loads (1) Pure torsion (2) Shear at center line of tube along 'Z' axis and (3) Shear ('Z' axis) and torsional moment are applied at the center of span (=20") shown as center line section on E-1 (c).

RESULTS AND DISCUSSION

The results of the three cases namely

- (1) Pure torsion
- (2) Shear at center line of tube, and
- (3) Shear and torsional moment at center of tube

are detailed in Figure E-2 pages (a) through (e).

PURE TORSION (Load 1)

A torsional moment of 4000 in. lbs. is applied at center of 20" span through nodes 544, 555, 560 & 564 shown in center line Section on E-1 (c).

Two conditions are analyzed:

- (a) There is a clearance between the bolt and tube
- (b) There is no clearance between the bolt and tube (i.e. bolt bearing against the tube).

The results are compared with case (c) which is the value obtained by using three design equations of Attachment D and are shown on Figure E-2 (a).

ANALYSIS OF THREE CASES

LOAD 1

Case (A) (Bolt with clearance)

The applied torsional moment is resisted by a couple produced by compression in the concrete and tension in the bolt. The arm of the resisting couple being the distance between the center line of the bolt and the tangent point of the round corner. With a radius of $2 \times \text{thickness}$, $\text{arm} = 2 - 2 \times .375 = 1.25"$.

The transfer of forces between the tube and top washer plate takes place along a line corresponding to the tangent point

of the interface. These forces are plotted in Section D-D, on E-2 (c). Except for the extreme two spikes the contact forces are relatively uniform.

The concrete reaction forces are shown in Section (1)-(1), (5)-(5) and (9)-(9) on E-2 (b). Maximum forces being at the edge and reducing toward the center.

LOAD 1

Case (B) (Bolt bearing against the tube - no clearance)

The applied torsional moment is resisted by the combination of a bolt tension/concrete compression couple and a moment in the bolt. The arm for the couple is same as in Case (A). The transfer of forces between the tube and top washer plate, top washer plate and concrete is similar to Case (A). This condition is an extreme case and provides an upper bound value for the moment in the bolt. Normally the bolt would not contact the tube steel because the lateral displacement of the tube steel at node 261 shown on E-1 (b) is only 0.0035" whereas there is a nominal all around gap of 1/16".

LOAD 1

Case (C)

The axial value shown is obtained by the use of three design equations. The value obtained from the finite element analysis (Case A) is 18.3% higher than the value for Case C.

Shear at Center of Tube (Load 2)

A shear load of 1000# is applied along 'Z' global axis at nodes 546 and 561 shown in center line section on E-1 (c). Because of the applied shearing force, the clearance between the bolt and the tube is assumed to have closed.

Applied shear causes a turning moment which is resisted by the combination of the couple produced by compression of concrete and pull in bolt and by the moment in the bolt itself. These results are shown in Case (a) of E-2 (d).

A comparison with the current design method of analysis is shown in Case (b). In the current design method, an equivalent pull based on the three design equations and calculated from torsional moment of 1500 lb. in. caused by the lateral force would be used. The 1500 in-lb torsional moment is caused by the shear force of 500 lb acting 3 in above the concrete on each bolt.

Transfer of forces between the tube and top washer plate, top washer plate and concrete is similar in nature to Load (1) as shown in E-2 (b) & E-2 (c).

Shear and Torsional Moment at Center of Tube (Load 3)

A shear force of 1000# is applied at center of 20 in. span through node 566 shown in center line section on E-1 (c). The node 566 is 2" off the face of Ts 4 x 4 x 3/8 tube. This case is basically a combination of Load 1 & 2. The torsional moment caused by the lateral load is resisted by the combination of the couple and the moment in the bolt similar to Load 2. Transfer of forces between the tube and the top washer plate, the top washer plate and the concrete is similar in nature to Load 1. These results are shown in E-2 (e) Case (A).

A comparison with the current design method of analysis are shown on Case (B). In the current design method an equivalent pull based on three design equations and calculated from a torsional moment of 3500 lb. in is used.

B. Analysis of Richmond Insert Assembly
Ts 4 x 4 x 3/8 Tube with 1 1/2" dia. Bolt Radius = 2t
Eccentricity = 3/4"

The finite element model and its method of analysis is the same as in part (A) except that model is modified to move the bolt hole to an eccentricity of 3/4".


Load points and the three load cases are same as in Part (A). 3/4" eccentricity is used to understand the behavior of the assembly and to determine the limiting value of eccentricity.

Results and Discussions

For all three cases of loading, all the applied loads are resisted by the bolt itself. The resisting couple provided by the compression in concrete and tension in bolt, which is evident in non-eccentric condition has disappeared due to the very small lever arm. The applied torsional moment is transferred by shear couple produced by lateral forces due to rotation of tube against the bolt.

Ts 4 x 4 x 3/8 with 1 1/2" Dia. Bolt (e = 0")


Figure E-2



Ts 4 x 4 x 3/8 Tube with 1 1/2" Dia. Bolt

e = 0"

E - 2 (a)

LOAD 1 (PURE TORSION)	BOLT REACTION (1 1/2" φ)			
	CASE	AXIAL (LB)	MOMENT (LB IN)	SHEAR (LB)
	(a)	1600	0	0
	(b)	986	767	0
	(c)	1353	0	0


* Ratio of (a) to (c) is 1.18. The 18% increase is less than what would have been obtained by ratioing the lever arm from bolt centerline to the tangent line to the old lever arm used (neutral axis to center of triangular distribution) which is 25%.

Ts 4 x 4 x 3/8 TUBE WITH 1 1/2" dia. BOLT
e = 0"

E-2 (b)

CONCRETE REACTION (Case A) Load I

These values are obtained from the finite element analysis for ground spring nodes shown on E-1 (d). Reactions for two boundary sections (1)-(1) and (9)-(9) and the center line section (5)-(5) are plotted to show the trend of compressive forces. The values shown are not to scale. These sections (1)-(1), (5)-(5) and (9)-(9) are shown in E-1 (a) & E-1 (e).



NOT TO SCALE


Only Two End Nodes Are Shown For All Sections

Due to three dimensional nature of the problem, the concrete reaction forces goes around the bolt.

Ts 4 x 4 x 3/8 With 1 1/2" dia. Bolt
 $e = 0''$
 E-2 (C)

Force Transfer Between Top of Tube and Top Washer Plate
 Case (A) Load I

These values are obtained from the beams connecting the tube to top washer plate interface. Only compressive forces are transferred through these beams. These beams are shown in E-1 (d) and the nodes are shown in E-1 (c). The values shown are not to scale. Beams 1160 to 1340 exists in Section D-D between beam 1130 & 1370.




The spikes shown at the ends are from the fact that concrete reactions are not uniform and are higher near the end section as shown in (1)-(1), (5)-(5) and (9)-(9) shown in E-2 (b). The finite element analysis shows that only the beams (1130 to 1370) along the tangent line carry the compressive forces.

Ts 4 x 4 x 3/8 Tube with 1 1/2" Dia. Bolt

e = 0"

E - 2 (d)


LOAD 2 (SHEAR AT CENTER OF TUBE)	BOLT REACTION (1 1/2" ϕ)			
		AXIAL (LB)	MOMENT* (LB IN)	SHEAR (LB)
	Case (a)	507	866	500
	Case (b)	1015	-	500

* Moment in bolt is set up by a shear couple with approximately 85 percent of the shear going to the upper tube steel face and 15 percent going to the lower tube steel face.

Ts 4 x 4 x 3/8 with 1 1/2" Dia. Bolt

e = 0"

E - 2 (e)

LOAD 3: (SHEAR & TORSIONAL MOMENT)	BOLT REACTION (1 1/2" Ø)			
	CASE	AXIAL (LB.)	MOMENT (LB-IN)	SHEAR (LB)
	Ⓐ	1500	1620	500
	Ⓑ	2368	-	500

ATTACHMENT E-3
FINITE ELEMENT ANALYSIS OF BOLT (1½" DIA.) FOR
TS 4 x 4 x 3/8 TUBE USING SOLID ELEMENTS

INTRODUCTION

A Richmond insert assembly has been analyzed using a finite element model whose analysis and results are provided in Attachment E. The purpose of the model was to determine the behavior of the assembly for various loading conditions. The 1½" diameter bolt is modeled as a beam element. The finite element result for all three load cases in Attachment E, (1) Pure torsion but bolt leaning against the tube, (2) Shear at center of tube and (3) Shear and torsional moment at center of tube, show some moment being resisted by the bolt.

Because of small span to depth ratio the behavior of the bolt will differ from the condition where simple theory of flexure for a cantilever beam can be readily applied to determine bending stresses. In order to determine the magnitude of stresses caused by lateral loading of the bolt, a finite element analysis of the 1½" dia. bolt is performed using solid elements via STARDYNE program.

FINITE ELEMENT MODEL

The bolt length between the center of (tube) bottom flange and face of concrete is divided into seven slabs of varying thickness and shown in E-3 (a) through (i). The last slab near the concrete face is ¼" thick and shown on E-3 (h) & (i).

The base of the bolt is connected to the insert through springs with same spring constant used in the Attachment 'E' model ie TS 4 x 4 x 3/8 with 1½" dia. bolt and zero eccentricity. A typical connection at base is shown on E-3 (i).

A 1000# lateral load is applied along global 'Z' (X_3) direction through nodes 24, 25 & 26 shown in E-3 b) to represent load from bottom flange.

RESULTS & DISCUSSIONS

$$\begin{aligned}\text{Applied Moment} &= 1000 \times 4.8125 \\ &= 4812.5 \text{ lb. in.}\end{aligned}$$

Using simple bending theory

$$\text{Bending stress} = \frac{\text{Moment}}{\text{Section Modulus}}$$

For 1½" Ø Bolt based on gross area

$$\text{Area} = 1.7671 \text{ in.}^2$$

$$\text{Diameter} = 1.5 \text{ inch}$$

$$\begin{aligned} \text{Section Modulus} &= 0.098175 \times (1.5)^3 \\ &= 0.331 \text{ in.}^3 \end{aligned}$$

$$\text{Bending stress} = \frac{4812.5}{0.331} = 14539 \text{ p.s.i.}$$

Based on finite element results the average stress across the furthest node (311) shown on E-3 (i) is about 10,836 p.s.i. This stress value is obtained by averaging the results of the elements (287), (297), (307) & (317).


Comparing the results it can be seen that stress obtained from finite element analysis is much less than that obtained from simple flexure theory. Hence it can be concluded that simple flexural behavior is not the case in this bolt and MC alone, without modification should not be used to

calculate bending stress. Actually the 14524 p.s.i. stress calculated would be higher if it was calculated on the basis of finite element model area which is 1.687 in.² and not 1.7671 in.² as used for comparison.

FINITE ELEMENT ANALYSIS FOR 1½" DIA. BOLT


For Ts 4 x 4 x 3/8 Tube Using Solid Elements

E - 3 (a)



FINITE ELEMENT ANALYSIS OF 1½" DIA. BOLT


E - 3 (b)



PLANE $X_2 = 0.0$

FINITE ELEMENT ANALYSIS OF 1½" DIA. BOLT


E - 3 (c)



PLANE 'X₂' = 0.9375"

FINITE ELEMENT ANALYSIS OF 1/2" DIA. BOLT


E - 3 (d)



PLANE $x_2 = 1.9375$ "

FINITE ELEMENT ANALYSIS OF 1/2" DIA. BOLT


E - 3 (e)



PLANE $X_2 = 2.9375$ "

FINITE ELEMENT ANALYSIS OF 1/2" DIA. BOLT


E - 3 (f)



PLANE 'X₂' = 3.625"

FINITE ELEMENT ANALYSIS OF 1/2" DIA. BOLT


E - 3 (g)



PLANE 'X₂' = 4.3125"

FINITE ELEMENT ANALYSIS OF 1/2" DIA. BOLT


E - e (h)



PLANE 'X₂' = 4.5625"

FINITE ELEMENT ANALYSIS OF 1 1/2" DIA. BOLT

E - 3 (i)



PLANE 'X₂' = 4.8125"

DOCUMENT/ PAGE PULLED

ANO. 8406060461

NO. OF PAGES 6

REASON

PAGE ILLEGIBLE

HARD COPY FILED AT: FOR CF
OTHER _____

BETTER COPY REQUESTED ON _____

PAGE TOO LARGE TO FILM

HARD COPY FILED AT: FOR CF
OTHER _____

FILMED ON APERTURE CARD NO 8406060461-01
thru-06

ATTACHMENT F

RICHMOND & TUBE STEEL
LOADING IN SHEAR
& TORSION

MAY 1984

1. Test Description

The following tests were performed on four Richmond Inserts/Tube Steel connections:

- o Shear load applied to 6"x6"x1/2" Tube Steel with bolt hole on TS centerline - Test No. 1
- o Shear load applied to 4"x4"x3/8" Tube Steel with bolt hole offset 3/4" from the TS centerline - Test No. 2
- o Torsional load applied to 4"x4"x3/8" Tube Steel with bolt hole on TS centerline - Test No. 3
- o Torsional load applied to 4"x4"x3/8" Tube Steel with bolt hole offset 3/4" from TS centerline - Test No. 4

Figure 1 shows photographs of the test set up and the final configurations of the assemblies after the test. Attachments F-1, F-2, F-3, and F-4 provide results for the four tests.

2. Summary of Results

Table F-1 presents a comparison of the test results with the following 4 Insert Design Methods. Columns A through D refer to each of the methods listed below:

Method A. This method assumes the torsion is resisted by a couple whose moment arm is $2/3$ the half width of the washer plate.

Method B. This method assumes the torsion is resisted by a couple whose moment arm is that predicted by strain compatibility as described earlier in Attachment D.

Method C. This method assumes the torsion is resisted by a couple whose moment arm is the distance from the bolt centerline to the point of tangency between the tube steel and the washer plate.

Method D. This method assumes the torsion is resisted partially as described in Method C above, and partially by bending of the bolt. This is the method utilized in generating the interaction ratios shown in Table F of this Affidavit.

Table F-1 also contains the Design Loads based on the insert and bolt capacities for the four methods and a factor of safety for these Design Loads based on the test results. The table also provides the tube steel deflection for the various loads.

3. Conclusions From Test Results

The test results indicated that little or no deformation of the tube steel occurs at loads corresponding to the design loads. The tests also indicate that the initial design methods have a factor of safety in excess of 3. They further indicate that the point of tangency methods has a factor of safety in excess of 4 when bolt bending is neglected and a factor of safety in excess of 12 when bolt bending stress is considered by calculating it using MC/I where M is the bending moment, C the bolt diameter and I the bolt moment of inertia. The test results indicate that the failure mechanism is by shear type deformation for the 6x6 TS

shear test (Case 1) and by bolt bending for the 4x4 TS with 3/4" eccentricity (Case 2 and 4) and Case 3 (4x4 TS with 0 eccentricity loaded in torsion).

Cases 2, 3 and 4 were designed to be analogous to the finite element analysis discussed previously in Attachment E so that they could be used to validate the following conclusions reached from the analysis.

The finite element analysis predicts that for the 4x4 TS with high eccentricity loaded either in shear or torsion, the bolt bending governs the design. The test verified that this is the failure mechanism, however, the failure load predicted by the test is considerably higher than that predicted by the finite element analysis. The analysis predicts that failure of an elastic-perfectly plastic round section loaded in bending is 2 1/4 times the load which produces a bending stress of .75 Fy (Fy is the yield strength). This load is defined as the Design Load. The test results indicate that the actual load for the bolt is 12.5 to 12.8, or about 5 times higher than the Design Load. This discrepancy is due in part to the conservatism involved in using MC/I to calculate the bending stress in the bolt. This conservatism is determined by comparison with the results of the bolt finite element analysis. It is due in part to the assumption of elastic perfectly plastic behavior of the bolt material, which in reality strain hardens, and it is also due in part to the assumption that all the torsional moment is carried by the bolt in bending. Although this is what the finite element

analysis predicts, some of the torsional moment is taken by a bolt tension/concrete compression couple, particularly at the higher loadings where the deformation of the tube steel provides a compressive area that establishes the couple. Since the finite element analysis is purely elastic, once some local yielding occurs, the analysis would not predict the redistribution of the torsional moment to the tension/compression couple that would result in higher load capacities. The discrepancy is also due in part to the fact that the finite element analysis, in predicting the bolt moment due to shear, does not account for redistribution of the shear between the upper and lower tube steel as deformation occurs. In addition, the discrepancy is due in part to the fact that friction is not included in the analysis. In summation, all of the above factors show why the test results verify that the calculation of the design capacity using a method based on the finite element analysis is very conservative.

The other two test cases also demonstrate that the calculation of the design load based on finite element analysis is also very conservative regardless of tube steel size and eccentricity for the same reasons as stated above.

When the test results are compared to either of the initial design methods (A or B), the test shows that the design load capacities of these methods have reasonable factors of safety and, therefore, there is no safety concern with the initial design methods.

In addition, comparison of the test results with method C which neglects bending of the bolt, shows that there is no concern if bending of the bolt is ignored.

In summary, the test results demonstrate that the original design methods used for the design of the connections were adequate and that the design method based on the finite element analysis is very conservative.

TABLE F-1

CASE	TEST ULTIMATE CAPACITY	METHOD A 2/3x1/2 WIDTH	METHOD B STRAIN COMPATIBILITY	METHOD C POINT OF TANGENCY W/O BOLT BENDING	METHOD D POINT OF TANGENCY W/ BOLT BENDING	
1. 0 Offset Shear	46.37	11.00	12.04	11.00	2.45	Max. Design Capacity
		4.2	3.8	4.2	18.9	FS = Test Ultimate Capacity ÷ Design Capacity
		.09	.10	.09	.01	Tube steel deflection at design capacity based on test curve.
2. 3/4 Offset Shear	23.85	7.14	NA*	4.53	1.91	Max. Design Capacity
		3.3	--	5.2	12.5	FS = Test Ultimate Capacity ÷ Design Capacity
		.07	--	.02	.01	Tube Steel deflection at design capacity based on test curve
3. 0 Offset Torsion	25.17	5.124	5.62	4.828	1.38	Max. Design Capacity
		4.9	4.4	5.2	18.2	FS = Test Ultimate Capacity ÷ Design Capacity
		.07	.07	.07	< .01	Tube steel deflection at design capacity based on test curve
4. 3/4 Offset Torsion	10.6	3.28	NA*	1.99	.824	Max. Design Capacity
		3.23	--	5.32	12.8	FS = Test Ultimate Capacity ÷ Design Capacity
		.02	--	.07	< .01	Tube steel deflection at design capacity based on test curve

Loads are in kips, Deflections are in inches

*The strain compatibility method was used only for eccentricities $\leq 3/8$ "



TEST ASSEMBLIES PRIOR
TO TESTING

5/11/84



TORSION TEST ON 4x4 TS
WITH HOLE ON TS ⊕

TEST #3



SHEAR TEST ON 6x6 TS
WITH HOLE ON TS ⊕


TEST #1

Figure 1




TEST ASSEMBLIES
AFTER TESTING

5/11/84



SHEAR TEST ON 4X4 TS
WITH HOLE $\frac{3}{4}$ " OFF-SET

TEST #2




TORSION TEST ON 4X4 TS
WITH HOLE OFF-SET $\frac{3}{4}$ "

TEST #4



CLIENT TUSI 103 NO. _____
 SUBJECT RICHMOND INSERT SHEAR TEST
 BASED ON _____ DRAWING NO. _____
 COMPUTER JR CHK'D. BY _____ APP'D. BY _____ DATE MAY 1



- ① TS 6"X6"X1/2" - 6" LONG
- ② A-36 PLATE 1"X6" - 6" LONG (2 REQ'D)
- ③ A-36 PLATE 1"X5" - 5" LONG
- ④ A-36 PLATE 3/4"X2" - 4" LONG
- ⑤ A-36 THREADED ROD 1 1/2" φ - 16" LONG




CLIENT TUS I JOB NO. _____

SUBJECT SHEAR TEST ON 6X6 TS WITH ϕ HOLE ON TS ϕ

BASED ON _____ DRAWING NO. _____

COMPUTER JR CHK'D. BY _____ APP'D. BY _____ DATE MAY 11 19__





BROWN & ROOT, INC.
ENGINEERING DIVISION


SHEET NO. 1

CLIENT TUSI

JOB NO. _____

SUBJECT RICHMOND INSERT SHEAR TEST

BASED ON _____ DRAWING NO. _____

COMPUTER IR CHK'D. BY _____ APP'D. BY _____ DATE MAY 1

① TS 4"X4" X 3/8" - 6" LONG

② A-36 PLATE 1"X4" - 4" LONG (2 REQ'D)

③ A-36 PLATE 1"X3" - 5" LONG

④ A-36 PLATE 3/4" X 1/4" - 4" LONG

⑤ A-36 THREADED ROD 1 1/2" Φ - 14" LONG




CLIENT TUSI JOB NO. _____

SUBJECT RICHMOND INSERT TORSION TEST


BASED ON _____ DRAWING NO. _____

COMPUTER IR CHK'D. BY _____ APP'D. BY _____ DATE MAY 1





CLIENT TUS I JOB NO. _____
SUBJECT SHEAR TEST ON 4X4 TS WITH 3/4" OFF-SET OF HOLE &
BASED ON _____ DRAWING NO. _____
COMPUTER JR CHK'D. BY _____ APP'D. BY _____ DATE MAY 11 19__






CLIENT TUSI

JOB NO. _____

SUBJECT RICHMOND INSERT TORSION TEST

BASED ON _____ DRAWING NO. _____

COMPUTER JR CHK'D. BY _____ APP'D. BY _____ DATE MAY 1



① TS 4" X 4" X 3/8" - 4 1/2" LONG

② A-36 PLATE 1" X 4" - 4" LONG (2 REQ'D)

③ A-36 PLATE 1" X 5" - 8" LONG (2 REQ'D)

④ A-36 PLATE 1" X 2 1/2" - 7 1/2" LONG

⑤ A-36 THREADED ROD 1/2" Ø - 4" LONG



BROWN & ROOT, INC.
ENGINEERING DIVISION


CLIENT TUS I

JOB NO. _____

SUBJECT TORSION TEST ON 4X4TS WITH HOLE & ON TS &

BASED ON _____ DRAWING NO. _____

COMPUTER JR CHK'D. BY _____ APP'D. BY _____ DATE MAY 11 19____






CLIENT TUSI JOB NO. _____

SUBJECT RICHMOND INSERT TORSION TEST

BASED ON _____ DRAWING NO. _____

COMPUTER JR CHK'D. BY _____ APP'D BY _____ DATE MAY 1



- ① TS 4" X 4" X 3/8" - 4 1/2" LONG
- ② A-36 PLATE 1" X 4" - 4" LONG (2 REQ'D)
- ③ A-36 PLATE 1" X 5" - 8" LONG (2 REQ'D)
- ④ A-36 PLATE 1" X 2 1/2" - 7 1/2" LONG
- ⑤ A-36 THREADED ROD 1 1/2" Ø - 14" LONG

TEST #4

ATTACHMENT F-4



BROWN & ROOT, INC.
ENGINEERING DIVISION

P. 2/4

SHEET NO. 2


CLIENT TUSI

JOB NO. _____

SUBJECT RICHMOND INSERT TORSION TEST


BASED ON _____ DRAWING NO. _____

COMPUTER IR CHK'D. BY _____ APP'D. BY _____ DATE MAY 1





CLIENT TUSI JOB NO. _____
SUBJECT TORSION TEST ON 4X4 TS WITH 3/4" OFF-SET OF HOLE
BASED ON _____ DRAWING NO. _____
COMPUTER JR CHK'D. BY _____ APP'D. BY _____ DATE MAY 11 19__



ATTACHMENT G

RAY PETER DEUBLER
PROJECT MANAGER - NPS INDUSTRIES

EDUCATION

B.S., Mechanical Engineering, Cornell University, 1969.
M.E., Mechanical Engineering, Cornell University, 1970.

EXPERIENCE

Mr. Deubler has 14 years of experience in the area of Mechanical Engineering. Mr. Deubler is currently Project Manager for NSPI for the Comanche Peak Project. As such he is responsible for all NPSI Design and Fabrication activities for this project.

Previously Mr. Deubler was Director of Engineering at NPSI and as such he supervised the engineering, development and qualification of standard pipe support components, field service activities, and the design and fabrication of supports including their conformance to ASME Section III.

Earlier at NPSI, Mr. Deubler supervised the design and fabrication of piping supports for various projects in both the nuclear and fossil industries. His responsibilities included the overall supervision and management of the design, fabrication, and detailed engineering work on all phases of the design, fabrication and quality assurance aspects of component supports.

Mr. Deubler was an Instrumentation Engineer at Gibbs and Hill. Principal work was performed in control valves, instrumentation, control systems, and components for power plants. Other work included the selection, specification, and procurement of components as well as the designing of instrumentation and control loops for fluid systems.

At the American Electric Power Service Corporation, Mr. Deubler was Mechanical Engineer in charge of specifying, selecting, and purchasing piping equipment for major power plant projects including valves, piping, supports, and miscellaneous piping systems components. He also designed plant fluid systems.

Other experience includes design work in the areas of plumbing and HVAC for Bucharth and Horn.

PROFESSIONAL

Professional Engineer, New York.

Member of ASME and AWS.

Member of working group on component supports of Subcommittee III of the ASME Boiler and Pressure Vessel Committee.

Member of Committee 8C3 - Pipe Hangers and Supports of Manufacturers Standardization Society of the Valve and Fitting Industry (MSS).

TABLE 1
PART A

SUPPORT MARK NO.	TUBE STEEL SIZE	ECCENTRICITY	BOLT SIZE	INSERT INTERACTION	BOLT INTERACTION	
AF-1-006-010-S33R	8 x 4 x 3/8"	1 3/4"	1"	.51	2.45	FE
CC-1-008-013-S33K	8 x 4 x 1/2"	7/16"	1"	1.53	4.32	FE
CC-1-197-005-C52R	4 x 4 x 3/8"	0	1 1/2"	.21	.924	
CC-1-197-014-C42R	4 x 4 x 3/8"	0	1 1/2"	.196	.3786	
CC-1-197-019-C52R	4 x 4 x 3/8"	1/8	1 1/2"	.32	.53	
CC-1-197-020-C52R	4 x 4 x 3/8"	0	1 1/2"	.143	.309	
CC-1-197-034-C52R	4 x 4 x 3/8"	1/16	1 1/2"	.19	.89	
CC-1-204-003-C52R	4 x 4 x 3/8"	0	1 1/2"	.239	.673	
CC-1-205-016-C53R	4 x 4 x 3/8"	0	1 1/2"	.059	.779	
CC-1-206-001-C53R	4 x 4 x 3/8"	0	1 1/2"	.259	.779	
CC-1-207-014-C53R	4 x 4 x 3/8"	0	1 1/2"	.029	.171	
CC-1-207-021-C53R	4 x 4 x 3/8"	0	1 1/2"	.102	.031	
CC-1-212-001-C53R	4 x 4 x 3/8"	5/8	1 1/2"	.12	.70	
CC-1-215-032-C53R	4 x 4 x 3/8"	0	1 1/2"	.07	.30	
CC-1-215-033-C53R	4 x 4 x 3/8"	0	1 1/2"	.03	.17	
CC-1-217-003-C53K	4 x 4 x 3/8"	0	1 1/2"	.21	.43	
CC-1-217-012-C53S	4 x 4 x 3/8"	3/8"	1 1/2"	.10	.995	
CC-1-218-009-C53K	4 x 4 x 3/8"	0	1 1/2"	.15	.33	
CC-1-218-010-C53K	4 x 4 x 3/8"	0	1 1/2"	.011	.07	
CC-1-218-012-C53K	4 x 4 x 3/8"	1/8"	1 1/2"	.75	.14	
CC-1-218-013-C53K	4 x 4 x 3/8"	0	1 1/2"	.223	1.74	
CC-1-218-014-C53K	4 x 4 x 3/8"	0	1 1/2"	.04	.38	
CC-1-226-004-C53R	4 x 4 x 3/8"	0	1 1/2"	.31	.61	
CC-1-226-005-C53R	4 x 4 x 3/8"	0	1 1/2"	.13	.42	
CC-1-227-003-C53R	4 x 4 x 3/8"	0	1 1/2"	.26	.56	
CC-1-231-002-C53R	4 x 4 x 3/8"	0	1 1/2"	.015	.06	
CC-1-233-001-C53R	4 x 4 x 3/8"	3/4"	1 1/2"	.084	.7	
CC-1-233-004-C53R	4 x 4 x 3/8"	0	1 1/2"	.073	.27	
CC-1-234-016-C53R	4 x 4 x 3/8"	0	1 1/2"	.18	.44	
CC-1-237-001-C53R	CC-1-235-001-C53R	0	1 1/2"	.06	.41	
CC-1-237-004-C53R	CC-1-233-001-C53R	-	-	-	-	
CC-1-239-005-C53R	4 x 4 x 3/8"	1/4	1 1/2"	.03	.30	
CC-1-239-008-C53R	CC-1-233-001-C53R	-	-	-	-	

FE - Requires further evaluation.

TABLE 1
PART A

SUPPORT MARK NO.	TUBE STEEL SIZE	ECCENTRICITY	BOLT SIZE	INSERT INTERACTION	BOLT INTERACTION
CC-1-242-002-C53R	4 x 4 x 3/8"	3/8"	1 1/2"	.03	.32
CC-1-242-003-C53R	4 x 4 x 3/8"	1/2"	1 1/2"	.02	.32
CC-1-245-010-C53R	4 x 4 x 3/8"	0	1 1/2"	.03	.38
CC-1-245-018-C53R	4 x 4 x 3/8"	0	1 1/2"	.009	.16
CC-1-249-003-C53R	4 x 4 x 3/8"	0	1 1/2"	.26	.35
CC-1-249-700-C53R	3 x 6 x 5/16"	0	1 1/2"	.12	.48
CC-1-255-007-C53R	6 x 6 x 3/8"	3/8	1 1/2"	.37	1.17
CC-1-271-008-C53R	4 x 4 x 3/8"	0	1 1/2"	.26	.81
CC-1-272-008-C53K	4 x 4 x 3/8"	0	1 1/2"	.024	.176
CC-2-040-401-A33K	4 x 4 x 3/8"	1/16	1"	.27	.52
CC-2-040-405-E33R	6 x 4 x 1/2"	0	1"	.54	1.72
CC-2-048-402-A33R	6 x 6 x 1/2"	0	1"	.52	.70
CC-2-048-403-A33R	6 x 6 x 1/2"	0	1"	.08	.52
CC-2-048-408-A33K	6 x 6 x 3/8"	0	1"	.29	1.17
CC-2-105-406-E23P	6 x 6 x 3/8"	0	1"	.06	.43
CC-2-107-403-E23S	4 x 6 x 3/8"	0	1"	.23	.52
CS-1-001-003-C42K	4 x 4 x 3/8"	0	1 1/2"	.008	.058
CS-1-001-011-C42R	4 x 4 x 3/8"	0	1 1/2"	.16	.44
CS-1-001-012-C42R	4 x 4 x 3/8"	0	1 1/2"	.36	.61
CS-1-001-024-C42K	4 x 4 x 3/8"	0	1 1/2"	.15	.45
CS-1-001-027-C42K	4 x 4 x 3/8"	0	1 1/2"	.15	.386
CS-1-001-035-C42R	4 x 4 x 3/8"	0	1 1/2"	.24	.67
CS-1-012-003-C42R	4 x 4 x 3/8"	0	1 1/2"	.11	.39
CS-1-077-004-C42R	4 x 4 x 3/8"	0	1 1/2"	.0315	.1498
CS-1-077-005-C42R	4 x 4 x 3/8"	5/16"	1 1/2"	.03	.30
CS-1-077-006-C42R	4 x 4 x 1/4"	0	1 1/2"	.05	.31
CS-1-078-003-C42R	4 x 4 x 3/8"	0	1 1/2"	.24	.92
CS-1-078-018-C42K	6 x 6 x 3/8"	0	1 1/2"	.048	.43
CS-1-079-006-C42R	6 x 4 x 3/8"	0	1 1/2"	.062	.6
CS-1-079-007-C42R	4 x 4 x 3/8"	0	1 1/2"	.48	.65
CS-1-079-020-C42R	6 x 6 x 3/8"	0	1 1/2"	.13	.51
CS-1-079-037-C42K	4 x 4 x 3/8"	1/4	1 1/2"	.09	.64
CS-2-033-408-A42R	4 x 4 x 3/8"	0	1 1/2"	.073	.037
CS-2-085-402-A42S	4 x 4 x 3/8"	5/8	1"	.06	.31
CT-1-018-005-S22R	4 x 4 x 3/8"	0	1"	.17	.8
CT-1-038-003-C52R	4 x 4 x 3/8"	0	1 1/2"	.037	.15
CT-1-038-402-C52R	4 x 4 x 3/8"	0	1 1/2"	.037	.15

FE - Requires further evaluation.

TABLE 1
PART A

SUPPORT MARK NO.	TUBE STEEL SIZE	ECCENTRICITY	BOLT SIZE	INSERT INTERACTION	BOLT INTERACTION	
CT-1-038-415-C62R	6 x 6 x 3/8"	13/16"	1"	.30	.15	
CT-1-038-430-C62K	4 x 4 x 3/8"	1/4	1 1/2"	.25	.59	
CT-1-038-431-C52R	4 x 4 x 3/8"	0	1 1/2"	.053	.18	
CT-1-039-008-C42R	4 x 4 x 3/8"	0	1 1/2"	.07	.21	
CT-1-039-020-C42R	4 x 4 x 1/2"	3/4	1 1/2"	.112	.81	
CT-1-039-402-C42S	5 x 5 x 3/8"	13/16	1 1/2"	.02	.17	
CT-1-039-405-C42S	4 x 4 x 3/8"	0	1 1/2"	.2	.144	
CT-1-039-407-C42R	4 x 4 x 3/8"	0	1 1/2"	.19	.31	
CT-1-039-413-C42A	10 x 6 x 1/2"	0	1"	1.4	3.03	FE
CT-1-039-415-C42R	4 x 4 x 3/8"	0	1 1/2"	.24	.93	
CT-1-039-424-C42R	4 x 4 x 3/8"	0	1"	.28	.69	
CT-1-039-432-C42K	4 x 4 x 3/8"	1/8	1 1/2"	.09	.086	
CT-1-039-433-C42K	4 x 4 x 1/4"	0	1 1/2"	.358	.506	
CT-1-039-434-C42R	4 x 4 x 3/8"	0	1 1/2"	.209	.477	
CT-1-039-435-C42K	CT-1-039-402-C42S	0	-	-	-	
CT-1-039-436-C42R	4 x 4 x 3/8"	5/16"	1 1/2"	.07	.58	
CT-1-039-445-C42R	4 x 4 x 3/8"	0	1"	.21	.82	
CT-1-039-447-C42R	4 x 4 x 3/8"	0	1"	.351	.99	
CT-1-051-406-C72K	4 x 4 x 3/8"	1/2"	1 1/2"	.024	.285	
CT-1-053-408-C62R	4 x 4 x 3/8"	0	1 1/2"	2.13	3.88	FE
CT-1-053-418-C62R	6 x 6 x 3/8"	0	1 1/2"	1.48	4.12	FE
CT-1-054-401-C42R	4 x 4 x 3/8"	1/4	1"	.17	1.26	
CT-1-054-404-C42R	4 x 4 x 3/8"	1/2	1 1/2"	.083	.616	
CT-1-054-406-C42R	6 x 6 x 3/8"	1 13/32	1 1/2"	.06	.21	
CT-1-054-409-C42K	4 x 4 x 3/8"	0	1 1/2"	.26	.364	
CT-1-054-413-C42R	6 x 6 x 3/8"	1/2	1 1/2"	.09	.86	
CT-1-054-420-C42R	6 x 6 x 3/8"	1"	1 1/2"	.17	1.49	
CT-1-054-424-C42R	4 x 4 x 3/8"	0	1"	.54	.61	
CT-1-054-429-C42R	4 x 4 x 3/8"	5/8	1 1/2"	.0975	.51	
CT-1-054-430-C42R	4 x 4 x 3/8"	3/8"	1"	2.78	8.41	FE
CT-1-054-431-C42A	6 x 6 x 3/8"	1/2"	1"	.55	3.39	FE
CT-1-054-438-C42R	4 x 4 x 3/8"	0	1"	.23	.63	
CT-1-054-442-C42R	4 x 4 x 3/8"	0	1 1/2"	.03	.219	
CT-1-117-403-C62R	4 x 4 x 3/8"	1/8"	1 1/2"	.11	.80	

FE - Requires further evaluation.

TABLE 1
PART A

SUPPORT MARK NO.	TUBE STEEL SIZE	ECCENTRICITY	BOLT SIZE	INSERT INTERACTION	BOLT INTERACTION	
CT-1-117-404-C62R	6 x 6 x 3/8"	1/8"	1 1/2"	.05	.22	
CT-1-117-405-C62K	4 x 4 x 3/8"	0	1 1/2"	.077	.394	
CT-1-117-410-C62K	4 x 4 x 3/8"	1/2"	1 1/2"	.07	.52	
CT-1-124-412-C72K	4 x 4 x 3/8"	0	1 1/2"	.026	.21	
FW-1-097-018-C62R	6 x 6 x 3/8"	0	1"	1.39	7.93	FE
MS-1-002-004-C72K	6 x 6 x 1/2"	0	1 1/2"	.34	.44	
MS-1-002-005-C72K	6 x 6 x 1/2"	3/4"	1 1/2"	2.22	6.36	FE
MS-1-002-006-C72K	8 x 8 x 1/2"	0	1 1/2"	.47	.38	
MS-1-002-013-C72K	8 x 8 x 1/2"	0	1 1/2"	1.22	1.38	FE
MS-1-073-007-C52K	4 x 4 x 3/8"	0	1 1/2"	.145	.434	
MS-1-074-001-C52K	4 x 4 x 3/8"	1/8"	1 1/2"	.16	.43	
MS-1-074-002-C52S	4 x 4 x 3/8"	0	1 1/2"	.196	.25	
MS-1-074-003-C52K	MS-1-074-002-C52S	-	-	-	-	
MS-1-074-010-C52K	4 x 4 x 3/8"	0	1 1/2"	.072	.33	
MS-1-074-012-C52K	4 x 4 x 1/2"	0	1 1/2"	.28	.52	
MS-1-150-002-C52S	4 x 4 x 3/8"	3/16"	1 1/2"	.15	.5	
MS-1-150-004-C52S	4 x 4 x 3/8"	1/2"	1 1/2"	.19	1.48	
MS-1-150-025-C52K	4 x 4 x 3/8"	0	1 1/2"	.095	.354	
MS-1-150-029-C52K	4 x 4 x 1/2"	3/16"	1 1/2"	.05	.4	
MS-1-150-044-C52R	6 x 6 x 3/8"	0	1 1/2"	.16	.68	
MS-1-150-045-C52K	4 x 4 x 1/2"	1/16"	1"	.187	1.56	
MS-1-150-058-C52K	4 x 4 x 3/8"	0	1 1/2"	.18	.53	
MS-1-150-059-C52K	MS-1-151-043-C52K	-	-	-	-	
MS-1-150-064-C52K	MS-1-150-024-C52K	0	1 1/2"	.65	.275	
MS-1-151-002-C52R	6 x 6 x 1/2"	1/8"	1 1/2"	.37	1.11	
MS-1-151-005-C52R	4 x 4 x 3/8"	5/16"	1 1/2"	.27	1.15	
MS-1-151-008-C52R	MS-1-150-010-C52S	0	1"	.34	.39	
MS-1-151-018-C52R	4 x 4 x 3/8"	0	1 1/2"	.23	.67	
MS-1-151-019-C52R	4 x 4 x 3/8"	0	1 1/2"	.34	.95	
MS-1-151-038-C52R	5 x 5 x 1/2"	0	1 1/2"	.18	.74	
MS-1-151-043-C52K	4 x 4 x 3/8"	1/2"	1 1/2"	.23	.66	
MS-1-345-005-C52K	4 x 4 x 3/8"	3/8"	1 1/2"	.07	.71	
MS-1-416-005-S33R	6 x 6 x 1/2"	11/16"	1"	.64	3.42	FE
RC-1-008-002-C41S	4 x 4 x 1/2"	3/8"	1 1/2"	.24	1.2	
RC-1-018-020-C71R	6 x 6 x 1/2"	0	1 1/2"	.03	.31	
RC-1-018-021-C71R	4 x 4 x 1/2"	0	1 1/2"	.17	.45	
RC-1-075-044-C51K	6 x 6 x 1/2"	3/16"	1 1/2"	.22	1.09	
RC-1-075-052-C61R	6 x 6 x 3/8"	0	1 1/2"	.6	1.66	

FE - Requires further evaluation.

TABLE 1
PART A

SUPPORT MARK NO.	TUBE STEEL SIZE	ECCENTRICITY	BOLT SIZE	INSERT INTERACTION	BOLT INTERACTION	
RC-1-087-004-C81K	6 x 6 x 3/8"	0	1 1/2"	.386	1.63	
RC-1-088-006-C81K	RC-1-087-001-C81S	0	1 1/2"	.17	.61	
RC-1-162-004-C81K	6 x 4 x 1/2"	0	1 1/2"	.21	.67	
RC-1-164-001-C81K	6 x 6 x 3/8"	0	1 1/2"	.1426	.412	
RH-1-005-007-C42R	4 x 4 x 3/8"	0	1 1/2"	.023	.14	
RH-1-005-013-C42R	6 x 6 x 3/8"	1-3/8"	1 1/2"	.07	.94	
RH-1-006-010-C42K	6 x 4 x 3/8"	0	1 1/2"	.37	.77	
SI-1-051-012-C42K	6 x 4 x 3/8"	1/2"	1 1/2"	.11	.37	
SI-1-087-009-C42R	6 x 6 x 3/8"	1/8"	1 1/2"	.89	1.72	
SI-1-095-017-C42R	6 x 6 x 3/8"	0	1 1/2"	.46	1.22	
SI-1-102-007-C41R	6 x 6 x 3/8"	0	1 1/2"	.38	1.24	
SI-1-103-008-C42K	6 x 6 x 3/8"	0	1 1/2"	1.54	4.63	FE
SI-2-178-714-A32R	4 x 4 x 1/4"	0	1"	.26	.61	

FE - Requires further evaluation.

TABLE 1
PART B

SUPPORT MARK NO.	REV.		TENSION (KIPS)	SHEAR (KIPS)	MOMENT (KIP IN)
AF-1-006-010-S33R	2		1.398	.694	-
CC-1-008-013-S33K	5		8.633	.46	1.021
CC-1-197-005-C52R	3		.113	.889	11.911
CC-1-197-014-C42R	3		6.0	.444	4.0
CC-1-197-019-C52R	2		2.0	.246	4.0
CC-1-197-020-C52R	3		2.0	.246	4.0
CC-1-197-034-C52R	3		1.0	1.0	4.0
CC-1-204-003-C52R	5		2.0	1.0	8.0
CC-1-205-016-C53R	4		2.0	2.0	2.0
CC-1-206-001-C53R	5		2.0	2.0	2.0
CC-1-207-014-C53R	4		-	.243	2.189
CC-1-207-021-C53R	4		1.0	1.0	4.0
CC-1-212-001-C53R	3		2.0	.247	2.0
CC-1-215-032-C53R	5		-	.256	4.0
CC-1-215-033-C53R	3		.25	0	2.5
CC-1-217-003-C53K	2		1.0	.5	4.0
CC-1-217-012-C53R	1		-	.319	5.583
CC-1-218-009-C53K	2		1.0	.5	4.0
CC-1-218-010-C53K	4		-	.144	.335
CC-1-218-012-C53K	2		6.0	.02	2.0
CC-1-218-013-C53K	2		-	1.0	7.98
CC-1-218-014-C53K	2		1.0	1.0	4.0
CC-1-226-004-C53R	2		1.0	.5	8.0
CC-1-226-005-C53R	3		-	.487	5.511
CC-1-227-003-C53R	3		6.0	.17	4.0
CC-1-231-002-C53R	3		.235	-	.883
CC-1-233-001-C53R	2		.651	.337	2.321
CC-1-233-004-C53R	6		.4	-	4.0
CC-1-234-016-C53R	4		-	.879	5.264
CC-1-237-001-C53R	CC-1-235-001-C53R		2.917	.765	2.16
CC-1-237-004-C53R	CC-1-233-001-C53R		-	-	-
CC-1-239-005-C53R	3		.22	-	1.87
CC-1-239-008-C53R	CC-1-233-001-C53R		-	-	-

TABLE 1
PART B

SUPPORT MARK NO.	REV.		TENSION (KIPS)	SHEAR (KIPS)	MOMENT (KIP IN)
CC-1-242-002-C53R	3		.273	.273	.956
CC-1-242-003-C53R	3		0	.338	1.01
CC-1-245-010-C53R	2		1.0	1.0	4.0
CC-1-245-018-C53R	2		.204	.373	.714
CC-1-249-003-C53R	1		6.0	-	4.0
CC-1-249-700-C53R	1		1.408	.817	4.496
CC-1-255-007-C53R	2		.433	1.59	0.0
CC-1-271-008-C53R	1		1.0	1.0	10.0
CC-1-272-008-C53K	2		-	.15	1.882
CC-2-040-401-A33K	2		2.0	.073	1.751
CC-2-040-405-E33R	1		.266	1.3	5.65
CC-2-048-402-A33R	2		3.0	-	5.0
CC-2-048-403-A33R	2		-	.493	0.0
CC-2-048-408-A33K	5		.04	.678	4.066
CC-2-105-406-E23P	4		-	.395	0.0
CC-2-107-403-E23S	2		1.0	-	5.0
CS-1-001-003-C42K	6		.076	.127	.67
CS-1-001-011-C42R	6		.50	1.0	2.0
CS-1-001-012-C42R	6		6.0	1.0	6.0
CS-1-001-024-C42K	3		1.0	1.0	2.0
CS-1-001-027-C42K	3		2.0	1.0	4.0
CS-1-001-035-C42R	5		2.0	1.005	8.0
CS-1-012-003-C42R	2		.356	-	5.696
CS-1-077-004-C42R	3		.626	-	2.2
CS-1-077-005-C42R	3		.474	-	1.6
CS-1-077-006-C42R	3		.287	.114	3.957
CS-1-078-003-C42R	4		-	1.591	11.0
CS-1-078-018-C42K	3		-	1.028	0.0
CS-1-079-006-C42R	4		.5	.05	3.0
CS-1-079-007-C42R	6		2.0	1.005	8.0
CS-1-079-020-C42R	4		1.0	.50	4.5
CS-1-079-037-C42K	3		.975	0.0	3.862
CS-2-033-408-A42R	4		.98	.086	.667
CS-2-085-402-A42S	3		1.0	.895	6.0
CT-1-018-005-S22R	2		.186	0	3.314
CT-1-038-003-C52R	4		.50	.50	-
CT-1-038-402-C52R	4		.5	.50	-

TABLE 1
PART B

SUPPORT MARK NO.	REV.		TENSION (KIPS)	SHEAR (KIPS)	MOMENT (KIP IN)
CT-1-036-415-C62R	5		-	.38	2.115
CT-1-038-430-C62K	3		6.0	.035	2.0
CT-1-038-431-C62R	3		.8	.4	2.0
CT-1-039-008-C42R	4		1.0	-	3.0
CT-1-039-020-C42R	2		1.394	.25	4.52
CT-1-039-402-C42S	4		.37	0	.674
CT-1-039-405-C42S	4		2.0	-	2.0
CT-1-039-407-C42R	4		4.0	-	4.0
CT-1-039-413-C42A	4		1.441	.55	1.0
CT-1-039-415-C42R	4		2.0	2.0	4.0
CT-1-039-424-C42R	3		.144	.425	2.676
CT-1-039-432-C42K	3		3.0	.20	2.0
CT-1-039-433-C42K	5		6.0	.180	6.0
CT-1-039-434-C42R	3		2.0	.48	6.0
CT-1-039-435-C42K	CT-1-039-402-C42S		-	-	-
CT-1-039-436-C42R	1		.515	.44	1.76
CT-1-039-445-C42R	3		.102	.72	2.458
CT-1-039-447-C42R	3		-	1.0	1.5
CT-1-051-406-C72K	4		.328	.031	1.312
CT-1-053-408-C62R	3		1.82	2.479	9.249
CT-1-053-418-C62R	3		3.0	1.72	46.068
CT-1-054-401-C42R	3		-	.304	1.357
CT-1-054-404-C42R	2		.50	-	2.0
CT-1-054-406-C42R	4		.383	0	1.186
CT-1-054-409-C42K	3		6.0	.187	4.0
CT-1-054-413-C42R	1		.1	.152	4.15
CT-1-054-420-C42R	3		1.5	1.025	3.0
CT-1-054-424-C42R	2		.523	-	4.7
CT-1-054-429-C42R	2		3.323	-	.786
CT-1-054-430-C42R	1		6.581	.274	9.889
CT-1-054-431-C42A	3		.227	.407	3.608
CT-1-054-438-C42R	2		-	.5	2.0
CT-1-054-442-C42R	2		-	.5	1.0
CT-1-117-403-C62R	3		.370	1.482	4.627

TABLE 1
PART B

SUPPORT MARK NO.	REV.		TENSION (KIPS)	SHEAR (KIPS)	MOMENT (KIP IN)
CT-1-117-404-C62R	2		.429	0	2.014
CT-1-117-405-C62K	5		.225	.04	5.43
CT-1-117-410-C62K	2		2.0	-	2.0
CT-1-124-412-C72K	4		-	.687	2.06
FW-1-097-018-C62R	3		1.46	1.95	36.941
MS-1-002-004-C72K	9		12.16	1.0	2.3
MS-1-002-005-C72K	7		19.37	2.37	9.80
MS-1-002-006-C72K	7		4.069	.455	2.048
MS-1-002-013-C72K	9		23.975	4.301	3.295
MS-1-074-001-C52K	4		2.128	.757	-
MS-1-074-002-C52S	5		2.0	-	4.0
MS-1-074-003-C52K	MS-1-074-002-052S		-	-	-
MS-1-074-010-C52K	2		.031	.372	4.253
MS-1-074-012-C52K	3		1.0	1.0	6.0
MS-1-150-002-C52S	2		.477	.09	6.55
MS-1-150-004-C52S	3		.246	.839	8.461
MS-1-150-025-C52K	5		.5	-	4.0
MS-1-150-029-C52K	4		.8	.2	2.2
MS-1-150-044-C52K	5		1.0	1.0	4.0
MS-1-150-045-C52K	4		-	.274	1.436
MS-1-150-058-C52K	3		2.0	1.0	5.0
MS-1-150-059-C52K	MS-1-151-043-C52K		-	-	-
MS-1-150-064-C52K	4		6.0	.059	2.0
MS-1-151-002-C52R	5		6.0	.605	5.0
MS-1-151-005-C52R	4		3.0	1.3	5.62
MS-1-151-008-C52R	6		.186	.318	4.364
MS-1-151-018-C52R	6		2.0	1.0	8.0
MS-1-151-019-C52R	4		1.0	.2	13.0
MS-1-151-038-C52R	4		-	.71	7.174
MS-1-151-043-C52K	2		.014	1.64	6.614
MS-1-345-005-C52K	4		-	.27	3.309
MS-1-416-005-S33R	3		.812	-	5.027
RC-1-008-002-C41S	3		1.939	2.169	5.899
RC-1-018-020-C71R	6		1.497	.742	-
RC-1-018-021-C71R	4		1.373	1.308	6.0
RC-1-075-044-C51K	4		2.25	.334	7.821
RC-1-075-052-C61R	3		.998	2.291	10.212

TABLE 1
PART B


SUPPORT MARK NO.	REV.		TENSION (KIPS)	SHEAR (KIPS)	MOMENT (KIP IN)
RC-1-087-004-C81K	8		.095	1.5	15.0
RC-1-088-006-C81K	4		.327	.68	7.808
RC-1-162-004-C81K	5		-	2.36	10.0
RC-1-164-001-C81K	6		1.83	.082	5.49
RH-1-005-007-C42R	2		-	.18	1.27
RH-1-005-013-C42R	2		2.08	.05	5.253
RH-1-006-010-C42K	3		1.961	1.124	6.11
SI-1-051-012-C42K	3		1.497	1.655	.749
SI-1-087-009-C42R	3		2.67	1.55	9.84
SI-1-095-017-C42R	7		2.855	3.678	16.687
SI-1-102-007-C41R	7		-	.798	13.59
SI-1-103-008-C42K	5		3.933	10.63	2.306
SI-2-178-714-A32R	2		.664	.227	2.512

TABLE 2

TUBE STEEL & RICHMOND INSERTS
 COMPARISON OF RESULTS OBTAINED WITH
 STRUDL WITH AND WITHOUT RELEASING M_z

A. GENERIC STUDY


Problem 1



All tube steel is
 4"x4"x1/4"

1 All moment constrained
 2 All moments released

Problem 2



a. Member results

Member	Max. Stress1	Max. Stress2	Member	Max. Stress1	Max. Stress2
5	448.6	448.6	7	2729	2902
6	448.6	448.6	8	2729	2902
7	640.9	897.2	3	1453	1477
8	649.9	897.6	4	1453	1477
9	448.6	448.6	5	540	497
10	448.6	448.6	6	579	384

Max. Increase 1/2 40%

Max. Increase 1/2 6%

b. Deflections at Pt. 5

.000902 .001184

.00569 .00607

Max. Increase 1/2 = 31%

Max. Increase 1/2 = 7%

c. Tension in Each Insert

838# 250#

1113# 500#

Max. decrease 1/2 = 340%

Max. decrease 1/2 = 220%

TABLE 2 (cont'd.)

B. ACTUAL SUPPORTS

The following tube steel frames have been STRUDL analyzed with tube steel to Richmond connections considered pinned in all directions. These frames were originally analyzed with the joints pinned in two directions, but resisting rotations about the member's axis.

SUPPORT NO.	INSERT AS ONE DIR. FIXED		INSERT AS PINNED	
	INSERT INTER.	HILTI BOLT IN.	INSERT INTER.	HILTI BOLT IN.
CC-2-323-112-A43R	0.54	0.27	0.03	0.24
DD-1-016-700-S33R	0.56	N/A	0.45	N/A
FW-1-019-700-C42K	0.44	0.95	0.086	0.85
FW-1-095-700-C62K	0.34	0.74	0.12	0.89
FW-1-096-706-C62K	0.66	N/A	0.62	N/A
FW-1-098-700-C62K	0.22	0.79	0.05	0.86
SF-1-004-700-C46K	0.37	N/A	0.22	N/A

SUPPORT NO.	INSERT AS ONE DIR. FIXED		INSERT AS PINNED	
	MAX ₁ Δ	MAX ₃ σ	MAX ₂ Δ	MAX ₃ σ
CC-2-323-712-A43R	0.021	8179	0.0477	8179
DD-1-016-700-S33R	0.0019	5333	0.002	9918
FW-1-019-700-C42S	0.0042	4752	0.052	6400
FW-1-095-700-C62K	0.0002	5388	0.0004	8423
FW-1-096-706-C62K	0.0028	7702	0.00231	7757
FW-1-098-700-C62K	0.0018	5651	0.0019	5916
SF-1-004-700-C46K	0.032	4950	0.032	4816
	(INCH)	(PSI)	(INCH)	(PSI)