



Carolina Power & Light Company

JUN 4 1984

ESS-84-57

Mr. Charles Wakild  
Regional Supervisor  
North Carolina Division of Environmental Management  
7525 Wrightsville Avenue  
Wilmington, NC 28403

RE: BRUNSWICK STEAM ELECTRIC PLANT  
NPDES PERMIT NO. NC0007064

Dear Mr. Wakild:

As required by the NPDES permit for this facility, this is to provide you with notification that the Brunswick Unit No. 1 was operated with less than two fine mesh screens during May. One of the cooling water pump bays was without screens from May 17 at 6:30 a.m. to May 21 at 7:08 p.m. due to removal of the bar trash rack for cleaning. On May 21, a spare rack was installed and the fine mesh screens were returned to service.

If there are any questions concerning this report, please contact R. K. Miller at (919) 836-7185.

Yours very truly,

R. B. Starkey, Jr.  
Manager  
Environmental Services

RBSjr/pdc (1558PTU)

cc: Mr. H. R. Denton ✓  
Mr. J. P. O'Reilly

54-325

B406070060 B40604  
PDR ADOCK 05000325  
S PDR

IE25  
'10