

JAN 6 1992

*Official
Copy*

Docket No. 50-395
License No. NPF-12

South Carolina Electric & Gas Company
ATTN: Mr. John L. Skolds
Vice President, Nuclear Operations
Virgil C. Summer Nuclear Station
P. O. Box 88
Jenkinsville, SC 29065

Gentlemen:

SUBJECT: NOTICE OF VIOLATION
(NRC INSPECTION REPORT NO. 50-395/91-23)

This refers to the inspection conducted by R. C. Haag of this office on November 9 through December 17, 1991. The inspection included a review of activities authorized for your V. C. Summer Nuclear Facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

Based on the results of this inspection, certain of your activities appeared to be in violation of NRC requirements, as specified in the enclosed Notice of Violations (Notice). We are concerned about the first violation because an identified deficiency which could have rendered an emergency diesel generator inoperable was not promptly corrected. For the second violation, we are concerned that ASME Code requirements governing a piping modification were not satisfied.

You are required to respond to this letter and should follow the instructions specified in the enclosed Notice when preparing your response. In your response, you should document the specific actions taken and any additional actions you plan to prevent recurrence.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter and its enclosures will be placed in the NRC Public Document Room.

The responses directed by this letter and the enclosures are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, Pub. L. No. 96-511.

920127C006 920106
PDR ADOCK 05000395
Q PDR

IE01

JAN 6 1992

Should you have any questions concerning this letter, please contact us.

Sincerely,

ORIGINAL SIGNED BY
DAVID M. VERRELLI

David M. Verrelli, Chief
Reactor Projects Branch 1
Division of Reactor Projects

Enclosures:

1. Notice of Violation
2. NRC Inspection Report

cc w/encls:

M. R. J. White
Nuclear Coordinator
S.C. Public Service Authority
Virgil C. Summer Nuclear Station
P. O. Box 88 (Mail Code 802)
Jenksville, SC 29065

J. B. Knotts, Jr., Esq.
Bishop, Cook, Purcell
and Reynolds
1400 L Street, N.W.
Washington, D.C. 20005-3502

Chairman, Fairfield County Council
P. O. Bcx 293
Winnsboro, SC 29180

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, SC 29201

Mr. A. R. Koon, Jr., Manager
Nuclear Licensing
Virgil C. Summer Nuclear Station
South Carolina Electric and Gas Company
P. O. Box 88
Jenksville, South Carolina 29065

bcc w/encls: (See page 3)

JAN 6 1992

South Carolina Electric & Gas Company 3

bcc w/encls:

J. Johnson, RII

G. F. Wunder, NRR

F. Cantrell, RII

S. D. Ebnetter, RII

Document Control Desk

NRC Resident Inspector

U.S. Nuclear Regulatory Commission

Route 1, Box 64

Jenkinsville, SC 29065

RII:DRP

RwW
RWright:tj
01/06/92

RII:DRP

FCantrell
FCantrell
01/06/92