



**Entergy
Operations**

Entergy Operations, Inc.
Route 3 Box 137G
Russellville, AR 72801
Tel 501-964-8880

Neil S. "Buzz" Carns
Vice President
Operations ANO

January 21, 1992

OCAN019201

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Units 1 and 2
Docket Nos. 50-313 and 50-368
License Nos. DPR-51 and NFP-6
Technical Specification Change Request
Seismic Monitor Measurement Range Correction

Gentlemen:

Attached for your review and approval are proposed ANO-1 and ANO-2 Technical Specification (TS) changes. ANO-2 is requesting the correction of an apparent typographical error to the measurement range for seismic monitor 2XR-8347, Item 2.a on Table 3.3-7. The range stated in the TS is 0.01-1.0g. The correct range is 0.05-1.0g. This correct range was provided in the original markup of the Standard Technical Specifications (STS) for ANO-2 submitted to the NRC March 23, 1976. However, the original issue of these TS with the ANO-2 license contained the error, apparently as a typographical oversight. No indication of NRC technical disagreement with the AP&L submitted range has been identified. The typographical error has gone undetected since that time.

On August 9, 1989 ANO-1 submitted a TS change request (1CAN088902) to incorporate Seismic Monitoring Instrumentation into Section 3.5.1, Operational Safety Instrumentation. A complete description of the appropriate ranges for this instrumentation is provided in this change request for ANO-1 TS, consistent with the description for ANO-2 TS. An additional typographical error in the ANO-1 TS equipment nomenclature is also corrected.

In accordance with 10CFR50.91(a)(1), and using the criteria in 10CFR50.92(c), Entergy Operations has determined that the change involves no significant hazards consideration. The basis for these determinations are included in the attached submittal.

200063

9201270028 920121
PDF ADOCK 05000313
P PDR

ADD 11

We request that the effective date of this change be upon NRC issuance of the amendment.

Very truly yours,

Joe Yelton for NSC

NSC/sjf
Attachments

cc: Mr. Robert Martin
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

NRC Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. Thomas W. Alexion
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 11-D-23
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Ms. Sheri Peterson
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 11-D-23
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

STATE OF ARKANSAS)
)
COUNTY OF LOGAN) SS

Affidavit

I, J. W. Yelverton, being duly sworn, subscribe to and say that I am General Manager, Plant Operation ANO for Entergy Operations, that I have full authority to execute this affidavit; that I have read the document numbered OCAN019201 and know the contents thereof; and that to the best of my knowledge, information and belief the statements in it are true.

J. W. Yelverton
J. W. Yelverton

SUBSCRIBED AND SWORN TO before me, a Notary Public in and for the County and State above named, this 21st day of January, 1992.

Lesly Sichenmorgen
Notary Public

My Commission Expires:

May 11, 2000