


7-19-77

PAUL O'CONNOR:

WE ARE FINISHED WITH OUR  
REVIEW OF SINGLE LOOP OPERATION  
AT PILGRIM. WE SUGGEST THAT  
THE TECHNICAL SPECIFICATIONS REQUIRE  
THAT THE EQUALIZER VALVE ~~CLOSES~~  
WHICH IS REQUIRED TO BE CLOSED  
BE LOCKED OUT SO THAT A SPURIOUS  
OPERATION OF THE VALVE WILL NOT  
RESULT IN THE VALVE BEING OPENED.



J. F. BURDOIN