



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TOLEDO EDISON COMPANY

CENTERIOR SERVICE COMPANY

AND

THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

DOCKET NO. 50-346

DAVIS-BESSE NUCLEAR POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 168
License No. NPF-3


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Toledo Edison Company, Centerior Service Company, and the Cleveland Electric Illuminating Company (the licensees) dated May 31, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-3 is hereby amended to read as follows:

(a) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 168, are hereby incorporated in the license. The Toledo Edison Company shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented not later than 45 days after issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Jon B. Hopkins, Sr. Project Manager
Project Directorate III-3
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of issuance: January 16, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 168

FACILITY OPERATING LICENSE NO. NPF-3

DOCKET NO. 50-346

Replace the following page of the Appendix "A" Technical Specifications with the attached page. The revised page is identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf page are also provided to maintain document completeness.

Remove

3/4 6-23

Insert

3/4 6-23

CONTAINMENT SYSTEMS

3/4.6.4 COMBUSTIBLE GAS CONTROL

HYDROGEN ANALYZERS

LIMITING CONDITION FOR OPERATION

3.6.4.1 Two independent containment hydrogen analyzers shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:

- a. With one hydrogen analyzer inoperable, restore the inoperable analyzer to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.
- b. With both hydrogen analyzers inoperable, restore at least one analyzer to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours.

SURVEILLANCE REQUIREMENTS

4.6.4.1 Each hydrogen analyzer shall be demonstrated OPERABLE at least once per 31 days by performance of a CHANNEL CHECK.

4.6.4.2 Each hydrogen analyzer shall be demonstrated OPERABLE at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using sample gases containing:

- a. Zero volume percent hydrogen, balance nitrogen, and
- b. 2.5 ± 0.5 volume percent hydrogen, balance nitrogen.

DELETED

DAVIS-BESSE, UNIT 1

3/4 6-24

Amendment No. #2, 66