

CONSUMERS POWER COMPANY
MIDLAND NUCLEAR PLANT
REQUEST FOR EXEMPTION
FROM
BRANCH TECHNICAL POSITION
BTP-CMEB 9.5-1
FOR
CONTROL PANELS C43 AND C44
MAY 25, 1984

B406070265 B40530
PDR ADOCK 05000329
F PDR

cpm2/C43-N/44/D8

TABLE OF CONTENTS

<u>Section</u>		<u>Page</u>
I.	BACKGROUND AND SUMMARY	1
II.	EXEMPTION REQUEST	3
III.	BASIS FOR EXEMPTION	4
	A. <u>INTRODUCTION</u>	4
	B. <u>DESIGN</u>	7
	C. <u>CONCLUSION</u>	12
IV.	REFERENCES	13

LIST OF TABLES

Table 1	Safe Shutdown Functions of Concern Within Panels C43 and C44
Table 2	General Fire Protection Information Safety Related Equipment Rooms

LIST OF FIGURES

Figure 1	Main Control Room General Arrangement
Figure 2	C43 and C44 Panel Arrangement
Figure 3	Safety Related Equipment Room Fire Detection/Suppression System

I. BACKGROUND AND SUMMARY

BACKGROUND

On October 26, 1983, a meeting was held between Consumers Power Company (CPCo), Bechtel, and the NRC staff to discuss fire protection for control panels containing redundant safe shutdown components and their potential susceptibility to fire damage. CPCo presented a discussion of all safe shutdown panels within the control room, control room peripheral rooms, and safety related equipment (SRE) rooms. The control panel arrangement and area layout are shown on Figure 1. CPCo stated that panels C43 and C44 contained redundant safe shutdown circuits that could be damaged by a single fire and, therefore, positive means would be required to safeguard these circuits from fire induced failures. CPCo indicated that a halon fire suppression system incorporating cross-zoned smoke detection system was being designed for the SRE room and panels C43 and C44 to provide this positive protection.

This submittal provides discussion on the low probability of actual fires in the SRE rooms and details of this state-of-the-art fire suppression system. This information will form the basis for an exemption request.

SUMMARY

There are only two panels within the SRE rooms, the C43 and C44 panels which contain redundant channels of safe shutdown circuits which require protection from fire induced failures. This document demonstrates that the proposed and existing fire protection features for the SRE rooms within fire area 65A combined with the low probability of fire in these rooms provide a level of fire protection consistent with the fire hazards both transient and in-situ identified

for these rooms. The highly reliable smoke detection/halon suppression system described in Section III will function such that internal or external panel fires will be extinguished before they can cause the loss of redundant safe shutdown functions. Alternate methods of safeguarding the safe shutdown circuits in these rooms were considered but determined to be less effective in protecting both redundant trains than the total flooding halon system described in this submittal.

This document contains information pertaining to the low fire probability and the highly reliable smoke detection/halon suppression system. Based on a probabilistic risk assessment study, the probability of a fire in the SRE room (2.3×10^{-5}) coupled with the overall probability of a failure of the smoke detection/halon suppression system (1×10^{-4}) results in a failure rate of 2.3×10^{-9} per reactor year. Included are discussions of the following:

- Very low fire probability for the SRE rooms,
- High sensitivity and rapid response of the cross-zoned detection system,
- The high success of Halon as a complete suppression agent,
- Redundant detection and automatic suppression components, and
- Passive protection of both redundant channels of safe shutdown circuits.

This information forms the basis for an exemption request from Branch Technical Position BTP-CMEB 9.5-1 as described in Section II.

II. EXEMPTION REQUEST

Branch Technical Position BTP-CMEB 9.5-1, Section C5.b.(2), requires that redundant trains of safe shutdown systems be protected from fire damage by 1) separation of cables and equipment by a 3-hour fire barrier; or 2) separation of cables and equipment by a horizontal distance of more than 20 feet with no intervening combustibles combined with the installation of fire detection and automatic fire suppression; or 3) enclosure of cables and equipment of one train by a 1-hour rated fire barrier combined with the installation of fire detection and automatic fire suppression.

Based on the information contained in this document describing the highly reliable smoke detection/halon suppression system and other passive fire protection features, CPCo is requesting an exemption from BTP- CMEB 9.5-1, Section C5.b.(2), for the circuits of safe shutdown functions identified on Table 1 for C43 and C44 panels.

III. BASIS FOR EXEMPTION

A. INTRODUCTION

A safe shutdown analysis was conducted for all control room cabinets, including the safety related equipment (SRE) room cabinets which contain safe shutdown circuits. Refer to Figure 1 for the location of the SRE room and for the layout of the panels within the room. The analysis of the SRE rooms indicated that potential fires in or near panels C41, C42, or C45 will not affect the safe shutdown capability of the plant. For panels C43 and C44, however, safe shutdown capability is threatened by the potential for uncontrolled fires in or adjacent to these panels. Some of the safe shutdown circuits within these panels are protected against such fires by transfer switches and require no further consideration. The remaining safe shutdown circuits of concern are the subject of this submittal and the accompanying exemption request. A list of the functions controlled by these circuits of concern is presented in Table 1.

Panel C43, a single multi-bay panel, is the Engineering Safety Features Actuation System (ESFAS) analog panel. Panel C44 is comprised of two multi-bay cabinets located end-to-end, separated by a 3 inch air space, and contains the ESFAS digital logic module and Loss of Off-site Power (LOP) and Emergency Core Cooling Actuation System (ECCAS) sequencers. Arrangement of the C43 and C44 panels is shown on Figure 2.

Circuit failures in any one channel, resulting in either inoperable equipment or spurious operation of ESFAS, will not affect the safe shutdown capability of the plant. Passive protection of the redundant circuits of concern within panels C43 and C44

is provided by physical separation of these circuits. In panel C43, the redundant circuits are located in different bays of that panel, and in C44 the redundant circuits are located in the opposite cabinets. This separation, combined with an effective fire detection/suppression system described in this submittal, provides protection against loss of redundant safe shutdown functions as a result of a fire.

Each Unit of the Midland Nuclear Plant has its own separate SRE room. The basis for this exemption request applies equally to both Units.

The SRE rooms in which these panels are located are an area of low activity and the in-situ fire loading is low, consisting primarily of wires and cable. A physical description of the SRE room is provided in tabular form in Table 2. A review of the potential for transient combustibles in the SRE rooms was performed by a Consumers Corporate Fire Protection Engineer. The results of this review indicate that the expected transient combustibles loading for these rooms is very small and would consist primarily of materials in the possession of plant personnel during the time that these rooms are occupied. The type and quantity of transient combustibles are controlled by administrative procedures. The low transient combustible loading contributes to a low fire probability from this room.

In addition to the items mentioned above, the SRE rooms of both Units form a separate fire area designated 65A. The fire area boundary which separates the SRE room from the main control room (area 65) and the balance of plant consists of 3-hour fire rated construction. Door openings and HVAC duct penetrations in the boundary walls are equipped with automatic self-closing fire rated doors and duct dampers. The fire rating on

the doors and duct dampers is equivalent to that of the fire area boundary. Circuits in the SRE room are low voltage signal or control circuits with over-current protection provided as necessary. The combination of these factors supports the low fire probability. Based on nuclear plant experience, the median estimate of a fire in the Midland control room is 3.2×10^{-4} per reactor year¹. It is further conservatively assumed that the SRE room contains equipment and materials representative of the control room and, therefore, the probability that a control room fire would occur in the SRE room (considering relative floor area) is 7.3 percent. This is a conservative estimate because activity levels within the SRE room will be less than within the main control room and because not all fires postulated to occur in the SRE room have the same potential for affecting panels C43 and C44. This gives a median estimate of a fire in the SRE room of 2.3×10^{-5} per reactor year.

Although the SRE room has a low fire probability, it was decided that positive means should be provided to protect redundant safe shutdown channels from a potential fire.

Several options to achieve this protection were considered. Relocation to achieve a separation of greater than 20' within the SRE room is not a reasonable approach for the bays of panel C43 considering panel and plant construction and layout. Similarly, separation of redundant circuitry within the SRE room by fire barriers is not a practical approach considering panel arrangement and due to lack of space. Electrical isolation devices were evaluated unfavorably, because their addition would significantly increase control system complexity, increase maintenance, and increase the susceptibility to control system failures due to the increased number of components. Therefore,

a highly reliable fire detection/suppression system was chosen to protect both channels. Through rapid and reliable detection and suppression, not only are the safe shutdown functions safeguarded, but also the progression of any potential fire is halted, minimizing the total extent of the damage. For fires internal to the C43 or C44 panels, fire damage will be limited to the local area of the ignition source or faulted circuit. Fires external to any cabinet in the SRE room would be detected and extinguished before circuit damage could occur, thus preserving full system function of both redundant safe shutdown channels.

B. DESIGN

It is the intent to provide maximum protection to the safe shutdown circuits and extinguish incipient fires, preventing damage to one redundant safe shutdown channel and minimizing fire damage to the affected channel. This will be accomplished by the installation of a highly reliable halon suppression system. The SRE room of each unit will be provided with a separate smoke detection/halon suppression system. In addition to the total flooding halon system being installed, the SRE rooms will be outfitted with 3-hour fire rated doors and HVAC supply duct dampers. The doors equipped with automatic self-closing devices will close upon activation of the detection system. These features provide containment of the halon gas within the SRE room to maintain the concentration at a suppression level. The highly reliable total flooding halon system being installed is composed of three subsystems: 1) a detection system, 2) an actuation system, and 3) a supply/distribution system. Components of these subsystems have been laboratory tested (U.L. or F.M.) and their reliability has been proven under actual fire conditions.

The detection system utilizes ionization detectors strategically located for maximum surveillance and to provide rapid detection of any SRE room fire in its earliest development, the incipient stage. Detector location is dependent on several factors including: 1) hazard location, 2) room construction and in particular the ceiling details, and 3) smoke and air movement. Placement of the detectors is in accordance with the guidance provided by NFPA72E.² Minimum standards for detector placement outlined in this standard have been developed based on extensive testing and data gathered from actual fire investigations.

The actuation system is the interface between the detection system and the supply/distribution system. The actuation system is composed of solid state electronic logic modules which accept input signals from either automatic fire detection devices or manually operated switches. These logic modules convert the input signals to output signals which alarm in the control room and initiate the discharge of halon from the storage cylinders into the distribution piping. Spurious automatic discharge of the halon system is minimized by the logic modules using the principle of cross-zoned detection.

The supply/distribution system consists of halon storage cylinders, each equipped with an electrically actuated valve, and a fixed piping manifold and distribution system with appropriately selected discharge nozzles to distribute the halon into the SRE room and into panels C43 and C44.

The high reliability and rapid extinguishing features of the halon system outlined above and detailed in NFPA 12A³ will be improved by: 1) improving detector response time, 2) improving system reliability, and 3) discharging the extinguishing agent directly into each bay of both the C43 and C44 panels. These improvements are shown on Figure 3 and detailed below.

Improving Detection Response Time

The ionization detectors are divided into two redundant strings, called zones and are arranged in a cross-zoned pattern. Each zone is capable of detecting the presence of products of combustion (POC) originating in the SRE room and from within either the C43 panel or the C44 cabinets. Area detection is accomplished using detectors installed within each SRE room in accordance with the guidance provided in NFPA 72E. The detection response time associated with this arrangement is improved by the addition of local (spot) detection directly above the C43 and C44 panels. The top of each bay of these panels will be opened and a smoke collection hood installed on each panel to direct the natural convection currents carrying the potential POC to the ionization detectors. This arrangement minimizes the dilution of the POC by the SRE room air before it reaches these detectors. A total of four ionization detectors (2 per detection zone) will be mounted within each smoke collection hood.

In addition to improving detector response time, this arrangement eliminates the potential for single failures to compromise the system function associated with local detection. Since four detectors are monitoring POC from within all bays of each panel, the failure of a single detector will not prevent detection.

Improving System Reliability

The reliability of the detection system has been improved by eliminating the system dependency associated with a single detector failure. The elimination of single failure modes within the actuation system has been accomplished through the following system improvements.

To prevent loss of power to the smoke detection and halon suppression system, a redundant power supply, consisting of a battery backup, is located in the fire protection panel. This redundant power supply is capable of powering the smoke detection system for 24 hours and still be capable of actuating the halon delivery system should a fire occur during loss of local power.

The halon is stored in two redundant cylinders, each sized to flood the room, including panels to a minimum concentration of 5 percent by volume which is sufficient for rapid extinguishment of a fire^{3,4}. The initial concentration of halon will assure that a minimum 5 percent concentration is maintained throughout a 10 minute soak time taking into account leakage of halon from the SRE room. The logic circuitry, on positive fire indication, will actuate; 1) alarms and 2) discharge the main cylinder releasing the total contents to the room and panels achieving a uniform 5 percent concentration. Should the main cylinder fail to discharge, after a short time delay (approximately 10 seconds), the second or reserve cylinder will be automatically actuated. Pressure switches, mounted in the halon discharge piping, will signal a successful discharge and will inhibit actuation of the reserve cylinder. Failure to detect the main cylinder discharge (or switch failure) may result in both cylinders discharging and will result in halon concentration of 10 percent which does not pose a hazard to operating personnel³.

To evaluate the smoke detection/halon suppression system reliability, a study was conducted utilizing the methods described in NUREG/CR 2300⁵. The failure rate of each of the components and functions shown on Figure 3 was developed based on established data^{6,7}. The SRE room 3-hour rated fire damper

has no function related to the smoke detection/halon suppression system reliability and was not included in the analysis. Based on the foregoing, the failure rate of the system was conservatively calculated to be 1×10^{-4} per year. Elements of conservatism include consideration of potential common mode failures, a conservative estimate of the reliability of the control module, and no operator intervention.

Surveillance and operability requirements, which minimize potential single failures of the fire detection/suppression system functions, will be performed in accordance with Technical Specifications. Technical Specifications will ensure the operability of the smoke detection/halon suppression system. Surveillance and maintenance of the automatic self-closing fire doors will be performed in accordance with the corporate Property Protection Department Fire Protection Manual.

Improved Distribution

The supply/distribution system consists of two 100 percent capacity halon storage cylinders manifolded into a seismically supported distribution system. The distribution piping terminates with approved (U.L. or F.M.) discharge nozzles located in the SRE room and in each bay of the C43 and C44 panels.

The standard total flooding halon system described in NFPA 12A relies on turbulence created by area discharge nozzles and migration of the halon molecules to assure the desired concentration of halon within electrical enclosures. Additional nozzles located within each bay of panels C43 and C44 are provided to improve the distribution of halon. This arrangement assures extinguishment of any transient or in-situ fire either internal or external before involvement of nearby circuits.

The halon system internal to the cabinets will be designed such that distribution nozzles will not permit the direct impingement of the halon onto the solid state logic modules.

C. CONCLUSION

Within the SRE rooms only panels C43 and C44 require fire protection. The probability of a fire in this room is very low and will further be limited through administrative procedures. The overall probability of a failure of the smoke detection/halon suppression system (1×10^{-4}) coupled with the probability of a fire in the SRE room (2.3×10^{-5}) is 2.3×10^{-9} per reactor year. This very low failure rate supports CPO's proposed request for an exemption from BTP-CMEB 9.5-1 as described in Section II. If a fire should occur, the halon suppression system described will extinguish any transient or in-situ fire, preventing loss of redundant safe shutdown functions.

IV. REFERENCES:

1. Midland Energy Center Probabilistic Risk Assessment; May, 1984; prepared by Pickard, Lowe, and Garrick, Inc.

National Fire Protection Association (NFPA)
2. NFPA 72E; Standard on Automatic Fire Detectors; 1982.
3. NFPA 12A; Standard on Halon 1301 Fire Extinguishing Systems; 1980.
4. Fire Protection Handbook, Fifteenth Edition, Section 18, Chapter 2, pp 18-11 through 18-22, National Fire Protection Association, Quincy, MA, 1981.
5. PRA Procedures Guide NUREG/CR, 2300.
6. S. H. Levinson and M.C. Yeater, "Methodology to Evaluate the Effectiveness of Fire Protective Systems in Nuclear Power Plants," Nuclear Engineering and Design 76(1983), pp 161-182
7. Reactor Safety Study, WASH-1400, 1975

TABLE 1

SAFE SHUTDOWN FUNCTIONS OF CONCERN
WITHIN PANELS C43 and C44*

<u>Panel Number</u>	<u>Circuit Description</u>	<u>Component</u>	<u>Function</u>
C43	Steam Generator Secondary Pressure Sensor/Logics	1PI3134A1	SG A Pressure Indicator
		1PR3134A	SG A Pressure Recorder
		1PI3134A2	SG A Pressure Indicator
		1PI3118B1	SG B Pressure Indicator
		1PR3118B	SG B Pressure Recorder
		1PI3118B2	SG B Pressure Indicator
		2PI3234A1	SG A Pressure Indicator
		2PR3234A	SG A Pressure Recorder
		2PI3234A2	SG A Pressure Indicator
		2PI3218B1	SG B Pressure Indicator
		2PR3218B	SG B Pressure Recorder
		2PI3218B2	SG B Pressure Indicator
C44	Reactor Building Cooling Fans Control Switches and Logic	*VV-57A	RPCAS Start
		*VV-57B	RPCAS Start
		*VV-57C	RBCAS Start
		*VV-57D	RBCAS Start
		*VV-57A	RBCAS Alarm
		*VV-57B	RBCAS Alarm
		*VV-57C	RBCAS Alarm
		*VV-57D	RBCAS Alarm
		*1 for Unit 1 2 for Unit 2	
		Auxiliary Building Safe-guard Chillers Control Switches and Logic	*VM-59A
	*VM-59A		Start Permissives
	*VM-59A		Start
	*VM-59A		Start Circuit
	*VM-59B		Alarm Circuit
	*VM-59B		Start Circuit
*VM-59B	Start		
*1 for Unit 1 2 for Unit 2			
Chilled Water Pumps Control Switches and Logic	*VP-02A	RBSAS Start	
	*VP-02B	RBSAS Start	
	*VP-02C	RBSAS Start	
	*VP-02D	RBSAS Start	
	*VP-02A	ESFAS Start	

TABLE 1

SAFE SHUTDOWN FUNCTIONS OF CONCERN
 WITHIN PANELS C43 and C44
 (Continued)

<u>Panel Number</u>	<u>Circuit Description</u>	<u>Component</u>	<u>Function</u>
		*VP-02B	ESFAS Start
		*VP-02C	ESFAS Start
		*VP-02D	ESFAS Start
		*1 for Unit 1	
		2 for Unit 2	
	CCW Pumps Control Switches and Logic	*P-73A	LOP/ECCAS Start Pump
		*P-73B	LOP/ECCAS Start and Prevent Manual Stop of Pump
			Prevent Automatic Block
		OP-73	LOP/ECCAS Start Pump
		OP-73	LOP/ECCAS Start Pump
			Prevent Automatic Block
		*1 for Unit 1	
		2 for Unit 2	
		0 Shared Both Units	
	Makeup Pumps Control Switches and Logic	*P-58A	LOP/ECCAS Start Pump
		*P-58B	LOP/ECCAS Start Pump
		*P-58C	LOP/ECCAS Start Pump
		*P-58C	LOP/ECCAS Prevent Trip Pump
		*P-58C	LOP/ECCAS Start Pump
		*1 for Unit 1	
		2 for Unit 2	
	AFW Isolation Valves - Control Switches and Logic	1LV-3875A1	AFW Control to SG A
		1LV-3875A2	AFW Control to SG B
		1LV-3875B1	AFW Control to SG B
		1LV-3875B2	AFW Control to SG A
		2LV-3975A1	AFW Control to SG A
		2LV-3975A2	AFW Control to SG B
		2LV-3975B1	AFW Control to SG B
		2LV-3975B2	AFW Control to SG A
	Motor-Driven AFW Pumps - Control Switches and Logic	*V-05A	Start Pump, Override Manual Stop
		*1 for Unit 1	
		2 for Unit 2	

TABLE 1
SAFE SHUTDOWN FUNCTIONS OF CONCERN
WITHIN PANELS C43 and C44
(Continued)

Panel Number	Circuit Description	Component	Function
	AWF Level Control Valve - Control Switch and Logic	1M0-3865A	Open Valve AWF Supply to SG A
		1M0-3865B	Open Valve AWF Supply to SG B
		1M0-3870B	Open Valve AWF Supply to SG B
		1M0-3870A	Open Valve AWF Supply to SG A
		2M0-3965A	Open Valve AWF Supply to SG A
		2M0-3965B	Open Valve AWF Supply to SG B
		2M0-3970B	Open Valve AWF Supply to SG B
		2M0-3970A	Open Valve AWF Supply to SG A
	Service Water Pumps Control Switches and Logic	OP-75A	LOP/ECCAS Start Pump
		OP-75B	LOP/ECCAS Start Pump
		OP-75C	LOP/ECCAS Start Pump
		OP-75D	LOP/ECCAS Start Pump
		OP-75E	LOP/ECCAS Start Pump
		OP-75E	LOP/ECCAS Start Pump
		OP-75E	LOP/ECCAS Start Pump
		OP-75E	LOP/ECCAS Start Pump
	Diesel Generators Control Switches and Logic	*G-11	ESFAS, Start DG A
		*G-11	ESFAS, Start DG B
			Automatic Stop for DG *G11
			Automatic Close for DG *G11
		*G-12	ESFAS, Start DG A
		*G-12	ESFAS, Start DG B
		Prevent Trip from High Jacket Water Temperature	
		Automatic Close for DG *G12	
		Automatic Stop for DG *G12	
		Prevent Trip from High Jacket Water Temperature	
		*1 for Unit 1	
		2 for Unit 2	

*Panels C43 and C44 contain additional safe shutdown functions which are protected by alternative methods.


TABLE 2
 GENERAL FIRE PROTECTION INFORMATION
 SAFETY RELATED EQUIPMENT ROOMS
 FIRE AREA 65A

1.	Auxiliary Building	e1. 659'-0"
2.	Rooms and Construction	
	a. Room Numbers	624 - Unit 1 626 - Unit 2
	b. Wall Height	14'-0"
	c. Wall Length	25'-1 1/2" N&S 16'-8" E&W
	d. Wall Area	351.7 sq ft N&S 233.3 sq ft E&W
	e. Wall Thickness	1'-6" N 3'-0" S 2'-3" E&W
	f. Wall Construction	Concrete all Perimeter Walls 8" Concrete Block Center Divider Wall
	g. Floor and Ceiling Area	419 sq ft per room
	h. Floor Thickness	1'-6" Concrete
	i. Ceiling Thickness	1'-3" Concrete 0'-3" Decking
	j. Total Volume	5,863 cu ft
3.	Ventilation	
	a. Type	Mechanical
	b. Volume	2,000 cfm


TABLE 2

GENERAL FIRE PROTECTION INFORMATION
SAFETY RELATED EQUIPMENT ROOMS
FIRE AREA 65A
(Continued)

4.	Fire Loading	
a.	Room 624	6,170 Btu/sq ft
b.	Room 626	8,388 Btu/sq ft
5.	Fire Protection Features	
a.	Automatic	Total Flooding Halon 1301 Cross Zoned Ionization Detection
b.	Manual	One 15 lb Portable CO ₂ per SRE Room Two 15 lb Portable CO ₂ Main Control Room One 1 1/2" dia 75 ft Fire Hose F.H.C. #18




PROCESS INSTRUMENTATION EQUIPMENT ROOM (FLOOR ELEV 646'-0") SCALE: 1/8" = 1'-0"



DESIGNATES ELEC CHASE FROM ELEV 655'-0"


UNIT 1 SRE ROOM

TI APERTURE CARD





MAIN CONTROL ROOM ARRANGEMENT SCALE: 1/8" = 1'-0"



Also Available On Aperture Card



SECTION A-A SCALE: 1/4" = 1'-0"



UNIT 2 SRE ROOM




NOTES:
 1. CONTROL PANEL DESCRIPTION:

QUOTED ITEMS	CONTROL PANEL (ARRANGEMENT DWS)	DESCRIPTION
UNIT NO.	UNIT NO. 2	COMMON
	OC01(J-748)	NUMBER ONE OPERATOR'S DESK
	IC59 2C59 *	PROGRAMMING FACILITY
	IC57 2C57 *	ATDR DISPLAY GENERATOR SEE NOTE 6
	IC04 2C04	LINE PRINTER
	IC06 2C06	CENTRAL PROCESSING UNIT * SEE NOTE 6
	IC07 2C07 *	ANALOG INPUT PERIPHERAL TERMINATION CABINET (4 BAYS)
	IC60 2C60	COMPUTER INPUT MULTIPLEXER CABINET (5 BAYS)
	IC60 2C60	COMPUTER INPUT MULTIPLEXER CABINET (5 BAYS TOTAL)
	IC60 2C60	LOGIC INPUT/OUTPUT PERIPHERAL TERMINATION CABINET (4 BAYS)
Q	OC10(J-726)	EVAPORATOR & COMMON AUXILIARY CONTROL BENCHBOARD
Q	IC11(J-727) 2C11(J-751)	TURBINE-GENERATOR AND FEEDWATER CONTROL BENCHBOARD
Q	IC12(J-729) 2C12(J-753)	REACTOR COOLANT CONTROL BENCHBOARD
Q	IC13(J-728) 2C13(J-752)	CONTROL ROD DRIVE AND COMPUTER CONTROL BENCHBOARD
Q	IC14(J-730) 2C14(J-754)	ENGINEERED SAFETY FEATURES CONTROL BENCHBOARD
Q	IC15(J-744) 2C15(J-749)	ELECTRICAL VERTICAL PANEL
	IC16 2C16	COMPUTER INPUT MULTIPLEXER CABINET (2 BAYS)
	IC58 2C58	MAGNETIC TAPE UNIT AND PERIPHERAL CONTROLLERS
	IC18 2C18	CONTROL OPERATOR'S DESK AND ALARM TYPER
	IC19 2C19	OC19 * MOVING HEAD DISK UNIT
Q	OC20(J-755)	COMMON AUXILIARY VERTICAL PANEL
Q	IC21(J-736) 2C21(J-740)	TURBINE SUPERVISORY INSTRUMENTATION & TURBINE-GEN AUXILIARIES VERT PNL
Q	IC22(J-735) 2C22(J-742)	BALANCE OF REACTOR COOLANT AND REACTOR AUXILIARIES VERTICAL PANEL
Q	IC23(J-728) 2C23(J-732)	BALANCE OF REACTOR MONITORING VERTICAL PANEL
Q	IC24(J-759) 2C24(J-743)	POST ACCIDENT MONITORING & BALANCE OF ENGINEERED SAFETY FEATURES VERT PNL
Q	IC25(J-745) 2C25(J-747)	ELECTRICAL PROTECTIVE RELAYS VERTICAL PANEL
Q	OC28	REACTOR BUILDUP, MONITOR BANDS AND HYDROGEN MONITORING CONTROL PANEL
Q	IC30 2C30	SAFETY RELATED AUXILIARY RELAY CABINET
Q	IC31 2C31	SAFETY PARAMETER DISPLAY CONSOLE
Q	IC32 2C32	RADIATION MONITORING SYSTEM VERTICAL PANEL
	OC33	ELECTRICAL SYSTEM STATUS DISPLAY PANEL
	IC34 2C34	ANNUNCIATOR TERMINATION CABINET
Q	IC35 2C35	ECCAS CONDITIONING CABINET (ACTUATION CHANNELS A)(B) (2 BAYS)
	OC36	NEPLC DATA ACQUISITION SENSITIVE STATION (CONTEL)
	OC37	ENGINEER'S CONSOLE * SEE NOTE 6
	OC38	SWITCHING TELEMETRY AND CONTROL CABINETS
Q	IC41 2C41	NUCLEAR INSTRUMENTATION AND REACTOR PROTECTION SYSTEM CABINET (SAFETY CHANNELS A, B AND C) (6 BAYS)
Q	IC42 2C42	NUCLEAR INSTRUMENTATION AND REACTOR PROTECTION SYSTEM CABINET (SAFETY CHANNEL D) (2 BAYS)
Q	IC43 2C43	B.O.P. ENGINEERED SAFETY FEATURES CABINET (ANALOG SENSOR CHANNELS 1, 2, 3 & 4) (6 BAYS)
Q	IC44 2C44	B.O.P. ENGINEERED SAFETY FEATURES CABINET (ACTUATION CHANNELS A & B) (6 BAYS)
Q	IC45 2C45	EMERGENCY CORE COOLING ACTUATION SYSTEM CABINET (6 BAYS)
Q	IC46 2C46	ESIS ANALOG CABINET (3 BAYS)
Q	IC47 2C47	ESIS DIGITAL CABINET (3 BAYS)
	IC50 2C50	INTEGRATED CONTROL SYSTEM CABINET (5 BAYS)
	IC51 2C51	NON-NUCLEAR INSTRUMENTATION X CABINET (5 BAYS)
	IC52 2C52	AUXILIARY RELAY CABINET (6 BAYS)
	IC53 2C53	PROCESS INSTRUMENTATION EQUIPMENT CABINET (6 BAYS)
	IC54 2C54	NON-NUCLEAR INSTRUMENTATION Y CABINET (5 BAYS)
	OC55	EVAPORATOR STEAM DEVELOPMENT SYSTEM CABINET (2 BAYS)
	OVM-45	PROCESS INSTRUMENTATION EQUIPMENT ROOM UNIT COOLER
	OVM-62A/B	PROGRAMMING ROOM AIR HANDLING UNIT
	OVM-62C/D	COMPUTER INPUT ROOM AIR HANDLING UNIT
Q	IC146 2C146	B.O.P. SAFETY RELATED INSTRUMENTATION CABINET (4 BAYS)
	OC62	FRONT END PROCESSORS * SEE NOTE 6
	OC218	SEISMIC MONITORING PANEL
	IC219 2C219	LOOSE PARTS MONITORING PANEL
Q	OC318	MAIN CONTROL ROOM FIRE/SMOKE DETECTION PANEL
Q	OC398	HAZARDOUS GAS MONITORING PANEL
	OC403A	RADIATION MONITORING PANEL CRT
	OC403B	RADIATION MONITORING PANEL PRINTER
	3RTY-8482	AREA RADIATION MONITOR LOCAL CONTROL UNIT
Q	IC456 2C456	ESIS ANALOG CABINET (1 BAY)
Q	IC457 2C457	ESIS DIGITAL CABINET (3 BAYS)
Q	IC458 2C458	ESIS ANALOG CABINET (1 BAY)
	OC458	PROCESS STEAM RADIATION MONITORING CRT AND KEYBOARD


- 2 ALL BAYS WITHIN CABINETS ARE NUMBERED FROM LEFT TO RIGHT AS VIEWED FROM THE FRONT
- 3 THIS SPACE IS RESERVED FOR THE SHIFT SUPERVISOR'S DESK NO EQUIPMENT IS TO BE LOCATED IN THIS RESERVED AREA
- 4 DESK MAY BE OFFSET TO IMPROVE VISIBILITY OF THE MAIN CONTROL BOARD
- 5 A MINIMUM SEPARATION OF 2' REQUIRED BETWEEN THE PANELS & A MINIMUM SEPARATION OF 1' REQUIRED BETWEEN PANELS AND WALLS
- 6 * ON "HOLD" PENDING INCORPORATION OF IDCN
7. DELAYED
8. PANEL OPEN IS SET AT 1 1/2" OUT FROM SOUTH SIDE OF W WALL FACE
9. PANEL IC43 IS SEPARATED FROM PANEL IC45 BY A DISTANCE OF 1' - 0"

**MCR GENERAL ARRANGEMENT
 FIGURE 1**

8406070265 -01



**HALON 1301 FIRE PROTECTION SYSTEM
(TYPICAL BOTH UNITS)**



TI
APERTURE
CARD


Also Available On
Aperture Card

STEM

**SRE ROOM
FIRE DETECTION/SUPPRESSION SYSTEM**

FIGURE 3

8406070265-02



No Detection or Suppression is Shown on This Panel Arrangement

**C43 AND C44
PANEL ARRANGEMENT
FIGURE 2**