

||

Duke Power Company
Oconee Nuclear Generation Department
P.O. Box 1439
Seneca, SC 29679

72-4
PDR/LPDR

J.W. HAMPTON
Vice President
(803)885-3499 Office
(704)373-5222 FAX



DUKE POWER

January 14, 1992

U. S. Nuclear Regulatory Comm.
Office of Nuclear Materials Safety
and Safeguards
Div. of Fuel Cycle and Material Saf.
Washington, D.C. 20555

Subject: Oconee Nuclear Station
Docket Nos. 72-04, 50-269, 50-270, 50-287
Independent Spent Fuel Storage Installation (ISFSI)
Final Safety Analysis Report
1992 Update

Pursuant to 10CFR 72.70, please find attached 8 copies of the 1991 Update to the Oconee ISFSI FSAR. This is a complete reissue of the FSAR in the Bookmaster Format and should replace the entire contents of the existing FSAR manual which should either be discarded or clearly marked as superseded.

Revisions effective with this update are marked by a "1" in the left hand margin. The effective date June 30, 1991, is indicated at the bottom of the page.

Very truly yours,

J.W. Hampton
J. W. Hampton

250000

9201270187 920114
PDR ADDCK 05000269
Y PDR


Change: F Brown
PM: F: 1/2

Ltr. Encl
1 0
1 0

NF06
1/1


U. S. Nuclear Regulatory Commission
January 14, 1992
Page 2

J. W. Hampton, being duly sworn, states that he is Vice President of Duke Power Company, Oconee Nuclear Site; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the ISFSI FSAR and that all statements and matter set forth therein are true and correct to the best of his knowledge.



J. W. Hampton, Vice President
Oconee Nuclear Site

Subscribed and sworn to before me this 14th day of January, 1992.



Notary Public

My Commission Expires:

March 3, 1992

Duke Power Company
Wachovia Center
P.O. Box 1007
Charlotte, N.C. 28201-1007

72-4
PDR / LPO



DUKE POWER

January 16, 1992

Subject: Oconee Nuclear Station
Docket Nos. 72-4, 50-269, 50-270, and 50-287
1991 FSAR Revision
Independent Spent Fuel Storage Installation (ISFSI)

The ISFSI FSAR was converted into an electronic publishing format just prior to initiating the 1991 revision cycle. This "converted" FSAR is thus a complete reissue, containing revisions effective as of June 30, 1991. Please discard your copy of the old FSAR, or ensure that it is clearly marked as a superseded document.

The revision line indicator is a "1" in the left hand margin corresponding to the 1991 update. These indicators will remain until they are superseded by subsequent indicators. Next year's revision line indicator will be the number "2".

Our goal is to reduce the costs associated with the maintenance of numerous copies of the ISFSI FSAR by providing it in an electronic format.

R. L. Gill, Jr., Technical System Manager
Regulatory Compliance

By: Helen Froebe
Regulatory Compliance

HAF/onsisfsi

Attachment

~~72-4-270071~~ 14. How many TBRs
F. STURZ
NEAB

TABLE OF CONTENTS

CHAPTER 1. INTRODUCTION AND GENERAL DESCRIPTION OF STORAGE SYSTEM	1-1
1.1 INTRODUCTION	1-3
1.1.1 FIGURES	1-4
1.2 GENERAL DESCRIPTION OF INSTALLATION	1-5
1.2.1 GENERAL DESCRIPTION	1-5
1.2.2 PRINCIPAL SITE CHARACTERISTICS	1-5
1.2.3 PRINCIPAL DESIGN CRITERIA	1-5
1.2.3.1 Structural Features	1-5
1.2.3.2 Decay Heat Dissipation	1-6
1.2.4 OPERATING AND FUEL HANDLING SYSTEMS	1-6
1.2.5 SAFETY FEATURES	1-6
1.2.6 RADIOACTIVE WASTE AND AUXILIARY SYSTEMS	1-6
1.2.7 TABLES	1-7
1.3 GENERAL SYSTEMS DESCRIPTIONS	1-11
1.3.1 SYSTEMS DESCRIPTIONS	1-11
1.3.1.1 DSC Design	1-11
1.3.1.2 Horizontal Storage Module	1-11
1.3.1.3 Transfer Cask	1-12
1.3.1.4 Transfer Trolley	1-12
1.3.1.5 Transfer Cask Skid	1-13
1.3.1.6 Horizontal Hydraulic Ram	1-13
1.3.1.7 System Operation	1-13
1.3.2 TABLES	1-15
1.4 IDENTIFICATION OF AGENTS AND CONTRACTORS	1-17
1.5 MATERIAL INCORPORATED BY REFERENCE	1-19
1.6 REFERENCES	1-21
CHAPTER 2. SITE CHARACTERISTICS	2-1
2.1 GEOGRAPHY AND DEMOGRAPHY	2-3
2.1.1 SITE LOCATION	2-3
2.1.2 SITE DESCRIPTION	2-3
2.1.2.1 Legal Responsibilities for Site	2-3
2.1.2.2 Other Activities Within the Site Boundary	2-3
2.1.2.3 Arrangements for Traffic Control	2-4
2.1.3 POPULATION DISTRIBUTION AND TRENDS	2-4
2.1.3.1 Transient Population	2-5
2.1.4 USES OF NEARBY LAND AND WATERS	2-5
2.1.5 TABLES	2-7
2.1.6 FIGURES	2-9
2.2 NEARBY INDUSTRIAL, TRANSPORTATION, AND MILITARY FACILITIES	2-13
2.2.1 INDUSTRIAL AND MILITARY FACILITIES	2-13
2.2.2 TRANSPORTATION ROUTES	2-13
2.2.2.1 Description of Products and Materials	2-13
2.3 METEOROLOGY	2-15
2.3.1 REGIONAL CLIMATOLOGY	2-15
2.3.2 LOCAL METEOROLOGY	2-15
2.3.2.1 Data Sources	2-15
2.3.2.2 Topography	2-15
2.3.3 ONSITE METEOROLOGICAL MEASUREMENT PROGRAM	2-15

2.3.4	DIFFUSION ESTIMATES	2-17
2.3.4.1	Basis	2-17
2.3.4.2	Calculations	2-17
2.3.5	TABLES	2-18
2.3.6	FIGURES	2-24
2.4	HYDROLOGIC ENGINEERING	2-27
2.4.1	HYDROLOGIC DESCRIPTION	2-27
2.4.1.1	Site and Facilities	2-27
2.4.1.2	Hydrosphere	2-27
2.4.2	FLOODS	2-28
2.4.2.1	Flood History	2-28
2.4.2.2	Flood Design Consideration	2-28
2.4.3	PROBABLE MAXIMUM FLOOD ON STREAMS AND RIVERS	2-30
2.4.3.1	Probable Maximum Precipitation	2-30
2.4.3.2	Runoff and Stream Course Models	2-30
2.4.3.3	Probable Maximum Flood Flow	2-30
2.4.3.4	Coincident Wind Wave Activity	2-30
2.4.4	POTENTIAL DAM FAILURES, SEISMICALLY INDUCED	2-30
2.4.5	FLOODING PROTECTION REQUIREMENTS	2-31
2.4.5.1	Flood Protection Measures for Oconee Station Seismic Class 1 Structures	2-31
2.4.5.2	Flood Protection Measures for ISFSI Site	2-31
2.4.6	ENVIRONMENTAL ACCEPTANCE OF EFFLUENTS	2-31
2.4.7	SUBSURFACE HYDROLOGY	2-31
2.4.7.1	Groundwater Usage	2-31
2.4.7.2	Regional Groundwater Conditions	2-32
2.4.7.3	Groundwater Quality	2-33
2.4.7.4	Program of Investigation	2-34
2.4.7.5	Groundwater Conditions Due to Keowee Reservoir	2-34
2.4.8	TABLES	2-36
2.4.9	FIGURES	2-38
2.5	GEOLOGY AND SEISMOLOGY	2-43
2.5.1	BASIC GEOLOGIC AND SEISMIC INFORMATION	2-43
2.5.1.1	Regional Geology	2-43
2.5.1.2	Site Geology	2-44
2.5.2	VIBRATORY GROUND MOTION	2-46
2.5.2.1	Earthquake History	2-46
2.5.2.2	Geologic Structures and Tectonic Activity	2-47
2.5.2.3	Correlation of Earthquake Activity with Geologic Structures or Tectonic Provinces	2-49
2.5.2.4	Maximum Earthquake Potential	2-49
2.5.2.5	Seismic Wave Transmission Characteristics of the Site	2-50
2.5.2.6	Maximum Hypothetical Earthquake (MHE)	2-50
2.5.2.7	Design Base Earthquake	2-50
2.5.2.8	Design Response Spectra	2-50
2.5.3	SURFACE FAULTING	2-50
2.5.4	SUBSURFACE MATERIALS	2-50
2.5.4.1	Exploration	2-51
2.5.4.2	Groundwater Conditions	2-51
2.5.5	ISFSI FOUNDATION	2-51
2.5.6	LIQUEFACTION	2-52
2.5.7	SLOPE STABILITY	2-52
2.5.8	TABLES	2-54
2.5.9	FIGURES	2-60

2.6 REFERENCES	2-87
CHAPTER 3. PRINCIPAL DESIGN CRITERIA	3-1
3.1 PURPOSE OF THE OCONEE ISFSI	3-3
3.1.1 MATERIAL TO BE STORED	3-3
3.1.1.1 Physical Characteristics	3-3
3.1.1.2 Reactivity Characteristics	3-3
3.1.1.3 Thermal Characteristics	3-3
3.1.1.4 Radiological Characteristics	3-4
3.1.2 GENERAL OPERATING FUNCTIONS	3-4
3.1.2.1 Overall Functions of the Facility	3-4
3.1.2.2 Handling and Transfer Equipment	3-4
3.1.3 TABLES	3-6
3.2 DESIGN CRITERIA FOR ENVIRONMENTAL CONDITIONS AND NATURAL PHENOMENA	3-7
3.2.1 TORNADO AND WIND LOADINGS	3-7
3.2.1.1 Applicable Design Parameters	3-7
3.2.1.2 Determination of Forces on Structures	3-7
3.2.1.3 Tornado Generated Missiles	3-8
3.2.1.4 Ability of Structures to Perform	3-8
3.2.2 WATER LEVEL (FLOOD) DESIGN	3-10
3.2.3 SEISMIC DESIGN	3-10
3.2.3.1 Input Criteria	3-10
3.2.3.2 Seismic System Analysis	3-11
3.2.4 SNOW AND ICE LOADS	3-11
3.2.5 COMBINED LOAD CRITERIA	3-11
3.2.6 TABLES	3-12
3.3 SAFETY PROTECTION SYSTEM	3-13
3.3.1 GENERAL	3-13
3.3.2 PROTECTION BY MULTIPLE CONFINEMENT BARRIERS AND SYSTEMS	3-13
3.3.2.1 Confinement Barriers and Systems	3-13
3.3.2.2 Ventilation - Offgas	3-14
3.3.3 PROTECTION BY EQUIPMENT AND INSTRUMENTATION SELECTION	3-14
3.3.3.1 Equipment	3-14
3.3.3.2 Instrumentation	3-15
3.3.4 NUCLEAR REACTOR QUALITY SAFETY	3-15
3.3.4.1 Core Management for Prevention of Criticality	3-15
3.3.4.2 Error Contingency Criteria	3-16
3.3.4.3 Verification Analysis	3-16
3.3.5 RADIOLOGICAL PROTECTION	3-17
3.3.6 FIRE AND EXPLOSION PROTECTION	3-18
3.3.7 MATERIALS HANDLING AND STORAGE	3-18
3.3.8 TABLES	3-19
3.4 SUMMARY OF STORAGE SYSTEM DESIGN CRITERIA	3-21
3.5 REFERENCES	3-23
CHAPTER 4. STORAGE SYSTEM	4-1
4.1 LOCATION AND LAYOUT	4-3
4.1.1 FIGURES	4-5
4.2 STORAGE SITE	4-7
4.2.1 STRUCTURES	4-7
4.2.2 STORAGE SITE LAYOUT	4-7

4.2.3 HSM DESCRIPTION	4-7
4.2.4 INSTRUMENTATION SYSTEM DESCRIPTION	4-8
4.2.5 FIGURES	4-9
4.3 TRANSFER SYSTEM	4-11
4.3.1 FUNCTION	4-11
4.3.2 COMPONENTS	4-11
4.3.2.1 Transfer Cask	4-11
4.3.2.2 Dry Storage Canister (DSC)	4-11
4.3.2.3 Transfer Cask Skid	4-12
4.3.2.4 Transfer Trailer	4-12
4.3.2.5 Skid Positioning System	4-13
4.3.2.6 Hydraulic Ram System (HRS) Description	4-13
4.3.3 DESIGN BASES AND SAFETY ASSURANCE	4-14
4.3.3.1 Transfer Cask	4-14
4.3.3.2 Transfer Cask Skid	4-14
4.3.3.3 Transfer Trailer	4-14
4.3.3.4 Skid Positioning System (SPS)	4-14
4.3.3.5 Hydraulic Ram	4-16
4.3.3.6 Other Equipment	4-17
4.3.3.7 Qualification of Components	4-18
4.3.3.8 Maintenance of HRS and SPS	4-18
4.3.4 TABLES	4-19
4.4 OPERATING SYSTEMS	4-21
4.4.1 LOADING AND UNLOADING SYSTEM	4-21
4.4.1.1 Preparation for Fuel Loading	4-21
4.4.1.2 Spent Fuel Selection	4-22
4.4.1.3 Spent Fuel Loading	4-22
4.4.1.4 DSC Drying, Backfilling, and Sealing	4-23
4.4.1.5 DSC Unloading	4-23
4.4.2 DECONTAMINATION SYSTEM	4-23
4.4.3 DSC K...AIR AND MAINTENANCE	4-24
4.4.4 TRANSFER CASK REPAIR AND MAINTENANCE	4-24
4.4.5 UTILITY SUPPLIES AND SYSTEMS	4-24
4.4.6 OTHER SYSTEMS	4-24
4.4.6.1 Communications and Alarm System	4-24
4.4.6.2 Fire Protection System	4-25
4.4.6.3 Maintenance System	4-25
4.5 FIGURES	4-26
4.5.1 CLASSIFICATION OF STRUCTURES, SYSTEMS, AND COMPONENTS	4-31
4.5.1.1 TRANSFER CASK	4-31
4.5.1.2 DRY STORAGE CANISTER	4-32
4.5.1.3 HORIZONTAL STORAGE MODULE	4-32
4.5.1.4 FOUNDATION	4-32
4.5.1.5 TRANSFER COMPONENTS	4-32
4.5.1.6 INSTRUMENTATION	4-33
4.5.1.7 TABLES	4-34
4.6 DECOMMISSIONING PLAN	4-35
4.7 REFERENCES	4-37
CHAPTER 5. STORAGE SYSTEM OPERATIONS	5-1
5.1 OPERATION DESCRIPTION	5-3
5.1.1 NARRATIVE DESCRIPTION	5-3

5.1.1.1 Loading of the DSC into the HSM	5-3
5.1.1.2 Monitoring Operations	5-4
5.1.1.3 Fuel Identification and Accountability	5-4
5.1.1.4 Unloading the DSC from the HSM	5-4
5.1.2 FLOW SHEET	5-5
5.1.3 IDENTIFICATION OF SUBJECTS FOR SAFETY ANALYSIS	5-5
5.1.3.1 Criticality Prevention	5-5
5.1.3.2 Instrumentation	5-5
5.1.3.3 Maintenance Techniques	5-5
5.1.3.4 Administrative Controls to Limit DBT Effects	5-6
5.1.4 FIGURES	5-7
5.2 CONTROL ROOM AND CONTROL AREAS	5-13
5.3 REFERENCES	5-15
CHAPTER 6. WASTE MANAGEMENT	6-1
CHAPTER 7. RADIATION PROTECTION	7-1
7.1 ENSURING THAT OCCUPATIONAL RADIATION EXPOSURES ARE ALARA	7-3
7.1.1 POLICY & ORGANIZATIONAL CONSIDERATIONS	7-3
7.1.2 DESIGN CONSIDERATIONS	7-5
7.1.3 ALARA OPERATIONAL CONSIDERATIONS	7-7
7.2 RADIATION SOURCES	7-9
7.2.1 CHARACTERIZATION OF SOURCES	7-9
7.2.2 AIRBORNE RADIOACTIVE MATERIAL SOURCES	7-9
7.2.3 TABLES	7-10
7.3 RADIATION PROTECTION DESIGN FEATURES	7-11
7.3.1 INSTALLATION DESIGN FEATURES	7-11
7.3.2 SHIELDING	7-11
7.3.2.1 Radiation Shielding Design Features	7-11
7.3.2.2 Shielding Analysis	7-12
7.3.3 TABLES	7-13
7.3.4 FIGURES	7-15
7.4 ESTIMATED ON-SITE COLLECTIVE DOSE ASSESSMENT	7-17
7.4.1 OPERATIONAL DOSE ASSESSMENT	7-17
7.4.2 STORAGE TERM DOSE ASSESSMENT	7-18
7.4.3 TABLES	7-19
7.4.4 FIGURES	7-24
7.5 RADIATION PROTECTION PROGRAM	7-29
7.6 ENVIRONMENTAL MONITORING PROGRAM	7-31
7.7 ESTIMATED OFF-SITE COLLECTIVE DOSES	7-33
7.8 REFERENCES	7-35
CHAPTER 8. ACCIDENT ANALYSES	8-1
8.1 OFF-NORMAL OPERATIONS	8-3
8.1.1 JAMMED DSC DURING LOADING OR UNLOADING	8-3
8.1.1.1 Postulated Cause of Jammed DSC	8-3
8.1.1.2 Detection of Jammed DSC	8-3
8.1.1.3 Analysis of Effects and Consequences	8-3
8.1.1.4 Corrective Actions	8-3
8.1.2 RADIOLOGICAL IMPACT OF OFF-NORMAL OPERATIONS	8-4
8.2 ACCIDENTS	8-5
8.2.1 LOSS OF AIR OUTLET SHIELDING	8-5

8.2.1.1 Cause of Accident	8-5
8.2.1.2 Accident Analysis	8-5
8.2.1.3 Accident Dose Consequences	8-6
8.2.2 TORNADO TORNADO MISSILE	8-6
8.2.2.1 Cause of Accident	8-6
8.2.2.2 Accident Analysis	8-6
8.2.2.3 Accident Dose Consequences	8-6
8.2.3 EARTHQUAKE	8-6
8.2.3.1 Cause of Accident	8-7
8.2.3.2 Accident Analysis	8-7
8.2.3.3 Accident Dose Consequences	8-7
8.2.4 CASK DROP	8-7
8.2.4.1 Cause of Accident	8-7
8.2.4.2 Accident Analysis	8-7
8.2.4.3 Accident Dose Consequences	8-7
8.2.5 TRANSFER CASK LOSS OF NEUTRON SHIELD	8-7
8.2.5.1 Postulated Cause of Solid Shield Loss	8-8
8.2.5.2 Detection of Shield Material Loss	8-8
8.2.5.3 Analysis of Effects and Consequences	8-8
8.2.6 LIGHTNING	8-8
8.2.6.1 Cause of Accident	8-8
8.2.6.2 Accident Analysis	8-8
8.2.6.3 Accident Dose Consequences	8-9
8.2.7 BLOCKAGE OF AIR INLETS AND OUTLETS	8-9
8.2.7.1 Cause of Accident	8-9
8.2.7.2 Accident Analysis	8-10
8.2.7.3 Accident Dose Consequences	8-10
8.2.8 DRY STORAGE CANISTER LEAKAGE	8-10
8.2.8.1 Cause of Accident	8-10
8.2.8.2 Accident Analysis	8-10
8.2.8.3 Accident Dose Consequences	8-11
8.2.9 ACCIDENTAL PRESSURIZATION OF DSC	8-11
8.2.9.1 Cause of Accident	8-11
8.2.9.2 Accident Analysis	8-11
8.2.9.3 Accident Dose Calculations	8-11
8.2.10 LOAD COMBINATIONS	8-11
8.2.10.1 Cause of Accident	8-12
8.2.10.2 Accident Analysis	8-12
8.2.10.3 Accident Dose Consequences	8-12
8.2.11 FLOODING	8-12
8.2.12 EXPLOSIONS	8-12
8.2.12.1 Cause of Accident	8-12
8.2.12.2 Accident Analysis	8-12
8.2.12.3 Accident Dose Consequences	8-12
8.2.13 TABLES	8-13
8.3 SITE CHARACTERISTICS AFFECTING SAFETY ANALYSIS	8-15
8.4 REFERENCES	8-17
CHAPTER 9. CONDUCT OF OPERATIONS	9-1
9.1 ORGANIZATIONAL STRUCTURE	9-3
9.1.1 CORPORATE ORGANIZATION	9-3
9.1.1.1 Corporate Functions, Responsibilities and Authorities	9-3

9.1.1.2 Applicant's In-House Organization	9-3
9.1.1.3 Interrelationship with Contractors and Suppliers	9-3
9.1.1.4 Applicant's Technical Staff	9-3
9.1.2 OPERATING ORGANIZATION, MANAGEMENT, AND ADMINISTRATIVE CONTROL SYSTEM	9-4
9.1.2.1 Onsite Organization	9-4
9.1.2.2 Personnel Functions, Responsibilities and Authorities	9-4
9.1.3 PERSONNEL QUALIFICATION REQUIREMENTS	9-4
9.1.3.1 Minimum Qualification Requirements	9-4
9.1.3.2 Qualifications of Personnel	9-4
9.1.4 LIAISON WITH OTHER ORGANIZATIONS	9-1
9.1.5 FIGURES	9-5
9.2 PREOPERATIONAL TESTING AND OPERATION	9-7
9.2.1 ADMINISTRATIVE PROCEDURES FOR CONDUCTING TEST PROGRAM	9-7
9.2.2 TEST PROGRAM DESCRIPTION	9-7
9.2.2.1 Operations	9-7
9.2.3 TEST DISCUSSION	9-8
9.3 TRAINING PROGRAM	9-9
9.3.1 TRAINING FOR OPERATIONS PERSONNEL	9-9
9.3.2 TRAINING FOR MAINTENANCE PERSONNEL	9-9
9.3.3 TRAINING FOR RADIATION PROTECTION PERSONNEL	9-9
9.3.4 TRAINING FOR SECURITY PERSONNEL	9-9
9.4 NORMAL OPERATIONS	9-11
9.4.1 PROCEDURES	9-11
9.4.2 RECORDS	9-11
9.5 EMERGENCY PLANNING	9-13
9.6 PHYSICAL SECURITY PLAN	9-15
9.7 REFERENCES	9-17
CHAPTER 10: OPERATING CONTROLS AND LIMITS	10-1
10.1 PROPOSED OPERATING CONTROLS AND LIMITS	10-3
10.2 DEVELOPMENT OF OPERATING CONTROLS AND LIMITS	10-5
10.2.1 FUNCTIONAL AND OPERATING LIMITS, MONITORING INSTRUMENTS AND LIMITING CONTROL SETTINGS	10-5
10.2.2 LIMITING CONDITIONS FOR OPERATION	10-5
10.2.2.1 Equipment	10-5
10.2.2.2 Technical Conditions And Characteristics	10-5
10.2.3 SURVEILLANCE REQUIREMENTS	10-6
10.2.4 DESIGN FEATURES	10-6
10.2.5 ADMINISTRATIVE CONTROLS	10-6
10.2.5.1 Qualification of Spent Fuel	10-6
10.2.5.2 Spent Fuel Identification	10-7
10.3 OPERATIONAL CONTROL AND LIMIT SPECIFICATION	10-9
10.3.1 FIGURES	10-10
10.4 REFERENCES	10-11
CHAPTER 11: QUALITY ASSURANCE	11-1

LIST OF TABLES

1-1.	Design Parameters for the Oconee ISFSI	1-7
1-2.	Summary of ISFSI Fuel Handling Operations	1-9
1-3.	Primary Design Parameters for the ISFSI Transport Systems	1-10
1-4.	Major Systems, Subsystems and Components of the Oconee ISFSI	1-15
2-1.	1970 Population Distribution 0-10 Miles	2-7
2-2.	Population Projection for Oconee Nuclear Station for the Year 2020	2-8
2-3.	Joint Frequencies of Wind Direction and Speed by Stability Class	2-18
2-4.	Soil Permeability Test Results	2-37
2-5.	Significant Earthquakes in the Southeast United States (Intensity V or Greater)	2-55
3-1.	Physical Characteristics of PWR Fuel Assemblies Based on Nominal Design	3-6
3-2.	Transfer Cask Stress Analysis for Tornado Effects	3-12
3-3.	Oconee ISFSI Major Components and Functions	3-19
3-4.	Oconee ISFSI Radioactive Material Confinement Barriers	3-20
3-5.	Oconee ISFSI Major Components and Design Requirements	3-20
4-1.	ONS ISFSI Project Transfer Trailer Design Parameters	4-19
4-2.	Oconee ISFSI Major Components and Classification	4-34
7-1.	Gamma Energy Spectrum	7-10
7-2.	Shielding Analysis Results	7-14
7-3.	Summary of Estimated On-Site Doses Resulting from ISFSI Operations ⁽¹⁾	7-19
7-4.	Dose Estimate for Construction of Additional Horizontal Storage Modules Based on Labor Estimates for 2 X 10 Array	7-22
7-5.	Neutron and Gamma Energy Spectra	7-23
8-1.	Comparison of Total Dose Rates for HSM With and Without Air Outlet Shielding Blocks	8-13
8-2.	Cask Drop Target Parameters	8-13

LIST OF FIGURES

	1-1.	Location of ISFSI	1-4
	2-1.	General Location	2-9
	2-2.	Site Plan	2-10
	2-3.	ISFSI Layout	2-11
	2-4.	Topography Within 5 Miles	2-24
1	2-5.	Relative Positions of Meteorological Instruments	2-25
1	2-6.	Relative Elevations of Meteorological Instruments	2-26
	2-7.	Areal Groundwater Survey	2-38
	2-8.	Groundwater Survey at Station Site	2-39
	2-9.	Well Permeameter Test Apparatus	2-40
	2-10.	Formulae For Determining Permeability	2-41
	2-11.	General Site Area	2-60
	2-12.	Site Boring Plan	2-61
	2-13.	Core Boring Record	2-62
	2-14.	Core Boring Record	2-64
	2-15.	Core Boring Record	2-66
	2-16.	Core Boring Record	2-67
	2-17.	Core Boring Record	2-68
	2-18.	Core Boring Record	2-70
	2-19.	Core Boring Record	2-72
	2-20.	Core Boring Record	2-74
	2-21.	Core Boring Record	2-76
	2-22.	Core Boring Record	2-78
	2-23.	Core Boring Record	2-79
	2-24.	Core Boring Record	2-81
	2-25.	Core Boring Record	2-83
	2-26.	Core Boring Record	2-85
	2-27.	ISFSI Foundation Profile	2-86
	4-1.	Site Layout and Route	4-5
	4-2.	Site Plan	4-9
	4-3.	Transfer Cask Lift Beam	4-26
	4-4.	Crane Hook Lift Adaptor	4-27
	4-5.	Spent Fuel Pool Area	4-28
	4-6.	Spent Fuel Pool Area	4-29
	4-7.	Spent Fuel Pool Area	4-30
	5-1.	NUHOMS System Loading Operations Flowchart	5-7
	5-2.	NUHOMS System Loading Operations Flowchart	5-8
	5-3.	NUHOMS System Loading Operations Flowchart	5-9
	5-4.	NUHOMS System Loading Operations Flowchart	5-10
	5-5.	NUHOMS System Loading Operations Flowchart	5-11
	5-6.	NUHOMS System Loading Operations Flowchart	5-12
	7-1.	Location of Dose Pates	7-15
	7-2.	Dose Rate Versus Distance From Surface of HSM	7-24
	7-3.	Dose From Filled HSM Array	7-25
	7-4.	Dose From Filled HSM Array	7-26
	7-5.	Radiation Zone Map of Module Surface Dose Rates	7-27
1	9-1.	Deleted	9-5
	10-1.	Fuel Assembly Acceptance Criteria Cooling Period > 10 Years	10-10

LIST OF ABBREVIATIONS

ACI	AMERICAN CONCRETE INSTITUTE
APM	ADMINISTRATIVE POLICY MANUAL
AFR	AWAY-FROM-REACTOR
AISC	AMERICAN INSTITUTE OF STEEL CONSTRUCTION
ALARA	AS LOW AS REASONABLY ACHIEVABLE
ANSI	AMERICAN NATIONAL STANDARDS INSTITUTE
AWS	AMERICAN WELDING STANDARDS
CFR	CODE OF FEDERAL REGULATIONS
DBT	DESIGN BASIS TORNADO
DOE	DEPARTMENT OF ENERGY
DPC	DUKE POWER COMPANY
DSC*	DRY STORAGE CANISTER
EPRI	ELECTRIC POWER RESEARCH INSTITUTE
EPZ	EMERGENCY PLANNING ZONE
ESF	ENGINEERED SAFETY FEATURE
ETQS	EMPLOYEE TRAINING AND QUALIFICATION SYSTEM
FEMA	FEDERAL EMERGENCY MANAGEMENT ADMINISTRATION
FSAR	FINAL SAFETY ANALYSIS REPORT
HSM	HORIZONTAL STORAGE MODULE
HRS	HYDRAULIC RAM SYSTEM
IFA	IRRADIATED FUEL ASSEMBLY
ISFSI	INDEPENDENT SPENT FUEL STORAGE INSTALLATION
IWM	LIQUID WASTE MANAGEMENT
MHE	MAXIMUM HYPOTHETICAL EARTHQUAKE
MRS	MONITORED RETRIEVABLE STORAGE
NDE	NONDESTRUCTIVE EXAMINATION
1 NEPA	NATIONAL ENVIRONMENTAL POLICY ACT
NRC	NUCLEAR REGULATORY COMMISSION
NUHOMS-24P	NUTTECH ENGINEERS, INC. HORIZONTAL MODULAR STORAGE
NUREG	NUCLEAR REGULATORY GUIDE
POR	PRUDENT OPERATING RESERVE
PWR	PRESSURIZED WATER REACTOR
ONS	OCONEE NUCLEAR STATION
SPS	SKID POSITIONING SYSTEM
VA	VENTILATION AIR SYSTEM
VR	STATION VOLUME REDUCTION SYSTEM
NWPA	WASTE POLICY ACT OF 1982, AS AMENDED

* The term Dry Storage Canister (DSC) in this report refers to the same item termed dry shielded canister in the Nutech Topical Report referenced in this SAR.

**CHAPTER 1. INTRODUCTION AND GENERAL DESCRIPTION
OF STORAGE SYSTEM**

1.1 INTRODUCTION

Duke Power Co. began commercial operation of the Oconee Nuclear Station, Units 1, 2, and 3 on July 15, 1973, September 9, 1974 and December 16, 1974 respectively. Since then these three 2568 MWt units have generated millions of KWH in a safe and reliable manner. In so doing, these units have discharged a total of approximately 2100 spent fuel assemblies. These assemblies are currently being stored in two onsite pools and in the McGuire Nuclear Station spent fuel pools. The need to provide additional onsite storage facilities to permit continued operation is discussed in 9, 10, and 11 of the Environmental Report (Reference 1 on page 1-21) submitted as part of the Oconee Independent Spent Fuel Storage Installation (ISFSI) license application.

To support this need and provide storage until the Department of Energy (DOE) begins to accept title to spent fuel under the requirements of the Nuclear Waste Policy Act of 1982, as amended in 1987, Duke Power is requesting permission to build and operate an ISFSI in compliance with 10CFR 72. Duke Power has chosen the NUHOMS-24P dry storage system designed by Nutech Engineers, Inc. to be used on the Oconee site. The NUHOMS-24P system is more fully described in Revision 1A of the Topical Report for the NUHOMS-24P system submitted by Nutech Engineers, Inc. in July 1988 and accepted by the NRC on April 21, 1989. The location of the ISFSI on the Oconee site is shown on Figure 1-1 on page 1-4.

The NUHOMS-24P system provides long-term interim storage for irradiated fuel assemblies. The fuel assemblies are confined in a helium atmosphere by a stainless steel canister. The canister is protected and shielded by a massive concrete module. Decay heat is removed by thermal radiation, conduction and convection from the canister to an air plenum inside the concrete module. Air flows through this internal plenum by natural draft convection.

The canister containing twenty-four irradiated fuel assemblies is transferred from the spent fuel pool to the concrete module in a transfer cask. The cask is precisely aligned and the canister is inserted into the module by means of a hydraulic ram.

The NUHOMS-24P system is a totally passive installation that is designed to provide shielding and safe confinement of irradiated fuel. The dry storage canister and horizontal storage module have been designed to withstand certain accidents as described in this SAR.

The fuel assemblies to be stored in the ISFSI are currently located in the Oconee spent fuel pools and were irradiated in the Oconee reactors. Twenty-four fuel assemblies are stored in each dry storage canister, and one dry storage canister is stored in each concrete module. The license application requests a license to construct and operate a total of eighty-eight modules (2112 assemblies). These modules will be built incrementally, as needed, to match the requirements for additional storage. Operation of the facility will continue past the first year for up to 20 years under the initial license and continue under license extension as necessary until the fuel can be shipped to a permanent repository. As defined in Table 1.2-2 of Reference 2 on page 1-21 the minimum service life of the facility is 50 years. During this service life, while any given HSM could be unloaded and later reloaded with a new DSC, reloading a given DSC following removal of the original fuel assemblies is not anticipated due to the potential destructive nature of the top end shield plug removal process. However, enhanced techniques may be developed which prevent DSC damage during plug removal. Eventual reuse of the HSMs will depend upon the schedule and restrictions for spent fuel deliveries to DOE under the NWPA.

1.1.1 FIGURES




Figure 1-1.
Location of ISFSI

1.2 GENERAL DESCRIPTION OF INSTALLATION

1.2.1 GENERAL DESCRIPTION

The ISFSI provides for the horizontal, dry storage of irradiated fuel assemblies (IFAs) in a concrete module. The principal components are a concrete horizontal storage module (HSM) and a stainless steel dry storage canister (DSC) with an internal basket which holds the IFAs. Each HSM contains one DSC and each DSC contains twenty-four fuel assemblies.

Despite DOE's obligations under the original Nuclear Waste Policy Act of 1982, Duke Power's current best estimate for receiving spent fuel storage relief under the Nuclear Waste Policy Amendments Act of 1987 is the year 2010 at the earliest. Oconee's prudent storage requirements through 2003 will necessitate the construction of 72 HSMs. This application, however, is for construction and use of up to eighty-eight HSMs. This additional margin of 16 HSMs will provide the minimum storage capacity needed to carry the Oconee Nuclear Station to its end of operating life if necessary.

The initial phase of construction including twenty modules was completed in May 1990. Additional modules will be added as required on separate foundations without impact to the preceding or succeeding modules. Analyses for structural and foundation requirements provide for constructing modules in any array size between a single HSM and a 10x2 array (2 rows of 10 modules back to back).

In addition to these primary components, the Oconee ISFSI also requires transfer equipment to move the DSCs from the spent fuel pool (where they are loaded with the IFAs) to the HSMs where they are stored. This transfer system consists of a transfer cask, a hydraulic ram, a truck, a trailer and a cask skid. This transfer system will interface with the existing Oconee spent fuel pool, the cask crane, the site layout (i.e., roads and topography) and other procedural requirements.

1.2.2 PRINCIPAL SITE CHARACTERISTICS

The ISFSI is located on the Oconee Nuclear Station site near Seneca, South Carolina. Duke Power Company owns and operates three 2568 MWt nuclear generating units on the Oconee site. The ISFSI is located outside the protected area but within the owner controlled area approximately 100 ft. west of the Station's condenser cooling water intake structure (Figure 1-1 on page 1-4).

1.2.3 PRINCIPAL DESIGN CRITERIA

The principal design criteria and parameters for the Oconee ISFSI are shown in Table 1-1 on page 1-7. The radiation sources are for the reference fuel assembly. For the majority of the fuel to be stored, the radiation sources will be less than or equal to the sources described in the NUHOMS-24P Topical Report (Reference 2 on page 1-21). For radiation sources larger than the sources described in Reference 2 on page 1-21 restrictive measures will be used to ensure surface dose rates that are ALARA and below design basis limits.

1.2.3.1 Structural Features

The HSM is a low profile reinforced concrete structure designed to withstand normal operating loads, the abnormal loads created by seismic activity, tornados and other natural events and the postulated accidental loads which may occur during operation.

The structural features of the DSC are defined, to a large extent, by the cask drop accident. The DSC body, the double seal welds on each end, and the DSC internals are designed to provide for fuel retrieval after a postulated maximum credible drop.

1.2.3.2 Decay Heat Dissipation

The decay heat of the IFAs is removed from the DSC by natural draft convection. Air enters the lower part of the HSM, rises around the DSC and exits through the top shielding slab. The flow cross-sectional area is designed to provide adequate air flow from the draft height of the HSM and the inlet and outlet air temperature differences for the hottest day conditions (i.e., 46.7°C or 116°F).

1.2.4 OPERATING AND FUEL HANDLING SYSTEMS

The major operating systems of the ISFSI are those required for fuel handling and transport of the fuel from the spent fuel pool to the ISFSI. General operations are outlined in Table 1-2 on page 1-9 and the primary design parameters of the required systems are listed in Table 1-3 on page 1-10. The majority of the fuel handling operations involving the transfer cask (i.e., fuel loading, drying, trailer loading, etc.) utilize standard techniques at Oconee for spent fuel shipment. The remaining operations (seal welding, transfer cask-HSM alignment, and DSC transfer) are unique to the ISFSI.

1.2.5 SAFETY FEATURES

The principal safety feature of the ISFSI is the containment provided by the DSC and the concrete shielding of the HSM. In addition to its structural and missile protection functions, this shielding reduces the gamma and neutron flux emanating from the IFAs inside a DSC so that the average outside surface dose rate on the HSM is less than 20 mR/hr. Additional ISFSI features include:

1. Filling the annulus between the DSC and transfer cask with demineralized water and sealing it prior to lowering them into the spent fuel pool - Prevents contamination of the DSC exterior by pool water.
2. Internal shield blocks inside the HSM which comprise the shielded ventilation plenum - Reduces scatter dose out of the air inlet.
3. External shield blocks on the HSM roof - Reduces scatter dose out of the air outlet.
4. Shield plugs on the DSC - Reduces dose during DSC drying, helium filling and seal welding.
5. Double seal welds on each end of the DSC - Prevents leakage of radioactive gases or particulates if the fuel rods should fail.

1.2.6 RADIOACTIVE WASTE AND AUXILIARY SYSTEMS

Because of the passive nature of the ISFSI, there are no radioactive waste or auxiliary systems required during normal storage operations. There are, however, some waste and auxiliary systems required during DSC loading, drying and transfer into the module. The Oconee waste systems handle the fuel pool water and air which are vented from the DSC during drying. Auxiliary handling systems (such as hydraulic pressure control, alignment, crane, etc.) are also required during the loading and transfer operation.

1.2.7 TABLES

Table 1-1 (Page 1 of 2). Design Parameters for the Oconee ISFSI

GENERAL DESIGN REQUIREMENTS

- Maximum weight on crane hook	100 tons
- Capacity (Casks/Canister)	24 PWR Assys
- Maximum assembly weight	1682 lbs.
- Reference Fuel Assembly parameters:	
a) Nominal burnup	40,000 MWD/MTU
b) Initial Enrichment (Maximum)	4.0%
c) Maximum initial Uranium Content	472 kg assembly
d) Cooling Time	10 years nominal
e) Fuel Rod Array	15 x 15
- Fuel Cell Envelope (Minimum)	8.75-8.85 in.
- Effective multiplication factor	$K_{eff} < 0.95$
- Internal DSC atmosphere	Inert Gas (Helium)
- Ambient temperature	-30°F to 116°F
- Solar heat load (Maximum)	127 BTU/hr-ft ²
- Average doses at HSM surface during storage	20 mR/hr combined gamma and neutron
- Maximum Axial Midplane Dose at Transfer Cask Surface during Transport ¹	200 mR/hr combined gamma and neutron
- Maximum Loading Height (Fuel Pool)	15'-6" above pool floor
- Storage orientation	Horizontal
- Normal Operating Equilibrium Clad Temperature	340°C
- Assume Credit for Burnup for Criticality Computations ²	Based on 1.45% Initial Enrichment equivalent.
- Accessible with Fuel Mast	

Table 1-1 (Page 2 of 2). Design Parameters for the Oconee ISFSI

- Maximum Assembly Length (Includes Radiation Growth and Control Components)	173 in.
- Active Fuel Length	144 in.

Note:

- 1 1. Licensing basis design calculations assume a homogeneous source over the active fuel region (See Section 7.2.1, "Characterization of Sources" on page 7-9). Elevated dose rates in excess of 200 mrem/hr over limited areas of the transfer cask surface may be observed. In particular, elevated gamma dose rates in excess of 200 mrem/hr, centered on fuel assembly end fittings, can be anticipated based on initial DSC loading dose rate survey data. Supplementary shielding calculations performed subsequent to ISFSI operation demonstrate dose rates as high as 565 mrem/hr centered on fuel or near assembly end fittings can be anticipated.
 - 1 2. Primary licensing basis criticality control design feature is credit for 1810 ppm soluble boron in DSC cavity during wet loading operations. Fuel assembly initial enrichment burnup qualification procedures provide additional criticality safety margin.
-

Table 1-2. Summary of ISFSI Fuel Handling Operations

1. Clean the DSC, if necessary, and Load it into the Transfer Cask
 2. Fill the DSC with borated water and Transfer Cask annulus with demineralized water
 3. Install the Inflatable Annulus Seal to seal the Cask/DSC annulus
 4. Lift the Transfer Cask Containing the DSC into the Spent Fuel Pool
 5. Load the Fuel into the DSC
 6. Place the Top Lead Shield Plug on the DSC
 7. Lift the Transfer Cask Containing the Filled DSC out of the Spent Fuel Pool and Place it in the Decon Pit.
 8. Remove the annulus seal.
 9. Lower the water level in the DSC transfer cask annulus to approximately 5 to 10 inches below the top of the DSC shell.
 10. Lower the water level in the DSC to approximately 4 inches below bottom surface of the top shield plug.
 11. Seal Weld the Top End Shield Plug onto the DSC Body and perform NDE.
 12. Evacuate and Dry the DSC
 13. Backfill the DSC with Helium
 14. Seal Weld Covers for the Drain and Vent Line of the DSC and perform NDE
 15. Place and Seal Weld the Top Cover Plate over the Shield Plug and perform NDE
 16. Install the Transfer Cask Lid and Bolt in Place
 17. Decontaminate the Transfer Cask Surface
 18. Drain the water from the Cask/DSC Annulus
 19. Lift the Transfer Cask onto the Transfer Trailer and Lower it into the Horizontal Position
 20. Tow the Transfer Trailer to the HSM
 21. Remove the HSM Front Access Door
 22. Align the Transfer Cask and the HSM
 23. Remove the Transfer Cask Lid and Bottom Access Plate
 24. Push the DSC into the HSM Using the Hydraulic Ram System
 25. Retract Hydraulic Ram Arm and reposition transfer cask
 26. Replace the HSM Front Access Door and Tack Weld in Place
-

Table 1-3. Primary Design Parameters for the ISFSI Transport Systems

System	Parameters	Value
Transfer Cask	Nominal Cavity Diameter	68 in.
	Nominal Cavity Length	188 in.
	Payload Capacity (Maximum)	90,000 lbs.
	Reference Heat Rating	15.8 kw (.66 assembly)
	Shielding (Surface Dose) at Axial Midplane	200 mR/hr average
Transfer Cask Movement	Liftable by Crane	200,000 lbs. maximum.
	Rotatable by Crane from Vertical to Horizontal	Has rotation trunnions
Transfer Cask Lid	Removable in Horizontal Position	5,400 lb.
Trailer and Skid	Truck Transportable	-
	Transfer Cask Lid Must Protrude Past End of Trailer and Skid	15.25 cm (6 in.)
	Capacity (Transfer Trailer) (Transfer Trailer Skid)	109,000kg (120 tons) 100,000kg (110 tons)

1.3 GENERAL SYSTEMS DESCRIPTIONS

The major systems, subsystems, and components of the Oconee ISFSI are listed in Table 1-4 on page 1-15. The following subsections briefly describe the principal systems and components and their operation.

1.3.1 SYSTEMS DESCRIPTIONS

1.3.1.1 DSC Design

The NUHOMS-24P DSC is shown in Figure 1.3-1 of the Topical Report for the NUHOMS-24P System (Reference 2 on page 1-21). The DSC is sized to hold twenty-four irradiated pressurized water reactor (PWR) fuel assemblies. The main component of construction is a stainless steel cylinder with a nominal 67 inch outside diameter. The nominal overall length is 187 inches, excluding grapple ring.

The components of the internal basket of the DSC are defined in Table 1-4 on page 1-15 and are also shown on Figure 1.3-1 of Reference 2 on page 1-21. The basket is comprised of twenty-four square cells. The structural component of the cells is type 304 stainless steel.

Structural support is provided by circular stainless-steel spacer disks. The basket is designed so that there is one disk under each spacer end of the fuel assembly. Longitudinal support is provided by the four support rods which run the length of the DSC.

The DSC is equipped with two shielded end plugs so that when the canister is inside the transfer cask or the horizontal storage module, the radiation dose at the ends is limited and they are accessible for handling. The end shield plugs are constructed of lead surrounded by a steel body.

The DSC has redundant seal welds at the top and bottom. The bottom cover plates are welded to the DSC body during fabrication and the top cover plates after fuel loading. Also, all connections (drain and vent ports) will be redundantly sealed. This assures that no single failure of the DSC end plates will breach the DSC. Furthermore, there are no credible accidents which would breach the main body of the DSC.

Criticality safety during wet loading operations is assured by 1) the design of the basket structure which maintains a minimum separation between fuel assemblies, 2) technical specification procedures which assure a minimum boron concentration in excess of 1810 ppm is maintained within the DSC storage cavity during wet loading and unloading operations, and 3) procedures which limit the reactivity of fuel assemblies loaded into the DSC to an established maximum through verification of initial enrichment and exposure history.

1.3.1.2 Horizontal Storage Module

An isometric view of a unit of four HSMs is shown in Figure 1.3-1A of Reference 2 on page 1-21. The HSM is fabricated from reinforced concrete and structural steel which will be constructed in place at the storage location. The thick concrete top, front, and sides of the HSM provide adequate neutron and gamma shielding to achieve an average 20 mR/hr surface dose. Nominal closure door surface doses are less than 100 mR/hr. The transfer cask surface has an average dose rate of less than 200 mR/hr for the locations where workers must perform loading and unloading operations.

Thick shield walls (3.0 ft. thick) are provided on the outside walls of the modules at the end of the unit to provide shielding on the sides. Sufficient (2.0 ft. thick) shielding between modules (to prevent scatter in adjacent modules during loading and retrieval) is provided by the interior module walls.

The HSM provides fuel cooling by a combination of radiation, conduction and convection. The air enters at the bottom of the HSM and passes around the DSC and exits through the flow channels in the top shield slab. Heat is conducted out of the DSC into the natural convection air flow. Heat is also radiated from the DSC to the HSM walls where the natural convection air flow removes the heat. Figure 1.3-2 of Reference 2 on page 1-21 shows the flow path and typical conditions. The passive cooling system of the HSM was designed to assure that peak cladding temperatures are less than 340°C (644°F) during long term storage for average normal ambient temperatures of 70°F. The fuel can withstand short term temperatures of up to 570°C (1,058°F) during operational and accidental transients with no anticipated adverse effects. However, calculations show that temperatures remain well below 570°C at any time during normal operation or any postulated accident.

The HSMs are independent, passive systems for the dry storage of irradiated fuel assemblies. Therefore, the HSMs are designed to ensure that normal operation and credible site hazards do not impair their function. To this end, the HSMs are designed to the following loads:

1. Winds and Tornado (includes missile) - Oconee FSAR, Chapter 3, "Design of Structures, Components, Equipment, and Systems" on page 3-1
2. Seismic - Oconee FSAR, Chapter 3, "Design of Structures, Components, Equipment, and Systems" on page 3-1
3. Flood - Oconee FSAR, Chapter 2, "Site Characteristics" on page 2-1
4. Snow and Ice - ANSI A58.1-1982.
5. Combined Load (dead weight, live loads, temperature) - ACI 349-85

The HSMs are placed in service on a load bearing foundation. Earth work is required to prepare the storage site for a level foundation and access area.

1.3.1.3 Transfer Cask

The transfer cask used with the ISFSI provides radiological shielding during the DSC drying operation and during the transfer to the HSM. Both neutron (Bisco NS-3, a cementitious material) and gamma (lead) shielding are incorporated into the cask design. For the Oconee ISFSI, the transfer cask has a nominal 188 inch long internal cavity with a nominal 68 inch internal diameter. Figure 1.3-2A of Reference 2 on page 1-21 shows the major components of the transfer cask.

1.3.1.4 Transfer Trailer

The transfer trailer has a capacity of 120 tons. The transfer trailer carries the transfer cask skid and the loaded transfer cask. The transfer trailer is designed to ride as low to the ground as possible to minimize the HSM height. Four hydraulic jacks are incorporated into the transfer trailer design to provide vertical movement for alignment of the cask and HSM. The transfer trailer is pulled by a conventional tractor. Figure 1.3-3 of Reference 2 on page 1-21 shows a typical transfer trailer arrangement. Also, as discussed in Section 8.2.5 of Reference 2 on page 1-21, the design basis drop height for the NUHOMS-24P Transfer cask is 80 inches. This analysis bounds the Oconee transport conditions. The nominal travel height of the transfer trailer deck is 41 inches which corresponds to a cask drop height of 59 inches. During transit from the fuel building to the HSM site, the trailer deck will be automatically leveled by the trailer's hydraulic suspension units. The maximum design travel for these units can raise the trailer deck height to 52 inches, which corresponds to a drop height of 70 inches. Mechanical stops attached to each

suspension unit cylinder ensure that the cask cannot be lifted to a height greater than 70 inches above the ground.

1.3.1.5 Transfer Cask Skid

The transfer cask skid is similar in design and operation to existing transport skids. The major differences are:

1. No equipment interferes with access to the top of the transfer cask when in the horizontal position.
2. The skid is mounted on a smooth bearing surface and hydraulic positioners provide horizontal alignment with the HSM. A restraining bolt system is provided to prevent movement during trailer towing.
3. The entire skid is mounted on a trailer.

The above features are shown on Figure 1.3-4 of Reference 2 on page 1-21.

1.3.1.6 Horizontal Hydraulic Ram

The horizontal hydraulic ram is a hydraulic boom with a capacity of 80,000 lb. and a reach of 6.55m (21.5 ft.). The ram will be mounted on a separate trailer for transportation and will be mounted on a surface supported tripod during the DSC pushing insertion or removal operation. Figure 1.3-5 of Reference 2 on page 1-21 shows the hydraulic ram.

1.3.1.7 System Operation

The primary operations (in sequence of occurrence) for the Oconee system are shown schematically in Figure 1.3-6 of Reference 2 on page 1-21 and are described below:

1. Transfer Cask Preparation - Cask preparation includes taking smears of the cask interior to ensure that the DSC will remain radiologically clean. These operations are done in the decontamination area inside the spent fuel pool area. The operations are standard cask operations and have been previously performed by Oconee personnel. Detailed procedures for these operations are described in Chapter 5, "Storage System Operations" on page 5-1.
2. DSC Preparation - The internals and externals of the canister are verified to be clean. This ensures that the newly fabricated canister will meet existing Oconee specific criteria for placement in the spent fuel pool.
3. Placement of DSC in Transfer Cask - The empty DSC is inserted into the transfer cask. Proper alignment is assured through the use of alignment marks on the cask and each DSC.
4. Transfer Cask Lifting and Placement in the Spent Fuel Pool - The DSC transfer cask annulus is filled with clean demineralized water. The DSC cavity is also filled with borated water from either the spent fuel pool or an equivalent source of borated water. This prevents an inrush of pool water when they are placed in the spent fuel pool. This will also prevent contamination of the DSC outer surface by the pool water. The DSC transfer cask annular region is then sealed with an inflatable seal at the top to prevent mixing. The water-filled transfer cask with the DSC inside is then placed into the spent fuel pool.
5. DSC Loading - Twenty-four spent fuel assemblies are placed into the DSC basket. This operation is identical to existing Oconee spent fuel shipping cask loading operations. These assemblies will be preselected to control reactivity and decay heat using the administrative controls on burnup, initial enrichment, and decay time detailed in Section 10.2.5, "Administrative Controls" on page 10-6.

6. DSC Top End Shield Plug Placement - The DSC top end shield plug is placed inside the DSC using the overhead crane with lift beam attached. The top end shield plug is suspended from the transfer cask lift beam by cables and is replaced as the lift beam is re-engaged to the transfer cask runways.
7. Transfer Cask Lifting out of the Pool - The loaded transfer cask is lifted out of the spent fuel pool and placed in the decontamination pit. This operation is identical to existing Oconee cask lifting operations.
8. DSC Sealing - The water level in the DSC transfer cask annulus is then lowered approximately 5-10 inches. Swipes are taken over the DSC exterior at the DSC upper surface and around the circumference. The water level in the DSC is lowered away from the inside surface of the top end shield plug. Then a seal weld is applied to the outer surface of the top end shield plug. This provides the primary seal for the DSC.
9. Transfer Cask DSC Drying - A pressure line is connected to the DSC and the water inside the canister is forced out by helium pressure. The water, which is removed from the transfer cask and the DSC, is returned to the spent fuel pool or routed to the Oconee radioactive waste processing equipment. The pressure line is then used to draw a vacuum to facilitate drying until the water content meets the design criteria.
10. Helium Filling - In order to ensure that no fuel and/or cladding oxidation occurs during storage, the DSC is filled with helium (He). To accomplish this, a portable helium gas bottle is connected. The DSC is then filled with He gas. After the DSC is filled with the inert gas, the filling line is removed and the DSC ports are plugged and welded closed.
11. Final DSC Sealing - The top cover plate is positioned and seal welded. This provides a redundant seal at the upper end of the DSC. The lower end also has redundant seal welds, which were provided and tested during fabrication. This operation provides the double seal integrity of the DSC.
12. Transfer Trailer Loading - After helium filling and seal welding, the transfer cask lid is positioned and bolted in place. The transfer cask is then lifted onto the transfer cask skid mounted on the transfer trailer and secured.
13. Transfer - Once loaded and secured, the transfer trailer is towed to the HSM. This movement takes place completely within the Oconee plant site and owner controlled area.
14. Transfer Cask HSM Preparation - At the Oconee ISFSI the transfer trailer is backed into position and the HSM front access cover is raised and removed. Next, the transfer cask lid is removed. An optical alignment system and the hydraulic skid positioners are used for the final alignment of the transfer cask and HSM.
15. HSM Loading - After final alignment the bottom cover plate on the transfer cask is removed, and the DSC is then pushed into the HSM by the hydraulic ram.
16. Storage - After the DSC is positioned inside the HSM, the hydraulic ram is released from the DSC and retracted. The transfer trailer is pulled away and the HSM front access door is closed and tack welded. The DSC is now in storage within the HSM.
17. Retrieval - For retrieval, the HSM access door is raised and removed and the transfer cask is positioned as previously described and the hydraulic ram is used to pull the DSC into the transfer cask. All coupling attachment, alignment, and closure operations are done in the same manner as previously described, but in reverse order. Once back in the transfer cask, the DSC and its cargo of canistered irradiated fuel assemblies are ready for shipment to a permanent repository or other storage location. Provisions will be made to return the DSC to the Oconee spent fuel pool if necessary.

1.3.2 TABLES

Table 1-4 (Page 1 of 2). Major Systems, Subsystems and Components of the Oconee ISFSI

Dry Storage Canister

DSC Basket

Guide Sleeves (24)

Spacer Disks (8)

Support Rods (4)

DSC Shell

Shielded End Plugs (Top and Bottom)

Cover Plates (Top and Bottom)

Drain and Fill Ports

Grapple Ring

Horizontal Storage Module

Reinforced Concrete Walls, Roof, and Basinat

DSC Structural Steel Support Assembly

DSC Seismic Retainer

Cask Docking Flange and Tie-Down Restraints

Heat Shield

Shielded Front Access Door

Ventilation Air Openings (One Inlet, Two Outlets)

Shielded Ventilation Air Inlet Plenum

Ventilation Air Outlet Shielding Blocks

Transfer Cask

Cask Structural Shell Assembly

Bolted Top Head Assembly

Cask Lifting Trunnions

Lead Gamma Shielding

Neutron Shield Assembly

Ram Access Penetration Cover Plate

Transfer Trailer

Heavy Industrial-Grade Trailer

Cask Support Skid

Skid Positioning and Alignment System

Table 1-4 (Page 2 of 2). Major Systems, Subsystems and Components of the Oconee ISFSI

Hydraulic Ram System

Hydraulic Cylinder and Supports

Hydraulic System

Grapple Assembly

1.4 IDENTIFICATION OF AGENTS AND CONTRACTORS

The prime contractor for design and analysis of the Oconee ISFSI is Pacific Nuclear Fuel Systems, Inc. of San Jose, California. HSM construction is the responsibility of the Duke onsite construction organization. Fabrication of transfer equipment and DSCs is also the responsibility of Pacific Nuclear Fuel Systems, Inc.

1.5 MATERIAL INCORPORATED BY REFERENCE

The Topical Report for the Nutech Horizontal Modular Storage (NUHOMS-24P) System for Irradiated Nuclear Fuel, originally submitted to the Nuclear Regulatory Commission by Nutech Engineers, Inc. (now Pacific Nuclear Fuel Systems, Inc.) on February 26, 1988 and amended in July 1989 is hereby incorporated into this SAR by reference.

1.6 REFERENCES

1. Duke Power Company, Oconee Nuclear Station, Independent Spent Fuel Storage Installation, Environmental Report.
2. Topical Report for the Nutech Horizontal Modular Storage (NUHOMS-24P) System for Irradiated Nuclear Fuel, NUH-002, Revision 1A, July 1989.

CHAPTER 2. SITE CHARACTERISTICS

2.1 GEOGRAPHY AND DEMOGRAPHY

2.1.1 SITE LOCATION

The Independent Spent Fuel Storage Installation (ISFSI) is located on the Oconee Nuclear Station Plant site. The site is located in Oconee County, South Carolina, approximately 8 miles northeast of Seneca, South Carolina at latitude $34^{\circ}47'38.2''$ N and longitude $82^{\circ}53'55.4''$ W. Lake Keowee is located to the north and west of the site. The Corps of Engineers' Hartwell Reservoir is south of the site and Duke's Lake Jocassee lies approximately 11 miles to the north. Figure 2-1 on page 2-9 (based on Figure 2-1 on page 2-13 of Oconee FSAR) shows the site location with respect to neighboring states and counties within 50 miles.

2.1.2 SITE DESCRIPTION

Figure 2-2 on page 2-10 (based on Figure 2-4 on page 2-16 of Oconee FSAR) shows the site, property line, exclusion area, site structures and general features of the area. Figure 2-3 on page 2-11 is a detailed site layout showing the ISFSI location in relation to major site features. There are no industrial, commercial, institutional or recreational structures within the site boundary. A visitors center and the Keowee Hydroelectric Station, both owned by Duke, are located within 1 mile of station center. Duke does not own the vacated Old Pickens Church and Cemetery, a small, historic property located east of the station which is not currently being used.

The topography immediately surrounding the ISFSI (Figure 2-3 on page 2-11) consists of relatively flat terrain which has been grassed or graveled over and is routinely maintained by the station. Routine maintenance of the immediate site vicinity assures that erosion will be minimal and that fire hazards due to burning vegetation are also minimized.

2.1.2.1 Legal Responsibilities for Site

All the property within the 1 mile radius exclusion area including mineral rights is owned by Duke except for the small vacant rural church plot belonging to Old Pickens Church, rights-of-way for existing highways and approximately 9.8 acres of U. S. Government property involved with Hartwell Reservoir.

The Hartwell property is either a portion of the Hartwell Reservoir or subject to flooding and not suitable for other uses. Duke has obtained from the owners of the church plot and from the United States the right to restrict activities on these properties and to evacuate them of all persons at any time without prior notice if, in its opinion, such evacuation is necessary or desirable in the interest of public health and safety.

The property which is within the exclusion area and which is not owned by Duke is shown on Figure 2-2 on page 2-10.

2.1.2.2 Other Activities Within the Site Boundary

Duke Power Company owns and operates the Oconee Nuclear Station and the Keowee Hydroelectric Station. The ISFSI is located within the owner controlled area of the nuclear plant. ISFSI operations have been considered for impacts upon the Oconee station's facility operating licenses. Duke submitted a request, pursuant to 10CFR Part 50, to amend these licenses for the three Oconee Units to permit Duke to operate the ISFSI. This amendment request concludes that with certain minor modifications all aspects

of ISFSI operation which are conducted within the existing Oconee station can be conducted safely while meeting the criteria for a "no significant hazards" finding.

All ISFSI operations are performed by the existing Oconee workforce. Only the transfer equipment used for the storage system is dedicated exclusively to ISFSI operations. No individual or group is dedicated exclusively to the ISFSI. Operational control of the ISFSI includes procedure for the spent fuel pool loading steps and the subsequent transfer to the ISFSI. All procedural steps necessary for preparing the DSC transfer cask for transport from the fuel building to the ISFSI are completed. At this point other procedures for transport of the DSC transfer cask and emplacement of the DSC into an HSM are used.

ISFSI operations required the following fuel building modifications:

1. Enlarging the opening of the cask decontamination pit covers.
2. Shortening the projection from the spent fuel pool wall of the cooling system intake pipe. This is needed to provide clearance for the transfer cask in the spent fuel pool cask pit.
3. The addition of a microdrive to the fuel crane positioning system to aid in the precision placement of the transfer cask.

The following auxiliary equipment is used exclusively for DSC transfer cask operations within the fuel building:

1. Transfer cask lift yoke and extension member.
2. Vacuum drying equipment.
3. Automatic welding equipment.
4. Slings for the transfer cask lid.
5. Cask pit depression platform.

Additional description of the ISFSI and Fuel Building systems and facility is included in Section 4.4, "Operating Systems" on page 4-25.

Other non-plant related activities are limited to the highways through the Exclusion Area, Duke's Visitors Center, recreation on the lakes, and the Old Pickens Church and Cemetery which are historical landmarks and will not be used for regular services.

2.1.2.3 Arrangements for Traffic Control

Arrangements have been made with the South Carolina State Highway Department to control and limit traffic on public highways in the Exclusion Area should it become necessary in the interest of public health and safety.

2.1.3 POPULATION DISTRIBUTION AND TRENDS

The population distribution is based on the 1970 census. Table 2-1 on page 2-7 gives the population distribution within 10 miles of Oconee. The majority of citizens live in the cities of Walhalla, Seneca, Clemson and Central, S.C. The area is largely rural and sparsely populated. The population projections for the 0-50 miles distribution around Oconee is given for year 2020 in Table 2-2 on page 2-8. These projections are based on the 1980 census. The population within the 10-mile radius is projected to approximately double by the year 2020 with no individuals permanently residing within the 1-mile radius of Oconee.

2.1.3.1 Transient Population

It is expected that Lake Keowee's 300 mile shoreline will be fully developed by the early 1990's at which time the estimated transient population will be 36,000. This estimate is based on development of lakeside lots, public access areas, and expanded commercial activities to take advantage of expanded recreational opportunities. There will not be any cottages within the Exclusion Area.

The visitors center, located on Duke Property just north of the plant and within the Exclusion Area, was host to 510,000 people during its first 25 months of operation.

There are no large industries within 5 miles of the site therefore no industrial transients.

2.1.4 USES OF NEARBY LAND AND WATERS

Residential development of Lake Keowee's shoreline is expected to be the major use of the nearby land. Commercial development is anticipated to increase in response to the residential development. The waters of Lake Keowee are used for fishing, boating and swimming by the public through various public and private recreational areas.

The following description of land use and localized populations in Pickens and Oconee Counties in the 10-mile EPZ of the Oconee Nuclear Station is based on the Oconee Nuclear Station Emergency Plan as of August 1, 1985.

Pickens County lies within the 10-mile EPZ of the Oconee Nuclear Station. Involved are approximately 157.08 square miles of county territory and approximately 30,000 people. Also included are approximately 300 dairy cattle, 10 milk-producing goats, 243 head of swine, 2,938 head of beef cattle and 15 head of meat-producing goats.

Also, involved in the 10-mile EPZ are approximately 256 acres of vegetables, 47 acres of apples, and a large number of residential vegetable gardens.

This area has approximately 1,297 acres of hay crops and 4,670 acres of pasture grass.

A large portion of Oconee County lies within the 10-mile EPZ of the Oconee Nuclear Station. Included in this zone are approximately 165,498 square miles of land and approximately 26,000 people, with the largest concentration in Seneca. Oconee County's 654 square miles are divided into 22,665 acres of cropland, 285,605 acres of woodlands, and approximately 127,333 acres that fall into a general category of "all other". There are a total of 13 dairies in the 10-mile EPZ.

The largest portion of land is devoted to crops such as soybeans, cotton, hay, wheat, small grain, and corn, apples, forestry, poultry, beef or dairying.

Production of meat, agricultural crops and milk for the 5-mile radius of Oconee Nuclear Station for 1980 was as follows:

meat = 118 tons
crops = 310 tons
milk = 86,300 gallons

This data has not significantly changed since it became available in 1980.

2.1 Geography and Demography

Oconee ISFSI Safety Analysis Report

There are two schools located within the 5-mile radius: Six Mile Elementary School - 522 students, and Keowee Elementary School - 299 students. Two special care institutions are located within the 5-mile radius: Harvey's Love and CareHome and Six Mile Retirement Center; nursing homes have a total of 80 patients.

2.1.5 TABLES

Table 2-1. 1970 Population Distribution 0-10 Miles

Sector	0-1 Mile	1-2 Miles	2-3 Miles	3-4 Miles	4-5 Miles	5-10 Miles	Total
N	0	0	0	0	0	40	40
NE	0	0	0	38	22	60	120
NE	9	0	0	115	235	2,000	2,350
ESE	0	22	38	108	112	681	961
E	0	0	0	140	417	670	1,227
ESI	0	0	51	70	131	1,326	1,578
SE	0	0	80	6	70	8,472	8,628
SEI	0	0	0	0	45	7,792	7,837
S	0	19	29	6	140	2,027	2,221
SSW	0	6	0	0	112	7,000	7,118
SW	0	19	0	128	166	538	851
WSW	0	13	80	181	35	1,102	1,411
W	0	0	150	38	102	1,419	1,709
WNW	0	3	22	51	26	1,456	1,558
NW	0	0	0	13	32	920	965
NNW	0	3	3	13	16	881	916
TOTAL	0	85	453	907	1,661	36,384	39,490

Table 2.2. Population Projection for Oconee Nuclear Station for the Year 2020

	0.1 Mile	0.5 Miles	5.10 Miles	10.20 Miles	20.30 Miles	30.40 Miles	40.50 Miles	Total
N	0	34	170	96	5456	2493	31930	40,189
NNI	0	206	429	1199	5656	29610	52620	80,720
NI	0	944	2767	7416	7329	7134	48540	74,121
INI	0	1028	2689	26130	76940	76540	33780	227,107
I	0	1183	2859	51930	165300	133200	37530	392,002
ISE	0	739	4720	8814	39110	11290	11100	75,773
SE	0	695	13240	9789	67290	24500	13470	128,984
SSE	0	221	23010	12100	55530	11870	3580	196,311
S	0	764	4037	5661	6277	11550	14050	42,339
SSW	0	14	14950	6550	7852	12210	11170	52,646
SW	0	391	3281	10570	5763	5780	5253	31,038
WSW	0	694	3756	7323	20990	15670	13490	67,023
W	0	401	5057	3312	2162	2413	3280	16,625
WNW	0	216	1247	1387	4558	5259	4951	17,618
NW	0	346	1621	607	3695	17470	6033	29,772
NNW	0	80	1677	171	2978	11590	19760	36,256
TOTAL	0	7,956	85,510	153,055	475,987	369,579	326,437	1,418,524




Figure 2-3.
ISFSI Layout

2.2 NEARBY INDUSTRIAL, TRANSPORTATION, AND MILITARY FACILITIES

2.2.1 INDUSTRIAL AND MILITARY FACILITIES

There are no large industrial or military facilities or activities within 5 miles of Oconee. No other nuclear facilities including university research reactors are presently located within a 50-mile radius of Oconee Nuclear Station.

2.2.2 TRANSPORTATION ROUTES

Figure 2-2 on page 2-10 shows the major transportation routes within 1 mile of Oconee. There are no oil or gas pipelines within 5 miles of the site. The nearest railroad line or spur is located at Newry, SC which is outside the 5-mile radius from the plant.

The nearest airport is the Clemson-Oconee Airport located approximately 9 miles to the south of the plant. The runway is oriented ENE-WSW. Pickens County Airport is located approximately 10 miles to the east of Oconee Nuclear Station. The runway is oriented in a NE-SW direction. Anderson County Airport is located approximately 23 miles SSE of the plant. It has two runways oriented as follows: NE-SW and NNW-SSE. The orientation of the NNW-SSE runway is not in a straight line toward Oconee Nuclear Station. The above information is based on the "Atlanta Sectional Aeronautical Chart Scale 1:500,000" 37th Edition, September 25, 1986, published by the U.S. Department of Commerce. No structures which could cause damage as described in Reg. Guide 3.48, para. 2.2 are located near the plant.

2.2.2.1 Description of Products and Materials

The highways passing through the 1 mile radius exclusion area are SC Routes 130 and 183 which carry local traffic only with infrequent trucking of hazardous chemicals and explosives since the general area is nonindustrial.

Only small amounts of chlorine are stored on-site since chlorine is not used for condenser cleaning at Oconee. No individual container contains more than 150 lbs. of chlorine. The chlorine is used for drinking water purification and waste treatment, with three to five 150 lb. containers typically being in use. The maximum total number of containers on hand at any time is approximately ten.

2.3 METEOROLOGY

2.3.1 REGIONAL CLIMATOLOGY

Western South Carolina is south of major storm tracks but experiences higher precipitation amounts than the east coast. The location in the lee of the Appalachian Mountains. A semi-permanent belt of high pressure usually influences the regional climate. During the fall season, the area has a high probability of experiencing atmospheric stagnation during which the dilution rate for effluents is low due to low wind speeds.

The Oconee plant site is situated on Lake Keowee which was established to provide cooling for the three existing Oconee nuclear units and future steam generating units as well as storage for Jocassee (pumped storage) and Keowee (conventional) hydroelectric stations. The topography in the vicinity of the site is moderately rolling and the local air flow is influenced to some extent by the contour of the lake. The prevailing winds are divided between the southwest and northeast quadrants due to the lake orientation and large scale pressure effects.

A complete description of regional and local wind data, including normal and extreme parameters can be found in Section 2.3 of the FSAR.

2.3.2 LOCAL METEOROLOGY

2.3.2.1 Data Sources

The accident analysis meteorological data base, discussed in the Oconee SER Section 3.2.4, Units 2 and 3, is for the period March 15, 1970 - March 14, 1972. Joint frequency tables of wind direction, wind speed and atmospheric stability are shown in Table 2-3 on page 2-18.

2.3.2.2 Topography

Figure 2-4 on page 2-24 shows the detailed topography within 5 miles of the storage site.

2.3.3 ONSITE METEOROLOGICAL MEASUREMENT PROGRAM

Meteorological measurements include wind direction and speed, horizontal wind direction fluctuation, temperature, vertical temperature gradient, and rainfall. The relative position of instruments with respect to station yard is noted in Figure 2-5 on page 2-25. Relative elevations of both surface levels and instrument levels are depicted in Figure 2-6 on page 2-26.

Wind measurements are made with the Packard Bell Model W S 101B series wind direction-speed system with starting thresholds of 0.7 and 0.6 miles per hour for direction and speed, respectively. Wind direction and speed are recorded in the control room on Esterline Angus Model A 601 C strip chart recorders with a system accuracy of ± 5.4 degrees for direction and ± 0.45 miles per hour for speed. Temperature and delta temperature measurements are made with the Leeds and Northrup 8100 Series 100 ohm resistance temperature device with Packard Bell Model 327 thermal radiation shields. Temperature and delta temperature are recorded on the Leeds and Northrup Speedomax W recorder with a system accuracy of $\pm 1^\circ\text{F}$ for temperature (at 10 m level) and $\pm 0.5^\circ\text{F}$ for delta temperature (46 m level referenced to the 10 m level). For data prior to February 24, 1977, delta temperature was measured at the 46 m level and the 1.5

2.3 Meteorology

m level. Rainfall is measured near the meteorological tower with the Belfort Weighing Rain Gauge Model 5-780 with an accuracy of ± 0.03 in. and ± 0.06 in. for zero to five and five to ten inch totals respectively.

Operational measurements consist of near real-time digital outputs in addition to the previously described analog system. An entirely new set of instrumentation has been installed including the measurement of dew point (at 10 m level); a supplemental low-level wind system (at 10 m level) provides input for emergency dose assessment (see Figure 2-5 on page 2-25 and Figure 2-6 on page 2-26). The rain gauge has been relocated near the supplemental wind system.

Instrument specifications for operational measurements are:

1. Wind Direction

- a. Manufacturer Teledyne Geotech
- b. Time - averaged digital accuracy $\pm 3^\circ$ of azimuth
- c. Time - averaged analog accuracy $\pm 6^\circ$ of azimuth
- d. Starting threshold 0.3 m sec at 10° initial deflection
- e. Damping ratio 0.4 at 10° initial deflection
- f. Distance constant 1.1 m

2. Wind Speed

- a. Manufacturer Teledyne Geotech
- 1 b. Time - averaged digital accuracy ± 0.27 m sec for speeds less than 27 m sec
- 1 c. Time - averaged analog accuracy ± 0.40 m sec for speeds less than 27 m sec
- 1 d. Starting threshold 0.45 m sec
- e. Distance constant 1.5 m

3. Temperature

- a. Manufacturer Teledyne Geotech
- b. Time - averaged digital accuracy $\pm 0.3^\circ\text{C}$
- 1 c. Time - averaged analog accuracy $\pm 0.5^\circ\text{C}$

4. Delta Temperature

- a. Manufacturer Teledyne Geotech
- 1 b. Time - averaged digital accuracy $\pm 0.10^\circ\text{C}$
- 1 c. Time - averaged analog accuracy $\pm 0.15^\circ\text{C}$

5. Dew Point

- a. Manufacturer General Eastern
- b. Time - averaged digital accuracy $\pm 0.4^\circ\text{C}$
- 1 c. Time - averaged analog accuracy $\pm 0.6^\circ\text{C}$

6. Precipitation

- a. Manufacturer Teledyne Geotech

- b. Digital accuracy $\pm 6\%$ of total accumulation at 15 cm/hr
- c. Analog accuracy $\pm 9\%$ of total accumulation at 15 cm/hr
- d. Resolution 0.25 mm

Near real-time digital output of meteorological measurements are summarized for end-to-end 15 min. periods for use in a near real-time puff-advection model to calculate offsite dose during potential radiological emergencies. The Operator Aid Computer (OAC) system computes the 15 min. quantities from a sampling interval of 60 sec. It calculates 15 min. average values for high and supplemental low level wind direction and speed; 15 min. averages are also calculated for delta temperature, ambient temperature and dew point temperature. Total water equivalence is computed for precipitation. All 15 min. values are stored with a 24 hr. recall. Permanent archiving of data from the digital system is made by combining the 15 min. quantities into one hour values.

2.3.4 DIFFUSION ESTIMATES

2.3.4.1 Basis

The design two-hour X/Q at the Exclusion Area Boundary (EAB) for accidental releases is $4.5E-4$ (sec m^3).

2.3.4.2 Calculations

The calculation of a two-hour X/Q value to estimate radiological doses from potential accidental releases from the storage site (See Figure 1-1 on page 1-4) is based on a plant design condition of Pasquill Type F stability with a wind speed of 1m/sec as proposed in the Oconee Safety Evaluation Report, Section 3.2.4, Units 2 and 3. The equivalent design condition [95 percentile hourly average X/Q] for the ISFSI is a Pasquill Type F stability with a wind speed of 0.65 m/sec. The calculation assumes a gaussian material distribution from a ground level release with essentially a point source geometry.

$$X/Q = [\bar{u} \pi \sigma_y \sigma_z]^{-1} = 4.5E-4 (\text{sec m}^3)^*$$

Where \bar{u} = mean wind speed at 10 m = 0.65(m/sec)
 σ_y (1.0 mi.) = crosswind concentration distribution standard deviation = 57 m
 σ_z (1.0 mi.) = vertical concentration distribution standard deviation = 19 m

* Slade, D. H. (ed.) 1968: Meteorology and Atomic Energy 1968, TID-24190, National Technical Information Service, Springfield, Va.

2.3.5 TABLES

Table 2-3 (Page 1 of 6). Joint Frequencies of Wind Direction and Speed by Stability Class

FOR PERIOD OF MAR. 1978 THRU MAR. 24, 1978
OCEAN METEOROLOGICAL STATION, TOWER DATA
WIND DIRECTION IN DEGREES TRUE
WIND VELOCITY IN METERS PER SECOND

DATE OF REPORT 3-28-78

WIND DIRECTION (DEGREES TRUE)	WIND SPEED CLASS											
	0.0-0.9	1.0-1.9	2.0-2.9	3.0-3.9	4.0-4.9	5.0-5.9	6.0-6.9	7.0-7.9	8.0-8.9	9.0-9.9	10.0-10.9	11.0-11.9
000-030	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
030-060	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
060-090	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
090-120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
120-150	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
150-180	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
180-210	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
210-240	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
240-270	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
270-300	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
300-330	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
330-360	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Table 2-3 (Page 3 of 6). Joint Frequencies of Wind Direction and Speed by Stability Class

OCCOEE METEOROLOGICAL SURVEY TOWER DATA
 WIND MEASUREMENTS BY SECTION + SPEED CLASS (NO. OCCURRING PER HOUR)
 FOR PERIOD OF NOV. 15, 1976 THROUGH MAR. 14, 1977
 DATE OF REPORT 5-28-77

WIND SECTION	WIND SPEED CLASS											
	1.0-3.9	4.0-7.9	8.0-11.9	12.0-15.9	16.0-19.9	20.0-24.9	25.0-29.9	30.0-34.9	35.0-39.9	40.0-44.9	45.0-49.9	50.0-54.9
SECTION 0000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0001	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0002	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0003	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0004	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0005	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0006	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0007	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0008	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0009	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0010	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0011	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0012	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0013	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0014	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0015	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0016	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0017	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0018	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0019	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0020	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0021	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0022	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0023	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0024	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0025	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0026	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0027	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0028	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0029	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0030	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0031	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0032	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0033	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0034	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0035	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0036	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0037	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0038	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0039	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0040	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0041	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0042	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0043	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0044	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0045	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0046	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0047	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0048	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0049	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SECTION 0050	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Table 2-3 (Page 4 of 6). Joint Frequencies of Wind Direction and Speed by Stability Class

SUMMARY OF METEOROLOGICAL SURVEY TOWER DATA		WIND OCCURRENCES BY SECTOR + SPEED CLASS												DATE OF REPORT																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
SUMMARY OF PASADILLA 5		FOR PERIOD OF MAR. 15, 1970 THROUGH MAR. 15, 1972												9-18-72																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
WIND	SECTOR	0-9-10	10-11-12	12-13-14	14-15-16	16-17-18	18-19-20	20-21-22	22-23-24	24-25-26	26-27-28	28-29-30	30-31-32	32-33-34	34-35-36	36-37-38	38-39-40	40-41-42	42-43-44	44-45-46	46-47-48	48-49-50	50-51-52	52-53-54	54-55-56	56-57-58	58-59-60	60-61-62	62-63-64	64-65-66	66-67-68	68-69-70	70-71-72	72-73-74	74-75-76	76-77-78	78-79-80	80-81-82	82-83-84	84-85-86	86-87-88	88-89-90	90-91-92	92-93-94	94-95-96	96-97-98	98-99-100	100-101-102	102-103-104	104-105-106	106-107-108	108-109-110	110-111-112	112-113-114	114-115-116	116-117-118	118-119-120	119-120-121	120-121-122	121-122-123	122-123-124	123-124-125	124-125-126	125-126-127	126-127-128	127-128-129	128-129-130	129-130-131	130-131-132	131-132-133	132-133-134	133-134-135	134-135-136	135-136-137	136-137-138	137-138-139	138-139-140	139-140-141	140-141-142	141-142-143	142-143-144	143-144-145	144-145-146	145-146-147	146-147-148	147-148-149	148-149-150	149-150-151	150-151-152	151-152-153	152-153-154	153-154-155	154-155-156	155-156-157	156-157-158	157-158-159	158-159-160	159-160-161	160-161-162	161-162-163	162-163-164	163-164-165	164-165-166	165-166-167	166-167-168	167-168-169	168-169-170	169-170-171	170-171-172	171-172-173	172-173-174	173-174-175	174-175-176	175-176-177	176-177-178	177-178-179	178-179-180	179-180-181	180-181-182	181-182-183	182-183-184	183-184-185	184-185-186	185-186-187	186-187-188	187-188-189	188-189-190	189-190-191	190-191-192	191-192-193	192-193-194	193-194-195	194-195-196	195-196-197	196-197-198	197-198-199	198-199-200	199-200-201	200-201-202	201-202-203	202-203-204	203-204-205	204-205-206	205-206-207	206-207-208	207-208-209	208-209-210	209-210-211	210-211-212	211-212-213	212-213-214	213-214-215	214-215-216	215-216-217	216-217-218	217-218-219	218-219-220	219-220-221	220-221-222	221-222-223	222-223-224	223-224-225	224-225-226	225-226-227	226-227-228	227-228-229	228-229-230	229-230-231	230-231-232	231-232-233	232-233-234	233-234-235	234-235-236	235-236-237	236-237-238	237-238-239	238-239-240	239-240-241	240-241-242	241-242-243	242-243-244	243-244-245	244-245-246	245-246-247	246-247-248	247-248-249	248-249-250	249-250-251	250-251-252	251-252-253	252-253-254	253-254-255	254-255-256	255-256-257	256-257-258	257-258-259	258-259-260	259-260-261	260-261-262	261-262-263	262-263-264	263-264-265	264-265-266	265-266-267	266-267-268	267-268-269	268-269-270	269-270-271	270-271-272	271-272-273	272-273-274	273-274-275	274-275-276	275-276-277	276-277-278	277-278-279	278-279-280	279-280-281	280-281-282	281-282-283	282-283-284	283-284-285	284-285-286	285-286-287	286-287-288	287-288-289	288-289-290	289-290-291	290-291-292	291-292-293	292-293-294	293-294-295	294-295-296	295-296-297	296-297-298	297-298-299	298-299-300	299-300-301	300-301-302	301-302-303	302-303-304	303-304-305	304-305-306	305-306-307	306-307-308	307-308-309	308-309-310	309-310-311	310-311-312	311-312-313	312-313-314	313-314-315	314-315-316	315-316-317	316-317-318	317-318-319	318-319-320	319-320-321	320-321-322	321-322-323	322-323-324	323-324-325	324-325-326	325-326-327	326-327-328	327-328-329	328-329-330	329-330-331	330-331-332	331-332-333	332-333-334	333-334-335	334-335-336	335-336-337	336-337-338	337-338-339	338-339-340	339-340-341	340-341-342	341-342-343	342-343-344	343-344-345	344-345-346	345-346-347	346-347-348	347-348-349	348-349-350	349-350-351	350-351-352	351-352-353	352-353-354	353-354-355	354-355-356	355-356-357	356-357-358	357-358-359	358-359-360	359-360-361	360-361-362	361-362-363	362-363-364	363-364-365	364-365-366	365-366-367	366-367-368	367-368-369	368-369-370	369-370-371	370-371-372	371-372-373	372-373-374	373-374-375	374-375-376	375-376-377	376-377-378	377-378-379	378-379-380	379-380-381	380-381-382	381-382-383	382-383-384	383-384-385	384-385-386	385-386-387	386-387-388	387-388-389	388-389-390	389-390-391	390-391-392	391-392-393	392-393-394	393-394-395	394-395-396	395-396-397	396-397-398	397-398-399	398-399-400	399-400-401	400-401-402	401-402-403	402-403-404	403-404-405	404-405-406	405-406-407	406-407-408	407-408-409	408-409-410	409-410-411	410-411-412	411-412-413	412-413-414	413-414-415	414-415-416	415-416-417	416-417-418	417-418-419	418-419-420	419-420-421	420-421-422	421-422-423	422-423-424	423-424-425	424-425-426	425-426-427	426-427-428	427-428-429	428-429-430	429-430-431	430-431-432	431-432-433	432-433-434	433-434-435	434-435-436	435-436-437	436-437-438	437-438-439	438-439-440	439-440-441	440-441-442	441-442-443	442-443-444	443-444-445	444-445-446	445-446-447	446-447-448	447-448-449	448-449-450	449-450-451	450-451-452	451-452-453	452-453-454	453-454-455	454-455-456	455-456-457	456-457-458	457-458-459	458-459-460	459-460-461	460-461-462	461-462-463	462-463-464	463-464-465	464-465-466	465-466-467	466-467-468	467-468-469	468-469-470	469-470-471	470-471-472	471-472-473	472-473-474	473-474-475	474-475-476	475-476-477	476-477-478	477-478-479	478-479-480	479-480-481	480-481-482	481-482-483	482-483-484	483-484-485	484-485-486	485-486-487	486-487-488	487-488-489	488-489-490	489-490-491	490-491-492	491-492-493	492-493-494	493-494-495	494-495-496	495-496-497	496-497-498	497-498-499	498-499-500	499-500-501	500-501-502	501-502-503	502-503-504	503-504-505	504-505-506	505-506-507	506-507-508	507-508-509	508-509-510	509-510-511	510-511-512	511-512-513	512-513-514	513-514-515	514-515-516	515-516-517	516-517-518	517-518-519	518-519-520	519-520-521	520-521-522	521-522-523	522-523-524	523-524-525	524-525-526	525-526-527	526-527-528	527-528-529	528-529-530	529-530-531	530-531-532	531-532-533	532-533-534	533-534-535	534-535-536	535-536-537	536-537-538	537-538-539	538-539-540	539-540-541	540-541-542	541-542-543	542-543-544	543-544-545	544-545-546	545-546-547	546-547-548	547-548-549	548-549-550	549-550-551	550-551-552	551-552-553	552-553-554	553-554-555	554-555-556	555-556-557	556-557-558	557-558-559	558-559-560	559-560-561	560-561-562	561-562-563	562-563-564	563-564-565	564-565-566	565-566-567	566-567-568	567-568-569	568-569-570	569-570-571	570-571-572	571-572-573	572-573-574	573-574-575	574-575-576	575-576-577	576-577-578	577-578-579	578-579-580	579-580-581	580-581-582	581-582-583	582-583-584	583-584-585	584-585-586	585-586-587	586-587-588	587-588-589	588-589-590	589-590-591	590-591-592	591-592-593	592-593-594	593-594-595	594-595-596	595-596-597	596-597-598	597-598-599	598-599-600	599-600-601	600-601-602	601-602-603	602-603-604	603-604-605	604-605-606	605-606-607	606-607-608	607-608-609	608-609-610	609-610-611	610-611-612	611-612-613	612-613-614	613-614-615	614-615-616	615-616-617	616-617-618	617-618-619	618-619-620	619-620-621	620-621-622	621-622-623	622-623-624	623-624-625	624-625-626	625-626-627	626-627-628	627-628-629	628-629-630	629-630-631	630-631-632	631-632-633	632-633-634	633-634-635	634-635-636	635-636-637	636-637-638	637-638-639	638-639-640	639-640-641	640-641-642	641-642-643	642-643-644	643-644-645	644-645-646	645-646-647	646-647-648	647-648-649	648-649-650	649-650-651	650-651-652	651-652-653	652-653-654	653-654-655	654-655-656	655-656-657	656-657-658	657-658-659	658-659-660	659-660-661	660-661-662	661-662-663	662-663-664	663-664-665	664-665-666	665-666-667	666-667-668	667-668-669	668-669-670	669-670-671	670-671-672	671-672-673	672-673-674	673-674-675	674-675-676	675-676-677	676-677-678	677-678-679	678-679-680	679-680-681	680-681-682	681-682-683	682-683-684	683-684-685	684-685-686	685-686-687	686-687-688	687-688-689	688-689-690	689-690-691	690-691-692	691-692-693	692-693-694	693-694-695	694-695-696	695-696-697	696-697-698	697-698-699	698-699-700	699-700-701	700-701-702	701-702-703	702-703-704	703-704-705	704-705-706	705-706-707	706-707-708	707-708-709	708-709-710	709-710-711	710-711-712	711-712-713	712-713-714	713-714-715	714-715-716	715-716-717	716-717-718	717-718-719	718-719-720	719-720-721	720-721-722	721-722-723	722-723-724	723-724-725	724-725-726	725-726-727	726-727-728	727-728-729	728-729-730	729-730-731	730-731-732	731-732-733	732-733-734	733-734-735	734-735-736	735-736-737	736-737-738	737-738-739	738-739-740	739-740-741	740-741-742	741-742-743	742-743-744	743-744-745	744-745-746	745-746-747	746-747-748	747-748-749	748-749-750	749-750-751	750-751-752	751-752-753	752-753-754	753-754-755	754-755-756	755-756-757	756-757-758	757-758-759	758-759-760	759-760-761	760-761-762	761-762-763	762-763-764	763-764-765	764-765-766	765-766-767	766-767-768	767-768-769	768-769-770	769-770-771	770-771-772	771-772-773	772-773-774	773-774-775	774-775-776	775-776-777	776-777-778	777-778-779	778-779-780	7

Table 2-3 (Page 5 of 6). Joint Frequencies of Wind Direction and Speed by Stability Class

DATE OF REPORT: 9-18-77

FOR PERIOD OF MAR. 15, 1976 THRU MAR. 14, 1977

OCEONEE METEOROLOGICAL SURVEY TOWER DATA

WIND DIRECTION BY SECTION + SPEED CLASS AND, DIRECTION + FREQUENCY

WIND SPEED CLASS

SECTION: 1.0-4.2 4.3-5.5 5.6-7.8 7.9-10.2 10.3-12.5 12.6-14.8 14.9-17.2 17.3-19.5 19.6-21.8 21.9-24.2

DIRECTION OF PASSAGE: 7

WIND OCCURRENCE BY SECTION + SPEED CLASS AND, DIRECTION + FREQUENCY

WIND DIRECTION	WIND SPEED CLASS									
	1.0-4.2	4.3-5.5	5.6-7.8	7.9-10.2	10.3-12.5	12.6-14.8	14.9-17.2	17.3-19.5	19.6-21.8	21.9-24.2
000°	0	0	0	0	0	0	0	0	0	0
005°	0	0	0	0	0	0	0	0	0	0
010°	0	0	0	0	0	0	0	0	0	0
015°	0	0	0	0	0	0	0	0	0	0
020°	0	0	0	0	0	0	0	0	0	0
025°	0	0	0	0	0	0	0	0	0	0
030°	0	0	0	0	0	0	0	0	0	0
035°	0	0	0	0	0	0	0	0	0	0
040°	0	0	0	0	0	0	0	0	0	0
045°	0	0	0	0	0	0	0	0	0	0
050°	0	0	0	0	0	0	0	0	0	0
055°	0	0	0	0	0	0	0	0	0	0
060°	0	0	0	0	0	0	0	0	0	0
065°	0	0	0	0	0	0	0	0	0	0
070°	0	0	0	0	0	0	0	0	0	0
075°	0	0	0	0	0	0	0	0	0	0
080°	0	0	0	0	0	0	0	0	0	0
085°	0	0	0	0	0	0	0	0	0	0
090°	0	0	0	0	0	0	0	0	0	0
095°	0	0	0	0	0	0	0	0	0	0
100°	0	0	0	0	0	0	0	0	0	0
105°	0	0	0	0	0	0	0	0	0	0
110°	0	0	0	0	0	0	0	0	0	0
115°	0	0	0	0	0	0	0	0	0	0
120°	0	0	0	0	0	0	0	0	0	0
125°	0	0	0	0	0	0	0	0	0	0
130°	0	0	0	0	0	0	0	0	0	0
135°	0	0	0	0	0	0	0	0	0	0
140°	0	0	0	0	0	0	0	0	0	0
145°	0	0	0	0	0	0	0	0	0	0
150°	0	0	0	0	0	0	0	0	0	0
155°	0	0	0	0	0	0	0	0	0	0
160°	0	0	0	0	0	0	0	0	0	0
165°	0	0	0	0	0	0	0	0	0	0
170°	0	0	0	0	0	0	0	0	0	0
175°	0	0	0	0	0	0	0	0	0	0
180°	0	0	0	0	0	0	0	0	0	0
185°	0	0	0	0	0	0	0	0	0	0
190°	0	0	0	0	0	0	0	0	0	0
195°	0	0	0	0	0	0	0	0	0	0
200°	0	0	0	0	0	0	0	0	0	0
205°	0	0	0	0	0	0	0	0	0	0
210°	0	0	0	0	0	0	0	0	0	0
215°	0	0	0	0	0	0	0	0	0	0
220°	0	0	0	0	0	0	0	0	0	0
225°	0	0	0	0	0	0	0	0	0	0
230°	0	0	0	0	0	0	0	0	0	0
235°	0	0	0	0	0	0	0	0	0	0
240°	0	0	0	0	0	0	0	0	0	0
245°	0	0	0	0	0	0	0	0	0	0
250°	0	0	0	0	0	0	0	0	0	0
255°	0	0	0	0	0	0	0	0	0	0
260°	0	0	0	0	0	0	0	0	0	0
265°	0	0	0	0	0	0	0	0	0	0
270°	0	0	0	0	0	0	0	0	0	0
275°	0	0	0	0	0	0	0	0	0	0
280°	0	0	0	0	0	0	0	0	0	0
285°	0	0	0	0	0	0	0	0	0	0
290°	0	0	0	0	0	0	0	0	0	0
295°	0	0	0	0	0	0	0	0	0	0
300°	0	0	0	0	0	0	0	0	0	0
305°	0	0	0	0	0	0	0	0	0	0
310°	0	0	0	0	0	0	0	0	0	0
315°	0	0	0	0	0	0	0	0	0	0
320°	0	0	0	0	0	0	0	0	0	0
325°	0	0	0	0	0	0	0	0	0	0
330°	0	0	0	0	0	0	0	0	0	0
335°	0	0	0	0	0	0	0	0	0	0
340°	0	0	0	0	0	0	0	0	0	0
345°	0	0	0	0	0	0	0	0	0	0
350°	0	0	0	0	0	0	0	0	0	0
355°	0	0	0	0	0	0	0	0	0	0
360°	0	0	0	0	0	0	0	0	0	0

Table 2-3 (Page 6 of 6). Joint Frequencies of Wind Direction and Speed by Stability Class

SUMMARY OF PAS2011 G		WIND OCCURRENCES BY SECTION & SPEED CLASS IND. OCCURRING PERCENT										DATE OF REPORT		
GEONEE METEOROLOGICAL SURVEY TOWER DATA		FOR PERIOD OF MAR. 15, 1970 TO MAR. 15, 1972										9-18-72		
DIR	SECTION	1-0-7-2	3-0-7-3	5-0-7-8	7-0-10-0	10-1-12-1	12-0-14-5	14-0-16-7	16-0-19-0	18-1-21-2	22-1-25-2	25-1-28-2	NO	PCF
DIR	SECTION	1-0-7-2	3-0-7-3	5-0-7-8	7-0-10-0	10-1-12-1	12-0-14-5	14-0-16-7	16-0-19-0	18-1-21-2	22-1-25-2	NO	PCF	
00-0	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
00-0	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
22-5	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
22-5	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
45-0	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
45-0	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
67-5	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
67-5	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
90-0	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
90-0	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
112-5	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
112-5	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
135-0	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
135-0	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
157-5	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
157-5	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
190-0	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
190-0	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
202-5	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
202-5	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
225-0	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
225-0	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
247-5	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
247-5	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
270-0	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
270-0	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
292-5	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
292-5	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
315-0	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
315-0	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
337-5	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
337-5	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
CALN	NO	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
CALN	PCF	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
TOTAL	NO	299	276	276	276	276	276	276	276	276	276	276	276	
TOTAL	PCF	13.64	2.00	5.01	5.00	1.62	6.36	6.03	6.03	6.02	6.00	6.00	6.00	
TOTAL VALID OBSERVATIONS 1744														

2.3.6 FIGURES




Figure 2-4.
Topography Within 5 Miles.





Figure 2-5.
Relative Positions of Meteorological Instruments



1 Figure 2-6.
 1 Relative Elevations of Meteorological Instruments

2.4 HYDROLOGIC ENGINEERING

2.4.1 HYDROLOGIC DESCRIPTION

2.4.1.1 Site and Facilities

The location and description of Oconee presented in Chapters 1 and 2 include reference to figures showing the general arrangement, layout and relevant elevations of the station. Station yard grade is 796 ft. mean sea level (msl). The mezzanine floor elevation in the Turbine, Auxiliary, and Service Buildings is 796.5 ft. (msl). Exterior accesses to these buildings are at elevation 796.5 ft. (msl).

All of the man-made dikes and dams forming the Keowee Reservoir are at an elevation of 815 ft. msl including the intake channel dike. The crest of the submerged weir in the intake canal is at elevation 770 ft. msl.

Flooding at the ISFSI will not occur. Figure 2-2 on page 2-10 shows the location of the ISFSI at the Oconee site, and Figure 2-11 on page 2-60 shows the relative location and topography of the ISFSI yard at Elevation 825.0 and the surrounding terrain features, including the Keowee dam and dikes. The Probable Maximum Flood level for Lake Keowee, as defined in Section 2.4.2.2, "Flood Design Consideration" on page 2-28, is Elevation 808.0, which is seventeen feet below the ISFSI site yard level of Elevation 825.0. Also, the peak flood level due to a postulated failure of the upstream Jocassee Dam is Elevation 813.12, as discussed in Section 2.4.5.1, "Flood Protection Measures for Oconee Station Seismic Class 1 Structures" on page 2-31. Thus, since all of the man-made dams and dikes forming Lake Keowee are constructed to an elevation of 815.0 and since the ISFSI site elevation of 825.0 is above the maximum lake level which can be maintained, there is no potential for the reservoir level reaching the ISFSI site by overtopping. Therefore, flooding of the ISFSI will not occur.

The ISFSI yard is surrounded by drainage intercept ditches sized to prevent local overland flow from reaching the ISFSI site. In addition, stormwater drainage is provided in the paved areas of the ISFSI site.

Therefore, flooding of the ISFSI site cannot occur either due to reservoir overflow or local intense precipitation.

2.4.1.2 Hydrosphere

The main hydrologic features influencing the Oconee plant site are the Jocassee and Keowee Reservoirs. Lake Jocassee was created in 1973 with the construction of the Jocassee Dam on the Keowee River. The lake provides pump storage capacity to the reversible turbine-generators of the Jocassee Hydroelectric Station, located approximately 11 miles north of the plant. At full pond, elevation 1110 ft. msl, Lake Jocassee has a surface area of 7565 Ac, a shoreline of approximately 75 mi, a volume of 1,160,298 Ac-ft., and a total drainage area of about 148 sq mi.

Lake Keowee was created in 1971 with the construction of the Keowee Dam on the Keowee River and the Little River Dam on the Little River. Its primary purpose is to provide cooling water for the plant and water to turn the turbines of the Keowee Hydroelectric Station. At full pond, elevation 800 ft. msl, Lake Keowee has a surface area of 18,372 Ac, a shoreline of approximately 300 mi, a volume of 955,586 Ac-ft., and a total drainage area of about 439 sq mi. The Jocassee and Keowee Reservoirs and the hydroelectric stations located at these reservoirs are owned and operated by Duke.

The area presently provides for a few raw water users. The City of Greenville and the Town of Seneca take their raw water supplies from Lake Keowee. The Town of Anderson, the Town of Clemson, the Town of Pendleton, Clemson University, and several industrial plants take their raw water supplies from Hartwell Reservoir, downstream of Lake Keowee.

1 Greenville's raw water intake is located approximately 2 miles north of the plant on Lake Keowee. Seneca's raw water intake is located approximately 7 miles south of the plant on the Little River Arm of Lake Keowee. Anderson raw water intake is located approximately 40 river miles downstream of the
1 Keowee tailrace.

1 The existing raw water intakes for Greenville, Seneca, and Anderson are shown and located relative to the
1 site on Figure 2.4.1 in the ISFSI Environmental Report.

2.4.2 FLOODS

2.4.2.1 Flood History

Since Oconee is located near the ridgeline between the Keowee and Little River valleys, or more than 100 ft. above the maximum known flood in either valley, the records of past floods are not directly applicable to siting considerations.

2.4.2.2 Flood Design Consideration

In accordance with sound engineering practice, records of past floods as well as meteorological records and statistical procedures have been applied in studies of floods routed through the Keowee and Jocassee Reservoirs as a basis for spillway and freeboard design.

The spillway capacities for Lake Keowee and Jocassee were selected in accordance with the empirical expression for design discharge:

$$Q = C \sqrt{DA}$$

Where Q = peak discharge in cfs
D A = drainage area in square miles
C = 5000, a runoff constant judged to be characteristic of the drainage area

The following tabulation gives pertinent data on this design flood flow:

Lake Keowee ⁽¹⁾	Lake Jocassee	
439	148	Drainage area at damsite, sq mi
25,200	21,000	Maximum recorded flow at nearby USGS gages, cfs D A
(Newry Gage, D A 455 sq mi)	(Jocassee Gage, D A 148 sq mi)	
8-13-40	10-4-64	Date of maximum flow
1939-1961	1950-1965	Period of record
105,000	61,000	Spillway design discharge, cfs
800	1,110	Full Pond elevation
815	1,125	Crest of dam elevation
0	0	Surcharge on full pond for design discharge
4	2	Number of spillway gates
38 ft. x 35 ft.	40 ft. x 32 ft.	Size of spillway gates Discharge capacity, cfs
107,200	45,700	Spillway
-	16,500	(2 units Dependable flood flow of 4) through units
-----	-----	Total discharge capacity, cfs
107,200	62,200	

Note: ⁽¹⁾Little River and Keowee River Arms

The above discharge capacities assume no surcharge above normal full pond level. Statistical analyses have shown design reservoir inflows for both Lake Keowee and Lake Jocassee equal to respective design discharge capacities outlined above to have recurrence intervals less frequent than once in 10,000 years.

The maximum wave height and wave run-up have been calculated for Lake Keowee and Lake Jocassee by the Sverdrup-Munk formulae. The results of these calculations are as follows:

Wave Height	Wave Run-Up	Maximum Fetch	Lake
3.70 ft.	7.85 ft.	8 miles	Keowee (Keowee River Arm)
3.02 ft.	6.42 ft.	4 miles	Jocassee
3.02 ft.	6.42 ft.	4 miles	Keowee (Little River Arm)

The wave height and wave run-up figures are vertical measurements above full pond elevations as tabulated above.

Studies were also made to evaluate effects on reservoirs and spillways of maximum hypothetical precipitation occurring over the entire respective drainage areas. This rainfall was estimated to be 26.6 inches within a 48 hour period. Unit hydrographs were prepared based on a distribution in time of the storms of October 4-6, 1964, for Jocassee and August 13-15, 1940, for Keowee. Results are summarized as follows:

Keowee	Jocassee	
147,800	70,500	Maximum spillway discharge, cfs
808.0	1114.6	Maximum reservoir elevation
7.0 ft.	10.4 ft.	Freeboard below top of dam

While spillway capacities at Keowee and Jocassee have been designed to pass the design flood with no surcharge on full pond, the dams and other hydraulic structures have been designed with adequate freeboard and structural safety factors to safely accommodate the effects of maximum hypothetical precipitation. Because of the time-lag characteristics of the runoff hydrograph after a storm, it is not considered credible that the maximum reservoir elevation due to maximum hypothetical precipitation would occur simultaneously with winds causing maximum wave heights and run-ups.

The maximum Keowee tailwater level during hydro operation has been calculated to be elevation 672.0 ft (msl), which is 124 ft. below the nuclear station yard elevation 796.0 ft. (msl) and 153 ft. below the ISFSI yard elevation of 825 ft. (msl).

The maximum discharge calculated, due to hydro operating, is expected to be 19,800 cfs. The minimum discharge calculated with no units operating, is expected to be 30 cfs.

In summary, the above results of flood studies show that Lakes Keowee and Jocassee are designed with adequate margins to contain and control floods which pose no risk to the ISFSI site.

2.4.3 PROBABLE MAXIMUM FLOOD ON STREAMS AND RIVERS

2.4.3.1 Probable Maximum Precipitation

See Section 2.4.2.2, "Flood Design Consideration" on page 2-28.

2.4.3.2 Runoff and Stream Course Models

See Section 2.4.2.2, "Flood Design Consideration" on page 2-28.

2.4.3.3 Probable Maximum Flood Flow

See Section 2.4.2.2, "Flood Design Consideration" on page 2-28.

2.4.3.4 Coincident Wind Wave Activity

See Section 2.4.2.2, "Flood Design Consideration" on page 2-28.

2.4.4 POTENTIAL DAM FAILURES, SEISMICALLY INDUCED

Duke has designed the Keowee Dam, Little River Dam, Jocassee Dam, Oconee Intake Canal Dike, and the Intake Canal Submerged Weir based on sound Civil Engineering methods and criteria. These designs have been reviewed by a board of consultants and reviewed and approved by the Federal Energy Regulatory Commission in accordance with the license issued by that agency. The Keowee Dam, Little River Dam, Jocassee Dam, Intake Canal Dike, and the Intake Canal Submerged Weir have also been designed to have an adequate factor of safety under the same conditions of seismic loading as used for design of Oconee.

The construction, maintenance, and inspection of the dams are consistent with their functions as major hydro projects. The safety of such structures is the major objective of Duke's designers and builders, with or without the presence of the nuclear station or ISFSI.

2.4.5 FLOODING PROTECTION REQUIREMENTS

2.4.5.1 Flood Protection Measures for Oconee Station Seismic Class 1 Structures

The Oconee Station plant yard elevation is 796.0 ft. msl and the ISFSI yard elevation is 825 ft. (msl). All of the man-made dikes and dams forming the Keowee Reservoir are constructed to an elevation of 815.0 ft. msl with a full pond elevation of 800.0 ft. msl. However, Class 1 structures and components at the station are not subject to flooding since the Probable Maximum Flood (PMF) would be contained by the Keowee Reservoir. The minimum external access elevation for the Auxiliary, Turbine, and Service Buildings is 796.5 ft. msl which provides a 6 in. water sill. Also, the plant site is provided with a surface water drainage system that protects the plants facilities from local precipitation.

In the Oconee PRA study, a postulated failure of the upstream Jocassee Dam resulted in a peak flood elevation at Keowee Dam of Elev. 813.12, which gives 1.9 feet available freeboard. Although the connecting canal between the two arms of Lake Keowee would lengthen the travel time of the flood wave, it is conservatively assumed that the water level resulting at Oconee Intake Dike would be the same as for Keowee Dam.

2.4.5.2 Flood Protection Measures for ISFSI Site

The site for the ISFSI is elevated well above the nominal plant yard grade at El. 825.0. Flooding of the ISFSI is not a credible event; therefore, no flood protection prevention measures are necessary.

2.4.6 ENVIRONMENTAL ACCEPTANCE OF EFFULENTS

The only liquid used for the ISFSI is during preparation of the DSC and transfer cask within the confines of the plant Auxiliary Building. No liquids are used during the actual operation of the ISFSI.

2.4.7 SUBSURFACE HYDROLOGY

The Independent Spent Fuel Storage Installation provides for the storage of spent nuclear fuel in a dry condition. Therefore, there will be no consumption of groundwater or impact to the groundwater system as a result of installing the ISFSI at the Oconee Station.

2.4.7.1 Groundwater Usage

The completed field survey of approximately 30 wells performed in the late 1960's determined that groundwater usage is almost entirely from the permeable zones within the saprolite with only minor amounts obtained from the underlying fractured bedrock. Yields from these shallow wells are low, generally less than 5 gpm, and are used to supply domestic water for homes and irrigation of lawns, gardens, and limited amounts for livestock. With only a few exceptions, the wells are hand dug, equipped with bucket lift and or jet pump, and 40 to 60 ft. deep. At present, there is no industrial demand for groundwater within the area. The only appreciable groundwater draft observed is being supplied by eight wells for Keowee High School, located four miles west of the site.

2.4.7.2 Regional Groundwater Conditions

The Oconee Station lies within the drainage area of the Little and Keowee Rivers which flow southerly into the Seneca River and subsequently discharge into the main drainage course of the Savannah River. The average annual rainfall at the site area is approximately 53 in.

The deposits of the Little and Keowee drainage basin are generally of low permeability which result in nearly total runoff to the two rivers and their numerous tributary creeks. Runoff occurs soon after precipitation, particularly during the spring and summer months when the soil percolation rates are exceeded by the short term but higher yielding rainfall periods. The area is characterized by youthful streams and creeks which discharge into the mature Little and Keowee Rivers.

Throughout the area, groundwater occurs at shallow depths within the saprolite (residual soil which is a weathering product of the underlying parent rock) soil mantle overlying the metamorphic and igneous rock complex (Reference 1 on page 2-87). Refer to Section 2.5, "Geology and Seismology" on page 2-43. This saprolite soil, which ranges in thickness from a few feet to over 100 ft., is the aquifer for most of the groundwater supply. Wells are shallow and few exceed a total depth of 100 ft. Depths to water commonly range from 5 to 40 ft. below the land surface. Seasonal fluctuation is wholly dependent of the rainfall and the magnitude of change may vary considerably from well to well due to the limited areas of available recharge. Average fluctuation is about 3 to 5 ft. Both surface water and groundwater in this area are of low mineral content and generally of good quality for all uses.

To determine the general groundwater environment surrounding the plant area, groundwater levels were established in numerous domestic wells and exploratory drill holes during the original program in the late 1960's within a four-mile radius. Additional data was obtained from interviews with local residents regarding specific wells and discussions with State and Federal personnel. The results of the groundwater level survey are shown on Figure 2-7 on page 2-38. The results demonstrate that local subsurface drainage generally travels down the topographic slopes within the more permeable saprolite soil zones toward the nearby surface creek or stream. Gross drainage is southward to the Little and Keowee Rivers which act as a base for the gradient.

Because the topography and thickness of the residual soil, overlying bedrock control the hydraulic gradient throughout the area, and further, the relief is highly variable within short distances, it is not possible to assign a meaningful average gradient for the 15 square mile area surveyed. In all small areas studied within the four-mile radius, the groundwater hydraulic gradient is steep and conforms to the topographic slope. Water released on the surface will percolate downward and move toward the main drainage channels at an estimated rate of 150 to 250 ft. per year.

The gradient throughout the area represents the upper surface of unconfined groundwater and therefore is subject to atmospheric conditions. Confined groundwater occurs only locally as evidenced by the existence of isolated springs and a few exploratory drill holes which encountered artesian conditions. These examples do not reflect general conditions covering large areas but merely represent isolated local strata within the saprolite soil which contain water under a semi-perched condition and/or permeable strata overlain by impermeable clay lenses which have been breached by erosion at its exit and recharged short distances upslope by vertical percolation.

The plant area is on a moderately sloping, northwest trending topographic ridge which forms a drainage divide between the Little and Keowee Rivers located approximately 0.5 mile to the west and east, respectively. Groundwater levels at the plant site, measured during the 1966 drilling program and subsequently in four piezometer holes drilled for pre-construction monitoring purposes, ranged from elevation 792 ft. (msl) to 696 ft. (msl). The slope of this apparently free water surface is predominantly southeasterly toward the Keowee River and its tributary drainage channels. An average hydraulic gradient

to the southeast of approximately 8.0 percent was plotted along a line of measured wells. This closely conforms to the existing topography as expected. Refer to Figure 2-8 on page 2-39 for measured water levels and typical water table profile.

2.4.7.3 Groundwater Quality

The surface water and groundwater of the area is generally of good quality (Reference 2 on page 2-87). Of the wells surveyed, none were noted where water treatment is being conducted. Temperature of well water measured ranged from a low of 46 to a high of 59 degrees. The majority of readings were from 50 to 53 degrees Fahrenheit.

Water contains different kinds and amounts of mineral constituents. Temperature, pressure and length of time water is in contact with different rock types and soils determine the type and amount of mineral constituents present. Because groundwaters are in intimate contact with the host rocks for longer periods of time, they have a higher mineral content than surface waters. The mineral content of natural surface waters in the Southeastern Province is low due to the relative insolubility of the granitic, gneissic, and schistose rocks and the reduced contact time caused by rapid runoff in the mountainous areas.

Tabulated below are the surface water samples reported in parts per million from the Keowee River near Jocassee, South Carolina. The water sample was taken and analyzed by the U.S. Geological Survey, Water Resources Division in June 1965.

Silica (SiO ₂)	7.8	Carbonate (CO ₃)	0.0
Iron (Fe)	0.01	Bicarbonate (HCO ₃)	7.0
Calcium (Ca)	1.0	Sulfate (SO ₄)	1.0
Magnesium (Mg)	0.1	Chloride (Cl)	0.6
Sodium (Na)	1.2	Fluoride (F)	0.1
Potassium (K)	0.4	Nitrate (NO ₃)	0.1
Dissolved Solids	15.0	Phosphate (PO ₄)	0.0
Hardness as CaCO ₃	3.0		
pH	6.6		
Specific Conductance	13.0		

Soil surveys conducted by the U.S. Department of Agriculture in cooperation with the South Carolina Agricultural Experiment Station assign pH values of between 5.0 and 6.0 for the Hayesville and Cecil soil series which are present at the site area (Reference 3 on page 2-87). Surface water samples taken from the Keowee River within one mile of the site have a pH of 6.5 to 7.0. It is expected groundwater at the site has a pH ranging between 5.5 and 6.0.

The cation exchange potential can be evaluated by knowing the SAR (Sodium Absorption Ratio), saturation extract values, and the pH of the soil. Two samples of saprolite soil were obtained from drill holes used in determining field permeability values and tested for Sodium Absorption Ratio (SAR). The results are tabulated as follows:

Saturation Extract Values
Milligram-equivalent per
100 grains of soil

Sample No.	pH	Cond. (mhos)	Calcium	Magnesium	Sodium	SAR
1	5.8	5	0.015	0.000	0.0108	0.122
2	5.7	7	0.010	0.000	0.0166	0.235

Considering the amount of soil that is available is so great, it is evident that many times the amount of strontium and or cesium contained in the waste could be absorbed. Further, the distribution coefficient for ion exchange of radionuclides with the sediments is dependent on the pH of the water in the formation (Reference 4 on page 2-87). The distribution coefficient is a ratio of the reaction of these radionuclides that are absorbed on the soil and the fraction remaining in solution. It is expected that the soils surrounding Oconee have a ratio in the range of 80 to 150, and consequently a substantially lower average velocity for any radionuclide to that of natural water will result.

The estimated maximum rate of movement of water through the soils is about 0.75 feet per day. Using this rate in relation with the above distribution coefficient, bulk density and porosity of the soil, and ratio of the weight of soil to volume of groundwater it indicates the radionuclide velocity will be about .0015 that of groundwater. Using a safety factor of five for variance in flow and competition for exchangeable sodium ions, it would require more than 1000 years for strontium or cesium ions to migrate a distance of one-half mile. In summary, the movement would be so extremely slow that the saprolite soil is an effective natural barrier to the migration of radionuclides.

2.4.7.4 Program of Investigation

Permeability tests were performed in borings in the late 60's as part of the original site investigation program to determine permeabilities of the soil underlying the site. The tests were run according to the Bureau of Reclamations Field Permeability Tests, Designation E-19. Figure 2-9 on page 2-40 shows the arrangement of the field test equipment along with a brief description of the procedure used in determining the soil permeability test results. Test results are from 5 borings as presented in Table 2-4 on page 2-37. The formulae used in the calculations of the k values are shown in Figure 2-10 on page 2-41. Field permeability tests conducted within the saprolite soil yielded values ranging from 100 to 250 ft./yr. The permeability tests were performed in holes of varying depths to determine if the zoned typed weathering of the saprolite soil affects vertical permeability. Based on the test results, inspection of nearby road cuts, and a study of the exploratory drill logs, it is concluded that the surficial saprolite possesses lower permeability values than that found in the deeper strata. This correlates with the general profile of the saprolite in that the later stages of weathering produce a soil having a higher clay content than the more coarse-grained silty sand sediments below. This natural process of weathering results in the formation of a partial barrier to downward movement of the surface water.

2.4.7.5 Groundwater Conditions Due to Keowee Reservoir

As previously discussed, the groundwater levels at the plant range from elevation 792 ft. (msl) to below elevation 696 ft. (msl). The Keowee Reservoir operates with a maximum pool elevation of 800 ft. (msl). This results in raising the surface water elevation to that datum on the northern and western portions of land adjoining Oconee. It also raises the existing groundwater table for those local areas bordering the reservoir where formerly the groundwater surface was below elevation 800.0 ft (msl). The reservoir materially contributes in establishing a potentially larger recharge area and where it effects the groundwater results in a more stable hydraulic gradient with less seasonal fluctuation than formerly existed.

Preliminary studies indicate that Keowee Reservoir has created the following groundwater conditions at Oconee.

1. Groundwater continues to migrate downslope through the saprolite soil on a slightly steeper gradient in a southeasterly direction toward the Keowee River base datum.
2. There are two topographic divides which separate the nuclear station from the nearby reservoir: (1) a one-half mile wide north-south stretch of terrain west of the site, and (2) a narrow 500 ft. wide ridge north of the site. Original groundwater measurements in drill hole K-12, located atop the northern ridge, show water table conditions exist at about elevation 810 ft. (msl).
3. There should be no reversal of groundwater movement at the site, and all water percolates downward and away from the plant area.
4. The construction of Keowee Dam and Reservoir has not created adverse groundwater conditions at the plant site.
5. Infiltration of domestic wells, located beyond the plant one-mile exclusion radius, by surface water from the site is not possible under the groundwater conditions imposed by Keowee Reservoir.

2.4.8 TABLES

Table 2-4. Soil Permeability Test Results

Well No.	h (ft)	r (ft)	$\frac{h}{r}$	T_u (ft)	Q (ft ³ /min)	T (°C)	WT Condition	k (ft./min)
NA 4W2	3.83	2.50	1.53	27.0	0.175	23.5	Low	3.9×10^{-5}
NA 11AW2	14.0	0.833	16.8	31.0	0.133	20.5	High	3.3×10^{-4}
NA 13W1	6.17	0.833	7.42	27.0	0.275	20.0	Low	2.0×10^{-4}
NA 15W1	14.0	0.833	16.8	30.3	0.240	20.5	High	6.1×10^{-4}
NA 15W2	12.25	0.833	14.7	30.5	0.190	21.0	High	5.1×10^{-4}

Note:

1. $\frac{h}{r} < 10$, not acceptable
2. $\frac{h}{r} < 10$, possibly acceptable
3. For manual incremental test, $k = 7.4 \times 10^{-4}$ ft/min

2.4.9 FIGURES




Figure 2-7.
Areal Groundwater Survey





Figure 2-8.
 Groundwater Survey at Station Site



Condition I
(Low Wt.)
 $T_u > 3h$

$$\text{Condition I: } k_{20} = 525,600 \frac{\left[\sinh^{-1} \frac{h}{r} - 1 \right] \frac{Q}{2\pi}}{h^2} \left(\frac{\mu_T}{\mu_{20}} \right)$$

$$\text{Condition II: } k_{20} = \frac{525,600 \log_e \frac{h}{r} \frac{Q}{2\pi}}{h^2 \left[\frac{1}{6} + \frac{1}{3} \left(\frac{h}{T_u} - 1 \right) \right]} \left(\frac{\mu_T}{\mu_{20}} \right)$$

k_{20} = coefficient of permeability, feet per year

h = height of water in the well, feet

r = radius of well, feet

Q = discharge rate of water from the well for steady state condition, ft^3/min .

μ_T = viscosity of water at temperature T

μ_{20} = viscosity of water at 20°C

T_u = unsaturated distance between the water surface in the well and the water table, feet

Figure 2-10.
Formulae For Determining Permeability

2.5 GEOLOGY AND SEISMOLOGY

Specific soil testing has been performed at the designated location for the ISFSI. The data obtained from this testing is utilized in the foundation design of the ISFSI (See Section 2.5.5, "ISFSI Foundation" on page 2-51). It should be noted that foundation conditions at the ISFSI site are typical of those encountered in the general station area. The following sections discuss the Oconee site geology and seismology.

2.5.1 BASIC GEOLOGIC AND SEISMIC INFORMATION

Geologic and seismic investigative studies for Oconee Nuclear Station include the following:

1. a review of the available geological and seismological literature pertaining to the region;
2. a geological reconnaissance of the site, performed primarily for the purpose of evaluating the possibility of active faulting in the area;
3. geophysical explorations and laboratory tests to provide parameters for evaluating the response of foundation materials to earthquake ground motion;
4. an evaluation of the seismic history to aid in the selection of the design earthquake that the station might experience; and
5. the development and recommendation of seismic design parameters for the proposed structures.

The geologic field work at the site was performed concurrently with the drilling for the original plant site. The site reconnaissance is a continuation of the geologic field work done for the Keowee Dam. Local outcrops, though scarce, are examined and the rock types, joint and foliation orientation noted.

The original plant structures are founded on normal Piedmont granite gneisses. The construction characteristics of the residual soils overlying the rock that form the foundation for the ISFSI are known and present no problems in design or construction. The rock underlying the site, below surface weathering, is hard and structurally sound and contains no defects which would influence the design of heavy structures.

The southeastern Piedmont rocks are highly stable seismologically, and the Oconee Nuclear Site should be one of the nation's most inactive areas with respect to earthquake activity.

2.5.1.1 Regional Geology

The regional structure is typical of the southern Piedmont and Blue Ridge. The region was subjected to compression in the northwest-southeast direction which produced a complex assortment of more or less parallel folds whose axes lie in a northeast-southwest direction. The Blue Ridge uplift was the climax of the folding, and it was accompanied by major faulting, along a line stretching northeast through Atlanta and Gainesville, Georgia and across South Carolina, 11 miles northwest of the site. This has been termed the Brevard Fault.

The age of these uplifts has not been agreed on by geologists. The consensus of geologic opinion seems to require a period of severe deformation followed by at least one additional period of less severity. Probably all occurred during the Paleozoic Era, but it has been suggested that the last major uplift was as late as the Triassic (180 million years ago) when the Coastal Plain to the east was downwarped. A number of

investigators have maintained that the major deformative movements occurred at least 225 million years ago. However, all the resulting stresses have not yet been fully dissipated.

There is no evidence of any displacement along these faults during either historic times or during the Geologic Recent Era as indicated in displacements in the residual soils that blanket the region. While the well known Brevard Fault passes 11 miles northwest of the site, there is no indication of a major fault in the immediate vicinity of the site. Furthermore, the major faults of the region are ancient and dormant, except for minor adjustments at considerable depth. Therefore, there is no indication of any structural hazard to foundations.

The site is underlain by crystalline rocks which are a part of the southeastern Piedmont physiographic province. This northeastward - trending belt of ancient metamorphic rocks extends northward from Alabama east of the Appalachians, and in South Carolina crosses the state from the Fall Line on the east to the Blue Ridge and Appalachian Mountains on the west. These rocks are generally recognized as being divided into four northeast-southwest trending belts in the Carolinas. From southeast to northwest they are the Carolina slate belt, Charlotte belt, Kings Mountain belt, and Inner Piedmont belt. The Oconee Nuclear Site is in the western, or Inner Piedmont Belt.

The Piedmont metamorphic rocks of the site were formed under many different combinations of pressure and temperature, and represent a complex succession of geologic events. The formerly accepted concept that the Piedmont consists only of the deep, worn-down roots of ancient mountains now seems untenable. The older theory that the rocks were exclusively of igneous origin is being replaced by the proposition that they represent highly metamorphosed sediments which have been folded, faulted, and injected to result in one of the most complex geologic environments in the world. It can be said with certainty, however, that these rocks represent some of the oldest on the continent. The new techniques of dating by radioactive decay have placed the age of the metamorphic episodes that produced these rocks as occurring from 1,100 my (million years) to 260 my ago. The successive northeastward trending bands of rocks vary greatly in lithology from granitic types to highly basic classifications, with gneisses and schists being the predominant classifications petrographically. In summary, the regional geology of the Oconee Nuclear Site can be accepted as typical of the southeastern Piedmont - narrow belts of metamorphic rocks trending northeast, with the foliation dipping generally to the southeast.

2.5.1.2 Site Geology

2.5.1.2.1 Geologic History, Physiography, and Lithography

The rock present at this site is metamorphic. It is believed to be Precambrian in age; thus, it was formed over 600 million years ago. The complete history of this region is quite complex and has not been fully unravelled. However, it is the consensus of the geologic opinion that the formation consisted of thick strata of sedimentary rocks which were later downwarped and altered by heat and pressure. This first rock formed is termed the country rock.

More than one episode of regional metamorphism transformed the rock into metasediments with accompanying injection and mobilization by plastic flow.

Since the formation of the country rock, most of the mass has been altered or replaced by injection of granite gneiss, biotite hornblende gneiss, and one or possibly more pegmatite dikes.

It is not definite which is the younger: the granite gneiss injection or the biotite hornblende gneiss injection. The limited evidence points to the granite gneiss as the younger of the two.

The pegmatite dikes are the youngest rock known at this site. One such dike is exposed in the road cut on the east side of the state highway passing through the site. It clearly shows the pegmatite cutting through the older rocks, and thus, demonstrates that it is the youngest.

Regional metamorphism, folding, and some minor faulting occurred concurrently much of this early time.

This site is located within the Inner Piedmont Belt, at this locality the westernmost component of the Piedmont Physiographic Province. The topography of the area is undulating to rolling; the surface elevations ranging from about 700 ft. to 900 ft. The region is moderately well dissected with rounded hilltops, representing a mature regional development. The area is well drained by several intermittent streams flowing away from the center of the site in a radial pattern.

The local geology of the Oconee Nuclear Site is typical of the southeastern Inner Piedmont Belt. The foundation rock is biotite and hornblende gneiss striking generally northeast, with the foliation dipping southeast. The rock is overlain by residual soils, which vary from silty clays at the surface, where the rock decomposition has completed its cycle, to partially weathered rock, and finally to sound rock.

The strike of the foliation planes or bands of mineral segregation is north 6 degrees to 15 degrees east with an average dip of 22 degrees to 28 degrees to the southeast. However, due to the local folding or warping at this site, minor variations in the strike and dip of the foliation will occur within the site.

There have been periods of erosion and perhaps even continuous erosion since the close of the Paleozoic Era. The rock now encountered at this site represents the deeper portions of the original metamorphic complex.

The rock encountered at this site is of three main types; light to medium gray granite gneiss, light gray to black biotite hornblende gneiss and white quartz pegmatite with local concentrations of mica, both muscovite and biotite varieties.

The dominate rock type at this site is the light to medium gray granite gneiss. This rock type is generally moderately hard and hard below the initial soft layers encountered in the rock surface. Joints in this rock are brown iron stained in the upper softer layers, but in the deeper harder rock, the joints are not stained. This helps illustrate that the jointing at this site does not control the weathering or decomposition of the rock.

The second most abundant rock type is the biotite hornblende gneiss. The rock is generally weathered or softer to a greater depth than the granite gneiss. This is probably due to the higher percentage of biotite mica. Biotite mica is a potassium magnesium-iron aluminum silicate. The iron content of the biotite mica causes the rate of decomposition to accelerate. However, generally at the deeper portions of the original plant borings, the biotite hornblende gneiss hardness increases to moderately hard or harder. Only a few thin soft layers were noted in this rock in the deeper portion of the original plant borings but not in the ISFSI site boring logs which are presented and discussed in Section 2.5.4, "Subsurface Materials" on page 2-50.

A few layers of hard quartz pegmatite with local concentrations of mica were recorded. The thickness of the pegmatite layers are generally less than three feet. These pegmatite layers are dikes. A dike is a sheetlike body of igneous rock that fills a fissure in the older rock which is encountered while in a molten condition. There is an exposure of mica-quartz pegmatite dike on the east side of the state road cut passing through this project. This dike exposure is about 3.5 ft. wide, but due to the lack of knowledge of orientation of the dike, the exact width cannot be computed. The quartz pegmatite encountered in the original station borings probably represent other smaller dikes of the same material. These dikes are of

hard, sound and durable material and should cause no concern to construction or foundation requirements.

2.5.1.2.2 Rock Weathering

Rock weathering at the Oconee Nuclear Site is about normal for Piedmont biotite gneisses. The range of depth before sound rock is reached is 0 to 35 ft. for the ISFSI foundation. Yard grade is nominally at elevation 825.0 msl. with the bottom of the foundation at elevation 822.0 msl. The resulting residual materials - clays, silts, and weathered rock - are structurally strong, and are used in situ for the foundation of this structure.

2.5.1.2.3 Jointing

The rock at the Oconee site is moderately jointed. All of the visible rock outcrops were studied in attempting to determine the correct orientation of the joint patterns.

Some moderately good rock outcrops were found and several joint pattern orientations measured. While studying and logging the original site rock cores, all of the joint dips were recorded. The dips of the joint patterns recorded in the rock cores were associated with the dips measured in the rock outcrops.

The rock has apparently not been subjected to stresses causing high concentrations of joints. The core borings indicate that jointing is widely spaced, and has not influenced the weathering pattern. Joints are about equally divided between strike and dip joints, with occasional oblique joints.

2.5.1.2.4 Ground Water

Subsurface water is typical of Piedmont area. The top of the zone of saturation, or water table, follows the topography, but is deeper in the uplands and more shallow in valley bottoms. It migrates through the pores of the weathered rock, where the feldspars have disintegrated and left interstitial spaces between the quartz grains. Additional water is contained in the deeper fractures and joints below the sound rock line. The water table is not stationary, but fluctuates continually as a reflection seasonal precipitation. Additional information on ground water is included in Section 2.4.7, "Subsurface Hydrology" on page 2-31. Groundwater elevations encountered during the ISFSI site borings are noted on the boring logs, Section 2.5.4, "Subsurface Materials" on page 2-50.

2.5.2 VIBRATORY GROUND MOTION

A seismological study for the Oconee Nuclear Site has been performed to determine the design and hypothetical earthquakes for the site and the ground motion associated with them. Details are discussed in Section 2.5.2, "Vibratory Ground Motion" on page 2-214 of Reference 5 on page 2-87.

2.5.2.1 Earthquake History

The largest earthquakes close to the site occurred near Charleston in August, 1886, some 200 miles from the site. Two shocks occurring closely in time, had an intensity estimated to be about Modified Mercalli IX at the epicenter and were perceptible over an area of greater than two million square miles.

Aftershocks of the main earthquake had intensities ranging up to Modified Mercalli VII. These shocks may be associated with a downfaulted Triassic basin under the coastal plain.

There have been two moderate earthquakes in the immediate vicinity of the plant since construction began.

In 1971, an earthquake occurred near Seneca, South Carolina. The descriptions of this event which occurred at 07:42 (EST) on July 13, 1971 have been examined from various sources. A MM intensity VI was assigned to the event by USGS based primarily on the report of a cracked chimney near Newry, about 10 km south of the present epicentral area. A detailed examination of the buildings and chimneys by Sowers and Fogle (1978) convinced them that the chimney in question had been broken and in a state of disrepair before the shock. They assigned an intensity IV (MM) to the shaking at Newry.

The July 13, 1971 event at 07:42 AM EDT was preceded by a felt shock at about 4:15 AM EDT and followed by at least one felt aftershock at 7:45 AM (Sowers and Fogle, 1978).

On August 25, 1979 (9:31 PM EDST, Aug. 26) a magnitude 3.7 earthquake occurred in the vicinity of Lake Jocassee, South Carolina. This MM intensity VI event was felt in an area of about 15,000 sq. km and was recorded locally on the three station Lake Jocassee seismographic network, and regionally on seismic stations in South Carolina, North Carolina, Georgia, Tennessee, and Virginia. During the period (August 26, 1979 - September 15, 1979) 26 aftershocks were recorded and they ranged in magnitude from -6.0 to 2.0.

A list of earthquakes in the region is provided in Table 2-5 on page 2-55.

2.5.2.2 Geologic Structures and Tectonic Activity

The region (defined as North Carolina and South Carolina, and parts of Georgia, Alabama, Tennessee, and Virginia) is comprised of three large northeast-southwest trending tectonic zones: The coastal plain, the crystalline-metamorphic zone and the overthrust zone.

The site is located nearly in the center of the crystalline-metamorphic zone, which consists of six generally recognized metamorphic belts. From southeast to northwest these are: The Carolina slate belt, Charlotte belt, Kings Mountain belt, Inner Piedmont belt, Brevard belt, and Blue Ridge belt. The site location is within the Inner Piedmont belt. The rocks in the belts consist of metamorphosed sediments and volcanics that have been folded, faulted, and intruded with igneous rocks. These belts are delineated by differing degrees of metamorphism. Generally, the degree of metamorphism becomes progressively less from the northwest to the southeast.

The oldest metamorphic rocks are located in the Blue Ridge belt. The more easterly belts of younger rocks have undergone progressively less metamorphism.

To the north and west are found a series of fault systems. Since these faults are both numerous and extensive, they can be grouped together and referred to as the overthrust zone. These faults no doubt resulted from the formation of the Appalachians.

The great system of thrust faults in the overthrust zone and most of the known faulting within the crystalline-metamorphic zone apparently occurred during the last period of metamorphism (260 million years ago).

During the Triassic Period (180 to 225 million years ago), sediments were deposited over parts of the exposed metamorphic belts. These deposits and the older metamorphics were intruded by a system of northwest-trending diabase dikes and were faulted by northeast-trending normal faults in the late Triassic Time (200 million years ago). Some of the older faults within the crystalline-metamorphic zone may have been active at this time.

From the late Triassic time until the present, the coastal plain has accumulated a sedimentary cover over its crystalline-metamorphic bedrock. These sediments overlap the bedrock and thicken toward the southeast, effectively masking any ancient faulting.

It is considered possible that igneous activity has occurred in the region after the Triassic because volcanic bentonitic clays of Eocene (approximately 50 million years ago) and possible Miocene age (12 million years ago) have been mapped in the sediments of the coastal plain in South Carolina. The source of this volcanic activity is presently unknown.

Faulting: The names, distances and directions from the proposed site, and the probable age of the known faulting in the region are as follows:

Name	Distance-Direction From Site	Probable Age Millions of Years
Brevard Fault	11 Miles NW	260
Dahlongega Fault	40 Miles W	260
Whitestone Fault	47 Miles NW	260
Towaliga Fault	90 Miles S	260
Cartersville Fault	104 Miles W	260
Gold Hill Fault	115 Miles E	260
Goat Rock Fault	140 Miles SW	260
Triassic, Deep River Basin, N.C. and S.C.	140 Miles E	200
Triassic, Danville Basin, N.C.	145 Miles NE	200
Crisp and Dooly Counties, Ga.	190 Miles SW	12 to 70
Probable Triassic Basin Charleston, S.C.	200 Miles SE	200

The first seven faults are all associated with the last metamorphic period. The Brevard, Whitestone, Dahlongega, and Cartersville faults apparently form an interrelated system. This system separates the eastern metamorphic belts from the Blue Ridge metamorphic belt and the overthrust zone on the west.

The Towaliga, Goat Rock, and Gold Hill Faults, and the Kings Mountain belt apparently form another interrelated alignment within the eastern metamorphic belts. The Kings Mountain belt is not considered a fault. Its association and alignment in relation to the three known faults mentioned and the location of earthquake epicenters within the area bounded by these features, lead to the conclusion that these features form an interrelated alignment.

There is no surface indication that any of these three faults have been active since the Triassic Period (200 million years).

Two fault locations in the region have been thoroughly investigated by borings. These are the Cartersville fault near the Allatoona Dam, and the Oconee-Conasauga fault in Georgia. These faults were found to be completely healed and not to have moved in many millions of years.

The Triassic basins of the Carolinas and further north may be due to the release of the compressional forces which formed the Appalachians. These basins are down-faulted grabens which are filled with

Triassic sediments. Two earthquakes in the vicinity of McBee, South Carolina, may be related to an extension of a Triassic basin which has been inferred in the Chesterfield-Durham area.

Some faulting within the tertiary sediments in Dooly, Spalding, and Clay Counties, Georgia, has been mapped. The true areal extent of this faulting is unknown. This faulting apparently ranges from Cretaceous to possibly Miocene in age (70 to 12 million years).

The earthquake activity near Charleston, South Carolina, may indicate an active fault in that region. However, no evidence of surface faulting has been found.

2.5.2.3 Correlation of Earthquake Activity with Geologic Structures or Tectonic Provinces

The region surrounding the Oconee Station site can be divided into three major areas on the basis of the regional tectonics and the seismic history. These major seismic areas are:

1. the overthrust zone and Blue Ridge metamorphic belt;
2. the crystalline-metamorphic zone, exclusive of the Blue Ridge belt; and
3. the coastal plain.

The greatest number of recorded shocks have occurred within the overthrust zone and the Blue Ridge metamorphic belt northwest of the Brevard, Whitestone, Dahlonga, and Cartersville fault system. The epicenters in this area are generally widely scattered.

There have been a small number of earthquakes within the crystalline-metamorphic zone, exclusive of the Blue Ridge metamorphic belt. These earthquakes, extending from central Georgia to North Carolina, may be associated with the Towaliga, Goat Rock, Gold Hill, Kings Mountain alignment.

The coastal plain has experienced few earthquakes outside of the Charleston area. Four shocks, at Wilmington, North Carolina and Savannah, Georgia, have occurred but are unrelated to any known faulting, although the Wilmington shocks were adjacent to the Cape Fear Arch.

The only earthquake which does not closely fit this system of seismic areas is the 1924 shock in Pickens County, South Carolina (MM V Intensity). However, it is likely that this earthquake is associated with the overthrust-Blue Ridge seismic area.

2.5.2.4 Maximum Earthquake Potential

The assignment of probable future earthquake activity can only be based upon the previous record and the known geology of the area. Although the seismic history of the region is fairly short, a reasonable picture of the seismicity of the area becomes apparent from a study of the epicenter locations and the regional tectonics.

There are three significant zones of seismic activity in the general vicinity of the site; the Brevard and related faults zone, the overthrust zone, and the Towaliga, Goat Rock, Gold Hill, Kings Mountain alignment.

An evaluation of the earthquake activity and the regional geology can result in the selection of a series of maximum-sized shocks which are likely to occur in these various areas. Conservatively, we can assume that the previous maximum-sized shock on a particular fault zone can occur during the economic life of the power station and ISFSI at perhaps the nearest approach of the particular fault system to the site.

Zone	Location	(MM) intensity at Epicenter	Estimated Magnitude (Richter)
Brevard Fault Zone	11 Miles NW	VI	Less than 4½ to 5
Overthrust	75 Miles NW	VIII	Less than 5½ to 6
Towaliga, Goat Rock Gold Hill, Kings Mountain Alignment	30 Miles SE	VII-VIII	Less than 5½ to 6

2.5.2.5 Seismic Wave Transmission Characteristics of the Site

Static and dynamic engineering properties of the soil and rock materials that underlie the general plant site area are discussed in Section 2.5.4, "Stability of Subsurface Materials and Foundations" on page 2-87 of Reference 5 on page 2-87. Design response spectra that include considerations of the thickness and distribution of these materials are discussed in Section 2.5.2.8, "Design Response Spectra" on page 2-219 of Reference 5 on page 2-87.

2.5.2.6 Maximum Hypothetical Earthquake (MHE)

The MHE acceleration value is 0.15 g for structures founded on overburden. The design response spectra are covered in Section 2.5.2.8, "Design Response Spectra."

2.5.2.7 Design Base Earthquake

It is considered likely that the shocks listed in Section 2.5.2.4, "Maximum Earthquake Potential" on page 2-49 could occur no closer than the indicated distances from the site during the life of the planned facilities. Since the magnitudes of these shocks are fairly small, the distance from the epicenter becomes extremely important. Ground accelerations would diminish rapidly with the distance from the epicenter. Although larger earthquakes occur within other fault zones, the highest ground accelerations at the site would be experienced from an earthquake along the Brevard fault zone. The assumption of a shock of less than Richter Magnitude five occurring along the Brevard fault zone at its closest location to the site (11 miles), would give ground motions on the order of five percent of gravity at the site. Vertical ground accelerations, as contrasted to the horizontal accelerations, would be only slightly less than five percent of the gravity in the competent rock at the site.

2.5.2.8 Design Response Spectra

The Oconee FSAR provides that the maximum ground acceleration for structures founded on overburden (MHE) is .15g (Reference 5 on page 2-87, Section 2.5.2, "Vibratory Ground Motion" on page 2-214 and Figure 2-51 on page 2-244). The accelerations considered and used for the design of the NUHOMS-24P system envelope the MHE acceleration (Reference 6 on page 2-87).

2.5.3 SURFACE FAULTING

This information is discussed in Sections 2.5.1, "Basic Geologic and Seismic Information" on page 2-43 and 2.5.2, "Vibratory Ground Motion" on page 2-46.

2.5.4 SUBSURFACE MATERIALS

2.5.4.1 Exploration

A grid pattern of borings was established to provide the maximum amount of information for determining the foundation and soil conditions and permit flexibility in final ISFSI layout, alignment, and elevation.

The general site area is shown on Figure 2-11 on page 2-60 and the site and boring layout is shown on the Boring Plan, Figure 2-12 on page 2-61.

The drilling, sampling, and rock coring were performed in accordance with methods specified by the American Society for Testing and Materials:

"Penetration Testing and Split Barrel Sampling of Soils" - D-1586-64T

"Diamond Core Drilling for Site Investigation" - D-2311-62T

"Thin Walled Tube Sampling of Soils" - D-1567-63T

Boring logs are given in Figure 2-13 on page 2-62 through Figure 2-26 on page 2-85.

2.5.4.2 Groundwater Conditions

Section 2.4.7, "Subsurface Hydrology" on page 2-31 provides a discussion of the existing groundwater conditions at the Oconee site.

It is anticipated that the removal of the overburden due to ISFSI construction will have little, if any, effect on the water table. If the water table elevation does change, it is anticipated that it will drop slightly. The present elevation of the water table at the ISFSI site varies from elevation 797 feet at the south end to elevation 822 feet at the north end.

Hydrostatic uplift will not occur during the life of the ISFSI because the foundation of the HSMs and associated pavement is at or above the water table. There may be some seepage through the cut into the hillside; however, adequate drainage is provided around the ISFSI site to carry away seepage.

At the south end of the ISFSI site, the elevation of the water table is far below the foundation of the HSMs. At the north end, the foundation of the HSMs will be near the water table elevation. However, the HSM structure at the north end of the ISFSI site is partially founded on rock. Therefore, there will be no reduction of shear resistance due to potential seepage along that bedding.

2.5.5 ISFSI FOUNDATION

A specific soil testing (results and locations presented in Section 2.5.4, "Subsurface Materials" on page 2-80) and foundation evaluation has been performed at the ISFSI site to assist in the development of the insitu static soil bearing pressure. Fourteen (14) soil borings were taken in and around the ISFSI site. The location of these borings is shown in Figure 2-12 on page 2-61. A line of boring was taken along the length of the future foundation of the HSMs. From these borings several undisturbed samples were taken. Several tests, including the triaxial shear test, were performed on selected undisturbed samples. The results from the triaxial shear test provided essential information used to determine the ultimate and allowable bearing capacity. (The triaxial shear tests were performed in accordance with the Corps of Engineers Manual EM10-2-1906, Appendix 10).

After inspection of the boring logs, soil samples, and tests, the worst case soil data were selected and used in the Meyerhoff bearing capacity equation to determine the ultimate soil bearing capacity, which is approximately 12.0 kips square foot. To obtain the allowable static soil bearing capacity, a factor of

safety of 3.0 was applied to the ultimate capacity, which yields the allowable bearing pressure of 4.0 kips-square foot (Reference 9 on page 2-87).

The largest applied static bearing pressure was calculated by first determining the dead weight of the HSM with a fully loaded DSC and then dividing by the area of the foundation. This maximum applied static bearing pressure was computed to be 3.3 kips square foot, which is less than the allowable soil bearing pressure of 4.0 kips square foot.

As shown by the boring logs, the HSM foundation will to a large degree rest entirely on either firm soil or partially weathered rock with penetration blow counts ranging from $n = 12$ to refusal. A conservative analysis was performed to determine the worst-case settlement of an HSM array. Both a 2x3 array and a 2x10 HSM array were considered. This analysis indicates that the worst-case differential settlement will cause the 2x10 HSM array to experience a differential settlement of about 3.0 inches along the North-South axis. Differential settlement in the East-West direction will be negligible.

These settlements are accounted for in the foundation design. The foundation was analyzed as a finite module using the computer code McAuto STRUDL (Reference 7 on page 2-87).

This computer code models settlements by the use of calculated soil springs which provide consideration for the settlements. Considering the small magnitude of this settlement, the integrity and radiological shielding of the HSM will not be adversely impacted. The foundation structure consists of a 3 ft. reinforced concrete mat. Typical H-1 reinforcement is shown in Figure 8.1-9 of Reference 6 on page 2-87.

The limiting calculated maximum stresses and allowable stresses for loadings as defined by Reference 6 on page 2-87 envelope the site foundation stresses for the Oconee ISFSI site. These forces are for the accident condition assuming blocked vents and bound all other loading combinations.

2.5.6 LIQUEFACTION

Potential liquefaction of soils under the Oconee ISFSI foundation area is not a concern because all of the foundation materials are non-liquefiable. The three foot thick concrete mat bears entirely on either firm soil or partially weathered rock having Standard Penetration Test blowcounts ranging from $N = 12$ to refusal. Figure 2-11 on page 2-60 shows the longitudinal profile of the ISFSI foundation level in relation to both the original ground and to partially weathered rock, based on site borings.

2.5.7 SLOPE STABILITY

The ISFSI site includes cut slopes along both sides of the ISFSI site access road, and along the west, north, and northeastern sides of the ISFSI site as shown in Figure 2-11 on page 2-60. Fill slopes are located along the southeastern and south sides of the ISFSI site. The maximum vertical cut is approximately fifty feet and the maximum vertical fill is approximately ten feet. The maximum ISFSI slope is two horizontally to one vertically.

The stability of slopes associated with the ISFSI site were modeled by a program that utilizes the circular arc analysis method of slices. The program postulates a failure arc through the soil embankment or foundation, computes the soil mass driving moment and the soil mass resisting moments associated with the postulated failure arc, and then determines the resulting safety factor by dividing the total resisting moment by the total driving moment. The computer program allows the computation of a large number of safety factors associated with many postulated failure arcs (Reference 8 on page 2-87).

The slope stability analyses were performed using the maximum ISFSI site slope of two horizontal to one vertical. Actual site soil engineering parameters, based on laboratory testing of soil samples, were determined. (Reference the site boring records presented in Figure 2-13 on page 2-62 through Figure 2-26 on page 2-85.) The Seismic Design Input Criteria specified in Section 3.2.3.1, "Input Criteria" on page 3-10 were used as input in determining the seismic behavior of the ISFSI site slopes.

The minimum safety factors calculated for any postulated failure arc of the vertical cut and fill slopes of the ISFSI site are as follows:

<u>Slope Loading Condition</u>	<u>Minimum Calculated Safety Factor</u>
55 feet vertical cut slope, static	1.62
55 feet vertical cut slope, dynamic	1.22
10 feet vertical fill slope, static	2.06
10 feet vertical fill slope, dynamic	2.03

Therefore, the stability of the ISFSI site slopes is ensured since the minimum safety factor is greater than 1.0 for all slopes for all analyzed conditions.

2.5.8 TABLES

Table 2.5 (Page 1 of 5). Significant Earthquakes in the Southeast United States (Intensity V or Greater)

Year	Date	Intensity (Modified Mercalli)	Locality	Epicentral Location			Perceptible Area (Square Miles)
				N.E.at.	W.Long.		
1843	January 4	VIII	Western Tennessee	35.2	90.0	400,000	
1857	December 19	Not Listed	Charleston, S.C.	32.8	79.8	Not Listed	
1872	June 17	V	Milledgeville, Ga.	33.1	83.3	Not Listed	
1874	February 10 April 17	V	McDowell County, N.C.	35.7	82.1	Local	
1875	November 1	VI	Northern Georgia	33.8	82.5	25,000	
1875	December 22	VIII	Arvonia, Virginia	37.6	78.5	50,000	
1877	November 16	V	Western N.C. and Eastern Tennessee	35.5	84.0	5,000	
1879	December 12	V	Charlotte, N.C.	35.2	80.0	Not Listed	
1884	January 18	V	Wilmington, N.C.	34.3	78.0	Local	
1885	August 6	IV-V	North Carolina	36.2	81.6	Local	
1886	February 4	V	Alabama	32.8	88.0	1,600	
1886	August 31	IX-X	Charleston, S.C.	32.9	80.6	2,000,000	
1886	October 22	VI	Charleston, S.C.	32.9	80.0	30,000	
1886	October 22	VII	Charleston, S.C.	32.9	80.0	30,000	
1886	November 5	VI	Charleston, S.C.	32.9	80.0	30,000	
1889	July 19	VI	Memphis, Tenn.	35.2	90.0	Local	
1897	April 30	IV-V	Tennessee and Ill.	Not Listed	Not Listed	Not Listed	
1897	December 18	V	Ashland, Virginia	37.7	77.5	7,500	
1900	October 31	V	Jacksonville, Fla.	30.4	81.7	Local	

Table 2-5 (Page 2 of 5). Significant Earthquakes in the Southeast United States (Intensity V or Greater)

Year	Date	Intensity (Modified Mercall')	Locality	Epicentral Location		Perceptible Area (Square Miles)
				N.Lat.	W.Long.	
1902	October 18	V	Southeastern Tenn. and Northwestern Ga.	35.0	85.3	1,500
1903	January 23	VI	Georgia and S.C.	32.1	81.1	10,000
1904	March 4	V	Eastern Tenn.	35.7	83.5	5,000
1905	January 27-8	VII	Alabama	34	86	250,000
1907	April 19	V	South Carolina	32.9	80.0	10,000
1911	April 20	V	North Carolina- South Carolina Border	35.2	82.7	600
1912	June 12	VII	Summersville, S.C.	32.9	80.0	35,000
1912	June 20	V	Savannah, Georgia	32	81	Not Listed
1913	January 1	VII-VIII	Union County, S.C.	34.7	81.7	43,000
1913	March 28	VII	Eastern Tennessee	36.2	83.7	2,700
1913	April 17	V	Eastern Tennessee	35.3	84.2	3,500
1914	January 23	V	Eastern Tennessee	35.6	84.5	Local
1914	March 5	VI	Georgia	33.5	83.5	50,000
1914	September 22	V	South Carolina	33.0	80.3	30,000
1915	October 29	V	North Carolina	35.8	82.7	1,200
1916	February 21	VI	Western N.C.	35.5	82.5	200,000
1916	August 26	V	Western N.C.	36	81	3,800
1916	October 18	VII	Alabama	33.5	86.2	100,000
1917	June 29	V	Alabama	32.7	87.5	Local
1918	June 21	V	Tennessee	36.1	84.1	3,000

Table 2.5 (Page 3 of 5). Significant Earthquakes in the Southeast United States (Intensity V or Greater)

Year	Date	Intensity (Modified Mercalli)	Locality	Epicentral Location			Perceptible Area (Square Miles)
				N. Lat.	W. Long.		
1918	October 15	V	Western Tennessee	35.2	89.2	20,000	
1920	December 24	V	Eastern Tennessee	36	85	Local	
1924	October 20	V	Pickens County, S.C.	35.0	82.6	56,000	
1926	July 8	VI	Southern Mitchell County, N.C.	35.9	82.1	Local	
1927	June 16	V	Alabama	34.7	86.0	2,500	
1928	November 2	VI	Western N.C.	36.0	82.6	40,000	
1931	May 5	V-VI	Northern Alabama	33.7	86.6	6,500	
1933	December 19	IV-V	Summerville, S.C.	33.0	80.2	Local	
1935	January 1	V	North Carolina- Georgia Border	35.1	83.6	7,000	
1939	May 4	V	Anniston, Ala.	33.7	85.8	Not Listed	
1941	November 16	V-VI	Covington, Tenn.	35.5	89.7	Local	
1945	June 13	V	Cleveland, Tenn.	35	84.5	Not Listed	
1945	July 26	VI	Murray Lake, S.C.	34.3	81.4	25,000	
1952	November 19	V	Charleston, S.C.	32.8	80.0	Not Listed	
1952	July 16	VI	Dyersburg, Tenn.	36.2	89.6	Not Listed	
1954	Jan , 22	V	Athens and Etowah, Tennessee	35.3	84.4	Not Listed	
1954	April 26	V	Memphis, Tenn.	35.2	90.1	Not Listed	
1955	January 25	VI	Tenn.-Arkansas- Missouri Border	35.6	90.3	30,000	

Table 2-5 (Page 4 of 5). Significant Earthquakes in the Southeast United States (Intensity V or Greater)

Year	Date	Intensity (Modified Mercalli)	Locality	Epicentral Location			Perceptible Area (Square Miles)
				N Lat.	W Long.		
1955	March 29	VI	Finley, Tenn.	36.0	89.5	Not Listed	
1955	September 5	V	Finley, Tenn.	36.0	89.5	Not Listed	
1955	September 28	V	Virginia-N.C. Border	Not Listed	Not Listed	1,700	
1955	December 13	V	Dyer County, Tenn.	36	89.5	Not Listed	
1956	September 7	VI	Eastern Tennessee	35.5	84.0	8,300	
1956	January 28	VI	Tennessee-Arkansas Border	35.6	89.6	Not Listed	
1957	April 23	VI	Northern Alabama	34.5	86.7	11,500	
1957	May 13	VI	Western N.C.	35.7	82	8,100	
1957	June 23	V	Eastern Central Tennessee	36.5	84.5	Not Listed	
1957	July 2	VI	Western N.C.	35.5	83.5	Not Listed	
1957	November 24	VI	North Carolina- Tennessee Border	35	83.5	4,100	
1958	March 5	V	Wilmington, N.C.	34.2	77.7	Not Listed	
1958	April 8	V	Obion County, Tenn.	36.2	89.1	400	
1958	October 20	V	Anderson, S.C.	34.5	82.7	Local	
1959	August 3	VI	South Carolina	33	79.5	25,000	
1959	August 12	VI	Alabama-Tennessee Border	35	87	2,800	
1959	October 26	VI	Northeastern S.C.	34.5	80.2	4,800	
1959	December 21	V	Finley, Tenn.	36	89.5	400	
1960	January 28	V	Dyer County, Tenn.	36	89.5	Local	
1960	February 26.2	V	Near Coast, S.C.	33	79	3,500	

Table 2.5 (Page 5 of 5). Significant Earthquakes in the Southeast United States (Intensity V or Greater)

Year	Date	Intensity (Modified Mercalli)	Locality	Epicentral Location		Perceptible Area (Square Miles)
				N.Lat.	W.Long.	
1960	April 15	V	Eastern Tenn.	35.7	84	1,300
1960	April 21	V	Lake County, Tenn.	36.3	89.5	Local
1960	July 23	V	Charleston, S.C.	33	80	Local
1971	July 13	IV-VI	Seneca, S.C.	34.35	82.83	Local
1979	August 25	VI	Lake Jocassee, S.C.	35	83	5,800

2.5.9 FIGURES




Figure 2-11.
General Site Area




Figure 2-12.
Site Boring Plan

BORING
DESIGNATION 1

Depth Ft	Description	ROD BIT		Remarks
		Size	Elev	
0.0	Red micaceous silty fine to medium sand		881.80	N = 13
5.0	Strong brown micaceous fine to medium sandy silt		876.80	N = 6
10.0	Gray/brown micaceous silty fine/coarse sand		871.80	N = 11
15.0			866.80	Undisturbed Sample 17.6'-19.5'
20.0	Black/gray micaceous slightly silty fine/coarse sand w/gravel		861.80	N = 12
22.6	Brown micaceous silty fine/coarse sand Black/reddish brown very micaceous fine to medium sandy silt		859.20	N = 6
25.0	Brown/white micaceous silty fine to coarse sand		856.8	N = 10
30.0	Black/gray micaceous silty fine to coarse sand		851.8	N = 100

Figure 2-13 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION 1

Depth Ft	Description	ROD BIT		Elev	Remarks
		Size	Size		
35.0	Black light gray micaceous slightly silty fine to coarse sand			846.80	N = 100 Undisturbed Sample 37.6' - 37.8'
40.0	Light brown/light gray micaceous slightly silty fine to coarse sand			841.80	N = 49
45.0	Top: Reddish brown micaceous fine sandy silt. Bottom: Light brown to gray (light) micaceous slightly silty fine to coarse sand			836.80	N = 100
50.7	Carbide fishtail refusal			831.10	
55.0		42.9	NX		
60.0		84.5	NX	821.80	
60.2	Water Table			821.60	
70.0		98.0	NX	811.80	
79.4	Coring Terminated			802.40	

Figure 2-13 (Part 2 of 2).
Core Boring Record

BURING
DESIGNATION 2

Depth Ft	Description	ROD BIT		Elev	Remarks
		X	Size		
0.0	Brownish red micaceous silty fine to coarse sand			881.62	N = 29
5.0	Brownish red micaceous fine to medium sandy silt, Black/light gray silty sand at bottom of sample			876.62	N = 100
10.0	Black strong brown micaceous silty fine to coarse sand			871.62	N = 100
14.5	Carbide fishtail refusal			867.12	
15.0		0.0	NX	866.62	
20.0				861.62	
25.0		0.0	NX	856.62	
30.6	Re-enter Hole w/fishtail Light brown to gray micaceous silty fine to medium sand			851.02	N = 17
35.0				846.62	Undisturbed sample 38.1' - 39.9'
40.0	Brown to light gray micaceous silty fine to coarse sand			841.62	N = 100

Figure 2-14 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION 2

Depth Ft	Description	ROD BIT		Elev	Remarks
		S	Size		
45.0	Brown to light gray micaceous silty fine to coarse sand			836.62	N = 100
53.7	Carbide fishtail refusal			827.92	
55.0				826.62	
60.0		97.0	KX	821.62	
60.3	Water Table			821.32	
70.0		100.0	KX	811.62	
78.8	Coring Terminated			802.82	

Figure 2-14 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION 3

Depth Ft	Description	ROD BIT		Elev	Remarks
		3	Size		
0.0				834.41	
5.0	Light brown/light gray micaceous silty fine to medium sand, strong brown/black micaceous silty fine to medium sand			829.41	N = 100
10.4	Carbide fishtail refusal			824.01	
15.0		3.6	NX	819.41	
18.9	Water Table			815.51	
19.9	Boring Terminated			814.51	

Figure 2-15.
Core Boring Record

BORING
DESIGNATION 4

Depth Ft	Description	ROD BIT		Remarks
		Size	Flow	
0.0			828.37	
5.0	Yellowish brown/light gray micaceous silty fine to coarse sand		823.37	N = 37
10.0	Brown/light gray micaceous silty fine to coarse sand		818.37	N = 100
13.1	Carbide fishtail refusal		815.27	
15.0		59.4 NX	813.37	
18.1	Water Table		810.27	
20.0	Coring Terminated		808.37	

Figure 2-16.
Core Boring Record

BORING
DESIGNATION B-1

Depth Ft	Description	ROD BIT		Elev	Remarks
		S	Size		
0.0	Reddish brown, mica, silty, fine to coarse sand (some ground)			828.32	N = 45
5.0				823.32	Undisturbed Sample 7.4'-9.9'
10.0	Olive brown, mica, silty, fine to medium sand			818.32	N = 10
15.0	Reddish yellow, mica, silty, fine to medium sand			813.32	Undisturbed Sample 17.4'-19.9' N = 51
20.0	Reddish yellow, mica, silty, fine to medium sand			808.32	N = 44
25.0	Light olive brown/white, mica, silty, fine to medium sand			803.32	Undisturbed Sample 27.4'-28.6' N = 49
30.0	Light olive brown/white, mica silty, fine to medium sand			798.32	Undisturbed Sample 32.4'-33.5' N = 100
32.5	Water Table			795.82	

Figure 2-17 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION B-1

Depth Ft	Description	R.O. BIT		Elev	Remarks
		S	Size		
35.0	Light olive brown, mica, silty fine to coarse sand			792.32	N = 100
40.0	Light olive brown/white, mica, silty fine to medium sand			788.32	N = 100
46.7	Carbide fishtail re-veal			781.62	
50.0		55.4	NQ	778.32	
55.0				773.32	
60.0		80.9	NQ	768.32	
64.5	Coring Terminated			763.82	

Figure 2-17 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION B-2

Depth Ft	Description	ROD BIT		Elev	Remarks
		Size	Size		
0.0				831.01	Undisturbed Sample 2.5'-5.0'
5.0	Strong brown, mica, silty fine to medium sand			826.01	N = 8 Undisturbed Sample 7.5'-10.0'
10.0	Light pale brown, mica, silty, fine to medium sand			821.01	N = 15 Undisturbed Sample 12.5'-15.0'
15.0	Yellowish brown, mica, silty, fine to medium sand			816.01	Undisturbed Sample 15.0'-16.7' N = 23
20.0	Strong brown, mica, silty, fine to medium sand			811.01	N = 100
25.0	No Description			806.01	N = 100
30.0	Very pale brown/yellowish brown mica, silty, fine to coarse sand			801.01	N = 30
32.2	Water Table			798.81	

Figure 2-18 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION B-2

Depth Ft	Description	ROD %	BIT Size	Elev	Remarks
37.4	Carbide fishtail refusal			793.61	
40.0		40.8	NQ	791.01	
45.0		61	NQ	786.01	
50.0		100	NQ	781.01	
59.0	Coring Terminated			772.01	

Figure 2-18 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION B-3

Depth Ft	Description	ROD BIT		Elev	Remarks
		%	Size		
0.0				820.98	Undisturbed Sample 2.0'-4.5'
5.0	Light yellowish brown/reddish brown, mica, silty, fine to medium sand			815.98	Undisturbed Sample 4.5'-7.0' N = 12
10.0	Light yellowish brown/strong brown, mica, fine to medium sandy silt			810.98	Undisturbed Sample 12.0'-14.5' N = 11
15.0				805.98	Undisturbed Sample 17.0'-19.5'
20.0	Light yellowish brown/strong brown mica, fine to medium sandy silt			800.98	Undisturbed Sample 19.5'-22.0' N = 13
23.9	Water Table			797.08	
25.0				795.98	Undisturbed Sample 27.0'-29.5'
30.0	White/pinkish gray, mica, silty, fine to coarse sand			790.98	N = 65 Undisturbed Sample 32.0'-33.6'

Figure 2-19 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION B-3

Depth Ft	Description	ROD BIT		Elev	Remarks
		Size	Size		
35.0	White/pinkish gray, mica, silty, fine to medium sand			785.98	N = 100
37.0	White/pinkish gray, mica, silty, fine to medium sand			783.98	N = 27
40.1	Carbide fishtail refusal			780.88	
45.0		99	HQ	775.98	
50.1	Coring Terminated			770.88	

Figure 2-19 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION B-4

Depth Ft	Description	ROD BIT		Elev	Remarks
		%	Size		
0.0				878.53	Undisturbed Sample 2.4'-4.9'
5.0	Reddish brown/red, mica, silty, fine to medium very sandy clay			873.53	N = 19 Undisturbed Sample 7.4'-9.9'
10.0	Reddish brown/red, mica, silty, fine to medium very sandy clay			868.53	N = 100
	Light brown yellow/yellowish brown, mica, silty, fine to coarse sand (with gravel)				N = 49
15.0	Light brownish yellow/yellowish brown, silty, fine to coarse sand			863.53	N = 100
20.2	Carbide fishtail refusal			858.33	
25.0		12.2	NO	853.53	
30.0		0	NO	848.53	
35.0				843.53	
40.0	Yellow/brownish yellow, mica, silty fine to medium sand			838.53	N = 100

Figure 2-20 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION B-4

Depth Ft	Description	ROD BIT		Elev	Remarks
		I	Size		
	Pale brown/light yellow brown, mica, silty, fine to medium sand				N = 100
43.9	Water Table			834.63	
45.0	No Description			833.53	N = 100
49.9	Carbide fishtail refusal			828.63	
50.0				826.53	
55.0		91	NQ	823.53	
59.9	Coring Terminated			818.63	

Figure 2-20 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION B-5

Depth Ft	Description	ROD BIT		Remarks
		%	Size Elev	
0.0			853.63	Undisturbed Sample 2.2'-4.7'
5.0	Red/Reddish brown, mica, silty, fine/medium sand		848.63	N = 12 Undisturbed Sample 7.2'-8.2'
	Red/yellowish red, mica, silty, clay, fine to medium sand			N = 12
10.0			843.63	Undisturbed Sample 12.2'-14.7'
15.0	Light yellow brown/brownish yellow, mica, silty, fine to coarse sand (with gravel)		838.63	Undisturbed Sample 14.7'-17.2' N = 11
20.0			833.63	Undisturbed Sample 22.2'-24.7'
25.0	White yellowish brown, mica, silty fine to coarse sand		828.63	Undisturbed Sample 24.7'-26.7' N = 100
25.8	Carbide fishtail refusal		825.38	
30.0		0	NO 823.63	

Figure 2-21 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION B-5

Depth Ft	Description	ROU BIT		Elev	Density
		S	Size		
35.0	White/dark red mica, silty fine to coarse sand			810.63	
36.5	Carbide fishtail refusal			817.13	
40.0		50	NQ	813.63	
44.9	Water Table			808.72	
45.0		48	NQ	808.63	
50.0				803.63	
55.0		96	NQ	798.63	
64.3	Coring Terminated			789.33	

Figure 2-21 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION B-1*

Depth Ft	Description	ROD BIT		Elev	Remarks
		Size	Size		
0.0	Strong brown/reddish brown mica, silty, fine to coarse sand			824.59	N = 12
5.0				819.59	Undisturbed Sample 7.0'-9.5'
10.0	Reddish brown/brownish yellow, mica silty fine/coarse sand			814.59	N = 17 Undisturbed Sample 9.5'-12.0'
15.0				809.59	Undisturbed Sample 17.0'-19.5'
20.0	White/brown mica, silty fine/coarse sand w/gravels			804.59	N = 59 Undisturbed sample
25.0	White/brown mica, silty fine to coarse sand			799.59	N = 100
26.2	Water Table			798.39	
30.4	Carbide Refusal Boring Terminated			794.19	

Figure 2-22.
Core Boring Record

BORING
DESIGNATION B-2*

Depth Ft	Description	ROD BIT		Remarks
		Size	Elev	
0.0	Reddish silty, clayey, fine/ medium sand		851.38	N = 20
5.0			864.38	Undisturbed Sample 6.9'-9.4'
10.0	Strong brown/white, mica, silty fine/medium sand		859.38	N = 8 Undisturbed Sample 9.4'-11.4'
15.0	Strong brown/dark brown, silty, mica, fine/medium sand		854.38	N = 9 Undisturbed Sample 16.9'-18.9' Undisturbed Sample 18.9'-20.9'
20.0	White, brown, mica, silty, fine to medium sand		849.38	Undisturbed Sample 20.9'-22.9' N = 100
25.0			844.38	
30.0	Yellowish red/strong brown mica, silty fine, medium sand		839.38	N = 16

Figure 2-23 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION B-2*

Depth Ft	Description	ROD BIT		Remarks
		Size	Eye	
35.0			834.38	Undisturbed Sample 36.9'-38.9'
				Undisturbed Sample 38.9'-40.9'
40.0	White/brown, mica, silty, fine/ medium sand		829.38	N = 17
45.0	White/strong brown mica, silty, fine/medium sand		824.38	N = 21
50.0			819.38	Undisturbed Sample 51.9'-54.1'
	Brown/yellowish red, mica, silty, fine medium sand			N = 29
55.0	Yellowish red/brown, mica, silty, fine/coarse sand		814.38	N = 27
60.0	White/brown mica, silty, fine/medium sand		809.38	N = 100 Undisturbed Sample 61.9'-62.65'
67.0	Carbide refusal Boring Terminated		802.38	

Figure 2-23 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION B-3*

Depth Ft	Description	ROD BIT		Remarks
		%	Size Elev	
0.0	Red, mica, silty, clayey, fine/ medium sand		861.54	N = 16
5.0	Dark brown/strong brown, mica, silty fine/coarse sand with gravels		856.54	Undisturbed Sample 7.0'-9.5' N = 20
10.0	Brown/strong brown, mica, silty, fine/medium sand		851.54	N = 12
15.0			846.54	
20.0			841.54	Undisturbed Sample 20.0'-22.5' Undisturbed Sample 22.5'-24.4'
25.0	White/light brown mica, silty, fine/medium sand		836.54	N = 25 Undisturbed Sample 26.9'-28.8'
	White/light brown, mica, silty, fine/medium sand			N = 48
30.0	White/strong brown, mica, silty, fine/coarse sand		831.54	N = 46

Figure 2-24 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION B-3*

Depth Ft	Description	ROD BIT		Remarks
		Size	Flux	
35.0	Brown/dark brown, mica, silty, fine/medium sand	826.54	N = 21	
40.0		821.54	N = 100	
45.0		816.54	N = 100	
50.9	Carbide refusal Boring Terminated	810.64		

Figure 2-24 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION B-4*

Depth Ft	Description	ROD BIT		Remarks
		Size	Elev	
0.0	Light gray/yellowish brown, mica silty, fine/coarse sand		814.66	N = 18
5.0			809.66	Undisturbed Sample 7.1'-9.6'
10.0	Red mica, silty, fine/medium very sandy clay		804.66	Undisturbed Sample 9.6'-12.1' N = 19
15.0			799.66	Undisturbed Sample 17.1'-19.6'
18.3	Water Table		796.36	
20.0	Red/Yellowish red, mica, fine/medium sandy silt		794.66	Undisturbed Sample 19.6'-22.1' N = 12
25.0			789.66	Undisturbed Sample 27.1'-29.6' Undisturbed Sample 29.6'-30.1'
30.0	White/brown, mica, silty, fine to medium sand		784.65	N = 52 Undisturbed Sample 32.1'-33.5'

Figure 2-25 (Part 1 of 2).
Core Boring Record

BORING
DESIGNATION B-4*

Depth Ft	Description	RQD BIT		Elev	Remarks
		%	Size		
35.0	Gray/white, mica, silty fine/ medium sand			779.66	N = 55
	White/brown, mica, silty, fine/ coarse sand				N = 37
40.0	Pinkish gray, mica, silty, fine/ coarse sand			774.66	N = 52
45.0	Light brown/reddish yellow, mica silty, fine/coarse sand			769.56	N = 100
50.0	Dark brown/yellowish brown, mica, silty fine/coarse sand			764.66	N = 100
57.4	Carbide fishtail refusal Boring Terminated			757.26	

Figure 2-25 (Part 2 of 2).
Core Boring Record

BORING
DESIGNATION B-5*

Depth Ft	Description	ROD BIT		Remarks
		Size	Elev	
0.0	Dark brown/white, mica, silty fine/medium sand		B17.17	N= 25
5.0			B12.17	Undisturbed Sample 6.5'-8.0'
10.0	White/brown, mica, silty, fine/ coarse sand		B07.17	N= 100
12.6	Carbide fishtail refusal Boring Terminated		B04.57	

Figure 2-26.
Core Boring Record




Figure 2-27.
ISFSI Foundation Profile

2.6 REFERENCES

1. *Geologic Notes*, Division of Geology, State Development Board, Vol. 7, No. 5, September-October 1963.
2. *Chemical Character of Surface Waters of South Carolina*, South Carolina State Development Board, (Bulletin No. 16C) 1962.
3. *Soil Survey - Oconee County, South Carolina*, United States Department of Agriculture, Series 1958, No. 25, February 1963.
4. *Storage of Radioactive Wastes in Basement Rock Beneath the Savannah River Plant*, DP-844 Waste Disposal and Processing (TID-4500, 28th Ed.), March 1964.
5. Oconee Nuclear Station, Final Safety Analysis Report.
6. Topical Report for the Nutech Horizontal Modular Storage (NUHOMS-24P) System for Irradiated Nuclear Fuel, NUH-002, Revision 1A, July, 1989.
7. STRUDL Structural Design Language Release 5.3 McDonnell Douglas Architectural Engineering and Construction Systems Company P.O. Box 516, St. Louis, MO 63166.
8. *Earth and Rockfill Dam Engineering*, Sowers, G. F., Asia Publishing House, Bombay, 1961.
9. *Soil Mechanics*, T. William Lambe and Robert V. Whitman, 1969.

CHAPTER 3. PRINCIPAL DESIGN CRITERIA

3.1 PURPOSE OF THE OCONEE ISFSI

The purpose of the Oconee ISFSI is to insure the uninterrupted operation of the three unit Oconee Nuclear Station by providing additional long-term spent fuel storage capacity. The existing storage system consisting of two separate wet spent fuel pools is rapidly approaching a maximum operating inventory. The ISFSI utilizes the NUHOMS-24P System. NUHOMS-24P is comprised of a series of reinforced concrete HSMs which will each house a stainless steel, helium filled DSC containing 24 qualified spent fuel assemblies. The DSC top end shield plug and separate cover plate are both independently seal welded to provide total confinement of the irradiated fuel. A shielded transfer cask is used to transfer the DSC to the HSM from the spent fuel pool. During storage, the HSM provides radiation shielding and passive decay heat removal from the DSC.

3.1.1 MATERIAL TO BE STORED

Each DSC is capable of storing 24 PWR assemblies. The following subsections will address the physical, reactivity, thermal and radiological characteristics of spent fuel to be stored in the DSC.

3.1.1.1 Physical Characteristics

The physical characteristics of the reference 15 x 15 fuel are listed in Table 3-1 on page 3-6. Additional information may be found in the Oconee FSAR, Section 4.0.

3.1.1.2 Reactivity Characteristics

The reactivity of the spent fuel assemblies must be limited for criticality control purposes. Reactivity is a function of both the initial enrichment and the discharge burnup. A reactivity equivalence curve which shows the acceptable combinations of initial enrichment and discharge burnup is given in Figure 10-1 on page 10-10. For criticality control, the spent fuel assemblies must fall into the acceptable range above the initial enrichment burnup curve in order to qualify for storage in the DSC. Despite the multiple verification steps and extensive administrative controls used to assure selection of qualified irradiated fuel assemblies, criticality control for a misloaded array of unirradiated fuel is maintained by assuring that the DSC is filled with borated water (≥ 1810 ppm boron) and submerged in a borated water spent fuel pool (≥ 1810 ppm boron) during loading and unloading operations.

In the event that unqualified IFAs or unirradiated assemblies are erroneously placed in the DSC, the double contingency principle is applied such that the negative reactivity worth of the (approximately 2000 ppm) soluble boron in the spent fuel pool water (from which the DSC cavity will be filled initially) is more than sufficient to maintain k_{eff} well below 0.95. Analysis shows that the soluble boron provides sufficient margin to maintain k_{eff} below 0.95 (0.98 under optimum moderator conditions) for 24 new, 4.0 wt % enriched fuel assemblies loaded into the DSC.

3.1.1.3 Thermal Characteristics

The heat generation is limited to 0.66 kw per fuel assembly. This value is based on storage of 24 assemblies per DSC with a nominal burnup of 40,000 MWD MTU, an initial enrichment of 4.0 wt % U-235 and a nominal decay period of ten years. Other combinations of burnup, initial enrichment and cooling times may also be acceptable upon further analysis demonstrating acceptable decay heat levels.

3.1.1.4 Radiological Characteristics

The DSC is designed for a maximum dose rate of 200 mr/hr at the surface of the top (with temporary neutron shielding if necessary during welding operations) and bottom end shield plugs. The HSM is designed for an average dose rate of 20 mr/hr at the surface of the module dropping down to a negligible level at the site boundary. Fuel with a maximum burnup of 40,000 MWD/MTU, an initial enrichment of 4.0 w/o U-235 and a decay of ten years will not exceed these dose values. Other combinations of burnup, initial enrichment and cooling times may also be acceptable upon further analysis demonstrating acceptable radiation dose rate levels.

3.1.2 GENERAL OPERATING FUNCTIONS

3.1.2.1 Overall Functions of the Facility

The Oconee ISFSI is designed to maximize the use of existing site features and equipment and minimize the need to add or modify equipment. The storage facility is located away from the existing plant security boundary such that a separate security "island" is created. The only services required from the station during the ongoing storage mode will be through security surveillance equipment tied in with the plant security center. The storage facility is included in routine daily security patrols. Power supply to the storage facility is retail. Other support services from the plant are necessary only during loading (and unloading) operations.

Following periodic delivery of the individual DSCs and construction of the HSMs, the DSC is loaded into the transfer cask and the two are lowered into the spent fuel pool. The DSC transfer cask is loaded with 24 spent fuel assemblies previously selected per criteria given in Section 10.3, "Operational Control and Limit Specification" on page 10-9. Once fuel loading is complete, the DSC is fitted with its top end shield plug and pulled out of the pool. The water level in the DSC is then lowered slightly and the top end shield plug is welded into place. This is followed by further draining and eventual vacuum drying of the DSC cavity. The cavity is then back-filled with helium followed by further seal welding of both penetrations. An additional cover plate is welded over the top end shield plug, the cask lid bolted in place, and the transfer cask is then lowered to the transfer trailer and rotated to the horizontal position. Transfer from the spent fuel pool receiving area to the independent storage facility is done with the use of a separate tractor. The transfer trailer is then carefully aligned with the opening in the HSM to allow the hydraulic ram system to push the DSC out of the transfer cask and into the HSM. This method utilizes a small penetration at the bottom of the transfer cask to allow access to the DSC through the transfer cask bottom. A large access door is then lowered and tack welded in place to close off the HSM access.

The HSMs are constructed on a level, reinforced concrete slab designed for normal transfer and storage conditions and postulated accidents.

Once loaded and secured, the passive design of the HSM provides for sufficient radiation shielding, tornado missile protection, and decay heat removal capabilities for the stored spent fuel. The double seal welded DSC closure system together with multi-pass welding procedures provide a multiple barrier against releases of radioactive material.

A more detailed description of each NUHOMS-24P system component is provided in the following subsections.

3.1.2.2 Handling and Transfer Equipment

All components of the NUHOMS-24P system are designed to interface where necessary with all existing Oconee fuel handling storage equipment and facilities. This includes fuel pool receiving areas, radwaste

systems, overhead cranes, yoke and yoke extension, fuel handling bridge and mast, auxiliary hoists, water, power and gas supplies, and clearance restrictions.

The additional equipment required to support the operation of the NUHOMS-24P system includes the DSC, the transfer cask, the transfer trailer with hydraulic alignment mechanisms, the hydraulic ram assembly, the HSM and various miscellaneous tools, lids, gauges, hoses. Other equipment necessary to operate the system include a tractor to be used for moving the transfer trailer to and from the ISFSI, and a mobile yard crane for raising and lowering the HSM front access door. This equipment is further described as follows:

1. DSC - The DSC serves as the actual confinement vessel for the 24 fuel assemblies during both the storage mode and transfer operations. Seal welds on the top end shield plug and cover plate provide multiple containment of all radioactive products within or on the surface of the spent fuel assemblies. The top and bottom shield plugs also provide for biological shielding during DSC welding, drying, and backfilling operations, transport of the fuel assemblies, and during all operations performed at the front end of the HSM.
2. Transfer Cask - The transfer cask provides for dry transfer of the DSC from the Oconee fuel storage pool to the storage facility. The transfer cask utilizes a lead gamma shield and a solid neutron shield to maintain acceptable surface dose levels during transfer operations. A removable access plate at the bottom of the cask provides access to the DSC by the hydraulic ram during transfer of the DSC into or out of the HSM. The cask has a bolt on closure lid to keep the DSC in place during cask movement. Lift trunnions are provided at the top end of the transfer cask to interface with a lift beam which will in turn interface with the spent fuel pool overhead crane. These top lift trunnions together with bottom trunnions provide cask support on the trailer during transfer operations.
3. Transfer Trailer - The transfer trailer allows for movement of the entire DSC/transfer cask assembly to the ISFSI. It is designed with a positioning mechanism that moves the cask in the horizontal and vertical directions to ensure alignment with the HSM. Final alignment accuracy is verified by an optical alignment system.
4. Hydraulic Ram - The hydraulic ram assembly is stored and transported on a separate trailer but is mounted on the ground during movement of the DSC into the HSM. The ram is aligned with the bottom access portal of the horizontally positioned cask and engaged to slowly push the DSC from the cask into the HSM. A grappling ring on the bottom of the DSC and grappling arms on the hydraulic ram allow for eventual retrieval of the DSC using the same operations in reverse.
5. Horizontal Storage Module (HSM) - The HSM provides protection for the DSC during the storage mode and provides sufficient biological shielding from the stored spent fuel. Passive decay heat removal results from air entering shielded air ducts near the bottom of the structure, passing up and around the DSC and picking up heat before being exhausted through shielded vents at the top of the HSM. The HSM design includes a front access fitted with a carbon steel door and the coupling system for mating with the transfer cask. The HSM is fitted with a set of rails which serve as a bearing surface for movement of the DSC into and out of the module and as the primary support structure for the DSC during storage.

A more detailed description of these primary NUHOMS components, including design criteria, is provided in Chapter 4, "Storage System" on page 4-1.

3.1.3 TABLES

Table 3-1. Physical Characteristics of PWR Fuel Assemblies Based on Nominal Design

Array	15 x 15
Maximum Assembly Length (including radiation growth and control component) (in.)	173
Weight (lb.)	1,682
Number of Fuel Rods	208
Number of Guide Tubes	16
Number of Instrument Tubes	1
Fuel Rod Length (in.)	153.69
Active Fuel Length (in.)	141.8-144.0
Maximum Distance between Grid Straps (in.)	21 7/32 ⁽¹⁾

Note: ⁽¹⁾Grid straps are placed on intervals of $21 \frac{3}{32} \pm \frac{1}{16}$ inch. Thus the maximum interval is 21 7/32 inch. These tolerances do not accumulate. The spacers in the DSC are two inches wide and the fuel grid straps are 1 1/2 inch wide (higher for later zircaloy grid fuel). Therefore, fuel assembly support will be provided at the grid straps by the DSC spacer discs through the entire tolerance range of 20.97 inches ($20 \frac{31}{32}$) - 21.22 inches ($21 \frac{7}{32}$). The nominal value of 21.12 used in Revision 1 of the NUHOMS-24P Topical Report (Table 3.1-2) falls within this range.

3.2 DESIGN CRITERIA FOR ENVIRONMENTAL CONDITIONS AND NATURAL PHENOMENA

The Oconee ISFSI is designed to perform its intended safety function under normal and extreme environmental conditions. In general, the structural and mechanical safety criteria of the ISFSI are the same as or enveloped by the criteria specified in the NUHOMS-24P Topical Report.

Details of the HSM lightning protection are contained in Section 8.2, "Accidents" on page 8-5. Oconee foundation conditions are described in Section 2.5, "Geology and Seismology" on page 2-43.

3.2.1 TORNADO AND WIND LOADINGS

3.2.1.1 Applicable Design Parameters

The ISFSI was constructed within the existing boundaries of the Oconee Nuclear Station. As stated in Section 3.2.1 (Tornado and Wind Loadings) of Reference 1 on page 3-23, the most severe tornado and wind loadings specified by NRC Regulatory Guide 1.76 and NUREG-0800, Section 3.5.1.4, were selected for design consideration. Therefore, both the HSM and the transfer cask are designed in accordance with NRC Regulatory Guide 1.76 and NUREG-0800, Section 3.5.1.4.

As stated in Section 3.2.1.1 of Reference 1 on page 3-23, "... the maximum wind speed is 360 miles per hour, the rotational speed is 290 miles per hour, the maximum translational speed is 70 miles per hour, the radius of the maximum rotational speed is 150 feet, the pressure drop across the tornado is 3.0 psi, and the rate of pressure drop is 2.0 psi per second."

3.2.1.2 Determination of Forces on Structures

The tornado loading combination used for design of the HSM is:

$$y = 1/\phi (1.0D + 1.0L + 1.0T_o + 1.0W_1 + 1.0P_1)$$

Where y = required yield strength of the structure

ϕ = concrete capacity reduction factor

$\phi = 0.90$ for concrete flexure.

$\phi = 0.85$ for shear in concrete.

$\phi = 0.90$ for axial tension in concrete.

$\phi = 0.70$ for tied compression members.

$\phi = 0.90$ for fabricated structural steel.

T_o = normal operating temperature.

L = live loads on structure

D = dead loads of structures and equipment

W_1 = stress induced by design tornado wind velocity (drag, lift, and torsion)

$P_1 =$ Stress due to differential pressure

Shape factors will be applied in accordance with ANSI A 58.1 - 1982.

3.2.1.3 Tornado Generated Missiles

As described in Section 3.2.1.2 of Reference 1 on page 3-23, the determination of impact forces created by Design Basis Tornado (DBT) generated missiles for the HSM was based on the criteria provided by NUREG-0800, Section 3.5.1.4, III.4. Accordingly, three types of missiles were postulated. The velocity of the missiles was conservatively assumed to be 35 per cent of the combined translational and rotational velocity for the DBT or $(0.35)(360)$, which is 126 miles per hour. For the massive high kinetic energy deformable missile specified in NUREG-0800, a 3,967 pound automobile with a 20 square foot frontal area impacting at normal incidence was assumed. For the rigid penetration-resistant missile specified, a 276 pound, eight-inch diameter blunt-nosed armor piercing artillery shell, impacting at normal incidence was assumed. For the protective barrier impingement missile specified, a one-inch diameter solid steel sphere was assumed.

The possibility of a tornado damaging a cask/DSC in transit to the HSM is a low probability event. The probability of a tornado occurring at the Oconee site and generating a missile that impacts the cask is less than 1×10^{-7} per transfer trip. This is based on site-specific tornado frequencies derived from 35 years of National Severe Storm Forecasting Center data and assumes a conservative exposure time to DBT effects of 24 hours. However, the transfer cask has been evaluated for the tornado wind speed and missiles specified for the HSM. The maximum DBT tornado wind speed of 360 mph produces a design pressure of 304 psf. The 3,967 pound automobile and 276 pound eight inch diameter shell missiles are also considered. The one inch diameter spherical missile effects are enveloped by the eight inch shell missile.

3.2.1.4 Ability of Structures to Perform

The ISFSI is designed to withstand the design basis tornado wind loads. All components of the ISFSI with the exception of the air outlet shielding blocks of the HSM are designed to withstand the tornado generated missile forces as described in Section 8.2.2 of Reference 1 on page 3-23. The loss of the air outlet shielding blocks is discussed in Section 8 of the NUHOMS-24P Topical Report. The HSM is anchored to the foundation slab to mitigate overturning and sliding effects using dowel rods of a size and spacing consistent with the HSM wall vertical reinforcement.

The possibility of total air inlet and outlet blockage by foreign objects or burial under debris during a tornado event is considered. The effect of facility burial under debris is presented in Section 8.2 of Reference 1 on page 3-23.

The transfer cask analysis for tornado wind speed and missile effects was performed for the cask secured in the horizontal position on the support skid and transfer trailer. The following criteria were used to evaluate the adequacy of the transfer cask for the loads described in Section 3.2.1.3, "Tornado Generated Missiles."

1. Stability
2. Penetration Resistance
3. Stresses

The main components of the transfer cask considered in this analysis were the structural shell, and the top and bottom cover plates. Since the primary purpose of the solid neutron shield is biological shielding and since it is located on the cask exterior, it was conservatively assumed that the neutron shield will be

ruptured by a DBT missile strike and therefore was not considered in the structural analysis. A brief description of the analysis follows.

1. Stability Analysis

A stability analysis for the transfer cask mounted on the skid/trailer assembly was performed for the wind pressure loads and the massive missile impact.

For the wind pressure loads, the overturning moment was compared to the stabilizing moment to determine the factor of safety against overturning. A factor of safety of 3.1 was calculated.

For the massive missile impact, it was conservatively assumed that the missile impacts the uppermost part of the cask. The angle of rotation (θ) of the cask/skid/trailer arrangement at impact was calculated as 3.0 degrees assuming a rigid pavement. This calculation was based on the conservation of angular momentum, and also compared to the angle (θ_{up}) necessary for the cask/skid/trailer to tip over. Tip-over occurs when the center of gravity of the cask is directly above the point of rotation. This was calculated as 32.7 degrees. Since $\theta < \theta_{up}$, tip-over does not occur and the stability of the cask/skid trailer arrangement is maintained.

2. Penetration Analysis

Penetration due to the 276 pound rigid missile was calculated using two formulas obtained from the literature. The added energy absorbing affect of the neutron shield material was omitted from this calculation to give a more conservative result. The first approach, suggested by Nelms (Reference 4 on page 3-23) is for a lead-backed shell:

$$T = \left[\frac{KE}{2.4 S_u D^{1.6}} \right]^{0.71} = 0.50 \text{ inches}$$

Where: T = Minimum required steel plate or shell thickness to resist penetration

KE = Kinetic energy = $1/2 mV^2$

m = Mass of missile = 276/g

= 0.714 lb. sec.²/in.

v = Velocity of missile

= 2,218 in./sec.

S_u = Ultimate strength of cask structural shell = 70,000 psi

D = Diameter of missile = 8.0 inches

The second formula used was developed by the Ballistic Research Laboratory (Reference 5 on page 3-23):

$$T = \frac{KE^{2/3}}{672D} = 0.52 \text{ inches}$$

Where: KE = Kinetic energy = $1/2 mV^2$

m = Mass of missile

= 8.57 lb. sec.²/ft.

V = Velocity of missile

$$= 184.8 \text{ ft./sec.}$$

$$D = \text{Diameter of missile} = 8.0 \text{ inches}$$

Both methods produce a consistent result which shows a predicted penetration of 0.5 inches compared to the minimum structural shell thickness of 1.5 inches. Therefore the DBT missile will not penetrate the cask and the DSC will remain intact.

3. Stress Analysis

Conservative hand calculations were performed to determine the peak stresses in the cask shell, and the top and bottom cover plates due to DBT loads. A summary of the stress results is provided in the attached Table 3-2 on page 3-12. The analytical method for each of the load cases shown in this table is briefly described below.

- a. Wind Pressure Loads: A uniform line load of 2.18 Kips/ft. was applied to the full length of the cask. The correlation of Roark and Young (Reference 6 on page 3-23) Table 31, Case 9c was conservatively used to calculate membrane and bending stresses. The analyses of the three inch top and two inch bottom cover plates were performed using Case 10, Table 24 of Roark and Young. The top cover plate was assumed pinned at the edges while fixed edge supports were assumed for the bottom cover plate.
- b. Massive Missile Impact: Based on the conservation of angular momentum, the total force on impact was calculated to be 257 kips. This force was applied as a line load to the cask shell and as a pressure load to the top and bottom cover plates. The analysis method followed that described above for the wind pressure loads.
- c. Penetration Resistance Missile: The impact force due to the eight inch diameter, 276 pound missile was calculated from the conservation of momentum as 63.4 kips. Case 9a, Table 31 of Reference 6 on page 3-23 was used to calculate the membrane and bending stress for the cask shell while Cases 16 and 17, Table 24 of Reference 6 on page 3-23 were used to calculate the stresses in the top and bottom cover plates respectively.

3.2.2 WATER LEVEL (FLOOD) DESIGN

The grade level of the ISFSI is El 825.0. This elevation is 11.9 ft. higher than the calculated maximum flood water elevation at Oconee due to a postulated breach of the upstream Jocassee Dam (See Section 2.4.5.1, "Flood Protection Measures for Oconee Station Seismic Class 1 Structures" on page 2-31).

3.2.3 SEISMIC DESIGN

3.2.3.1 Input Criteria

The maximum horizontal and vertical ground acceleration (Maximum Hypothetical Earthquake - MHE) specified for the Oconee site is .15g (Reference 3 on page 3-23, Section 2.5.2.8, "Design Response Spectra" on page 2-219). The Oconee site accelerations are less than the analyzed values of .17g vertical and .25g horizontal used for NUHOMS components (Reference 1 on page 3-23) and thus are enveloped by the generic NUHOMS analysis.

The Oconee HSMs were designed using the seismic criteria from Reference 1 on page 3-23. As stated in Section 3.2.3 of Reference 1 on page 3-23, "The maximum horizontal ground acceleration component selected for design of the NUHOMS-24P was 0.25g. The maximum vertical acceleration component selected was two-thirds of the horizontal component which is 0.17g. In order to establish the amplification factor associated with the generic design basis response spectra, various frequency analyses were performed

for the different NUHOMS-24P components and structures. The results of these analyses indicated that the dominant lateral frequency for the reinforced concrete HSM was 25 Hertz. The corresponding horizontal seismic acceleration used for design of the HSM was 0.32g. Conservatively assuming that the dominant HSM vertical frequency is also 25 Hz. produces a vertical seismic design acceleration of 0.22g."

The effects of a seismic event occurring during the transport of a loaded DSC resting inside the NUHOMS-24P transfer cask and secured to the transport skid/trailer was postulated. This load case is conservatively enveloped by the postulated normal transport load accelerations of $\pm 0.5g$ acting in the vertical, axial, and transverse directions, applied simultaneously at the center of gravity of the transfer cask, as specified in Section 8 of Reference 1 on page 3-23. These accelerations envelope those which would result from a seismic event in the highly unlikely event that a design basis earthquake would occur during transport of the loaded DSC to or from the HSM.

3.2.3.2 Seismic System Analysis

The stresses in the Oconee HSM and the DSC due to the .15g horizontal and vertical motion for the MHE are enveloped by the results of the generic seismic analysis reported in the NUHOMS-24P Topical Report (Reference 1 on page 3-23). The maximum HSM reinforced concrete bending moments and shear forces in Table 8.2-3 of Reference 1 on page 3-23 envelope the seismic loads at Oconee.

The foundation of the HSM is also designed to withstand the forces generated by the MHE (See Section 2.5.5, "ISFSI Foundation" on page 2-51).

3.2.4 SNOW AND ICE LOADS

The NUHOMS-24P Topical Report specified a postulated live load of 200 pounds/ft² which conservatively envelopes the maximum snow and ice loads for the Oconee site.

3.2.5 COMBINED LOAD CRITERIA

Load combination criteria established in the NUHOMS-24P Topical Report for the HSM, DSC and DSC support assembly meet or envelop the load combinations required by the Oconee FSAR Section 3.8, "Design of Class 1 Structures" on page 3-99 (Reference 3 on page 3-23).

The HSM analyses summarized in Reference 1 on page 3-23 considered combinations of HSMs ranging from a single stand-alone module up to the maximum array size of 2x10. The finite element models used in the analyses are applicable to both side-by-side or back-to-back arrangements. Different DSC loading patterns were analyzed for each size of array to establish the worst case design loadings.

The analyses showed that the single HSM provides the governing case for load combinations containing tornado wind and missile loads, seismic loads and flooding conditions. The postulated failure mode for each of these cases is sliding or overturning of the HSM unit. The analyses also showed that the thermal loads for a 2x10 array control the reinforcement requirements for the walls, roof and foundation members for all intermediate array sizes.

Therefore, Reference 1 on page 3-23 presents a design configuration which envelopes the loads from a single HSM to a 2x10 array.

3.2.6 TABLES

Table 3-2. Transfer Cask Stress Analysis for Tornado Effects

Load Case	Load Description	Stress Category	Calculated Stresses (ksi)			Allowable ⁽¹⁾ Stress (ksi)
			Cask Shell	Top Cover Plate	Bottom Cover Plate	
1	Wind Pressure Loads	Primary Membrane	0.9	0.0	0.0	49.0
		Membrane + Bending	2.9	0.4	0.3	70.0
2	Massive Missile	Primary Membrane	6.4	0.0	0.0	49.0
		Membrane + Bending	20.5	19.7	17.5	70.0
3	Penetration Resistance Missile	Primary Membrane	4.9	0.0	0.0	49.0
		Membrane + Bending	20.3	13.2	22.2	70.0
4	Protective Barrier Missile	Primary Membrane	Bounded by Case (3) Above			49.0
		Membrane + Bending				70.0

Note: ⁽¹⁾Service Level D Allowables are used.

3.3 SAFETY PROTECTION SYSTEM

3.3.1 GENERAL

The Oconee ISFSI is designed for safe and secure, long-term containment and storage of IFAs. The major components which assure that the safety objectives are met are listed in Table 3-3 on page 3-19. The major procedures which require special design consideration are:

- Double Closure Seal Welds on DSC Ends
- Radiation Exposure During DSC Closure and Drying Operations
- Minimization of Contamination of DSC Exterior by Pool Water
- Minimization of Radiation Exposure During Transfer of the DSC from the Transfer Cask to the HSM

These items are addressed in the following subsections.

3.3.2 PROTECTION BY MULTIPLE CONFINEMENT BARRIERS AND SYSTEMS

3.3.2.1 Confinement Barriers and Systems

The Oconee ISFSI design incorporates multiple confinement barriers to ensure there will be no release of airborne radioactive effluent to the environment. The radioactivity which must be confined is from the IFAs themselves and DSC exterior contamination from IFA loading operations in the spent fuel storage pool. ISFSI multiple radioactivity confinement barriers are listed in Table 3-4 on page 3-20.

DSC exterior contamination is minimized by preventing spent fuel storage pool water from contacting the DSC exterior. DSC loading procedures (See Section 4.4.1, "Loading and Unloading System" on page 4-21) require that the annulus between the transfer cask and DSC be filled with demineralized water and sealed prior to immersion in the spent fuel pool. Annulus sealing is accomplished by an inflatable seal between the transfer cask and DSC. The combination of the above operations provides assurance that the DSC exterior surface has less residual contamination than required for shipping cask externals (i.e., 10CFR 71.87(i)(1)). A surface swipe of the DSC exterior is taken while it is in the cask decontamination pit to assure this level of contamination is not exceeded.

The annulus seal is an inflatable fabric reinforced elastomeric tube. An automotive-type valve stem permits inflation to approximately 25 psig. This design can accommodate the maximum variation in the annulus width (.5 to 1.5" at the cask flange). The seal is placed in the annulus and inflated prior to immersion in the fuel pool. It remains in place at least through the completion of top end shield plug decontamination. The seal may remain in place until just prior to DSC seal welding. The seal is then stored for future use, or discarded if it has become damaged.

The function of the annulus seal is to minimize the potential for DSC and cask contamination during fuel loading. It is not intended to be a "safety protection system" for the NUHOMS system. The seal provides an added assurance that minimizes the potential spread of contamination and therefore reduces personnel radiation exposures. The NUHOMS system will safely function with or without the seal, and as such, its correct placement and operation are not critical to the safety of the system. In the event that the seal should fail, the water filled annulus will minimize the spread of contamination below the top of the DSC.

Should the DSC surface become contaminated, clean demineralized water will be flushed through the DSC/transfer cask annulus until surface smears show that the contamination levels meet Technical Specification limits.

Transfer cask external contamination will also be controlled to minimize personnel radiation exposure and potential off-site radiological releases during cask handling operations outside the spent fuel pool. 49CFR 173.443(d), which governs contamination levels for off-site shipment in a closed, exclusive use vehicle, will be used as a guideline for establishing cask release limits.

Containment of radioactive material associated with IFAs is provided by fuel cladding, the stainless steel DSC body, and double seal welded primary and secondary closures. These multiple confinement barriers assure that any accidental radioactive releases from stored IFAs to the environment will be ALARA.

3.3.2.2 Ventilation - Offgas

The ISFSI design limits the temperature history of stored fuel rods, such that no fuel damage will occur under design basis conditions. Decay heat dissipation is discussed in Section 1.2.3.2, "Decay Heat Dissipation" on page 1-6 of this SAR. ISFSI response to abnormal cooling conditions (i.e. convective air flow blockage conditions) is provided in Chapter 8, "Accident Analyses" on page 8-1 of this SAR. There are no radioactive effluent releases during normal operations. Additionally, there are no credible accidents which cause releases of radioactive effluent from the DSC. Therefore, there are no offgas system or radiological effluent release monitoring requirements for the ISFSI.

The only offgas concern results from the DSC/transfer cask purge and drying operations. During this operation, the gases purged from the DSC/transfer cask internals are directed to the spent fuel storage facility HVAC system upstream of the Engineered Safety Feature (ESF) HEPA, and carbon filter units. The purged air and helium are ultimately released from the station unit vent. Potential radiological effluent releases are monitored by both spent fuel storage facility HVAC and unit vent monitors prior to release. This is the same method and system currently utilized for spent fuel shipping cask operations.

3.3.3 PROTECTION BY EQUIPMENT AND INSTRUMENTATION SELECTION

3.3.3.1 Equipment

1 The transfer cask and DSC are the only equipment considered safety related during normal and
1 off-normal operations. The HSM is not safety related. However, the functions of the HSM are
1 considered important to the safe operation of the ISFSI and therefore the HSM is designed, constructed,
1 and tested in accordance with the Duke QA-2 Quality Assurance Program. The design criteria for all
equipment comprising the ISFSI that is classified to be important to safety are summarized in Section 3.4,
"Summary of Storage System Design Criteria" on page 3-21 of this SAR. Design code standards for
ISFSI components are summarized in Table 3-5 on page 3-20.

The design criteria for the NUHOMS reinforced concrete HSM including its foundation and DSC support structure, the DSC and its internal basket assembly, and the transfer cask are provided in Section 3.2, "Design Criteria for Environmental Conditions and Natural Phenomena" on page 3-7 and summarized in Tables 3.2-1 through 3.2-9 of Reference 1 on page 3-23.

The Oconee lifting beams used for movement of the transfer cask within the fuel building are designed and procured as components important to safety. The lifting beams used in that part of the operation are controlled by 10CFR Part 50 and NUREG-0612 and are designed to ANSI 14.6-1986 criteria for nonredundant yokes.

The vacuum drying system described in Section 4.7.3 of Reference 1 on page 3-23 is not safety related. Failure of any part of this system can only result in a delay of operations, and not in a hazardous situation to the public or operating personnel. The welding materials required to make the closure welds on the DSC top end shield plug and top cover plate are purchased to the same ASME Code criteria as the DSC (Section NB Class 2). The actual equipment used for making the closure welds is purchased in accordance with standard industry codes such as ANSI, AWS and AISC.

As noted in Section 4.5.5, "Transfer Components" on page 4-32 of this SAR, all other components of the NUHOMS system, including the transfer cask skid, skid positioning system, and hydraulic ram system are required to perform their function to successfully transfer a DSC to and from the HSM. These systems are described in Reference 1 on page 3-23 with the design requirements further delineated in Chapter 4, "Storage System" on page 4-1 of this SAR. However, the failure of any of this equipment may cause additional operational effort but will not endanger the health and safety of the public or plant personnel. Therefore, these transfer components are not considered to be important to safety and are therefore designed, constructed, and tested in accordance with accepted industry standards.

In addition, the transfer cask, HSM, and DSC have been designed to meet very conservative design criteria including postulated conditions which envelop those which may result from the mechanistic failure of the transfer system equipment. Design conditions such as cask drop accident and jammed DSC have been included even though there is no plausible way for these worst case events to occur. Conservative bounding analysis for these conditions have been performed using minimum material yield strengths, strength reduction factors, and factors of safety in accordance with the stringent requirements of the ASME and ACI Codes. Even when applying this conservative criteria considerable design margin for these components and structures remains as evidenced by the analysis results comparisons with acceptance criteria contained in Reference 1 on page 3-23. Further, these components and structures are fabricated and constructed to the rigorous standards and methods of the ASME and ACI Codes under a 10CFR 50 Appendix B Quality Assurance Program. These include material qualification, welding and nondestructive examination, and strict surveillance and quality control inspection. The resulting high integrity of the Transfer Cask, DSC, and HSM provide more than adequate assurance that the health and safety of the public and plant personnel are protected.

3.3.3.2 Instrumentation

The Oconee ISFSI is designed to maintain a safe and secure, long-term containment and storage environment for IFAs using only totally passive components. Therefore, no safety related instrumentation is required for operation of the facility.

3.3.4 NUCLEAR CRITICALITY SAFETY

3.3.4.1 Control Methods for Prevention of Criticality

A combination of DSC fuel basket design and station administrative procedures assure subcritical conditions exist at all times. DSC fuel basket material properties and geometry are established to assure subcriticality assuming a full loading of IFAs with a specified minimum burnup that encompasses the majority of the available spent fuel inventory at Oconee. Oconee administrative procedures assure that only qualified IFAs are loaded for storage in a DSC and that a minimum soluble boron concentration of 1810 ppm is maintained within the DSC basket cavity during underwater loading/unloading operations. IFA qualification for storage in a DSC is determined based on initial enrichment, burnup history and post-irradiation cooling time as governed by Oconee ISFSI Technical Specifications.

IFA qualification requirements are provided in Section 10.2.5, "Administrative Controls" on page 10-6 on Administrative Controls. Using special nuclear materials control and accountability (SNMCA) records

and the burnup results from the Oconee Operator Aided Computer, the specific data needed to characterize any given spent fuel assembly can be gathered. This includes the initial enrichment, discharge burnup, cladding defects (if any), current storage location, and cumulative cooling time since reactor discharge. After verifying that all the spent fuel specifications of Reference 2 on page 10-11 are met, documentation of individual fuel qualifications will be transmitted to fuel handling personnel. Oconee administrative procedures will require receipt of this qualification documentation, and independent verification of fuel assembly identification numbers prior to loading a given assembly into the DSC. In addition, all assembly serial numbers will be checked following the complete loading of 24 assemblies into the DSC.

The Oconee ISFSI Technical Specifications which govern IFA qualification for storage are given in Reference 2 on page 10-11. The administrative procedures outlined above will be used to ensure that the requirements for fuel qualification are met.

IFA qualification criteria do not include a specification on axial burnup distribution. The axial burnup profile used in analyzing the nonuniform axial burnup reactivity effects on fully loaded DSC spent fuel storage arrays is considered worst-case based on a comprehensive review of axial burnup profiles generated by the EPRI-NODE computer program (reference Section 3.3.4.3 of Reference 1 on page 3-23). Although some individual IFAs may not be enveloped by the worst-case axial burnup profile considered, the conservative treatment of nonuniform axial burnup in the Reference 1 on page 3-23 analysis and the averaging effects of loading up to 24 qualified IFAs per DSC provide adequate assurance that the K_{eff} of any loaded DSC configuration will not exceed the worst-case value presented in Reference 1 on page 3-23.

Criticality analyses applicable to Oconee have been performed which demonstrate that subcriticality is maintained within appropriate safety margins under the worst conditions. Worst-case conditions analyzed include fuel misload events and optimum moderation effects on reactivity. A bounding off-normal case of 24 misloaded unirradiated new fuel assemblies with a 4% U-235 initial enrichment combined with the reactivity effects of optimum moderation has been analyzed. A minimum fuel pool water boron concentration of 1810 ppm is assumed in the off-normal case calculations. Criticality analysis details are provided in Section 3.3.4 of Reference 1 on page 3-23.

3.3.4.2 Error Contingency Criteria

The design basis for preventing criticality in ISFSI spent fuel storage operations is taken from American National Standard Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants, ANSI/ANS-57.2-1983. ANSI/ANS-57.2-1983 requires a demonstrated margin of subcriticality of $\geq 0.05 \Delta K$ under all credible conditions except under certain extreme off-normal conditions where a $\geq 0.02 \Delta K$ subcritical margin may be justified. Additionally, ANSI/ANS-57.2-1983 requires all uncertainties be included in the final calculated K_{eff} value at 95/95 tolerance limits. See Section 3.3.4 of Reference 1 on page 3-23 for details on how these criteria are applied in demonstrating ISFSI criticality safety.

3.3.4.3 Verification Analysis

The analysis method which ensures ISFSI criticality safety uses the Criticality Analysis Sequence No. 2 (CSAS2) and the 123GROUPGMTH master cross-section library included in the SCALE-3 system of codes (Reference 2 on page 3-23). CSAS2 consists of two cross-section processing codes (NITAWL and BONAMI), a 1-D transport code for cell-weighting cross-section data (XSDRNPM), and a 3-D monte-carlo code (KENO-IV) for calculating the effective multiplication factor for a system.

In CSAS2 calculations involving the zero burnup intercept point, cross section processing and cell weighting of cross sections was performed assuming fresh fuel. For CSAS2 calculations involving irradiated fuel, cross section processing and cell weighting, cross sections was performed assuming irradiated fuel actinide and fission product isotopes.

Irradiated fuel fissile nuclide number density data was obtained from CASMO-2 (Reference 4 on page 3-23) calculations and input to the CSAS2 criticality code sequence (reference Section 3.3.4.2 of Reference 1 on page 3-23). The CASMO-2 lattice physics code has been used extensively in reactor physics calculations. Its ability to accurately predict fissile nuclide depletion and generation as well as neutron multiplication is well established in benchmark calculations (References 5 and 6 on page 3-23) and through its successful application in numerous licensed reactor physics and core reload design calculations.

The Shielding Analysis Sequence No. 2 (SAS2) included in the SCALE-3 package of codes was used to develop irradiated fuel fission product number density data for input to CSAS2. SAS2 is an industry recognized code which employs ORIGEN-S to perform fuel burnup, depletion and decay calculations.

A set of 40 critical experiments have been analyzed using the CSAS2/123GROUPGMTH reactivity calculation method to demonstrate its applicability to criticality analysis and to establish method bias and variability. The experiments analyzed represent a diverse group of water moderated, heterogeneous oxide fuel arrays separated by various materials (stainless steel, Boron, water, etc.) that are representative of LWR shipping and storage conditions. The method bias and uncertainty applied in the calculation of the final K-eff result is based on CSAS2/123GROUPGMTH calculated results for the set of 40 critical experiments summarized in Table 3.3-6 of Reference 1 on page 3-23. All 40 critical experiments included in the method benchmark are similar to zero burnup/nominal case flooded DSC conditions in that all are water moderated, low enrichment heterogeneous UO₂ systems. Additional benchmark calculations were performed to demonstrate that the irradiated fuel criticality/equivalence method used is conservative when compared to the method bias basis UO₂ benchmark results (i.e., Reference 1 on page 3-23 Table 3.3-6 results). CSAS2/123GROUPGMTH benchmark results for systems containing PuO₂-UO₂ mixed oxide fuel pins are provided in Table 3.3-7 of Reference 1 on page 3-23. Benchmark data representative of irradiated fuel assemblies was obtained from the results of CASMO-2 infinite lattice criticality calculations; the results of benchmark comparisons between CASMO-2 and CSAS2/CASMO2/SAS2 calculated K-inf values are provided in Table 3.3-8 of Reference 1 on page 3-23. Inspection of the benchmark results provided in Reference 1 on page 3-23 Table 3.3-7 and 3.3-8 demonstrates that the criticality/equivalence method used conservatively overpredicts K-eff for systems containing plutonium or irradiated fuel of the type proposed for Oconee ISFSI storage.

Further details on the analysis method and the ISFSI verification analysis are provided in Section 3.3.4 of Reference 1 on page 3-23.

3.3.5 RADIOLOGICAL PROTECTION

The Oconee ISFSI is designed to maintain onsite and offsite doses ALARA during loading operations and long-term storage conditions. ISFSI loading procedures, shielding design, and access controls provide the necessary radiological protection to assure radiological exposures to station personnel and the public will be maintained ALARA. Further details on collective onsite and offsite doses resulting from ISFSI operations and the ISFSI ALARA evaluation are provided in Chapter 7, "Radiation Protection" on page 7-1 of this SAR.

Access to the spent fuel assemblies stored in the ISFSI is restricted by a security fence, and the thick walls and heavy door of the Horizontal Storage Module. Since there are no active systems in the storage module, there is no need for continuous monitoring of conditions. Appropriate monitoring will be

performed prior to loading or unloading Dry Storage Canisters inside the ISFSI fence. Appropriate monitors are in place inside the station to provide warning of radiation hazards while DSC loading and cask handling operations are performed in the fuel building and loading area. During transport, the transfer cask will be monitored to assure no danger to the health of the public or station personnel.

3.3.6 FIRE AND EXPLOSION PROTECTION

The ISFSI HSM and DSC contain no flammable material and the concrete and steel used for their fabrication can withstand any credible fire hazard. There is no fixed fire suppression system within the boundaries of the ISFSI; however, portable suppression equipment is provided within the fenced boundary. Also, the facility is located such that the station fire brigade can respond to any fire emergency using portable fire suppression equipment or the site's Fire Protection System, as described in Section 9.5.1, "Fire Protection System" on page 9-107 of the Oconee FSAR.

ISFSI initiated explosions are not considered credible since no explosive materials are present in the fission product or cover gases. Externally initiated explosions are considered to be bounded by the design basis tornado generated missile load analysis presented in Section 3.2, "Design Criteria for Environmental Conditions and Natural Phenomena" on page 3-7 of this SAR and Reference 1 on page 3-23.

3.3.7 MATERIALS HANDLING AND STORAGE

Major ISFSI materials handling and storage requirements include irradiated fuel and radioactive waste handling and storage. No hazardous chemicals or chemical reactions are involved in the normal ISFSI loading and storage processes.

All irradiated fuel handling outside the fuel storage pool is performed with the fuel assemblies enclosed in a DSC. DSC handling equipment and handling procedures are described in detail in Chapter 4, "Storage System" on page 4-1 and Chapter 5, "Storage System Operations" on page 5-1 of this SAR, respectively.

Radioactive waste generation, treatment and disposal is addressed in Chapter 6, "Waste Management" on page 6-1 of this SAR.

The design criteria for handling spent fuel outside the pool area is to keep the fuel enclosed in the DSC and the Transfer Cask or HSM at all times. There is no waste generation outside the fuel building for normal DSC transfer operations. Waste generated in loading and decontaminating the cask is handled by existing Oconee waste systems in the pool and decontamination areas.

The canister/cask design is such that fuel handling in the pool area is unchanged from normal fuel handling procedures. Specific criteria for selecting fuel assemblies for storage are detailed in Reference 2 on page 10-11. IFAs are selected to meet design criticality, cooling and radiation protection parameters. Once the assemblies are loaded into the DSC, there is no individual assembly handling. Thus, the only fuel handling procedures are those already in existence for the pool and the administrative criteria for selecting assemblies for storage. Damaged fuel assemblies are not normally considered for storage and would be handled according to existing pool procedures in the event damage occurred during DSC loading or unloading in the pool. (Fuel damage in the context of this discussion represents gross clad or structural failure and does not include pin-hole clad leaks.) Fuel handling operations will be monitored with existing pool area monitors.

All radioactive waste generation is from cask decontamination and consists of liquid waste which is input into the cask decontamination pit drain and thus into the existing plant liquid radwaste system and solid waste which is collected for disposal via the existing plant radwaste facility.

3.3.8 TABLES

Table 3-3. Oconee ISFSI Major Components and Functions

• Transfer	Cask Outside IFA Transport, Shielding
• Dry Storage Canister (DSC) Guide Sleeves Spacer Disks Support Rods End Shield Plugs DSC Body End Cover Plates	Criticality Control, IFA Support, Cover Gas Containment, Radioactive Material Confinement, Shielding (Lead Plugs)
• Horizontal Storage Module (HSM) Concrete Shielding DSC Support Assembly	Shielding, DSC Support, DSC Tornado Missile Protection, DSC Cooling
• Foundation	HSM Foundation Support
• Transfer Components Transfer Trailer Hydraulic Ram Trailer Optical Alignment System	Transfer Cask Movement, DSC Transfers

Table 3-4. Oconee ISFSI Radioactive Material Confinement Barriers

Radioactivity Source	Confinement Barriers
• Contaminated Spent Fuel Storage Pool Water	1. Demineralized Water in DSC/Transfer Cask Annulus 2. Inflatable Annulus seal between DSC and Transfer Cask
• Irradiated Fuel and Fission Gases	1. Fuel Cladding 2. DSC Body 3. Seal Welded Primary Closure (Top End Shield Plug) 4. Seal Welded Secondary Closure

Table 3-5. Oconee ISFSI Major Components and Design Requirements

Item	Design Code	Design Criteria
Transfer Cask	ASME Section III Class 2	Presented in Ref. 3.1, Section 3.2.5.3
DSC	ASME Section III Class 1	Presented in Ref. 3.1, Section 3.2.5.2
HSM Including Foundation and DSC Support Structure	ACI 349-85 ACI 318-83 AISC	Presented in Ref. 3.1, Section 3.2.5.1
Transfer Trailer and Skid	Industry Standards ⁽¹⁾	Ref. 3.1, Section 1.3.1.4 and 1.3.1.5
Hydraulic Ram	Industry Standards ⁽²⁾	Ref. 3.1, Section 1.3.1.6
Cask Lifting Devices	ASME Section III, Subsection NF	None required at HSM site. Fuel bldg. lifts controlled by 10CFR Part 50 criteria.
HSM Site Electrical Power	NEC, NEMA, NEPA	Required for DSC transfer operations only.

Note:

1. See Sections 1.3, "General Systems Descriptions" on page 1-11 and 3.1.2.2, "Handling and Transfer Equipment" on page 3-4 of this SAR.
2. See Section 5.1, "Operation Description" on page 5-3 of this SAR.

3.4 SUMMARY OF STORAGE SYSTEM DESIGN CRITERIA

1. REFERENCE SPENT FUEL CHARACTERISTICS -

- a. 15x15 PWR Assemblies (24 Per Module/DSC)
- b. Decay Heat = .66 KW Per Assembly
- c. Nominal Burnup = 40,000 GWD/MTU
- d. Initial Enrichment = 4.0 weight % U-235
- e. Equivalent Zero Burnup Enrichment ≤ 1.45 weight % U-235 (criticality)

2. COMPONENT FUNCTIONS -

- a. DSC Provides Fuel Support, End Shielding, Heat Transfer, Criticality Control, and Confinement of cover gas and Radioactive Material.
- b. Transfer Cask Provides Shielding, DSC Loading, Handling and Transfer Mechanism, HSM Docking Functions, and Tornado Wind and Missile Protection.
- c. HSM Provides Shielding, Passive Decay Heat Removal, Structural/Seismic DSC Support and Environmental Protection, including Tornado Wind and Missile Protection.
- d. Hydraulic Ram System Provides Mechanism for DSC Transfer From Transfer Cask to HSM and eventual removal of DSC from HSM.

3. ENVIRONMENTAL CONDITIONS -

- a. Maximum Tornado:
 - 1) wind speed = 360 miles per hour
 - 2) rotational speed = 290 miles per hour
 - 3) translational speed = 70 miles per hour
 - 4) pressure drop across the tornado = 3.0 psi
 - 5) rate of pressure drop = 2.0 psi per second
- b. Tornado Missiles @ 35% of the Combined translational and rotational DBT velocity = 126 miles per hour.
 - 1) 3967 pound automobile with a 20 square foot frontal area
 - 2) 276 pound, eight inch diameter blunt-nosed armor piercing artillery shell
 - 3) one-inch diameter solid steel sphere
- c. Flood Design: Not Applicable
- d. Seismic Forces = .17g Vertical, .25g Horizontal (NUHOMS components)
= .15g Vertical, .15g Horizontal (Oconee site conditions)
- e. Snow Ice Loads = 200 Pounds Per Square Foot

4. SAFETY PROTECTION -

- a. Normal Operating Clad Temperature $\leq 340^{\circ}\text{C}$
- b. Material Confinement - Multiple Barrier Concept

- c. Purged-gasses - Passed Through Spent Fuel Pool Ventilation System During Fuel - Loading
Otherwise Not Applicable.
- d. Criticality Control Through Burnup Credit and 1810 ppm Soluble Boron Credit - $K_{eff} < 0.95$,
 $K_{eff} < 0.98$ (off-normal)

3.5 REFERENCES

1. Topical Report for the Nutech Horizontal Modular Storage System for Irradiated Nuclear Fuel (NUHOMS-24P), Rev. 1A, dated July, 1989, NUH-002.
2. "SCALE-3: A Modular Code System for Performing Standardized Computer Analysis for Licensing Evaluation," NUREG/CR-0200, ORNL, Revision 3, December 1984.
3. Oconee Nuclear Station Final Safety Analysis Report (FSAR).
4. "Structural Analysis of Shipping Cask, Effects of Jacket Physical Properties and Curvature and Puncture Resistance", H. A. Nelms, Vol. 3, ORNL TRM-1312, Oak Ridge National Laboratory, Oak Ridge Tennessee, June, 1968.
5. "Design of Structures for Missile Impact," R. B. Linderman, J. V. Rotz, and G. C. K. Yeh, Topical Report BC-TOF-9-A, Bechtel Power Corporation, Revision 2, September 1974.
6. "Formulas for Stress and Strain," R. J. Roark and W. C. Young, Fifth Edition, McGraw-Hill, New York, New York, 1975.
7. "CASMO-2 A Fuel Assembly Burnup Program," Malte Edenius, et. al., STUDSVIK/NR-81/3, March 1981.
8. "CASMO Benchmark Report," M. Edenius, et. al., RF-78/6293, STUDSVIK, March 1978.
9. "CASMO Benchmarking Against Experiments in Rack Geometries," M. Edenius, et. al., NR-81/61 STUDSVIK, November 1981.

CHAPTER 4. STORAGE SYSTEM

The Oconee ISFSI is located within the existing Owner Controlled Area on the Oconee Nuclear Station site. The storage area is located west of the existing intake structure. Figure 4-1 on page 4-5 depicts the site layout in relation to other plant features and defines the onsite route that the transfer cask and trailer will travel in moving loaded storage canisters from the Fuel Buildings to the ISFSI.

The Oconee ISFSI utilizes the NUHOMS-24P storage system which provides for the horizontal, dry storage of irradiated nuclear fuel assemblies. The fuel assemblies are contained in a DSC made of stainless steel which is placed inside a reinforced concrete HSM for long term storage.

In addition to the DSC and HSM, the NUHOMS-24P system utilizes handling and transfer equipment to load the DSC with fuel, to seal the DSC, to move the loaded DSC inside a heavily shielded transfer cask from the Fuel Building to the HSM and to insert the DSC into the HSM. The DSC is designed to hold 24 PWR fuel assemblies. The margins of safety in the structural design of the HSM, DSC, and transfer cask are more fully described in Section 8, Tables 8.1 and 8.2 of Reference 1 on page 4-37. Additional information for the handling and transfer equipment is presented in Section 4.3.5, "Transfer Components" on page 4-32.

The fuel assemblies to be stored are described in Section 3.1.1, "Material to be Stored" on page 3-3. The dose to the general public from the operation of the ISFSI is far below the allowable dose limits as set by regulation. Estimates of the annual dose rates are provided in Section 7.7, "Estimated Off-Site Collective Doses" on page 7-33.

1. It should be noted that the Oconee ISFSI is licensed for the storage of as many as 2112 assemblies; this storage capacity will be added incrementally as needed to support the actual refueling schedules. HSMs and foundation have been designed to be built in any array size no smaller than 2x3 (three modules side by side and back to back with three additional modules) and no larger than 2x10 (Ten modules side by side and back to back with ten additional modules).

The ISFSI system is designed to interface with existing plant equipment and systems. Roadways, buried pipes, trenches, and positioning aprons were verified to be acceptable for the wheel loadings of the transfer vehicle. Oconee Nuclear Station asphalt roadways were verified as meeting the design minimum thickness requirements of the American Association of State Highway and Transportation Officials as specified for loading comparable to the ISFSI transfer vehicle. Approximately 64 buried pipes and over 26 drain lines were analyzed and verified acceptable according to the applicable codes for each piping material. All interfacing trench systems were analyzed for transfer vehicle loadings. These include the 115 KV, 230 KV, 525 KV, Radwaste and Interim Radwaste, and the Standby Shutdown Facility trenches. Necessary modifications to these trenches will be completed prior to the transit of the ISFSI transfer vehicle.

The size and weight of the transfer cask, DSC, and crane hook lift adapter are acceptable within the current design limits of the crane, cask handling area, and transfer cask positioning aprons of the spent fuel pools. Design features employed to withstand environmental and accident forces are detailed in Chapter 3, "Principal Design Criteria" on page 3-1 and Chapter 8, "Accident Analyses" on page 8-1 of this SAR. The DSC and transfer cask are inspected per Duke's QA 1 program that is more fully described in Chapter 11, "Quality Assurance" on page 11-1. The HSM is designed, constructed and inspected in accordance with Duke's QA condition 2 program.

The HSM is designed in accordance with the requirements of ACI 349-85 as discussed in Section 3.2.5.1 of Reference 1 on page 4-37. The HSM is constructed following the guidelines of ACI 318-83 as discussed in Section 4.2.1 of Reference 1 on page 4-37. The DSC and transfer cask are designed and built in

accordance with the ASME Code, 1983 edition through Winter 1985 addenda. In addition this equipment will comply with the following: ANSI N 14.6-1978, American National Standard for Special Lifting Device for Shipping Containers Weighting 10,000 lbs. or More for Nuclear Materials; ANSI/ANS 57.9-1984, Design Criteria for An Independent Spent Fuel Storage Installation (Dry Storage Type); ASTM E499-73, Standard Methods of Testing for Leaks Using the Mass Spectrometer Leak Detector in the Detector Probe Mode.

4.1 LOCATION AND LAYOUT

The location and layout of the storage site with respect to other site structures is shown in Figure 4-1 on page 4-5. This figure also denotes the transportation route for movement of the DSCs from the spent fuel pool to the HSMs.

If, during the transfer of a DSC from the fuel building to a HSM, an event requiring return to the fuel handling building occurred inside the Oconee Nuclear Station protected area fence, the tractor-trailer could either continue on around the east side of the Turbine Building and return to the fuel building or, if it is close to the fuel building, it could reverse to return.

From the point where it leaves the Oconee Nuclear Station protected area until the point where it reaches the ramp leading up to the ISFSI, the tractor-trailer has sufficient space to turn around as needed.

Once it is on the access ramp leading to the ISFSI, the tractor-trailer would have to continue to the ISFSI site in order to turn around.

The transport route has been reviewed and found to be within the design basis of the cask drop analysis discussed in Section 8.2 of Reference 1 on page 4-37. The potential causes for cask and DSC drop accidents are described in Section 8.2.5.1 of Reference 1 on page 4-37. The enveloping postulated drop events assumed for design are:


1. A horizontal side drop or slap down from a height of 80 inches.
2. A vertical end drop from a height of 80 inches onto the top or bottom of the transfer cask.
3. A corner drop from a height of 80 inches at an angle of 30° to the horizontal, onto the top or bottom corner of the transfer cask.

These drop scenarios were used to define an equivalent static deceleration load of 75g for cases (a) and (b) and 25g for the corner drop (case (c)). As described in Reference 1 on page 4-37, these deceleration values were developed for assumed surface conditions which will envelop all Oconee site conditions which may be encountered. Specifically, these decelerations are based on the work contained in EPRI report NP-4830 and are applicable to impacted surfaces with target hardness numbers up to 400,000. The maximum target hardness along the Oconee transfer route is 2750 for an edge drop scenario.

The transfer cask route from the fuel buildings to the HSM was evaluated to ensure that the maximum transfer cask drop height of 80 inches is not exceeded. The nominal travel height of the transfer trailer deck is 41 inches which corresponds to a cask drop height of 59 inches. During transit from the fuel building to the HSM site, the trailer deck will be automatically leveled by the trailer's hydraulic suspension units. The maximum design travel for these units can raise the trailer deck height to 52 inches, which corresponds to a drop height of 70 inches. Mechanical stops attached to each suspension unit cylinder ensure that the cask cannot be lifted to a height greater than 70 inches above the ground. Therefore, since the Oconee target hardness and maximum potential cask drop height are less than the values presented in Reference 1 on page 4-37, the deceleration values presented in Reference 1 on page 4-37 envelop all Oconee site conditions.

The site area will be sloped appropriately to permit surface drainage to collection ditches for channelling the water away from the site. As noted in Section 2.4, "Hydrologic Engineering" on page 2-27, the site is 11.9 feet above the probable maximum flood elevation. Local intense rainfall is not a problem since the inlet air opening is 24 in. above yard grade. There is a small drainage pipe passing through the HSM front

wall into the plenum area. The base slab of the plenum area is sloped towards this drainage pipe. Additionally, the concrete approach apron is sloped away from the HSM front wall. During a local intense rain, it is remotely possible that some rainwater may backup into the HSM plenum area temporarily, but this water will drain out of the HSM soon after the intense rain subsides. Therefore, due to surface drainage, rain water will not collect to a depth of any concern.



4.1.1 FIGURES




Figure 4-1.
Site Layout and Route

4.2 STORAGE SITE

The design bases covering the analysis and design procedures for the appropriate loadings are specified in Chapter 3, "Principal Design Criteria" on page 3-1 of this report and in Reference 1 on page 4-37 for the HSM, DSC, transfer cask and transfer trailer. The foundation design includes allowances for seismic loads. The ground accelerations are from the site ground motions specified in Chapter 2, "Site Characteristics" on page 2-1. Liquefaction potential for the ISFSI site is discussed in Section 2.5, "Geology and Seismology" on page 2-43. Based on the soil investigations and using an equivalent static methodology to account for dynamic effects, spring stiffeners are determined representing the force-deflection relationship of the underlying soil. This information is utilized as input to the structural model described in Reference 1 on page 4-37 to determine settlement effects. See Section 2.5.4, "Subsurface Materials" on page 2-50 for details of the foundation analysis. Temporary loadings from the extreme environmental cases (Chapter 3, "Principal Design Criteria" on page 3-1) and accident conditions (Chapter 8, "Accident Analyses" on page 8-1) have been reviewed and are acceptable.

4.2.1 STRUCTURES

The HSM design bases, materials of construction, codes and standards, etc. are fully described in Reference 1 on page 4-37. The HSM foundation requirements are discussed in Section 2.5.5, "ISFSI Foundation" on page 2-51. The concrete approach aprons will not be attached to the HSM but will be separated by an expansion joint. Differential settlement between the slab and the HSM is not anticipated to be a problem.

The approach aprons are sized for bearing pressures using the same allowable and ultimate pressures as used for the HSM as discussed in Section 2.5.5, "ISFSI Foundation" on page 2-51. Settlement of the approach aprons will be minimal since they are normally unloaded. In addition, the transfer trailer has jacks used in vertically positioning the cask for DSC insertion into the HSM. The trailer leveling procedure will compensate for any differential settlement that may occur between the HSM and the concrete approach aprons. Outlying areas are concrete or asphalt to provide the space required for transfer trailer maneuvers.

4.2.2 STORAGE SITE LAYOUT

Figure 4-2 on page 4-9 depicts the site layout and its functional features.

4.2.3 HSM DESCRIPTION

The HSM is constructed of reinforced concrete and structural steel. The HSMs are placed in service on a load bearing foundation which is within a fenced, controlled access area.

The HSM provides the structural support for the DSC as well as protection against tornado missiles plus neutron and gamma shielding. The exterior walls form an array of modules and the front and roof of the modules are sufficiently thick to provide average surface doses that are below 20 mR/hr.

The HSM provides fuel cooling by a combination of radiation, conduction and convection. Natural circulation air flow enters at the bottom of the HSM and passes around the DSC and exits through the flow channels in the top shield slab.

The design of the HSM system includes consideration of both normal and off-normal operating conditions including a range of credible and hypothetical accidents. The HSM design and analysis were performed in accordance with Chapter 3, "Principal Design Criteria" on page 3-1 and Chapter 8, "Accident Analyses" on page 8-1 of this SAR and Reference 1 on page 4-37.

The design criteria for the operational and accident conditions fall into three main categories: structural, nuclear and thermal-hydraulic. Reference 1 on page 4-37 describes in detail the analysis of these accidents. The bounding structural loading combinations include thermal, earthquake, tornado and cask drop accidents. For the nuclear analyses, shielding of the DSC end shield plugs, the HSM walls and penetrations, and the criticality analyses were primary considerations. The thermal-hydraulic criteria assures adequate air flow inside the module, acceptable air and concrete temperatures as well as DSC and fuel clad temperatures.

4.2.4 INSTRUMENTATION SYSTEM DESCRIPTION

The Oconee ISFSI is designed to maintain a safe and secure, long-term containment and storage environment for IFAs using only totally passive components. Therefore, no safety related instrumentation is required for operation of the facility.

Instrumentation is necessary to perform the DSC transfer cask draining, purging, and drying operations. This instrumentation consists of commercial grade pressure gauges. The functions served by pressure instrumentation in the DSC loading procedure are discussed in Chapter 5, "Storage System Operations" on page 5-1 of this SAR.

Radiation monitoring is provided by existing station area, and process effluent monitors. The station radiation monitoring system is described in Oconee FSAR (Chapter 11, "Radioactive Waste Management" on page 11-1).

4.2.5 FIG. 4.5




Figure 4-
Site Plan

4.3 TRANSFER SYSTEM

4.3.1 FUNCTION

The function of the transfer system is to transfer the DSC containing irradiated fuel assemblies to and from the HSM.

4.3.2 COMPONENTS

The transport system consists of the transfer cask, DSC, transfer cask skid, transfer trailer skid positioning system and hydraulic ram.

4.3.2.1 Transfer Cask

The transfer cask is used to transfer the loaded DSC to and from the HSM. The cask provides shielding along the axial length of the fuel during transfer, loading and retrieval operations. A description of the transfer cask is provided in Reference 1 on page 4-37. For Oconee, two (2) hard surface shields were added to the enhance cask sliding characteristics and the liquid neutron shield described in Reference 1 on page 4-37, has been replaced by a solid neutron shield comprised of BISO NS-3 which is a cementitious material cast in place in the neutron shield jacket. The drain and fill ports, as well as the expansion tank, which are needed for the liquid neutron shield have been deleted. To ensure that degassing or vapor expansion will not result in overpressurization of the neutron shield jacket, pressure relief valves set at 45 psig have been added. This change results in a more passive neutron shield in that operational and maintenance considerations are reduced. Also, the possibility of a complete loss of neutron shielding as a result of an accident is eliminated, although it is still assumed that substantial degradation may occur in some localized area.

This substitution satisfies the requirements of 16CFR 72 because:

1. The surface dose rates still satisfy the requirements established in Reference 1 on page 4-37.
2. The temperature of the fuel cladding does not exceed the criteria established in Reference 1 on page 4-37.
3. The material characteristics are suitable for the service environment.
4. The consequences of postulated accidents are enveloped by the criteria established in Reference 1 on page 4-37.
5. The structural integrity of the transfer cask and DSC is not compromised.

4.3.2.2 Dry Storage Canister (DSC)

The DSC provides the primary confinement for up to 24 irradiated fuel assemblies. The DSC provides shielding at the ends and also maintains the fuel array subcritical under the worst case conditions. The DSC fits inside the transfer cask for safe movement from the spent fuel pool to the ISFSI site.

4.3.2.3 Transfer Cask Skid

The purpose of the transfer cask skid is to provide a support base for rotating the transfer cask to a horizontal position and to maintain the transfer cask in the properly aligned position during transport, loading and retrieval operations.

The basic dimensions and layout for the transfer cask skid are presented in Section 1.3.1.5 and Figure 1.3-4 of Reference 1 on page 4-37.

The main load carrying longitudinal skid members are 12WF210 wide flange sections with stiffeners added as required for the design loads. The main load carrying cross members and vertical supports for the upper and lower trunnion pillow blocks are built up steel box sections.

As shown on Figure 1.3-4 of Reference 1 on page 4-37, the transfer cask is secured to the transfer cask skid by the use of bolted top and bottom cask trunnion pillow blocks. The skid is bolted to the transfer cask trailer using the locking brackets shown on the figure.

The transfer cask skid is a non-safety related item which is designed in accordance with the requirements of the AISC code, eighth edition using linear elastic analytical methods and normal allowables for the bounding design basis loading. The design loads for the transfer skid and attachments are the same as the transfer cask trunnion loads presented in Section C.1-4 and Figure C.1-2 of Appendix C of Reference 1 on page 4-37.

The design basis loads for the transfer cask skid were conservatively established to envelope all applied loads including downending of the cask, rotational loads, and transport loads during transfer to the ISFSI site. The transfer skid design loads envelope the postulated off-normal and accident loads discussed in Section 8.2 of Reference 1 on page 4-37 such as earthquake and tornado wind loads. Along with the basic Code allowable stresses used in the design analysis, this conservative design basis assures that the skid will adequately support the NUHOMS-24P transfer cask for all postulated events.

4.3.2.4 Transfer Trailer

The transfer trailer has a capacity of 120 tons. The transfer trailer is designed to ride as low to the ground as possible to minimize the HSM height. Four hydraulic jacks are incorporated into the trailer design to provide vertical movement for alignment of the transfer cask with the HSM. The trailer is pulled to the ISFSI by a conventional tractor.

The trailer is configured as a 4x2 hydraulically steered dolly. Eight hydraulic suspensions carry four pneumatic tires each and are located two wide, in four axle lines. There are a total of 32 tires.

Hydraulic suspensions enable coupled steering of all axles around a common point, thus minimizing tire scuffing and the resulting damage to pavement and tires. The suspensions also allow other advantages, such as adjustable deck height, lockout or repair of failed suspensions or tires, and compensation for road surface irregularities.

The trailer is pulled by a conventional tractor via a drawbar unit. The drawbar unit includes hydraulic master cylinders that provide motive force for the slave steering cylinders in the trailer.

Additional features and accessories for the trailer include: diesel power pack and hydraulic control valves, hand held remote control unit, all-wheel braking, and provisions for mounting four bearing pads, hydraulic alignment system hardware, and four hydraulic lifting jacks to the trailer frame.

The trailer is a commercial grade item of the type commonly used to move heavy loads, such as the space shuttle. The design parameters for a typical trailer are provided in Table 4-1 on page 4-19. It is constructed in accordance with the manufacturer's standard QA program using the following codes of construction:

- American Institute of Steel Construction (AISC) Specification for the Design, Fabrication, and Erection of Structural Steel for Buildings
- American Society of Testing and Materials (ASTM)
- American Welding Society (AWS) AWS D1.1 Structural Welding Code-Steel
- Steel Structures Painting Council (SSPC)

4.3.2.5 Skid Positioning System

The Skid Positioning System (SPS) includes the following items which either actively or passively position the skid during storage, transport, and alignment operations: low friction bearing plates, skid tie down brackets, hydraulic lifting jacks, hydraulic x-y-theta positioning cylinders, and all associated instrumentation and controls. Controls for the SPS are located on a control skid which is located several feet from the cask.

The loaded cask is supported by a steel skid structure. The skid's weight is supported by a set of four low friction bearing plates. The bearing material offers a coefficient of friction of 5% or less with negligible breakaway friction. The skid is restrained from lateral motion during transport and storage by a set of tie down brackets which are attached to the trailer frame.

Four support plates for hydraulic lifting jacks are located on the trailer frame. Although the trailer's hydraulic suspensions could be used to perform trailer deck height adjustments, the jacks will more firmly support the load than pneumatic tires. The jacks provide elevation adjustment, plus adjustment of pitch and roll of the trailer frame relative to the concrete HSM pad. The jacks are also used in the fuel building during cask loading. There, the front pair of jacks carries most of the load during the cask setdown and downending.

A system of hydraulic actuators are oriented in the transverse and longitudinal directions on the trailer deck. These cylinders are used to align the cask correctly relative to the HSM after the deck is leveled at the appropriate height.

4.3.2.6 Hydraulic Ram System (HRS) Description

Reference 1 on page 4-37 includes a system description of the hydraulic ram in Section 1.3.1.6, a system operation description of loading and retrieval of the DSC in Section 1.3.1.7 and a functional description in Section 5.2.1.1. Figure 1.3-5 shows a typical design for the hydraulic ram system. Figure 1.3-6 shows the primary operations for the NUHOMS system.

The operations system for loading and unloading of the DSC into and out of the HSM is discussed in Sections 5.1.1.6 and 5.1.1.8 of Reference 1 on page 4-37. Figure 5.1-4 of the same reference shows the NUHOMS System retrieval operations flow chart. Safety features of the ram system are presented in Section 5.2.1.2 of Reference 1 on page 4-37.

The HRS consists of the following main components: one double-acting hydraulic cylinder (ram); one trailer-mounted tripod support assembly for rear support and alignment of the ram hydraulic cylinder; one ram support frame assembly for front support and alignment of the ram hydraulic cylinder; one grapple

assembly; one hydraulic power unit with controls; and hydraulic tubing, hoses, hose reel and accessories as required for system operation.

4.3.3 DESIGN BASES AND SAFETY ASSURANCE

4.3.3.1 Transfer Cask

The design bases of the transfer cask are given in Section 1.2.2 of Reference 1 on page 4-37. These are based primarily on radiological and structural considerations.

As discussed in Section 4.3.2.1, "Transfer Cask" on page 4-11, the solid neutron shield will be permanently filled with Bisco NS-3 - a neutron absorbing cementitious material cast in place in the neutron shield jacket. Pressure relief valves are designed to relieve pressure in the event that any off-gassing were to create excessive internal pressure.

4.3.3.2 Transfer Cask Skid

The transfer cask skid supports the transfer cask in a horizontal position on the trailer deck during the on site road transportation to the ISFSI site. The transfer cask skid is designed to support a transfer cask weighing 110 tons and to allow rotation of the transfer cask between the horizontal and vertical positions. The transfer cask skid is secured to the transfer trailer during movement and is restrained by a securing system to resist the peak loads anticipated under normal conditions of transport between the fuel buildings and the ISFSI.

4.3.3.3 Transfer Trailer

The design parameters for the transfer trailer are presented in Table 4-1 on page 4-19. Also, as shown in Section 8.2.5 of Reference 4.1, "Location and Layout" on page 4-3, the design basis drop height for the NUHOMS-24P Transfer cask is 80 inches. This analysis bounds the Oconee transport conditions. The nominal travel height of the transfer trailer deck is 41 inches which corresponds to a cask drop height of 59 inches. The maximum design travel of these units can raise the trailer deck height to 52 inches, which corresponds to a drop height of 70 inches. Mechanical stops attached to each suspension unit cylinder ensure that the cask cannot be lifted to a height greater than 70 inches above the ground.

If an event requiring return to the fuel handling building occurred inside the Oconee Nuclear Station protected area, hence, the tractor-trailer could either continue on around the east side of the Turbine Building and return to the fuel building or, if it is close to the fuel handling building, it could reverse to return.

From the point where it leaves the Oconee Nuclear Station protected area until the point where it reaches the ramp leading up to the ISFSI, the tractor-trailer has sufficient space to turn around as needed.

Once it is on the access ramp leading to the ISFSI, the tractor-trailer would have to continue to the ISFSI site in order to turn around.

4.3.3.4 Skid Positioning System (SPS)

The SPS is designed to compensate for the following variance in true alignment between the cask and HSM, in any combination.

- Pure Vertical Translation

3°

• Pure Sideways Translation	3°
• Pitch	1/4° / ft.
• Yaw	3 degrees

In addition to the above corrections, the SPS must move the cask and skid from the transport position, in which the payload's center of gravity lies directly over the centroid of the trailer, to a position where the cask slightly overhangs the rear of the trailer. The required actuator strokes to achieve the design basis compensations are (in terms of pure directional motion) approximately:

• Vertical Travel	6"
• Transverse Travel	10"
• Longitudinal Travel	39"

The SPS components which restrain the cask and skid during cask setdown and transport are designed to withstand the loads described for the cask trunnions in Appendix C.1 of Reference 1 on page 4-37. The design basis weights for use in sizing SPS actuators and hardware are, in U.S. tons:

• Empty Cask	56 tons
• Loaded DSC	38 tons
• Skid	6 tons
• Trailer	20 tons

The SPS will be designed and built to the following codes and specifications:

- American Institute of Steel Construction (AISC) Specification for the Design, Fabrication, and Erection of Structural Steel for Buildings
- American Society of Testing and Materials (ASTM)
- American Welding Society (AWS) AWS D1.1 Structural Welding Code-Steel
- National Fluid Power Association (NFPA)
- Steel Structures Painting Council (SSPC)

The SPS is specified for use in the following environmental conditions:

• Ambient Storage Temperature	-30°F to 116°F
• Ambient Operating Temperature	0°F to 110°F
• Ambient Humidity	10% to 100%
• Ambient Radiation	Negligible

The SPS is designed with several safety features to avoid unnecessary delays in the transfer process. The trailer lifting jacks have mechanical locking collars which preclude settling of the trailer deck, due to loss of hydraulic pressure to the jack cylinders. A hand pump provides redundant power as a backup in the event of pump or power unit failure. Operation of the trailer jacks, transverse, and longitudinal cylinders are mutually exclusive; it is impossible to operate more than one sub-system at a time. During alignment

and fuel transfer, the skid tie down brackets are unbolted, and the x-y travel of the skid is limited by both the hydraulic cylinder travel and by mechanical restraints on the low friction bearing travel. A tie down between the HSM and cask provides additional restraint during fuel transfer.

4.3.3.5 Hydraulic Ram

HYDRAULIC RAM SYSTEM (HRS) PERFORMANCE REQUIREMENTS:

- Ram Force - 20,000 lb., Push and pull (Nominal)
80,000 lb., Push and Pull (Maximum)
- Ram Piston Speed - 36 in/min (max)
- Stroke - Approximately 21 feet

CODES AND STANDARDS:

The HRS components are not safety related and are designed to conform to standard industrial requirements. The HRS design conforms to the following codes and standards:

- Ram Cylinder - National Fluid Power Association (NFPA) Standards Recommended Standards and American National Standards Institute (ANSI) Standards;
- Ram Connections/Clevis - NFPA and American Institute of Steel Construction (AISC) Standards;
- Hydraulic Power Unit - NFPA Recommended Standards;
- Grapple Assembly - AISC;
- Trailer-Mounted Tripod Support Design - AISC;
- Welding of Tripod Support and Ram Support Frame - AWS Structural Welding Code and American Society for Nondestructive Testing, Inc. Recommended Practices;
- Pump Motor - National Electrical Manufacturers Association (NEMA) Standards and Publications;
- Instrumentation and Controls - Instrument Society of America (ISA) Standards and the International Organization for Standardization (ISO) Standards;
- Component Materials - American Society for Testing and Materials (ASTM) Standards and ANSI Standards;
- Corrosion Protection - Steel Structures Painting Council (SSPC) Specifications and National Association of Corrosion Engineers (NACE) Recommended Practices and Material Requirements.

DESIGN LOAD CONDITIONS:

All system load bearing components of the HRS are designed to withstand the stresses associated with a maximum column load of 80,000 pounds at full extension centered 4.5 inches above the longitudinal axis of the ram cylinder. The system load bearing components include the ram hydraulic cylinder, grapple assembly and ram support frame assembly.

The trailer-mounted tripod support for the ram hydraulic cylinder is designed per American Institute of Steel Construction (AISC) Manual of Steel Construction Standards.

ENVIRONMENTAL CONDITIONS:

The HRS is designed to withstand the following environmental conditions:

- Ambient Storage Temperature Range: -30°F to 116°F
- Ambient Humidity Range: 10 to 100% (coincident with outdoor temperature range)
- Radiation Dose Rate (Section 10.3.4.1 of Reference 1 on page 4-37): 250 mrem/hr
- Ram force is limited to 20,000 pounds during the extension and retraction strokes for normal operation.
- Ram force is limited to no more than 80,000 pounds under all conditions.
- Ram extension and retraction speeds are variable from 0 to 36 inches per minutes.

INSTRUMENTATION AND CONTROLS:

The HRS is designed to allow the operator to extend and retract the ram hydraulic cylinder using hand-operated devices. The control system includes safety features to prevent the inadvertent operation of the HRS and to regulate speeds and forces of the ram to within the design criteria limitations.

COMPONENT DESCRIPTIONS:

Ram Hydraulic Cylinder - The ram hydraulic cylinder is a single stage, double-acting, horizontal design. The maximum extension or retraction force is 80,000 pounds at the maximum extension and retraction fluid pressures. The maximum piston speed for extension or retraction is 36 inches per minute (ipm). The cylinder is designed with trunnion front mounts and a rear clevis mount. The trunnions are designed to fit into the ram support frame. The rear clevis fits the ram tripod frame.

Ram Hydraulic Pump - The hydraulic pump is a positive displacement type pump.

Grapple Cylinder and Pump - The grapple is operated with a small, double acting hydraulic cylinder. The cylinder is manually operated with a hydraulic hand pump.

Reservoir - The HRS includes a 140 gallon reservoir sized to meet the system capacity requirements.

Instrumentation and Controls - The control system is designed to allow the operator to extend or retract the ram hydraulic cylinder using manually actuated pressure and flow control devices.

Grapple Assembly - The grapple assembly is depicted by Revision 1 of the NUHOMS-24P Topical Report Figure 1.3-5.

The power for the hydraulic system is provided from a retail 24 KV Oconee support line through a 75 KVA, 3 phase transformer.

Although this system does not have a backup power source, the retail power provided is considered very reliable. However, in the event of a power failure - whether momentary or extended - all efforts to transfer the DSC into the HSM will be halted until power is restored. In the interim period, the hydraulic system will be secured in the "off" position and all personnel will leave the immediate area of the cask. At any point in the transfer process, the HSM, the transfer cask, or a combination of both will provide sufficient shielding to maintain dose rates at acceptable levels during such a loss of power.

4.3.3.6 Other Equipment

All equipment other than the HSM, DSC, and transfer cask used in the transfer operations is classified as non-safety related. Equipment used for loading fuel into the DSC and transfer of the DSC/transfer cask within the fuel building is safety related and is covered by the Oconee 10CFR Part 50 license.

The failure of any non-safety related piece of transfer equipment described in Section 1.3 of Reference 1 on page 4-37 will not increase human radiation exposures by any significant amount. As described, the transfer trailer has 32 wheels. The route from the fuel building to the ISFSI site is approximately 1/2 mile. The trailer and all its components are carefully inspected prior to use, and the probability of a breakdown is small. In the event of a component failure, the trailer can be configured to overcome failure of a wheel or suspension unit and off-loading can be completed prior to repairs. A failure in the system hydraulics could be repaired or the trailer pulled to the HSM site and the DSC off-loaded. Because of this design simplicity, failure of the hydraulic ram will be limited to the hydraulic control system. Such a failure would be easy to repair and because the hydraulic controls are located at least 25 feet from the transfer cask, and therefore additional human radiation exposure during repairs would be minimal.

4.3.3.7 Qualification of Components

Qualification of the hydraulic ram system (HRS) and skid positioning system (SPS) was done per standard administrative procedures and check out testing for operation of non-safety related equipment. The qualification tests consisted of pre-operational system checkout tests. All phases of the HRS and SPS operation were tested to verify the operability of the system. Normal operation and off-normal events and the respective recovery procedures were confirmed. All system performance criteria were verified to be met.

The HRS and SPS have simple, reliable designs which require minimal maintenance on active components and negligible maintenance on passive components. Primary maintenance requirements consist of periodic inspections of the hydraulic power units, ram hydraulic cylinder, grapple assembly, SPS actuator assemblies, and manual controls. In addition, the hydraulic fluid requires periodic testing to ensure that no water, dirt or other deleterious materials have contaminated the system.

4.3.3.8 Maintenance of HRS and SPS

Maintenance requirements for the HRS and SPS are minimized by corrosion protection provided by component design. All components are manufactured from corrosion resistant materials, or coated with corrosion resistant paints, and/or stored and operated with a grease or oil surface protectant. All controls and instrumentation which are subject to corrosion are housed in a weatherproof enclosure. The ram hydraulic cylinder is stored in its retracted position, filled with hydraulic fluid.

Operating procedures, maintenance procedures and storage procedures will ensure that all HRS and SPS components are kept in operable condition throughout the system design life.

4.3.4 TABLES

Table 4-1. ONS ISFSI Project Transfer Trailer Design Parameters

Ambient Storage Temperature	-30°F to 116°F
Ambient Operating Temperature	0°F to 110°F
Ambient Humidity	10% to 100%
Ambient Radiation	Negligible
Pressure Altitude	0' to 5000' el.
Payload (Cask + Skid)	120 tons
Minimum Deck Height	34"
Maximum Deck Height	52"
Maximum Deck + Steering Unit Length	25'-0"
Maximum Deck Length	21'-1"
Maximum Width	12'-0"
Inside Turn Radius	9' or less
Outside Turn Radius	27' or less
Maximum Pulling Speed (Laden)	5 mph
Maximum Grade	6.5%
Road Surface:	
(Fully Laden)	Asphalt
(Empty Cask)	Packed Gravel or Asphalt

4.4 OPERATING SYSTEMS

4.4.1 LOADING AND UNLOADING SYSTEM

Loading and unloading of IFAs from the DSC and transfer cask requires use of the following equipment:

- 100 ton spent fuel cask handling crane
- spent fuel pool manipulator crane auxiliary hoist
- spent fuel handling tool
- transfer cask lift beam
- DSC lifting rig
- crane hook lift adapter
- cask pit platform

4.4.1.1 Preparation for Fuel Loading

Following receipt inspection and acceptance, a DSC is placed in the transfer cask. The orientation of the DSC in the cask is controlled by permanent alignment marks on each DSC and the transfer cask. The DSC is filled with borated water with a minimum concentration of 1810 ppm boron. The transfer cask is then positioned in the decontamination pit. The DSC/transfer cask annulus is filled with demineralized water and sealed with an inflatable seal. The transfer cask is then placed on the cask pit platform in the spent fuel pool.

The following components are used for this operation:

1. 100 Ton Crane - the 100 ton spent fuel cask handling crane is used to place the DSC into the transfer cask and to move the DSC/transfer cask to the spent fuel pool. The 100 ton crane is described in Section 9.1.4.2.2, "Loading and Removing Fuel" on page 9-15 of the Oconee FSAR (Reference 2 on page 4-37).
- 1 2. DSC Lift Rig - The DSC lift rig is bolted to two of the four lifting lugs attached to the support ring for the top lead shield plug inside the top of the DSC. It is used for up-ending the DSC prior to loading into the transfer cask.
- 1 3. Transfer Cask Lift Beam - The transfer cask lift beam adapts the transfer cask to the 100 ton crane hook. It is used during up-ending and transport of the transfer cask within the fuel building. The transfer cask lift beam is designed, built, and maintained in accordance with the criteria of ANSI N14.6. The lift beam is a passive, open hook design with two parallel lifting beams. It is fabricated from high strength carbon steel plate and is protected by a decontaminable coating. Figure 4-3 on page 4-26 depicts the transfer cask lift beam.
4. Crane Hook Lift Adaptor - After the DSC/transfer cask is placed on the cask pit platform, the crane hook lift adaptor is attached between the 100 ton crane hook and the transfer/cask lift beam. The crane hook lift adaptor is designed to prevent wetting the 100 ton crane hook and block when the DSC/transfer cask is lowered from the cask pit platform into the cask pit. The crane hook lift adaptor is designed, built, and maintained in accordance with the criteria of ANSI N14.6. Like the lift beam, it is fabricated from high strength carbon steel plate and is protected by a decontaminable coating. The adaptor has an elongated pin hole (48 inches) and a screw actuator at the lift beam end. For lifting the transfer cask, the adaptor is in the elongated configuration with the lift beam pin supported by the

bottom of the pin hole. When disengaged from the cask, the adaptor may be placed in the retracted configuration by means of the screw actuator, which provides support for the lift beam while in this configuration. The retracted configuration is required for the combined adaptor and lift beam to clear the spent fuel pool operating deck. Figure 4-4 on page 4-27 depicts depicts the crane hook lift adaptor.

5. Cask Loading Pit Insert - A removable platform approximately 18 inches in height is placed in the spent fuel pool cask pit. Its functions are to allow release of the transfer cask at an elevation that prevents the 100 ton crane block from contacting spent fuel pool water and to position the cask so that spent fuel can be loaded into the DSC.

4.4.1.2 Spent Fuel Selection

A description of the administrative procedures which are followed in spent fuel identification is presented in Section 10.2.5, "Administrative Controls" on page 10-6. Using special nuclear material control and accountability records, the initial enrichment and burnup for each candidate spent fuel assembly are compared against the acceptable region in Figure 10-1 on page 10-10. Fuel assemblies falling in the acceptable regions will have qualifying reactivity and decay heat characteristics for safe storage in the NUHOMS-24P System. If all requirements for spent fuel qualification are met, then documentation of this fact for a given assembly is transmitted to fuel handling personnel prior to assembly retrieval and placement in the DSC. Based upon station maps and special nuclear materials accountability records which indicate the current location of these assemblies, fuel handling personnel visually verify the assembly identification numbers and transfer these assemblies into the DSC. An independent visual verification (using binoculars or CCTV) of the assembly serial number by two different persons is performed prior to assembly retrieval from the spent fuel pool. After all assemblies have been loaded into the DSC, the assembly identification numbers are again checked. In the event that these assemblies must subsequently be retrieved in the future from the HSM/DSC and inserted back into the spent fuel pool, similar accountability/verification procedures will be used.

No fuel will be loaded into the DSC which is known to have any gross structural damage. Duke's damaged fuel assembly and component database contains a record of confirmed and suspect fuel assembly cladding and other structural failures. Assemblies which are suspected of having cladding failure are further examined visually (using cameras) to determine the extent of the damage. Of these assemblies, only those showing gross cladding or structural damage will be excluded. This inspection is performed after verification of the assembly identification number. Fuel assemblies which have no record of cladding damage are not inspected in detail; they are observed during the routine fuel handling transfer operation to ensure that the structural integrity of the assembly is maintained.

No fuel assembly cleaning or crud removal operations are planned on initial loadings or retrieval. These operations are not necessary for storage in the NUHOMS-24P system and would likely increase personnel exposures during fuel loading. The DSC will provide full containment of all radioactive crud materials which are dislodged during the handling and/or storage operations.

4.4.1.3 Spent Fuel Loading

The layout of the spent fuel pool area is shown in Figure 4-5 on page 4-28 through Figure 4-7 on page 4-30. After the DSC/transfer cask is lowered from the cask pit platform onto the cask loading pit insert, IFAs which have been qualified are loaded into the DSC. The components and equipment used for this operation are described below:

1. Spent Fuel Pool Manipulator Crane - The spent fuel pool manipulator crane mast or its monorail hoist is used to extract IFAs from their pool storage cells and to lower them into the DSC. The spent fuel pool manipulator crane is described in Section 9.1.4.2.2, "Loading and Removing Fuel" on

page 9-15 of the Oconee FSAR. If the monorail hoist is utilized, it is in conjunction with a manual spent fuel handling tool.

2. Spent Fuel Handling Tool - The spent fuel handling tool consists of a pneumatically actuated gripper and suspension cables. Its purpose is to provide remote underwater engagement and disengagement of IFAs. This tool has been used at Oconee for loading IFAs into spent fuel shipping casks, and it required no alteration for use with the DSC.

4.4.1.4 DSC Drying, Backfilling, and Sealing

After the IFAs are loaded into the DSC, the top end shield plug is replaced on the DSC. The DSC top end shield plug is suspended by cables from the transfer cask lifting yoke. The 100 ton spent fuel cask handling crane allows fine adjustment of bridge and trolley positions, hook height, as well as rotation of the crane hook. The bottom of the top lead shield plug is chamfered to allow a degree of self-centering by the plug. Two separate paths exist for displacement of DSC cavity water as the shield plug is lowered. A gap exists between the shield plug and the DSC shell, and the DSC vent port is open during installation of the top lead shield plug, both of which provide for displacement of some of the fluid from the DSC. Placement of the shield plug is recognized as a critical step requiring close attention and gradual movements to assure no misalignment or damage to components. The DSC transfer cask is raised to the cask pit platform by use of the 100 ton crane with the crane hook lift adaptor. As the DSC approaches the surface of the spent fuel pool, the correct placement of the top lead shield plug is verified visually and through dose rate monitoring. On the cask pit platform the crane hook lift adaptor is removed and the crane hook is attached directly to the lift beam in order to provide sufficient lift height during transport of the DSC/transfer cask over the pool deck and into the decontamination pit.

In the decontamination pit the top end shield plug is seal welded, and the water is purged from the DSC. The DSC is then vacuum dried and backfilled with helium. Helium leak tests are performed on the top lead shield plug seal weld and the vent and siphon port seal welds. Finally, the top cover plate is seal welded into place. These operations are described in detail in Chapter 5 of Reference 1 on page 4-37.

During the above operations, IFAs are confined within the DSC with the top end shield plug in place, and the DSC remains seated in the transfer cask. Following these operations, the transfer cask lid is placed, the annular water is drained, and the transfer cask is placed on the transfer trailer for transport to the ISFSI.

The design basis and safety assurance features of the DSC are described in Sections 3.2 and 3.3 of Reference 1 on page 4-37. The design basis and safety assurance features of the transfer cask are described in Section 1.3.1.3 of Reference 1 on page 4-37. The DSC drying and sealing equipment and operations utilize the use of industry-standard equipment and procedures commonly used for such operations.

4.4.1.5 DSC Unloading

The equipment discussed in Sections 4.4.1.1, "Preparation for Fuel Loading" on page 4-21 and 4.4.1.2, "Spent Fuel Selection" on page 4-22 is used for DSC unloading operations. Appropriate DSC cutting equipment and procedures as discussed in Section 5.1.1.9 of Reference 1 on page 4-37 will be used to open the DSC which is contained within the transfer cask.

4.4.2 DECONTAMINATION SYSTEM

No decontamination facilities are needed at the ISFSI.

Decontamination of the transfer cask is performed in the decontamination pit. The transfer cask exterior is decontaminated manually before removal from the fuel building by use of detergents and wiping cloths.

Also, the DSC top end shield plug is decontaminated in this manner prior to seal welding to the DSC body.

It is not anticipated that either the exterior of the DSC or the inside of the transfer cask will become contaminated. The DSC/transfer cask annulus is filled with demineralized water and sealed with an inflatable seal. However, in the event that such contamination occurs, the DSC/transfer cask annulus will be flushed with demineralized water until an acceptable level is achieved.

4.4.3 DSC REPAIR AND MAINTENANCE

No maintenance is required for the DSC for its design life.

4.4.4 TRANSFER CASK REPAIR AND MAINTENANCE

The function of the transfer cask is to ensure integrity of the DSC during applicable design basis accidents and to provide radiological shielding for the operators during handling and transfer operation. Confinement of radioactive materials is provided by the DSC. Accordingly, a periodic maintenance program has been established to ensure the proper operation of the cask valves, bolts, washers, o-rings and neutron shield pressure relief valves. The lifting surfaces of the cask trunnions are periodically inspected for surface deterioration.

4.4.5 UTILITY SUPPLIES AND SYSTEMS

The design of the Oconee ISFSI is based on the NUHOMS-24P system for storage of irradiated fuel. Each module is a self-contained, passive system requiring no support systems during storage.

However, the ISFSI is provided with a 480/208/120 VAC power supply for operation of the transfer trailer hydraulic positioners, hydraulic ram site security equipment and lighting.

Other electrical connections required for ISFSI physical security are described in the ISFSI Physical Security Plan (Reference 3 on page 4-37).

4.4.6 OTHER SYSTEMS

4.4.6.1 Communications and Alarm System

Details of the communication and alarm system are provided in the Physical Security Plan (Reference 3 on page 4-37).

4.4.6.2 Fire Protection System

No flammable or combustible materials are stored within ISFSI or in its immediate vicinity and the ISFSI is constructed of noncombustible heat-resistant materials (concrete and steel). Therefore, no fixed fire extinguishing system is required; however, portable suppression equipment will be provided within the fenced boundary. In the unlikely event of a fire at the ISFSI, the fire brigade will be dispatched from the Oconee Station. The Oconee Nuclear Station Pre-Fire Plan (Reference 4 on page 4-37) will be revised to incorporate fire protection requirements for the ISFSI.

4.4.6.3 Maintenance System

The ISFSI requires no maintenance other than periodic inspection of the HSM air inlets and outlets and removal of debris, if needed. Specific inspection periods and their justification are discussed in Section 10.3.3.1.

4.4.7 FIGURES




Figure 4-3.
Transfer Cask Lift Beam




Figure 4-4.
Crane Hook Lift Adaptor





Figure 4-5.
Spent Fuel Pool Area



TYPICAL LONGITUDINAL SECTION

Figure 4-6.
Spent Fuel Pool Area




Figure 4-7.
Spent Fuel Pool Area

4.5 CLASSIFICATION OF STRUCTURES, SYSTEMS, AND COMPONENTS

Table 4-2 on page 4-34 provides a list of major ISFSI components and their classification. Classification of major components as "Safety Related" or "Radwaste Related" is based on the specific need for component performance under accident conditions. However, designation of specific components as "Safety Related" or "Radwaste Related" is not the only basis for establishing whether any part is important to the safe operation of the ISFSI facilities.

As listed in Revision 1 of the NUHOMS-24P Topical Report, Section 3.2, Reference 1 on page 4-37, the NUHOMS reinforced concrete HSM including its foundation and DSC support structure, the DSC and its internal basket assembly, and the transfer cask are components considered important to safety. The design criteria for these components are provided in Section 3.2 and summarized in Tables 3.2-1 through 3.2-9 of Reference 1 on page 4-37.

The Oconee fuel building crane and the lifting beams used for movement of the transfer cask within the fuel building are designed and procured as components important to safety. The lifting beams used in that part of the operation are controlled by 10CFR Part 50 and NUREG-0672 and are designed to ANSI 14.6-1986 criteria for nonredundant yokes.

As noted in Section 4.5.5, "Transfer Components" on page 4-32, all other components of the NUHOMS system, including the transfer trailer and cask support skid, skid positioning system, and hydraulic ram system are required to perform their function to successfully transfer a DSC to and from the HSM. These systems are described in Reference 1 on page 4-37 with design requirements further delineated in Section 4.5.5, "Transfer Components" on page 4-32 of this SAR.

In addition, the transfer cask, HSM, and DSC have been designed to meet very conservative design criteria including postulated conditions which envelop those which may result from the mechanistic failure of the transfer system equipment. Design conditions such as cask drop accident and jammed DSC have been included even though there is no plausible way for these worst case events to occur. Conservative bounding analysis for these conditions have been performed using minimum material yield strengths, strength reduction factors, and factors of safety in accordance with the stringent requirements of the ASME and ACI Codes. Even when applying this conservative criteria considerable design margin for these components and structures remains as evidenced by the analysis results comparisons with acceptance criteria contained in Reference 1 on page 4-37. Further, these components and structures are fabricated and constructed to the rigorous standards and methods of the ASME and ACI Codes under a 10CFR 50 Appendix B Quality Assurance Program. These include material qualification, welding and nondestructive examination, and strict surveillance and quality control inspection. The resulting high integrity of the Transfer Cask, DSC, and HSM provide more than adequate assurance that the health and safety of the public and plant personnel are protected.

4.5.1 TRANSFER CASK

The transfer cask is considered Nuclear Safety Related (QA Condition 1) since it performs primary DSC protection functions under certain transport accident conditions. The transfer cask proposed for use in DSC transfer operations is described in Section 1.3.1.3 of Reference 1 on page 4-37.

4.5.2 DRY STORAGE CANISTER

The DSC is considered Nuclear Safety Related (QA Condition 1) since it performs criticality control and primary IFA support functions as well as serving as the primary storage containment for the IFAs. It is designed to remain intact under all accident conditions identified in Chapter 8, "Accident Analyses" on page 8-1 of this SAR with no loss of function. DSC components are designed, constructed, and tested in accordance with Nuclear Safety Related requirements as defined by 10CFR 50, Appendix B and the DPC QA-1 Quality Assurance Program.

4.5.3 HORIZONTAL STORAGE MODULE

The HSM functions include shielding, heat removal, DSC support, and DSC tornado missile protection. The HSM is not considered Nuclear Safety Related since it performs no primary IFA containment or criticality control functions. However, HSM functions are considered important to the safe operation of the ISFSI and appropriate levels of documentation and control are applied. The concrete HSM is designed in accordance with ACI 349-85 and the level of testing, inspection and documentation provided during construction is in accordance with the DPC QA-2 Quality Assurance Program.

As shown by Table 8.1-12 of Reference 1 on page 4-37, the maximum HSM concrete temperature for the long term 70°F ambient storage temperature case is 144°F. This is less than the maximum permissible concrete temperature of 150°F specified by ACI 349-85. The effect of extreme ambient temperatures will be to increase the maximum concrete temperature. However, the methods used to calculate these temperatures assumed that the extreme ambient temperatures would remain constant until steady state conditions can be established within the HSM. In reality, the extreme ambient temperatures will occur infrequently and will last for a short duration insufficient to cause steady state conditions. Therefore, the long term maximum temperatures for the HSM concrete easily meet the ACI 349 temperature limitations.

Coupled with the conservative reductions in concrete material strength used in the HSM design calculations, the design criteria utilized in Reference 1 on page 4-37 are adequate to ensure that the HSM will perform its intended safety function for all design conditions.

Typical reinforcing steel design for the HSM basemat, walls, and roof is shown in Figure 8.1-9 of Reference 1 on page 4-37. The HSM reinforcing designs are in accordance with the ACI 349-85 Code and are comparable to those previously reviewed and approved by the NRC for the NUHOMS-07P design.

4.5.4 FOUNDATION

The ISFSI foundation is designed, constructed and tested to the same design criteria and quality assurance requirements as the HSM.

4.5.5 TRANSFER COMPONENTS

The remaining DSC transfer components (i.e. transfer cask trailer and skid, skid positioning system, hydraulic ram system) are necessary for the successful loading of the DSC into the HSM. As discussed in Section 4.3, "Transfer System" on page 4-11, failure of these components would not endanger the health and safety of the public or plant personnel. Therefore, transfer components are not considered Nuclear Safety Related and are designed, constructed and tested in accordance with good industry practices.

4.5.6 INSTRUMENTATION

The Oconee ISFSI is designed to maintain a safe and secure, long-term containment and storage environment for IFAs using only totally passive components. Therefore, no Nuclear Safety Related instrumentation is required for operation of the facility. Instrumentation necessary to perform DSC/transfer cask draining, purging and drying operations consists of industrial grade pressure gauges.

4.5.7 TABLES

Table 4-2. Oconee ISFSI Major Components and Classification

• Transfer Cask	Safety Related ⁽¹⁾
• Dry Storage Canister (DSC)	Safety Related ⁽²⁾
Basket	
Spacer Disks	
Support Rods	
End Shield Plug/Support (top and bottom)	
DSC Body	
End Closure Plates	
• Horizontal Storage Module (HSM)	Radwaste Related ⁽³⁾
Concrete Shielding	
DSC Support Assembly	
• Foundation	Radwaste Related ⁽³⁾
• Transfer Components	Industrial Grade
Transfer Trailer/Skid	
Ram Assembly	
• Instrumentation	Industrial Grade

Notes:

1. To ensure containment and criticality control under all applicable transport accident conditions, transfer cask components are designed, constructed, and tested in accordance with Nuclear Safety Related requirements as defined by 10CFR 50, Appendix B and the DPC QA-1 Quality Assurance Program.
2. To ensure safe and secure, long-term containment and criticality control during transfer and storage of IFAs, DSC components are designed, constructed, and tested in accordance with Nuclear Safety Related requirements as defined by 10CFR 50, Appendix B and the DPC QA-1 Quality Assurance Program.
3. Components which are not required to perform a safety function or mitigate the consequences of an accidental radiological release comparable to 10CFR 100 site dose criteria guide values are designed, constructed, and tested in accordance with the DPC QA-2 Quality Assurance Program. Additionally, the concrete HSMs and foundation are designed to withstand Safe Shutdown Earthquake seismic forces and tornado missiles so as to preclude any interaction with the DSC pressure boundary or loss of shielding. Therefore, construction and inspection shall be in accordance with the QA-2 Quality Assurance Program.

4.6 DECOMMISSIONING PLAN

Decommissioning of the ISFSI will be performed consistent with decommissioning of the Oconee Nuclear Station. This is predicated on the ability of the federal government to accept spent fuel at the rates and dates specified in the Nuclear Waste Policy Act of 1982, as amended. It is anticipated that the DSCs will be transported to a federal repository when such a facility is operational. However, should the storage facility not accept the DSCs intact, the NUHOMS-24P system allows the DSCs to be brought back into the spent fuel pool and the fuel repositioned into the racks for loading into transport casks to be provided by the Department of Energy.

All components of the NUHOMS-24P system are manufactured of similar materials found in the existing Oconee Station (i.e., reinforced concrete, stainless steel, lead). These components will be decommissioned by the same methods in place to handle similar materials within the plant. Any of these components that may be contaminated will be cleaned and/or disposed of consistent with the decommissioning technology available at the time of decommissioning.

Although operation of the ISFSI will likely need to continue well beyond decommissioning of the Oconee Nuclear Station, the costs of decommissioning the ISFSI are expected to represent a small and negligible fraction of the cost of the decommissioning the Oconee Nuclear Station. Reference 5 on page 4-37 submitted a schedule and justification for a decommission plan which will encompass decommissioning of both Oconee Nuclear Station and the Oconee ISFSI in accordance with 10CFR 50.75 and 10CFR 72.30. The financial options for this plan were submitted on July 24, 1990 for the NRC review and approval. Reference 6 on page 4-37.

The radiological impacts due to postulated accidents or operation of the ISFSI are bounding for the conditions when the ISFSI is fully operational. The collective dose to residents within one to two miles of the ISFSI is based on capacity loading of 2112 spent fuel assemblies in 88 storage modules. The occupational dose to site workers assumes radiation from an array of 2 x 10 modules loaded with dry shielded casks each containing 24 spent fuel assemblies. The consequences from accidents are based on failure of 24 spent fuel assemblies contained in a dry shielded cask. The expected radiological impact due to operation of the ISFSI is much less than the regulatory limits specified in 10CFR 72.104 and 10CFR 106(b) and the EPA Protection Action Guides. Furthermore, Duke intends to operate the Oconee ISFSI for the life of the licensed plant. It can be projected that once the spent fuel is removed from the ISFSI, the radiological consequences of decommissioning will actually be lower than that of operating the facility. Thus, the health and safety of the public are not affected by this exemption request.

4.7 REFERENCES

1. Topical Report for the Nutech Horizontal Modular Storage System, for Irradiated Nuclear Fuel NUH-002, Rev. 1A, dated July 1989
2. Oconee Nuclear Station Final Safety Analysis Report
3. Oconee Nuclear Station ISFSI Physical Security Plan - January 12, 1988
4. Oconee Nuclear Station Pre-Fire Plan
5. Letter from H. B. Tucker to U.S. NRC, Document Control Desk dated May 9, 1989
6. Letter from D. L. Hauser to U.S. NRC dated July 24, 1990

CHAPTER 5. STORAGE SYSTEM OPERATIONS

5.1 OPERATION DESCRIPTION

As a supplement to Sections 4.3, "Transfer System" on page 4-11 and 4.4, "Operating Systems" on page 4-21 of this report and Section 5.1 of Reference 1 on page 5-15 which describe the transport and fuel loading systems and their operation, this chapter describes the actual operations which occur at the ISFSI site after transfer of the DSC from the fuel building.

5.1.1 NARRATIVE DESCRIPTION

The following steps describe the operating procedures which occur after the DSC has been loaded with irradiated fuel assemblies and transferred to the ISFSI site. A more detailed description of HSM loading steps is provided in Section 5.1.1.6 of Reference 1 on page 5-15.

5.1.1.1 Loading of the DSC into the HSM

1. Inspect all air inlets and outlets on the HSM to ensure that they are clear of debris. Inspect all screens on the air inlets and outlets for damage. Replace screens if necessary. Using an available yard crane, completely remove the front access door of the HSM. Inspect the interior of the HSM and the DSC support rail surfaces for obstructions or debris.
2. Using an appropriate towing vehicle position the transfer cask/trailer assembly inside the gross alignment marks on the HSM pad and move it slowly, toward the HSM until the docking collar is at the minimum distance from the HSM opening to allow for cask lid removal.
3. Using the optical alignment system, the targets on the transfer cask and HSM, and the skid positioning system, adjust the position of the cask until the cask is properly aligned with the HSM.
4. Unbolt and remove the cask lid and the cask bottom access plate.
5. Move the cask against the HSM so that the docking collar is completely seated in the HSM recess.
6. Secure the cask to the HSM using the cask restraint system and the anchors on the front wall of the HSM.
7. Assemble and align hydraulic ram assembly with transfer cask/trailer and secure in place. Recheck alignment of the HSM, transfer cask, and ram assembly.
8. Extend the hydraulic ram toward the cask and activate the grapple to engage the DSC.
9. Continue extension of the hydraulic ram to move the DSC into the HSM. If the ram fails to extend when the load on the hydraulic system is increased beyond 20,000 lbs., or, if a sudden, large increase in hydraulic pressure is observed, the DSC may be jammed or bound. If jamming or binding is suspected, corrective actions as described in Section 8.1.1.4, "Corrective Actions" on page 8-3 will be applied.
10. When the DSC is in the HSM, release the grapple from the DSC and retract the hydraulic ram arm from the transfer cask.
11. Disassemble and return the hydraulic ram to its transfer trailer and pull the transfer cask trailer a few inches away from HSM.
12. Lower the HSM front access door back into the door frame to within a few feet of the closed position.
13. Install seismic restraint.

14. Lower to the closed position and tack weld the steel HSM front access door.
15. Measure the change in temperature between the HSM inlet and outlet air vents.
16. Return all equipment to storage locations pending delivery/loading of next DSC.

5.1.1.2 Monitoring Operations

On a 24 hour frequency site personnel will visually inspect all air inlets of each loaded HSM for both obstructions and screen damage. HSM air outlets will be monitored daily using site surveillance cameras. Obstructions and/or damage will be removed/repared immediately. The ISFSI site will also be included in the routine site patrols performed by Oconee's Security personnel.

5.1.1.3 Fuel Identification and Accountability

In compliance with NRC regulations, accountability records for all fuel assemblies transferred to, stored in or removed from the ISFSI will be maintained.

The asymmetrical design features of the DSC allow for easy identification of specific assembly storage locations within the DSC. No visible physical labels are necessary for the individual storage locations. Unique storage location symbols will be administratively assigned to each of the 24 DSC storage cells. This is similar to the method which is currently used to track assembly locations within the spent fuel pools. Unique identifications will be assigned to the HSMs, and will be labeled on the HSM exterior. This visible physical identification in combination with the administrative assignment of cell storage locations within the DSC, and a unique serial number stamped on each DSC, will allow for the positive identification of the locations of all ISFSI spent fuel assemblies.

Once a DSC has been inserted into a HSM, the door will be lowered and tack welded into place. These tack welds will sufficiently indicate any attempts at tampering as required in ANSI 57.9-84.

Unique identification of the transfer cask will not be required since only one transfer cask is to be used. This eliminates the possible mixup of transfer casks which might occur with multiple casks being used for concurrent transport operations. Accountability and control of special nuclear materials will be maintained at all times during the loading, transport, and storage of spent fuel assemblies.

5.1.1.4 Unloading the DSC from the HSM

1. Inspect the front access components of the HSM and cut tack welds on HSM access door. Remove cask lid.
2. Position the cask/trailer assembly so that the docking collar is at the minimum distance from the HSM to allow for opening of the HSM front access door.
3. Using the optical alignment system, the targets on the transfer cask and HSM, and the skid positioning system, adjust the position of the transfer cask until the transfer cask is properly positioned with respect to the HSM.
4. Using an available yard crane, raise the front access door of the HSM just high enough to access the seismic restraint.
5. Remove seismic restraint.
6. Remove the HSM access door from the support rails.
7. Move the transfer cask against the HSM so that the docking collar is completely seated in the HSM recess.

8. Secure the transfer cask to the HSM, using the cask restraint system and the anchors on the front wall of the HSM.
9. Align hydraulic ram assembly with transfer cask/trailer and secure in place. Recheck alignment of HSM, cask and ram assembly.
10. Recheck the cask and ram alignment to ensure it is properly positioned with respect to the HSM.
11. Extend the hydraulic ram through the transfer cask into the HSM and activate the grapple to engage the DSC.
12. Retract the hydraulic ram to move the DSC out of the HSM and into the transfer cask. If the ram fails to retract when the load on the hydraulic system is increased beyond 20,000 lbs., or if a sudden large increase in hydraulic pressure is observed, the DSC may be jammed or bound. If jamming or binding is suspected, corrective actions as described in Section 8.1.1.4, "Corrective Actions" on page 8-3 will be applied.
13. When the DSC is in the transfer cask, release the grapple from the DSC and retract the hydraulic ram arm from the transfer cask.
14. Replace the top lid and bottom access plate on the transfer cask and move all hydraulic equipment away to allow for transfer cask trailer movement to appropriate location for DSC removal or offsite shipment.

5.1.2 FLOW SHEET

Loading and unloading operations are illustrated in Figure 5-1 on page 5-7.

5.1.3 IDENTIFICATION OF SUBJECTS FOR SAFETY ANALYSIS

5.1.3.1 Criticality Prevention

Criticality in the NUHOMS-24P DSC is prevented through a combination of geometrical separation of the fuel cells, neutron absorption in the cell walls and administrative controls on fuel pool soluble boron concentration and the selection of fuel to be stored in the DSC. The DSC basket makes use of two material thicknesses in the cell walls as well as some over-sleeves at the top and bottom of interior cells to accommodate sufficient neutron absorption with qualified fuel assemblies. While the DSC design features will be essentially fixed, the selection of fuel for storage will be a variable. Administrative control of fuel selection will be incorporated into plant procedures. Further discussion of these controls and procedures are provided in Sections 4.4, "Operating Systems" on page 4-21 and 10.2, "Development of Operating Controls and Limits" on page 10-5. The criticality analysis for the NUHOMS-24P System can be found in Section 3.3.4 of Reference 1 on page 5-15.

5.1.3.2 Instrumentation

The proposed ISFSI is a system requiring no instrumentation for radiation, temperature or criticality considerations.

5.1.3.3 Maintenance Techniques

Due to the passive nature of the proposed ISFSI, the only maintenance on the HSM will be periodic surveillance of the air inlet and outlet vents to insure continued air flow. Routine maintenance on the transfer cask will also be performed to maintain integrity of top lid, bottom access plate and trunnions.

5.1.3.1 Administrative Controls to Limit DBT Effects

Administrative controls for limiting transfer operations due to potential tornado weather conditions will not be required. The transfer cask in transit has been evaluated for tornado wind speeds and DBT effects in accordance with 10CFR Part 72 and was found to be enveloped by the evaluation for a design basis cask drop accident.

5.1.4 FIGURES




Figure 5-1. NUHOMS System Loading Operations Flowchart




Figure 5-2.
NUHOMS System Loading Operations Flowchart




Figure 5-3.
NUHOMS System Loading Operations Flowchart




Figure 5-4.
NUHOMS System Loading Operations Flowchart





Figure 5-5. NUHOMS System Loading Operations Flowchart



NOTE: NUHOMS SYSTEM RETRIEVAL OPERATIONS FLOW CHART
IS SHOWN IN FIGURE 5.1-4 OF REFERENCE 5.1

Figure 5-6.
NUHOMS System Loading Operations Flowchart

5.2 CONTROL ROOM AND CONTROL AREAS

This is a passive system and there is no need for annunciators or other systems to indicate off-normal conditions.

Surveillance for such conditions will utilize visual inspection techniques. Security surveillance will be tied into the main central alarm station and /or secondary alarm station at the Oconee Nuclear Station.

5.3 REFERENCES

1. Topical Report for the Nutech Horizontal Modular Storage System for Irradiated Nuclear Fuel, NUH-002, Revision 1A, dated July 1989

CHAPTER 6. WASTE MANAGEMENT

No radioactive wastes are generated during the storage life of DSCs. Radioactive wastes generated during loading operations are treated using existing station facilities and procedures.

Contaminated pool water removed from loaded DSCs will normally be drained back into the spent fuel pool with no additional processing. A small amount (< 15 CF/DSC) of liquid waste results from transfer cask decontamination. The decontamination procedure results in a small amount of a detergent/demineralized water mixture being collected in the Cask Decontamination Pit. Liquid wastes collected in the Cask Decontamination Pit are directed to the Station Liquid Waste Management System (LWM) for processing.

Potentially contaminated air and helium purged from the DSC following DSC loading and seal welding operations are directed to the Auxiliary Building Ventilation Air System (VA) at a point upstream of the Fuel Building HVAC filter units and radioactive effluent monitor. Purged gases processed with the Fuel Building HVAC filter units are released from the unit vent and will meet station release requirements. This is the same procedure currently utilized for shipping cask operations.

1. A small quantity (< 5 CF/DSC) of low level solid waste is generated as result of DSC loading operations and transfer cask decontamination. The solid waste generated is processed by compaction or incineration using appropriate facilities. This low level waste consists of disposable Anti-C garments, tape, blotter paper, rags, etc.

Descriptions of the LWM, VA and VR Systems are provided in Chapter 11 of the Oconee FSAR.

CHAPTER 7. RADIATION PROTECTION

7.1 ENSURING THAT OCCUPATIONAL RADIATION EXPOSURES ARE ALARA

7.1.1 POLICY & ORGANIZATIONAL CONSIDERATIONS

Duke Power Co. Radiation Protection and ALARA policies are described in Chapter 12, "Radiation Protection" on page 12-1 of the Oconee FSAR (Reference 1 on page 7-35). These policies will be applied to the Independent Spent Fuel Storage Facility. Duke Power is committed to a strong ALARA program in design and operation of nuclear facilities. The ALARA program follows the general guidelines of Regulatory Guides 1.8, 8.8, 8.10 and 10CFR 20. Plant and design personnel are trained and updated on ALARA practices and dose reduction techniques. Design and implementation of systems and equipment are reviewed to insure ALARA work on all new and modification projects. The basic ALARA Program consists of

1. The Duke Power Company ALARA Manual;
2. continued surveillance and evaluation of in-plant radiation and contamination conditions, as well as the monitoring and control of the exposure of personnel, by the station and general office radiation protection staff;
3. an ALARA Committee at each station consisting of management and representatives from all groups, including liaison from the general office radiation protection staff, whose purpose is to conduct and appraise the effectiveness of the ALARA program at the nuclear facility.

The committee members have extensive background in nuclear plant radiation and exposure control, including such areas as layout, shielding, personnel access, ventilation, waste management, monitoring systems, operations, and maintenance.

Although upper level management is vested with the primary responsibility and authority for administering the Duke ALARA program, the responsibility for ALARA is extended through lower management to the individual employee.

Specific responsibilities of the general office and station radiation protection staffs are contained in the Duke Power Company Radiation Protection Manual.

This manual ensures that:

1. An effective ALARA program is administered at the Oconee nuclear station that appropriately integrates Duke management philosophy and NRC regulatory requirements and guidance.
2. Facility design features, operating procedures and maintenance practices are in accordance with ALARA program guidelines; and that written reviews of the on-site radiation control program assure that objectives of the ALARA program are attained.
3. Pertinent information concerning radiation exposure of personnel from other utilities and research work are reflected in the design and operation of the Duke Facility.
4. Appropriate experience gained during the operation of nuclear power stations relative to in-plant radiation control is factored into revisions of procedures to assure that the procedures continually meet the objectives of the ALARA program.
5. Necessary assistance is provided to insure that operations, maintenance, and decommissioning activities are planned and accomplished in accordance with ALARA objectives.

6. Trends in station personnel and job exposures are analyzed in order to permit corrective actions to be taken with respect to adverse trends.

Reports of the findings of the general office and station radiation protection staffs are also effectively conveyed to management.

Specific responsibilities of station personnel are to ensure that:

1. Activities are planned and accomplished in accordance with the objectives of the ALARA program.
2. Procedures and their revisions are implemented in accordance with the objectives of the ALARA program.
3. The general office radiation protection staff is consulted as necessary for assistance in meeting ALARA program objectives.

Other group and individual responsibilities to the ALARA program are outlined in Section II of the DPC ALARA Manual.

The primary goal of the radiation protection and ALARA programs is to minimize exposure to radiation such that the total exposure to personnel in all phases of design, construction, operation and maintenance are kept As Low As Reasonably Achievable. This is achieved by integrating ALARA concepts into design, construction, and operation of facilities. The radiation protection program identifies the positions and responsibilities of participating organizations in conducting these programs.

Trained personnel adequate to develop and conduct all necessary radiation protection and ALARA programs are provided. These personnel are trained to assure that all procedures are followed to meet company and regulatory requirements. Training programs in the basics of radiation protection and exposure control are provided to all facility personnel whose duties require working in radiation areas. Design personnel responsible for design of systems and equipment in the radiation area are trained in ALARA design techniques and the fundamentals of dose reduction. Radiation Protection personnel are provided training to improve their performance in implementing the radiation protection programs. All personnel are retrained as needed to update practices to current state of the art methods.

The administrative organization is responsible for and has appropriate authority for assuring that the three basic objectives of the Radiation Protection program at Oconee Nuclear Station are achieved. These objectives are to:

1. Protect personnel
2. Protect the public
3. Protect the station

Protection of Personnel, includes surveillance and control over internal and external radiation exposure and maintaining the exposure of all personnel within permissible limits and as low as reasonably achievable (ALARA).

Protection of the public, includes surveillance and control over all conditions and operations that may affect the health and safety of the public. Included are such activities as radioactive gas, liquid and solid waste disposal, shipment of radioactive materials, an environmental radioactivity monitoring plan and maintaining portions of the station emergency plan.

Protection of the Facility, includes monitoring to warn of possible detrimental changes and exposure hazards, to determine changes or improvement needed, and to note trends for planning future work.

This administrative organization is also responsible for and has appropriate authority for maintaining occupational exposures as far below the specified limits as reasonable achievable by assuring that:

1. Station personnel are made aware of management's commitment to keep occupational exposures as low as reasonably achievable;
2. Formal reviews are performed periodically to determine how exposures might be lowered;
3. There is a well-supervised radiation protection capability with specific defined responsibilities;
4. Station workers receive sufficient training;
5. Sufficient authority to enforce safe station operation is provided;
6. Modification to operating and maintenance procedures and to station equipment and facilities are made where they should substantially reduce exposures at a reasonable cost;
7. The radiation protection staff understand the origins of radiation exposures in the station and seek ways to reduce exposures;
8. Adequate equipment and supplies for radiation protection work are provided.

The Station Manager is responsible for the protection of all persons against radiation and for compliance with NRC regulations and license conditions. This responsibility is in turn shared by all supervisors. Furthermore, all personnel are required to work safely and to follow the regulations, rules, and procedures that have been established for their protection.

The Duke Power Company Technical System Manager - Radiation Protection establishes the Radiation Protection Program including the program for handling and monitoring radioactive material for Oconee that is designed to assure compliance with applicable regulations, technical specifications, and regulatory guides. This person also provides technical guidance and support for conducting this program, reviews the effectiveness and the results of the program and modifies it as required based on experience and regulatory changes, to assure that occupational radiation exposure and exposure to the general public are maintained as low as reasonably achievable.

The Technical System Manager also provides technical assistance to the Vice President, Nuclear Production, who has management authority to implement the "as low as reasonably achievable" (ALARA) occupational exposure policy, to which Duke Power Company is committed.

The Radiation Protection Manager at Oconee is responsible for conducting the Radiation Protection Program that has been established for the station, including the ISFSI. The Radiation Protection Manager has the duty and the authority to measure and control the radiation exposure of personnel; to continuously evaluate and review the radiological status of the station; to make recommendations for control or elimination of radiation hazards; to assure that all personnel are trained in radiation protection; to assist all personnel in carrying out their radiation protection responsibilities; and to protect the health and safety of the public both on-site and in the surrounding area.

In order to achieve the goals of the Radiation Protection Program and fulfill these responsibilities for radiation protection, radiological monitoring, survey and personnel exposure control work are performed on a continuing basis for station operations and maintenance including the ISFSI.

7.1.2 DESIGN CONSIDERATIONS

The design of the DSC and HSM comply with 10CFR 72 concerning ALARA considerations. Specific considerations that are directed toward ensuring ALARA are:

- Thick concrete walls on the HSM to reduce the surface dose to below an average of 20 mr/hr. The 20 millirem per hour dose rate was the approved maximum for HSM wall dose rates in the NUHOMS-07P Typical Report. Actual calculated HSM wall surface dose rates are below 10 millirem per hour except at vent and door openings. The HSM shielding design was deemed ALARA considering construction costs, heat dissipation, and access requirements. Also, refer to Section 7.1.2 of Reference 2 on page 7-35 for the basis of the average 20 millirem per hour HSM contact dose rate. Additional shielding analysis is included in Section 7.3.2.2, "Shielding Analysis" on page 7-12 and Table 7.3-2 of Reference 2 on page 7-35.
- Lead shield plug on the ends of the DSC to reduce the dose to workers performing drying, sealing, and loading operations.
- Use of a shielded transfer cask for handling and transportation operations of loaded DSCs.
- Fuel loading procedures which follow accepted practice and build on existing experience.
- Recess in the HSM front for the transfer cask to fit into so as to reduce scattered radiation during transfer.
- Double seal welds on each end of DSC to provide redundant radioactive material containment.
- Placing clean water in the transfer cask and DSC and sealing the DSC/transfer cask annulus to prevent contamination of DSC exterior during loading.
- Placing external shielding blocks over HSM air outlets to reduce direct and streaming doses.
- Passive system design that requires minimum maintenance.
- Insertion of internal shielding blocks around air inlets to reduce direct and streaming doses.
- Use of portable shielding during DSC drying/welding operations to limit streaming from top end shield plug/DSC annulus. The portable shield used during DSC closure operation to limit streaming from top end shield plug/DSC annulus consists of 2.0 inches of Bisco NS-3, or equivalent, as shown in Figure A.2, Appendix A of Reference 2 on page 7-35. The portable shield will be put in place to minimize doses during direct-access operations such as top shield plug automatic welding setup, draining and drying operations, and setup of automatic welding equipment for the top cover plate. The portable shield will incorporate provisions to facilitate access to the drain and fill ports but may not be necessary during automatic welding operations.
- To minimize scatter at the HSM door during DSC loading, the top of the transfer cask docks into a recess in the HSM access door opening.
- Use of existing shipping procedures and experience to control contamination during handling and transfer of fuel.
- Leaving water in the DSC cavity and DSC/transfer cask annulus during welding operations as long as possible to reduce streaming through the gap. The water level in the DSC/transfer cask annulus is lowered to approximately 5 to 10 inches below the top of the DSC shell. The water level in the DSC cavity is lowered to approximately 4 inches below the bottom surface of the top end shield plug. These levels are maintained during shield plug welding operations. The remaining water in the annulus is not drained until after the cask cover plate is bolted into place.
- Providing a large control area around the ISFSI and locating the facility well away from normally occupied areas.
- Operation of the ISFSI will be performed under the Radiation Protection program of the station as described in 7.1.1, "Policy & Organizational Considerations" on page 7-3.

- Lead blanket screens may be employed to further reduce dose during decontamination and transfer operations. These and other ALARA measures precautions may be employed as needed based on experience gained from preoperational testing and early fuel loading efforts.

7.1.3 ALARA OPERATIONAL CONSIDERATIONS

Consistent with Duke Power Company's overall commitment to keep occupational radiation exposures as low as reasonably achievable, (ALARA), specific plans and procedures are followed by station personnel to assure that ALARA goals are achieved. Operational ALARA policy statements are formulated at the corporate staff level in the Nuclear Production Department through the issuance of the System Radiation Protection Manual and the ALARA Manual and are implemented at each nuclear plant by means of procedures. These statements and procedures are consistent with the intent of Section C.1 of Regulatory Guides 8.8 and 8.10.

Since the ISFSI is a passive system, no maintenance is expected on a normal basis in the facility. Maintenance operations on the transfer cask, transfer trailer and other ancillary equipment is performed in a very low dose environment when fuel movement is not occurring.

Maintenance activities that could involve significant radiation exposure of personnel are carefully planned. They utilize any previous operating experience, and are carried out using well trained personnel and proper equipment. Radiation Work Permits (RWPs) for non-routine operations, or Standing Radiation Work Permits (SRWPs) for routine operations are issued for each job, listing Radiation Protection requirements that shall be followed by all personnel working in the Radiation Control Area (RCA). Where applicable, specific radiation exposure reduction techniques, such as those set out in Regulatory Guide 8.8, are evaluated and used.

The station ALARA Committee carefully reviews operations and maintenance activities involving the major plant systems to further assure that occupational exposures are kept ALARA.

7.2 RADIATION SOURCES

7.2.1 CHARACTERIZATION OF SOURCES

This section describes the design basis radiation sources and source geometries used for the ISFSI shielding calculations.

Neutron and gamma sources are developed based on the reference irradiated fuel assembly described in Table 1-1 on page 1-7. The reference fuel assembly is assumed to be irradiated to a burnup of 40,000 mwd/mtu and cooled to a decay heat rate of less than or equal to 0.66Kw before being stored in the DSC. The initial enrichment considered is 4.0 weight percent U-235. The source terms include the irradiated fuel, activated portions of the fuel assemblies and deposited activity from corrosion products in the reactor coolant. All primary sources are considered to be originating in the fuel with secondary gammas generated in the shielding considered by the shielding codes used.

The detailed calculation of gamma ray group fractions provided in Table 7.2-2 of Reference 2 on page 7-35 is summarized in Table 7-1 on page 7-10.

The fuel region is modeled as a homogeneous cylinder for shielding calculations as shown in the model geometry descriptions. The homogeneous source over the active fuel region includes fission product, actinide and light element activation product sources. The burnup distribution is assumed flat along the axial and radial extent of source. This modeling technique is used in all shielding calculations except supplementary calculations performed subsequent to ISFSI operation. The supplementary calculations use a heterogeneous source distribution to demonstrate the effect IFA end fitting and plenum region light element activation and reduced self-shielding have on localized TC surface dose rates.

Additional details of the radiation source terms and dose conversion factors used in ISFSI shielding analysis are provided in Section 7.2.1 of Reference 2 on page 7-35.

7.2.2 AIRBORNE RADIOACTIVE MATERIAL SOURCES

The DSC is double weld welded to prevent any gaseous release of material during storage. The possibility of release during fuel handling in the spent fuel pool is covered in the accident analysis. The other possible source of airborne radioactive material is the outside surface of the DSC. This surface is protected from contamination while the DSC is in the fuel pool by filling the annulus between the DSC and the transfer cask with demineralized water and sealing the annulus to prevent pool water from coming in contact with the outside surface of the DSC. This prevents any significant accumulation of potential airborne sources on the canister. The outside surface of the transfer cask is considered to be contaminated upon removal from the fuel pool and will be cleaned and swiped to be sure no unacceptable contamination remains before leaving the fuel building.

Cask venting releases are directed to the fuel pool HVAC units upstream of the HEPA and carbon filter units. The filtered gas is ultimately released through the unit vent after it is monitored by both the spent fuel pool storage area HVAC monitor and unit vent monitor.

7.2.3 TABLES

Table 7-1. Gamma Energy Spectrum

Cask Energy Group No.	E_{upper} (MeV)	E_{mean} (MeV)	Gamma Source Strength (Photons/sec/ N_c TIHM)
23	10.0		0
24	8.0		0
25	6.5	5.50	$3.84 + 6$
		4.75	
26	5.0	4.25	$1.16 + 7$
		3.75	
27	4.0	3.25	$1.53 + 9$
28	3.0	2.80	$8.93 + 9$
		2.40	
29	2.5	2.00	$3.96 + 11$
30	2.0		0
31	1.66	1.57	$1.88 + 13$
32	1.33	1.13	$2.66 + 14$
33	1.0		0
34	0.8	0.65	$4.34 + 15$
35	0.6		0
36	0.4	0.30	$1.92 + 14$
37	0.3		0
		0.17	
38	0.2	0.12	$4.91 + 14$
		0.085	
39	0.1	0.055	$1.11 + 15$
		0.030	
40	0.05	0.010	$3.38 + 15$
			$9.80 + 15$
		Σ All Group	

7.3 RADIATION PROTECTION DESIGN FEATURES

7.3.1 INSTALLATION DESIGN FEATURES

The design considerations listed in Section 7.1.2, "Design Considerations" on page 7-5 ensure that occupational exposures to radiation are ALARA and that a high degree of integrity is obtained for the confinement of radioactive materials. The ISFSI will be hand monitored as needed for construction, loading and unloading operations. Since the storage facility contains no active systems, no continuous monitoring systems other than fence-mounted dosimetry or alarms are needed. Applicable portions of the guidance given in Regulatory Position 2 of Regulatory Guide 8.8 have been followed: 1) Access control of radiation areas is addressed in Sections 7.1.3, "ALARA Operational Considerations" on page 7-7 and 10.2.5, "Administrative Controls" on page 10-6. 2) Radiation shields substantially reduce exposure of personnel during operations and storage; radiation streaming has been reduced by providing labyrinth-type shield penetrations. 3) NUHOMS-24P is a passive storage system; no process instrumentation or controls are necessary during storage. 4) Airborne contaminants and gaseous radiation sources are controlled by the integrity of the double seal welded DSC assembly. 5) No crud is produced by the NUHOMS-24P system. 6) The necessity for decontamination is reduced by maintaining the cleanliness of the DSC during operations (see Section 5.1, "Operation Description" on page 5-3); the DSC surfaces are smooth, nonporous, and free of crevices, cracks, and sharp corners. 7) No radiation monitoring system is required during storage. 8) No resin or sludge is produced by the NUHOMS-24P system.

Radiation sources are contained within DSCs which are stored in concrete HSMs. The radioactive sources are described in detail in Section 7.2.1 of Reference 2 on page 7-35.

7.3.2 SHIELDING

7.3.2.1 Radiation Shielding Design Features

Radiation shielding is an integral part of both the DSC and HSM designs. The features described in this section assure that doses to personnel and the public are "as low as is reasonably achievable" (ALARA).

The DSC body is a rolled stainless steel plate. Details of the DSC and HSM and relevant dimensions can be found in the drawings in the proprietary supplement of Reference 2 on page 7-35. Two lead-filled shield plugs provide neutron and gamma shielding at the ends of the DSC. During handling operations, shielding in the radial direction is provided by the NUHOMS-24P transfer cask.

Two penetrations in the top shielded end plug allow water draining, vacuum drying and helium backfilling of the DSC. The penetrations are located away from fuel assemblies and contain sharp, non-coplanar bends to reduce radiation streaming. Figure 7-1 on page 7-15 shows the physical arrangements of the DSC end-shields and location of doses reported in Table 7-2 on page 7-14. These dose rates assume the water levels in the DSC cavity and DSC/Cask annulus are lowered to the levels specified in Section 1.3.1.7, "System Operation" on page 1-13.

The transfer cask provides radiological shielding during the DSC drying operation and during the transfer to the HSM. Both neutron (solid Biscor NS-3) and gamma (lead) shielding are incorporated into the cask design. The NS-3 neutron shield is 3" thick (nominal) and has a density of 1.76 gm/cc. A 10% hydrogen content loss is assumed in the shielding analysis due to anticipated degassing of the NS-3 induced by elevated temperatures. The as-built transfer cask lead gamma shield thickness is verified through radiographic examination to be 3.38" thick (nominal), but varies in thickness from approximately 3.15" to

3.5". Areas where the lead thickness falls below 3.38" are covered by an additional 1/4" thickness of stainless steel neutron shield jacket to compensate for the reduced gamma shielding effectiveness of the lead.

The HSM provides shielding in both the radial and axial directions during the storage phase. Thirty six inch thick, portland cement, concrete walls and roofs provide neutron and gamma shielding. The module's front end opening is covered by a three inch thick carbon steel door with a neutron shield.

Openings to the HSM interior are placed above the end shield region, and not directly over the active fuel region. Sharp duct bends and concrete shielding caps over the exhaust exits assure that radiation streaming is reduced to a minimum. Figure 7-1 on page 7-15 shows details of the module penetrations and locations of doses reported in Table 7-2 on page 7-14.

Portable shielding during handling operations may be applied during specific handling operations. However, Section 7.4, "Estimated On-Site Collective Dose Assessment" on page 7-17 provides an assessment of design basis on-site doses without the use of portable shielding.

7.3.2.2 Shielding Analysis

This section describes the radiation shielding analytical methods used in calculating relevant NUHOMS-24P system dose rates during the handling and storage phases. The dose rates were calculated at the locations listed in Table 7-2 on page 7-14. Figure 7-1 on page 7-15 shows these locations on the HSM, DSC and transfer cask. The three computer codes used for analysis are described below.

Computer Codes ANISN (Reference 3 on page 7-35), a one-dimensional discrete ordinates transport computer code, was used to obtain neutron and gamma dose rates at the outer HSM wall, centerline of DSC end plug, and outside the loaded transfer cask. The CASK (Reference 6 on page 7-35) cross section library, which contains 22 neutron energy groups and 18 gamma energy groups, was applied in an S_4P_3 or $S_{16}P_3$ approximation. Calculated radiation fluxes were multiplied by flux-to-dose conversion factors to obtain final dose rates. The ANISN calculations used coupled neutron and gamma libraries. Therefore, both primary and secondary gammas are calculated in each run.

- 1 QAD-CG (Reference 4 on page 7-35), a three-dimensional point-kernel code, was used for direct gamma shielding analysis of the HSM door, the DSC and transfer cask end sections, the DSC/transfer cask annulus, and the HSM air vent penetrations. Mass attenuation, and buildup were all obtained from
- 1 QAD-CG's internal library for eight energy groups. The gamma energy spectrum was determined in the
- 1 same manner as the ANISN analysis.

Shielding analysis results are summarized in Table 7-2 on page 7-14. Additional details regarding methods, models and assumptions used in ISFSI shielding analyses are provided in Section 7.3 of Reference 2 on page 7-35.

- 1 A similar version, QAD-CGGP, is used in supplementary calculations performed to determine the level of
- 1 localized gamma dose rate peaking which may occur over areas of the TC surface corresponding to IFA
- 1 end fitting and fuel pin plenum axial elevation. Gamma sources and spectra for the various IFA source
- 1 regions modeled (i.e., active fuel, upper and lower end fittings, and upper and lower fuel pin plenums) are
- 1 determined in the same manner as in ISFSI shielding calculations described in Section 7.3 of Reference 2
- 1 on page 7-35.

7.3.3 TABLES

Table 7-2. Shielding Analysis Results

Location	Neutron Dose Rate (mr/hr)		Gamma Dose Rate (mr/hr) Primary and Secondary*		Total Dose Rate (mr/hr)
	Direct	Reflected	Direct	Reflected	
<u>DSC In HSM</u>					
1. HSM Wall or Roof	0.1	**	7	**	7
2. HSM Air Outlet Shielding Cap	No	0.2	< 1	83	83
3. HSM Air Outlet (No Shielding Cap)	0.7	15	390	4200	4606
4. Center of Door	37	**	8	**	45
5. Center of Opening	430	**	330	**	760
6. Center of Air Inlets	0.1	2	< 7	86	88
7. 4.5 Ft. From HSM Door	20	**	4	**	24
<u>DSC In C/ASK</u>					
1. Centerline Top of DSC Plug (with water in annulus and with 2 inches temporary neutron shielding)	5.3	**	10	**	15
2. Top of DSC Cover Plate (with water in annulus and with 2 inches of temporary neutron shielding)					
a. Centerline	40	**	30	**	70
b. Gap (Peak)***	32	**	24	100	156
3. Transfer Cask Surface					
1 a. Radial (Centerline)	54	**	146	**	200
1 b. Radial (Peak****)	54	**	511	**	565
b. Top axial	15	**	1	**	16
c. Bottom axial	32	**	16	**	48

Notes:

* T. DSC/Cask annulus is filled with water and additional neutron shielding material is utilized as required. In addition, all but top six inches of the DSC inner cavity is assumed to be filled with water for this operation.

** The reflected dose at these locations is negligible.

*** The same gap dose rate applies for case where only top lead plug is on DSC. The dose rates reported are with water in the DSC/cask annulus (however, no water was assumed to be in the DSC).

1 **** Estimated maximum radial surface dose rate localized near IFA end fitting and fuel pin plenum axial elevations

7.3.4 FIGURES




Figure 7-1. Location of Dose Rates. Reported in Table 7-2 on page 7-14

7.4 ESTIMATED ON-SITE COLLECTIVE DOSE ASSESSMENT

7.4.1 OPERATIONAL DOSE ASSESSMENT

This section establishes the expected cumulative dose delivered to site personnel during the fuel handling and transfer activities associated with one NUHOMS-24P module. Chapter 5, "Storage System Operations" on page 5-1 describes in detail the ISFSI operational procedures, a number of which involve radiation exposure to personnel.

The storage facility is surrounded by a large open area for operational and security purposes. Access to the storage modules is restricted such that for normal operation, no access closer than 50 feet is allowed except for security purposes. Except during periods of additional module construction, there is no adjacent work area close by, so very little dose is received from fuel in storage. Access is primarily needed to load new canisters into storage modules and dose from previously stored fuel will be received during these operations. The occupational exposure received during DSC transfer operations is included in the operational dose assessment summarized in Table 7-3 on page 7-19. The occupational dose estimates provided in Table 7-3 on page 7-19 are calculated using reference fuel assembly characteristics (see Table 1-1 on page 1-7) and other site-specific parameters. Dose contributions from hidden module scatter effects and self shielding for an 88 loaded module array are included in the Table 7-3 on page 7-19 results for DSC transfer operations. The dose received for other operations performed within the HSM storage facility secured area is negligible.

The phased construction of modules up to the licensed capacity of 88 will be undertaken on an as-needed basis considering required lead time, station operation and construction schedules. Increments of additional module construction are flexible. Duke expects to construct an average of 4 to 5 additional modules per year (considering normal station discharge rates) until the ultimate licensed capacity of 88 HSMs is reached. Construction work performed subsequent to the loading of any HSM with spent fuel will result in worker exposures from direct and sky shine radiation in the vicinity of the loaded HSMs.

Duke plans to locate additional storage units beside the existing units to eventually form an effective 2 x 44 array of modules upon completion as shown in Figure 4-3 on page 4-26. In this manner, dose to construction workers will be minimized since the dose rates along the side of the HSM are much lower than those at the front of the module where there are vent openings. Construction materials will be staged away from the adjacent loaded HSMs, and very little work will be done in the higher dose rate area in front of the HSMs. Also, it is expected that new HSM construction will be commenced before all the existing HSMs are filled. Therefore, the HSMs adjacent to the new construction may be empty during some or most of the construction phase. The construction area will be surveyed prior to beginning work to ascertain actual dose rates and temporary shielding may be provided if needed to lower any unacceptable dose rates. The most significant dose rate contributors to the construction area are the inlet and exhaust vent openings. These dose rates may be reduced using temporary shielding screens around the vents near the construction area. After the concrete is placed for the additional modules, the additional shielding will further reduce dose rates.

The dose estimate for additional construction is based on labor cost estimates for a 2 x 10 module array. It is assumed that 60 percent of the labor hours are expended in the radiation area and the prefabrication work is done in low or no dose areas. Table 7-4 on page 7-22 summarizes expected construction doses by task.

The maximum dose received from the loading, construction, and maintenance of Horizontal Storage Modules is 15 Rem per year for the expected loading rates. This is approximately 1.5% of normal station dose. The total includes fuel handling and canister loading operations, additional module construction and general maintenance of the facility. The dose estimate conservatively assumes design basis source terms for all fuel, construction of additional modules at a rate of 5 modules per year and general area doses from a full 88 module array for the entire period of HSM construction. Actual doses will be far below these estimates.

7.4.2 STORAGE TERM DOSE ASSESSMENT

No firm construction schedule for module addition has been developed at this time and thus the array sizes mentioned in Section 7.4.1, "Operational Dose Assessment" on page 7-17 are representative of possible additional increments. Additional increments of HSMs will be constructed as required to balance the off-loading of Oconee's fuel from the storage pools and transshipment to the federal repository.

Figure 7-2 on page 7-24 is a graph of the dose rate (mR/hr) versus distance from the face of a 2 x 3 array of NUHOMS-24P HSMs. Figure 7-3 on page 7-25 and Figure 7-4 on page 7-26 show the dose rate versus distance from the front or side of the array for various other HSM array sizes. These curves were constructed from the shielding analysis described in the previous sections and are for the dose rate in the worst case direction from the modules (perpendicular to the doors). The bounding conditions may be obtained by simply scaling the results from these curves. Direct neutron and gamma flux, as well as the air-scattered radiation from the module surfaces are considered. The surface radiation sources used for the direct and air scattered dose calculations are shown in Figure 7-5 on page 7-27. Neutron and gamma flux spectra for the surface of the HSM are provided in Table 7-5 on page 7-28. The HSM surface spectra are obtained from normalized ANISN model flux data. The ANISN HSM model as well as the CASK cross section library are described in Section 7.3.2.2 of Reference 7.2, "Radiation Sources" on page 7-9. The CASK cross section library is made up of 40 energy groups (groups 1-22 are neutron and groups 23-40 are gamma). Air-scattered dose rates are determined with the computer code SKYSHINE-II (Reference 7.5, "Radiation Protection Program" on page 7-29); direct dose rates are calculated using the computer code MICROSHIELD (Reference 7.7, "Estimated Off-Site Collective Doses" on page 7-33). The direct flux from the "hidden" row of modules is considered completely shielded by the front row. All HSMs are assumed loaded with sufficiently cooled (≤ 0.66 Kw per assembly) spent fuel.

7.4.3 TABLES

Table 7-3 (Page 1 of 3). Summary of Estimated On-Site Doses Resulting from ISFSI Operations⁽¹⁾.
(Per DSC Transfer to HSM)

Operation	Number of Personnel	Time ⁽²⁾ (Hours)	Ave. Dist. From Cask/DSC/Cask Surface (Feet)	Dose Rate (mR/Hr)	Total Personnel Dose (P-mR)
Location: Fuel Pool					
Load Fuel into DSC	2	8	GA ⁽³⁾	2	32
Place Shielded End Plug on DSC	2	0.5	GA	2	2
Location: Cask Handling Area					
Decontaminate and Survey Surface of Cask	3	2	8 Side	35	210
Lower Water Level in DSC Cavity and DSC Transfer Cask Annulus	2	0.25	1.5 F/D Port	48	24
	2	2	GA	2	8
Tack Weld Top End Shield Plug to DSC	1	0.25	1.5 Top Edge	48	12
Set up Automatic Welder and Seal Weld Top End Shield Plug to DSC	2	1.5	1.5 Top Edge	48	144
	2	3	GA	2	12
Perform Dye Penetrant Test on Welds	1	0.5	1.5 Top Edge	48	24
Remove Remaining Water/Vacuum Dry DSC Cavity	2	0.25	1.5 F/D Port	55	27
	2	3.75	GA	2	15
Backfill DSC Cavity With Helium	2	0.5	GA	2	2
Helium Leak Test	1	0.5	1.5 Top Edge	61	31
Seal Weld Vent/Siphon Ports	2	1	1.5 F/D Port	61	122
Perform Dye Penetrant Test on Welds	1	0.25	1.5 Top Edge	61	15
Install Top Cover Plate	2	0.25	1.5 Top Edge	61	31
Weld Top Cover Plate to DSC	2	0.35	1.5 Top Edge	61	43
	2	2.65	GA	2	11

Table 7-3 (Page 2 of 3). Summary of Estimated On-Site Doses Resulting from ISFSI Operations⁽¹⁾.
(Per DSC Transfer to HSM)

Operation	Number of Personnel	Time ⁽²⁾ (Hours)	Ave. Dist. From Cask/DSC/Cask Surface (Feet)	Dose Rate (mR/Hr)	Total Personnel Dose (P-mR)
Perform Dye Penetrant Test on Weld	1	0.5	1.5 Top Edge	61	31
Remove Seal, Drain Cask/DSC Annulus and Swipe	2	0.75	1.5 Top Edge	151	227
	2	3.25	GA	2	13
Install Cask Head and Bolt Into Place	2	0.5	1.5 Top Edge	85	85
Lower Transport Cask to Skid and Trailer	2	1	4 Side	120	240
	4	2	8 Side	67	536

Location: Trailer/HSM

Attach Skid-Tiedown to Trailer	2	0.25	1.5 Side	210	105
Transport Cask to HSM	1	1	8 Side	67	67
	3	1	GA	2	6
Remove Cask Head, Bottom Cover Plate and Position Ram	2	0.5	1.5 Bot/Top	90	90
Align Cask with HSM and Install Cask Restraints	4	1.5	4 Side	120	720
Transfer DSC from Cask to HSM	4	0.5	4 Side	120	240
Install Seismic Restraint	2	0.08	1 DSC Top	760	122
Close and Tack Weld HSM Door	1	0.25	4.5 HSM	23	6
Radiation Protection Survey of HSM	1	1	3 HSM	5	5

Table 7-3 (Page 3 of 3). Summary of Estimated On-Site Doses Resulting from ISFSI Operations⁽¹⁾,
(Per DSC Transfer to HSM)

Operation	Number of Personnel	Time ⁽²⁾ (Hours)	Ave. Dist. From Cask/ DSC/Cask Surface (Feet)	Dose Rate (mR/Hr)	Total Personnel Dose (P·mR)
<u>Total for Transfer Operation (P·mrem)</u>					<u>3255</u>

Notes:

1. Monitoring operation - Personnel will be monitoring the operation so that any problems which may arise can be swiftly corrected. The personnel may leave the area if necessary and the operation could be monitored from a remote location out of the radiation field.
2. Estimated times are conservative estimates for personnel working in the radiation field around the cask or ISM.
3. GA refers to General Area and is used to indicate workers in the room or area with the DSC/Transfer Cask to maintain visual control over operations in areas where the dose contribution from ISFSI operations is very low.

Table 7-4. Dose Estimate for Construction of Additional Horizontal Storage Modules Based on Labor Estimates for 2 X 10 Array

Task	Number Workers	Hours in Radiation Area	Average Dose Rate (mRem/hr.)	Maximum Indiv. dose (P-mRem)	Total Task Dose (P-mRem)
Survey	4	50	2	25	100
Excavation	4	192	2	96	383
Concrete Basemat	8	192	2	48	383
Forming Scaffolding Rebar	8	8496	2	2124	16992
Crane Operation	1	96	2	192	192
Steel Installation	8	1920	1	240	1920
Welding	1	30	1	30	30
Surveyors (steel)	4	167	1	42	167
Crane Operation (steel)	1	75	1	75	75
Paint	8	96	1	12	96
Clean up	2	42	1	21	42
TOTALS		11354			20379


Estimated dose/module constructed = 1.02 Person Rem

Estimated maximum individual dose/module = 106 Person mRem

Table 7.4 Neutron and Gamma Energy Spectra

	Cask Library Group No.	Normalized Flux
	1	0.000005
	2	0.000030
	3	0.000138
	4	0.000982
	5	0.002867
	6	0.002456
	7	0.002970
	8	0.007440
	9	0.006820
	10	0.011135
	11	0.017633
	12	0.018344
	13	0.026756
	14	0.042225
	15	0.019154
	16	0.024170
	17	0.020290
	18	0.014654
	19	0.019803
	20	0.017683
	21	0.018689
	22	0.726046
* sum of Neutrons = 1.0		
	23	0.000018
	24	0.000145
	25	0.000248
	26	0.000283
	27	0.000383
	28	0.000275
	29	0.001008
	30	0.009272
	31	0.007947
	32	0.057772
	33	0.051577
	34	0.074007
	35	0.123743
	36	0.093142
	37	0.137524
	38	0.316630
	39	0.125240
	40	0.006775
** Sum of Gammas = 1.0		

7.4.4 FIGURES



LEGEND

- SKYSHINE
- - - CR
- JAL

Figure 7-2.
Dose Rate Versus Distance From Surface of HSM!




Figure 7-3.
Dose From Filled HSM Array

DOSE FROM HSM ARRAY






Figure 7-4.
Dose From Filled HSM Array



NRM ROOF PLAN



NRM FRONT PLAN

<u>LOCATION</u>	<u>AREA</u> (ft ²)	<u>NEUTRON</u> <u>DOSE RATE</u> (mrem / hr)	<u>GAMMA</u> <u>DOSE RATE</u> (mrem / hr)	<u>TOTAL</u> <u>DOSE RATE</u> (mrem / hr)
<u>ROOF</u>				
1"	168.87	0.1	6.5	6.6
2"	33.33	0.2	50	50.2
AREA WEIGHTED AVG		0.1	14	14.1
<u>AVG</u>				
<u>FRONT</u>				
3"	118	0.1	6.5	6.6
4	28	37	7.8	47.8
5"	6.0	2.1	94	96.1
AREA WEIGHTED AVG		6.6	10	16.6

- * DIRECT AND REFLECTED DOSES
- ** DOSE RATES FOR ALL OF AREA 1 ON BOTH THE ROOF AND FRONT WALL ARE ESTIMATED TO BE THE SAME AS THE DOSE RATE CALCULATED AT THE CENTER OF THE ROOF.

Figure 7-5.
Radiation Zone Map of Module Surface Dose Rates

7.5 RADIATION PROTECTION PROGRAM

The ISFSI is to be located adjacent to the Oconee Nuclear Station within the Owner Controlled Area. The Oconee Nuclear Station Radiation Protection Manager will have responsibility for Radiation Protection activities at the ISFSI.

The Radiation Protection and ALARA programs are discussed briefly in Section 7.1.1, "Policy & Organizational Considerations" on page 7-3 and will be as discussed in the Oconee Nuclear Station FSAR, Chapter 12. Detailed discussions of Radiation Protection and ALARA are contained in Duke Power Company's Health Physics and ALARA program manuals.

Radiation protection requirements for all radiological work at the Oconee Nuclear Station is governed by existing station directives, the Oconee Radiation Protection Manual, and station radiation protection (R.P.) procedures. R.P. practices for DSC loading, transfer, storage, monitoring, and retrieval will also be based on existing procedures, as well as on current and anticipated conditions when the task is to be performed. These procedures include, but are not limited to, the following:

1. Procedure for personnel dosimetry issue.
2. Issuance, revision, and termination of radiation work permits and obtaining radiation work permits.
3. Procedure for roping off, barricading, and posting of radiation control zones.
4. Decontamination procedure for equipment and areas.
5. Smear swab sampling, counting, and calculation.
6. Procedure for quantifying airborne radioactivity.
7. Radiation Protection ALARA preplanning work.

In addition, the Radiation Work Permits for the maintenance and fuel handling tasks associated with DSC operations will incorporate radiological hold points and precautions, where necessary, to ensure these activities are performed in a radiological safe manner and are ALARA.

Procedures and equipment for personnel in decontamination operations are in place at Oconee and will be utilized as needed for ISFSI operations.

7.6 ENVIRONMENTAL MONITORING PROGRAM

The current radiological environmental monitoring program for Oconee Nuclear Station will also serve as the operational program for the ISFSI.

No liquid or airborne effluents are anticipated from the HSM. Therefore, the dose to any offsite point will only be from direct and scattered gamma radiation. Several environmental sampling locations for direct radiation are presently located at the Oconee site boundary surrounding the ISFSI. The closest of these is less than 0.3 miles from the ISFSI, well within the 1-mile exclusion area boundary. In addition, the dose rates at the ISFSI will be monitored periodically with fence-mounted dosimetry as part of the Oconee routine radiological monitoring program. This will be used in part to control occupational exposures and will also augment the environmental program.

As a result, no changes to the environmental program are anticipated.

7.7 ESTIMATED OFF-SITE COLLECTIVE DOSES

Doses to any offsite point are only from direct and scatter gamma radiation from the storage module. The estimated dose from the modules to any dose point beyond the site boundary is well below regulatory limits even when combined with station doses for both airborne and direct gamma dose.

The ISFSI is situated approximately 1 mile from the exclusion area boundary. The estimated maximum dose rate in any direction at 5000 feet for up to an 88 module array of HSMs as provided by Figure 7-2 on page 7-24 through Figure 7-4 on page 7-26 is less than 1.0×10^{-6} mR/hr. The estimated annual dose to the public is conservatively calculated as 7 person-millirem per year. The maximum dose to the nearest potential future resident from the ISFSI is $7.5E-2$ millirem per year.

7.8 REFERENCES

1. Oconee Nuclear Station Final Safety Analysis Report
2. Topical Report for the Nutech Horizontal Modular Storage (NUHOMS-24P) System for Irradiated Nuclear Fuel, NUH-002, Revision 1A, July 1980
3. Oak Ridge National Laboratory, "ANISN - Multigroup One-Dimensional Discrete Ordinates Transport Code with Anisotropic Scattering" CCC-254, Oak Ridge National Laboratory (1977)
4. Oak Ridge National Laboratory, "QAD-CGGP, Point-Kernal Gamma Ray Shielding Code," CCC-396, Oak Ridge National Laboratory (1979)
5. C. M. Lampley, "The SKYSHINE-II Procedure: Calculation of the Effects of Structure Design on Neutron, Primary Gamma-Ray and Secondary Gamma-Ray Dose Rates in Air" NUREG/CR-0781, RRA-T7901, USNRC (1979)
6. Radiation Shielding Information Center, "CASK: 40 Group Neutron and Gamma Ray Cross Section Data," DLC-23, September 1978
7. Grove Engineering, Inc., "Microshield User's Manual. A Program for Analyzing Gamma Radiation Shielding," Version 2.0, 1985

CHAPTER 8. ACCIDENT ANALYSES

In previous chapters, features important to safety have been identified and discussed. The purpose of this chapter is to identify and analyze a range of credible accident occurrences (from minor accidents to the design basis accidents) and their causes and consequences. For each situation, reference is made to the appropriate chapter and section describing the considerations to prevent or mitigate the accident.

ANSI/ANS-57.9-1984, "Design Criteria for an Independent Spent Fuel Storage Installation (Dry Storage Type)," defines four categories or design events that provide a means of establishing design requirements to satisfy operational and safety criteria. The first design event is associated with normal operation. The second and third design events apply to events that are expected to occur during the life of the installation. The fourth design event is concerned with severe natural phenomena or low probability events. The second design event is addressed in Section 8.1, "Off-Normal Operations" on page 8-3 and the third and fourth design events are discussed in Section 8.2, "Accidents" on page 8-5. (The first design event is addressed in Chapter 4, "Storage System" on page 4-1 and need not be addressed here.)

8.1 OFF-NORMAL OPERATIONS

In this section, design events of the second type as defined by ANSI/ANS-57.9-1984 are addressed. Design events of the second type consist of events that might occur with moderate frequency on the order of once during any calendar year of operation.

The limiting off-normal event is defined as jammed DSC during loading or unloading at the ambient temperature extremes of -40°F and $+125^{\circ}\text{F}$ as described in Reference 1 on page 8-17 (Section 8.1, "Off-Normal Operations"). This postulated event results in the limiting structural loads on the DSC and thermal loads on the DSC and HSM for all identified off-normal events. The ambient extremes for the Oconee site are bounded by the assumed values.

8.1.1 JAMMED DSC DURING LOADING OR UNLOADING

8.1.1.1 Postulated Cause of Jammed DSC

If the transfer cask is not accurately aligned with the HSM, the DSC might become bound or jammed during the transfer operation. The maximum tolerable misalignment for the Oconee ISFSI transfer operation is discussed in Section 5.1 of Reference 1 on page 8-17.

8.1.1.2 Detection of Jammed DSC

When DSC jamming occurs, the hydraulic pressure in the ram will increase above normal insertion pressures. When this occurs, the DSC will be presumed to be jammed. The pushing and pulling forces are limited to 20,000 lbs., with override control available to the operator.

8.1.1.3 Analysis of Effects and Consequences

The analysis of the DSC under assumed jamming and binding conditions is covered in Section 8.1.2.1 of Reference 1 on page 8-17. In both jammed DSC scenarios considered, the stress on the DSC body is shown to be much less than the ASME code allowable stress. Therefore, plastic deformation of the DSC body will not occur and there is no potential for rupture. The analysis presented in Reference 1 on page 8-17 is applicable to Oconee ISFSI operation.

The ram force is limited to 80,000 pounds by a factory set and sealed crossport relief valve. This relief valve is installed in the hydraulic control system and is factory set to relieve at pressures which limit both the extension and retraction forces of the hydraulic cylinder to 80,000 pounds force.

8.1.1.4 Corrective Actions

In cases of DSC jamming or binding, the required corrective action is to reverse the direction of applied force on the DSC, and return the DSC to its previous position. Since no plastic deformation has occurred, the return of the DSC to its previous position will be unimpeded. The transfer cask alignment is then rechecked and the transfer cask repositioned as necessary before reinsertion is renewed.

8.1.2 RADIOLOGICAL IMPACT OF OFF-NORMAL OPERATIONS

Based on the off-normal operation analysis results presented, there is no additional radiological impact due to off-normal operations beyond what is presented in Chapter 7, "Radiation Protection" on page 7-1 of this SAR.

8.2 ACCIDENTS

This section addresses design events of the third and fourth types as defined by ANSI/ANS-57.9-1984, and other credible accidents which could impact the safe operation of the Oconee ISFSI. The postulated events addressed are:

- Loss of Air Outlet Shielding
- Tornado/Tornado Missile
- Earthquake
- Transfer Cask Drop
- Transfer Cask Loss of Neutron Shield
- Lightning
- Blockage of Air Inlets and Outlets
- DSC Leakage
- Accidental Pressurization of DSC
- Load Combinations
- Floods
- Explosions

The postulated accidents listed above include all events identified as potentially resulting in offsite doses in excess of 25 mrem.

8.2.1 LOSS OF AIR OUTLET SHIELDING

This postulated accident involves the loss of both air outlet shielding blocks from the top of the HSM. All other components of the Oconee ISFSI are assumed to be in their normal conditions.

8.2.1.1 Cause of Accident

The air outlet shielding blocks are designed to remain in place and completely functional for all events except tornado missiles. To demonstrate the safety of the ISFSI design, this accident assumes that both shielding blocks are completely lost.

The air outlet shield blocks are attached to the HSM by welding to an embedded plate in the HSM roof. In the highly unlikely event of a recovery situation, the damaged shield block would be removed from the HSM and temporary shielding would be placed around the outlet opening in such a way that a worker could perform the necessary recovery techniques with a minimal radiation exposure. All Duke ALARA procedures, such as pre-staging construction activities in a no-dose area, would be followed throughout the entire recovery process.

8.2.1.2 Accident Analysis

There are no structural or thermal consequences to the ISFSI facility resulting from the loss of the air outlet shielding blocks. The air flow resistance is less without the shield blocks and, hence, the air flow

will increase (slightly) and provide more cooling of the DSC. Radiological consequences of this accident are described in the next section.

8.2.1.3 Accident Dose Consequences

Offsite radiological consequences result from an increase in air scattered (skyshine) dose due to the loss of the shield blocks. Onsite radiological consequences result from an increase in direct (during recovery operations on the HSM roof) and skyshine radiation. The calculation of these doses during normal conditions is described in Section 7.4, "Estimated On-Site Collective Dose Assessment" on page 7-17. Removal of the shield blocks results in local surface dose increase of 3600 mr/hr at the vent opening. This increased surface dose was used in the models described in Section 7.4, "Estimated On-Site Collective Dose Assessment" on page 7-17 to calculate the direct and scattered doses as a function of distance from the HSM. Table 8-1 on page 8-13 shows comparisons of the increased dose rate as a function of distance due to loss of the shielding blocks. The dose increase to a person located 100 feet away from the ISFSI installation for eight hours a day for seven days (recovery time) would be 30 mr. The increased dose to an offsite person for 24 hours a day for seven days located 5000 feet away would be minimal.

To recover from the loss of shielding blocks, a new block is transferred to the HSM. After the shield block is transferred to the HSM, a yard crane is used to lift the block into position. The block is then bolted in place. The entire remounting operation should take less than 30 minutes, of which a mechanic will be on the HSM roof for approximately 15 minutes. During this time he will receive less than 50 mr. An additional dose to the mechanic and to the crane operator on the ground while putting the shield block in place will be 10 mr each (assuming an average distance of 10 ft. from the center of the HSM front wall).

8.2.2 TORNADO/TORNADO MISSILE

8.2.1 Cause of Accident

The most severe tornado wind loadings specified by NUREG-0800, NRC Regulatory Guide 1.76 and the Oconee FSAR are used as the design basis for this accident condition.

8.2.2.2 Accident Analysis

The applicable design parameters of the design basis tornado (DBT) are specified in Section 3.2.1, "Tornado and Wind Loadings" on page 3-7 of this SAR. The DBT design parameters specified in Section 3.2.1, "Tornado and Wind Loadings" on page 3-7 are identical to those used in the reference Topical Report in the determination of forces on structures for this accident. The analysis of the HSM and Transfer Cask response to DBT loadings is covered by the analysis presented in Section 8.2.2 of Reference 1 on page 8-17.

8.2.2.3 Accident Dose Consequences

The only component of the ISFSI facility which is not capable of withstanding tornado generated missiles are the precast air outlet shielding blocks. The consequences of losing the shielding blocks during this accident is presented in Section 8.2.1.3, "Accident Dose Consequences" of this SAR.

8.2.3 EARTHQUAKE

8.2.3.1 Cause of Accident

As specified in Section 3.2.3, "Seismic Design" on page 3-10, the ISFSI MHE acceleration value is 0.15g for both vertical and horizontal ground acceleration.

8.2.3.2 Accident Analysis

The reference Topical Report analysis of earthquake loads assumes a value of 0.25g and 0.17g for maximum horizontal and vertical acceleration, respectively. Reference 1 on page 8-17 seismic stress analysis also used a multiplier of 1.5.

Since the value of the seismic accelerations for the Oconee ISFSI site are lower than that assumed in Reference 1 on page 8-17, the stress analysis envelopes the site specific criteria.

In summary, the Oconee ISFSI seismic analysis using site specific criteria is enveloped by the analysis in Reference 1 on page 8-17.

8.2.3.3 Accident Dose Consequences

Major components of the Oconee ISFSI are designed and evaluated to withstand the forces generated by the MHE. Hence, there are no dose consequences.

8.2.4 CASK DROP

8.2.4.1 Cause of Accident

This section addresses the structural integrity of the DSC and its internals under a postulated transport cask accident condition. It is postulated that the transfer cask described in Section 4.3, "Transfer System" on page 4-11 with the DSC inside is dropped 80 inches onto a thick concrete slab. Due to the use of transfer cask trailer tie-downs, an actual drop event is not considered credible. Cask drop target parameters are given in Table 8-2 on page 8-13.

8.2.4.2 Accident Analysis

The Oconee ISFSI transfer cask is analyzed for an 80 inch drop accident using the method of analysis presented in Section 8.2.5. of Reference 1 on page 8-17.

The analysis presented in Reference 1 on page 8-17 assumes an 80 inch cask drop using Oconee ISFSI transfer cask parameters. Hence, the Reference 1 on page 8-17 analysis covers the Oconee accident analysis. Therefore, the stress on the various structural components of the DSC and its internals are the same as those reported in Table 8.2-7 of Reference 1 on page 8-17.

8.2.4.3 Accident Dose Consequences

Since the stress analysis has shown that all components important to safety of the DSC and its internal basket will perform their intended function under this accident condition, there are no dose consequences.

8.2.5 TRANSFER CASK LOSS OF NEUTRON SHIELD

8.2.5.1 Postulated Cause of Solid Shield Loss

The neutron shield jacket is designed, fabricated, tested, and inspected as ASME Section III, Division 1 Class 2 vessels. The associated ASME quality assurance program will assure that there are no poor joints, or other substandard components in the transfer cask. The Bisco NS-3 neutron shield material is a rigid solid when cured and will not flow freely through openings in the jacket. Therefore, a loss of shield material will only occur in cases of external damage to the shield jacket and concurrent displacement of NS-3 material.

8.2.5.2 Detection of Shield Material Loss

Damage to the neutron shield jacket and material would be visually obvious. Anticipated loss of hydrogen from the NS-3 material resulting from degassing at evaluated temperatures is accounted for in the shielding analysis (see Section 7.3.2, "Shielding" on page 7-11).

8.2.5.3 Analysis of Effects and Consequences

For the purpose of this analysis, it is assumed that the transfer cask neutron shield will be breached as a result of postulated drop accident, and the shielding effect of the NS-3 will be lost. The effect of this will increase the cask surface contact dose from 180 mrem/hour to 837 mrem/hour. The only potential off-site dose consequences would be additional direct and air scattered radiation if the accident were to occur sufficiently close to the site boundary. It is assumed that eight hours would be required to either recover the neutron shield or to add temporary shielding while arranging recovery operations. As result, it is estimated that on-site workers at an average distance of fifteen feet would receive an additional dose rate of 80 mrem/hr.

Off-site individuals at a distance of 2000 feet would receive an additional dose of $5.7E-4$ mrem for the assumed eight hour exposure. This increase is well within the limits of 10CFR 72 for an accident condition. Also, this does not preclude handling operations for recovery of the cask and its contents. Water bags or other neutron absorbing material could be wrapped around the cask to reduce the surface dose to an acceptable limit for recovery operations thus minimizing exposure of personnel in the vicinity. The actual local and off-site dose rates, recovery time and operations needed to retrieve the cask, and the required actions to be performed following the event will depend upon the severity of the event and the resultant cask and trailer/skid damage.

8.2.6 LIGHTNING

8.2.6.1 Cause of Accident

The likelihood of lightning striking the ISFSI and causing an off-normal operating condition is not considered a credible accident given the ISFSI lightning protection provided. The lightning protection system for the ISFSI is designed in accordance with NFPA NO. 78-1979 Lightning Protection Code. This system precludes any damage to the HSM or its internal due to lightning.

8.2.6.2 Accident Analysis

8.2.6.2.1 HSM

Should lightning strike the ISFSI, the normal operation of the HSM will not be affected. The current discharged by the lightning will follow the low impedance path offered by the lightning protection system. Therefore, the HSM is not damaged by the heat or mechanical forces generated by current passing

through the higher impedance concrete. Since the HSM requires no equipment for its continued operation, the resulting current surge from the lightning will not affect the normal operation of the HSM.

8.2.6.2.2 Power Supplies

The hydraulic power supplies for the transfer trailer hydraulic positioners and the hydraulic ram are independent systems. Each of these systems have manually operated pumps which could be used in case of a power failure. Electrical power supplies to the ISFSI site serve no safety related functions, since their loss would not adversely affect the NUHOMS-24P safety related components or the health and safety of plant personnel or the public.

The electrical power distribution system and associated equipment are electrically bonded to the lightning protection and grounding system for the ISFSI. The retail power transformer is installed with lightning protection features in accordance with National Electric Safety code requirements.

The lightning protection design meets the requirements of NEPA-78, Lightning Protection Code: 1986 Edition and IEEE Standard 665.

8.2.6.2.3 Welding of DSC to Support Structure

Movement of the DSC from the transfer cask to the fully inserted position in the HSM takes less than 10 minutes. Transfer operations will not be attempted during a major thunderstorm when there is potential danger to plant personnel or costly damage to equipment. Therefore, the possibility of the DSC becoming welded to the support structure by a lightning strike is extremely unlikely. In addition, there is contact between the transfer cask and HSM mating collar, such that the anchorage of the transfer cask to the HSM shown in Topical Report Figure 4.2-6 provides a grounding path to the HSM. To complete this path, the attachment plates are grounded to the HSM reinforcing which will provide additional assurance that this event will not occur. Lightning would likely strike the highest nearby structure, which is a light pole.

The HSM rails are bonded to the HSM grounding system by means of exothermically welding a bare copper conductor to the embedded steel support plates and the HSM grounding system. Additionally, the trailer mounted ram assembly tripod is bonded to the HSM grounding system during cask positioning operations.

8.2.6.3 Accident Dose Consequences

Since no off-normal operating condition will develop as a result of lightning striking the ISFSI, there are no radiological consequences.

8.2.7 BLOCKAGE OF AIR INLETS AND OUTLETS

This accident involves the complete and total blockage of all HSM air inlets and outlets.

8.2.7.1 Cause of Accident

Since the HSMs are located outdoors, the air inlets and outlets could potentially be blocked by debris from such unlikely events as tornados. ISFSI design features such as a perimeter fence and separation of air inlets and outlets reduce the potential for this accident.

8.2.7.2 Accident Analysis

The structural consequences due to the weight of debris blocking the air openings are bounded by the structural consequences of other accidents described in this section (i.e., tornado and earthquake analyses). The thermal consequences of this accident result from heating of the DSC and HSM due to the loss of natural convection cooling. An analysis of this condition is provided by Section 8.2.7 of Reference 1 on page 8-17.

8.2.7.3 Accident Dose Consequences

There are no offsite dose consequences as a result of this accident. The only dose increase is related to the recovery operation where the onsite worker will receive an additional 700 mr during an estimated 8 hour debris removal period.

8.2.8 DRY STORAGE CANISTER LEAKAGE

The DSC is designed for no leakage and analysis of normal and accident conditions have shown that no credible conditions could breach the canister body or fail the double seal welds at each end of the DSC. However, to show the ultimate safety of the ISFSI system, a total and complete instantaneous leak is postulated.

This postulated accident is the instantaneous release directly to the environment of 30% of all fission gasses mainly Kr_{85} and I_{129} contained in all the fuel rods in all 24 PWR fuel assemblies. This accident assumes that all fuel rods are ruptured and that concurrent DSC leakage occurs. All other components of the ISFSI system remain intact.

8.2.8.1 Cause of Accident

Due to the passive nature of the Oconee ISFSI system and the various design features, there is no credible event that could result in the rupture of all fuel rods concurrent with DSC leakage. However, to demonstrate the safety of the ISFSI design, this accident assumes that the fuel rods and the canister are ruptured due to an event of unspecified origin.

8.2.8.2 Accident Analysis

In the postulated Dry Storage Canister Leakage Accident, it is assumed that one DSC is breached and fuel fails simultaneously releasing 30% of all fission gasses contained in 24 fuel assemblies. Following long-term wet storage (> 7.5 years) the gaseous fission products which can be released are Kr_{85} and I_{129} . The total DSC inventories assumed for Kr_{85} and I_{129} are $2.75E+03$ and $1.87E-02$ Curies, respectively; these inventories are based on ORIGEN-S computer code (Reference 2 on page 8-17) analysis for 24 B&W 15x15 fuel assemblies irradiated for 40,000 MWD/MTU and decayed for 7.5 years.

Whole body and maximum organ doses are calculated for a hypothetical maximum individual assumed to be present at the nearest site boundary location (a distance of approximately 1 mile) for the duration of the event. A meteorological dispersion parameter (X/Q) of $4.5E-04$ sec/m³ is used in calculating the maximum potential offsite doses; this X/Q value is consistent with the value referenced in the Oconee SER, Section 3.2.4, Units 2 and 3. Dose conversion factors used are obtained from NRC Regulatory Guide 1.109 and a breathing rate of $3.47E-04$ m³/sec is used in calculating inhalation dose.

There are no structural or thermal consequences resulting from the DSC leakage accident described above. The radiological consequences of this accident are presented in Section 8.2.7.3, "Accident Dose Consequences."

8.2.8.3 Accident Dose Consequences

This postulated accident involves the rupture of one DSC. All fuel rods contained in the ruptured DSC are assumed to fail simultaneously such that 30% of all the fission gasses in the irradiated fuel assemblies are instantaneously released to the atmosphere. Whole body and maximum organ doses are calculated for a hypothetical individual assumed to be present at the Oconee Nuclear Station exclusion zone for the duration of the event. A meteorological dispersion parameter of $4.5E-4s/m^3$ is used in calculating the maximum potential offsite doses. The resulting calculated doses are 7 and 200 mr for the maximum offsite whole body and thyroid doses, respectively. These accident doses are well within the 10CFR 72 limit of 5000 mr whole body dose equivalent.

8.2.9 ACCIDENTAL PRESSURIZATION OF DSC

This accident addresses the consequences of accidental pressurization of the DSC.

8.2.9.1 Cause of Accident

Internal pressurization of the DSC could result from fuel cladding failure which would release fuel rod fill gas and free fission gas.

8.2.9.2 Accident Analysis

The maximum DSC accident pressurization is calculated assuming that the fuel rod fission gas release fraction is 30%, and that the original fuel rod fill pressure is 480 psig (Oconee fuel actually has a maximum initial fill pressure of 465 psig). The resulting internal DSC pressures at Oconee's maximum ambient temperature of 116°F and at the minimum ambient temperature of -30°F are below the accident pressures reported in Section 8.2.9 of Reference 1 on page 8-17 (for temperature extremes of 125°F and -40°F). The limiting accident for DSC pressurization is the loss of transfer cask neutron shield. Under these conditions, the gas temperatures in the DSC will rise to 600°F producing a DSC internal pressure of 49.1 psig. The DSC shell stresses due to accident pressurization are enveloped by those reported in Reference 1 on page 8-17.

During DSC opening, appropriate health physics techniques will be employed for respiratory protection of the workers and for preventing any uncontrolled releases to the environment. During cutting operations these techniques may include installation of exhaust hoods which discharge to the fuel building ventilation system upstream of the HEPA and carbon filter units and supplied air to the workers. During filling and venting, the vented gases will, also, be routed to the fuel building ventilation system. This is a routine precaution taken for opening of spent fuel shipping casks, and it would provide protection from respirable radioactive particles and, also, from the unlikely presence of a significant amount of escaped fission gases.

8.2.9.3 Accident Dose Calculations

Since the accidental pressurization is within the design basis limits of the DSC, there are no dose consequences.

8.2.10 LOAD COMBINATIONS

The load categories associated with normal operating conditions and accident conditions have been described and analyzed in previous chapters of this report. The load combination evaluation of various ISFSI safety related components is addressed in this section.

8.2.10.1 Cause of Accident

The simultaneous loading of major ISFSI components by combined accident and normal loads would result in the load combinations analyzed.

8.2.10.2 Accident Analysis

The methodology used in combining normal operating and accident loads and their associated overload factors for various ISFSI components is presented in Section 8.2.10 of Reference 1 on page 8-17. The Reference 1 on page 8-17 analysis envelopes the Oconee ISFSI. The load combination and fatigue analysis in Reference 1 on page 8-17 indicates major ISFSI components can withstand severe load combination and thermal cycling without failure.

8.2.10.3 Accident Dose Consequences

There are no dose consequences for postulated load combination events.

8.2.11 FLOODING

The elevation of the ISFSI yard at Elevation: 825.0 is more than eleven feet higher than the maximum flood level postulated for Lake Keowee, and therefore, flooding of the ISFSI site will not occur.

8.2.12 EXPLOSIONS

8.2.12.1 Cause of Accident

The explosion on S.C. Highways 130 or 183 of a tanker containing 8500 gallons of gasoline would subject the ISFSI to a surface overpressure.

8.2.12.2 Accident Analysis

According to the NRC Regulatory Guide 1.91 "Evaluations of Explosives Postulated on Transportation Routes Near Nuclear Power Plants," the explosion of 8,500 gallons of gasoline 1,100 feet from the ISFSI on S. C. Highway 130 or 183, would result in a peak overpressure of 1 psi about 1,900 feet from the point of explosion and therefore an overpressure of 2.3 psi at the ISFSI. The HSM has been designed to withstand a maximum tornado wind pressure of 3.0 psi. Therefore, the HSM overpressure from the explosion of a gasoline tanker on either S. C. Highway 130 or 183 is enveloped by the wind pressure analysis and design for a "DBT".

8.2.12.3 Accident Dose Consequences

There are no dose consequences for postulated explosions.

8.2.13 TABLES

Table 8-1. Comparison of Total Dose Rates for HSM With and Without Air Outlet Shielding Blocks

Distance (meters) from Nearest HSM Wall, 2x10 Array	Normal Case Dose Rate* (mrem/hr.) (with Shield Blocks)	Accident Case Dose Rate* (mrem/hr.) (Without Shield Blocks)
10	2.85	21.9
100	0.1587	0.533
500	8.97E-4	2.14E-3
2000	3.77E-8	9.62E-7

* Air scattered plus direct radiation.

Table 8-2. Cask Drop Target Parameters

1. Slab reinforcement:
 - Bottom mat - #5's @ 6" c-c each way
 - Top mat - #4's @ 6" c-c each way
 - Yield strength = 60 ksi per ASTM 615
2. Slab thickness = 1'-6" of concrete
3. Concrete strength (28 days) = 4000 psi (minimum)
4. Soil ultimate strength = 12.0 ksf (Based on laboratory testing)
5. Soil elastic modulus = 174 ksf (Based on laboratory testing)
6. Poisson's ratio of soil = 0.3 (Based on soil test data and "Foundation Analysis and Design" 3rd Ed., Joseph E. Bowles.)

8.3 SITE CHARACTERISTICS AFFECTING SAFETY ANALYSIS

All site characteristics affecting safety analyses presented in this SAR are noted where they apply.

8.4 REFERENCES

1. Topical Report for the Nutech Horizontal Modular Storage (NUHOMS-24P) System for Irradiated Nuclear Fuel, NUH-002, Revision 1A, dated July 1989
2. "SCALE-3: A Modular Code System for Performing Standardized Computer Analysis for Licensing Evaluation," NUREG/CR-0200, ORNL, Revision 3, December 1984

CHAPTER 9. CONDUCT OF OPERATIONS

9.1 ORGANIZATIONAL STRUCTURE

9.1.1 CORPORATE ORGANIZATION

Duke Power Company is responsible for development of the ISFSI including design, construction, quality assurance, testing and operation of the facility. The corporate organization of Duke Power Company is fully described in Chapter 13, "Conduct of Operations" on page 13-1 of Reference 1 on page 9-17.

9.1.1.1 Corporate Functions, Responsibilities and Authorities

- 1 The corporate organization provides line responsibility for operation of the Company. Various departments within the Company have responsibility for design, construction, quality assurance, testing and operation of the Oconee Nuclear Station as well as the ISFSI. Duke's corporate functions, responsibilities and authorities for quality assurance addressed in Topical Report DUKE-1-A, as described in Chapter 11 "Quality Assurance" on page 11-1 of this report, are applicable for appropriate portions of the ISFSI.

9.1.1.2 Applicant's In-House Organization

- 1 Duke's Nuclear Generation Department, headed by the Senior Vice President, Nuclear Generation, has corporate responsibility for overall nuclear safety, as established by Technical Specifications. Reporting to the Senior Vice President is a Vice President for each nuclear site, and the General Manager, Nuclear Services.
- 1 The Nuclear Generation Department Organization is described in Section 13.1.2, "Operating Organization" on page 13-4 of Reference 1 on page 9-17.

9.1.1.3 Interrelationship with Contractors and Suppliers

- The development of the ISFSI including design, construction, testing and operation are managed and conducted by Duke Power Company. Technical support and other services for the program relating to the
- 1 Nutech Engineers, Inc. supplied NUHOMS-24P are provided by Nutech Engineers, Inc. (now Pacific Nuclear Fuel Systems, Inc.).

9.1.1.4 Applicant's Technical Staff

The Corporate technical staff supporting the ISFSI is described in Section 13.1.1, "Corporate Organization" on page 13-3 of Reference 1 on page 9-17.

9.1.2 OPERATING ORGANIZATION, MANAGEMENT, AND ADMINISTRATIVE CONTROL SYSTEM

9.1.2.1 Onsite Organization

The onsite organization of the Oconee Nuclear Station is responsible for operation of the ISFSI facility. The organization for Oconee Nuclear Station is fully described in Section 13.1.2, "Operating Organization" on page 13-4 of Reference 1 on page 9-17.

9.1.2.2 Personnel Functions, Responsibilities and Authorities

The functions, responsibilities and authorities of major personnel positions, including discussions of specific succession of responsibility for overall operation of the Oconee Nuclear Station including the ISFSI facility are described in Section 13.1.2.2, "Personnel Functions, Responsibilities and Authorities" on page 13-5 of Reference 1 on page 9-17.

9.1.3 PERSONNEL QUALIFICATION REQUIREMENTS

The qualifications of personnel in the operating staff are in accordance with Section 4 of ANSI 3.1-1978, "Selection and Training of Nuclear Power Plant Personnel," and are in accordance with Regulatory Guide 1.8 (Rev. 1). Section 13.1.3, "Qualifications of Station Personnel" on page 13-7 of Reference 1 on page 9-17 provides more details on personnel qualification requirements.

9.1.3.1 Minimum Qualification Requirements

The minimum qualification requirements for major operating, technical, and maintenance supervisory personnel are described in Section 13.1.3.1, "Minimum Qualification Requirements" on page 13-8 of Reference 1 on page 9-17.

9.1.3.2 Qualifications of Personnel

The qualification of personnel assigned to the managerial and technical positions are provided in Table 13-2 on page 13-9 of Reference 1 on page 9-17.

9.1.4 LIAISON WITH OTHER ORGANIZATIONS

All aspects of the ISFSI development including design, procurement, construction, and operation are managed and conducted by Duke Power Company. Nutech Engineers, Inc. (now Pacific Nuclear Fuel Systems, Inc.), Duke Power Company's subcontractor, provides certain engineering, technical support, and other services for the ISFSI project relating primarily to the NUHOMS-24P dry storage cask system design.

9.1.5 FIGURES

1
1

Figure 9-1.
Deleted

9.2 PREOPERATIONAL TESTING AND OPERATION

Prior to operation of the ISFSI, complete functional tests of the in-plant operations, transfer operations, and HSM loading and retrieval were performed. These tests verified that the storage system components (e.g. DSC, transfer cask, transfer trailer, etc.) could be operated safely and effectively.

9.2.1 ADMINISTRATIVE PROCEDURES FOR CONDUCTING TEST PROGRAM

Pre-operational testing procedures were written in accordance with existing Oconee procedure controls as governed by Duke Power Company's QA Program.

9.2.2 TEST PROGRAM DESCRIPTION

The testing program required the use of a DSC mock-up, transfer cask and associated handling equipment, transfer trailer, hydraulic ram and an HSM. The tests simulated, as nearly as possible, the actual operations involved in preparing a DSC for storage and ensured that they could be performed safely during actual emplacement of IFAs in the ISFSI. Shielding verification - which was not completely achievable during dry runs took place during the initial IFA loadings.

9.2.2.1 Operations

9.2.2.1.1 DSC and Associated Equipment

An actual DSC and a part-length mock-up of a DSC were obtained for pre-operational testing. The DSC was loaded into the transfer cask to verify fit and suitability of the DSC lift rig. Additionally, the DSC was used in operational testing of the transfer equipment and HSM.

The part-length mock-up was similar to the top end of the DSC with lead shield plug facsimile. The mock-up was welded by the automated welding equipment. Emphasis was placed on acceptability of the weld, as well as compliance with approved ALARA practices. The mockup was also used for verification of vacuum drying, helium backfilling, and cutting open operations.

9.2.2.1.2 Transfer Cask and Handling Equipment

Functional testing was performed with the transfer cask, lift beam, crane hook lift adaptor, and remote actuation equipment associated with the lift beam. These tests ensured that the transfer cask could be safely transported from the ONS truck bay to the decontamination pit. From there, the DSC/transfer cask was placed into the spent fuel pool cask pit to verify clearances and travel path and proper operation of the annular seal.

9.2.2.1.3 Off-Normal Testing of the DSC and Transfer Cask

In the unlikely event that a problem arises during loading of IFAs into the DSC, seal welding/evacuation drying, transport of the DSC, or emplacement of a DSC into an HSM, no immediate action would be required. Operations in the spent fuel pool could be suspended indefinitely with IFA cladding temperatures well below the average long-term storage temperature limit of 340°C. During the other operations the IFA cladding temperature remains well below 570°C - an acceptable temperature for short-term operational and accident conditions. The DSC/transfer cask could be returned to the spent fuel pool if these other operations could not be completed in a timely manner. As stated in Section

9.2.2.1.1, "DSC and Associated Equipment," the ability to open a sealed DSC was demonstrated by cutting open the DSC mockup.

9.2.2.1.4 Transfer Trailer and HSM

The DSC/transfer cask was loaded with test weights to simulate loaded fuel and placed on the transfer trailer. It was then transported to the ISFSI and aligned with an HSM. Compatibility of the transfer trailer with the transfer cask, negotiation of the travel path to the ISFSI, and maneuverability within the confines of the ISFSI were verified. Additionally, it was verified that the 80 inch design basis height for a postulated cask drop could not be exceeded.

The transfer trailer was aligned and docked to the HSM. The hydraulic ram was used to emplace a DSC loaded with test weights in the HSM and remove it. Loading of the DSC into the HSM verified that the transfer skid alignment system, hydraulic positioners, and ram grapple assembly could operate safely for both emplacement of a DSC into an HSM, and removal of a DSC from an HSM.

9.2.2.1.5 Off-Normal Testing of the Transfer Trailer and HSM

In the unlikely event that a problem should occur that prevents loading the DSC into the HSM, no immediate remedial action will be required. IFAs may be stored in the transfer cask while corrective action is taken.

The most severe condition would occur if a failure of the hydraulic ram, after partial insertion of a DSC into an HSM, were to prevent complete emplacement of the DSC. (Radiological shielding and decay heat removal are not compromised by this condition, but the transfer trailer may not be moved away until the DSC is completely within the confines of either the transfer cask or the HSM.) Pre-operational testing verified that reversal of DSC movement could be completed by the operator of the hydraulic ram.

9.2.3 TEST DISCUSSION

1. The purpose of the pre-operational tests was to ensure that a DSC could be properly and safely placed in the spent fuel pool, loaded with IFAs, transported to the ISFSI, emplaced in the HSM, and removed from the HSM. Proper operation of the DSC, transfer cask, and transfer trailer, as well as the associated handling equipment (e.g. lift beam, welding equipment, vacuum equipment) provided this assurance.
2. Pre-operational test procedures were developed as stated in Section 9.2.1, "Administrative Procedures for Conducting Test Program" on page 9-7. Specific detailed procedures were developed and implemented by ONS personnel who were responsible for ensuring that the test requirements were satisfied. Changes made to the pre-operational procedures were incorporated into the appropriate loading procedure.
3. The result of the pre-operational tests was the successful completion of the following without damage to any component associated piece of equipment: loading of a DSC into the transfer cask, seal welding, drying, backfilling, and cutting open of the mockup DSC, placement of the transfer cask into and out of the ONS spent fuel pool, transporting the transfer cask loaded with a DSC to the ISFSI, and emplacement in an HSM and removal from an HSM.

9.3 TRAINING PROGRAM

The existing training program for ONS was modified to incorporate the training needed for operation of the ISFSI, in accordance with the Duke Power Employee Training and Qualification System (ETQS) Standards Manual. ETQS provides a systemic approach to training as described in the ONS FSAR, Section 13.1, "Organizational Structure" on page 13-3 of Reference 1 on page 9-17.

9.3.1 TRAINING FOR OPERATIONS PERSONNEL

Since the ISFSI is a passive storage system, generalized training is provided in the areas of cooling, radiological shielding, and structural characteristics of the DSC/HSM.

Detailed operator training is provided for DSC preparation and handling, fuel loading, transfer cask preparation and handling, and transfer trailer loading. Although operations personnel may not be directly involved in transport or HSM loading, detailed training is provided to permit oversight of these operations by fuel handling personnel.

Additionally, Fire Brigade training has been expanded to include the ISFSI in the Oconee Nuclear Station Pre-Fire Plan.

9.3.2 TRAINING FOR MAINTENANCE PERSONNEL

Maintenance personnel, involved with the ISFSI operations, receive generalized training in the NUHOMS-24P storage system. Specific training is provided for use of the automated seal welding equipment for the top end shield plug; operation of the transfer trailer; alignment of the cask skid with the HSM; alignment of the hydraulic ram assembly; and normal and off-normal operation of the hydraulic ram. Specific training is also being provided for cleaning of the HSM air inlets and outlets.

9.3.3 TRAINING FOR RADIATION PROTECTION PERSONNEL

Radiation Protection personnel have received generalized training in the NUHOMS-24P system. Specific training has been provided in radiological shielding design of the system, particularly the top end shield plug, DSC/transfer cask, the shielding issue associated with transfer of the DSC into the HSM, and the HSM itself.

9.3.4 TRAINING FOR SECURITY PERSONNEL

Details of the training program for security personnel are provided in the Guard Training Plan contained in a separate enclosure which is withheld from public disclosure in accordance with 10CFR 2.790(d) and 10CFR 73.21.

9.4 NORMAL OPERATIONS

Under normal operations, the ISFSI provides independent storage of Oconee spent fuel away from the Oconee plant facilities. With the exception of some limited physical and continuous electronic security surveillance, the facility functions as a passive system. Loading of fuel assemblies into the facility, which occurs periodically, require specific procedures that are separate from those of normal plant operations.

9.4.1 PROCEDURES

Operating, testing, and maintenance procedures are prepared, revised, reviewed, and approved in accordance with the Duke Power Company Nuclear Production Department "Administrative Policy Manual" (APM). (The APM sets forth the specific requirements of the Duke Power Company QA Topical Report, DUKE-1-A, which has been approved by the NRC as meeting the requirements of 10CFR 50 Appendix B.)

9.4.2 RECORDS

The ISFSI records are maintained in accordance with existing Oconee Nuclear Station procedures.

9.5 EMERGENCY PLANNING

The Emergency Program for Oconee Nuclear Station has been determined to be adequate to manage the consequences of events which might occur involving the ISFSI. Appropriate reviews were made of the existing emergency plan initiating conditions and it was determined that no changes were necessary. The Emergency Program consists of the Oconee Nuclear Station Emergency Plan and the Duke Power Company Crisis Management Plan for Nuclear Stations and their related implementing procedures. Also included are related radiological emergency plans and procedures of state and local governments. The purpose of these plans is to provide protection of plant personnel and the general public and to prevent or mitigate property damage that could result from an emergency at the Oconee Nuclear Station. The combined emergency preparedness programs have the following objectives:

1. Effective coordination of emergency activities among all organizations having a response role.
2. Early warning and clear instructions to the population-at-risk in the event of a serious radiological emergency.
3. Continued assessment of actual or potential consequences both on-site and off-site.
4. Effective and timely implementation of emergency measures.
5. Continued maintenance of an adequate state of emergency preparedness.

The emergency plans have been prepared in accordance with Section 50.47 and Appendix E of 10CFR Part 50. The plans shall be implemented whenever an emergency situation is indicated. Radiological emergencies can vary in severity from the occurrence of an abnormal event, such as a minor fire with no radiological health consequences, to nuclear accidents having substantial onsite and/or offsite consequences. In addition to emergencies involving a release of radioactive materials, events such as security threats or breaches, fires, electrical system disturbances, and natural phenomena that have the potential for involving radioactive materials are included in the plans. The plans contain adequate flexibility for dealing with any type of emergency that might occur.

The activities and responsibilities of outside agencies providing an emergency response role are detailed in the State Emergency Plans and the emergency plans for Oconee and Pickens Counties.

The emergency response resources available to respond to an emergency consist of the personnel at Duke Power Corporate Headquarters, at other Duke Power nuclear stations, and, in the longer term, at federal emergency response organizations (e.g. NRC, DOE, FEMA). The first line of defense in responding to an emergency lies with the normal operating shift on duty when the emergency begins. Therefore, members of the Oconee staff are assigned defined emergency response roles that are to be assumed whenever an emergency is declared. The overall management of the emergency is initially performed by the shift supervisor until he/she is relieved by the Station Manager. In the event of an emergency, he serves as the Emergency Coordinator. Because of his overall knowledge, he is best able to bring the full resources of the plant to bear on controlling the emergency. Onsite personnel have preassigned roles to support the Emergency Coordinator and to implement his directives.

Special provisions have been made to assure that ample space and proper equipment are available to effectively respond to the full range of possible emergencies.

The emergency facilities available include the Oconee Control Room, Operational Support Center, Technical Support Center, Crisis News Center, and the Crisis Management Center (Emergency

Operations Facility). These facilities are described in the station emergency plan and the Crisis Management Plan.

Emergency plan implementing procedures define the specific actions to be followed in order to recognize, assess, and correct an emergency condition and to mitigate its consequences. Procedures to implement the Plan provide the following information:

1. Specific instructions to the plant operating staff for the implementation of the Plan.
2. Specific authorities and responsibilities of plant operating personnel.
3. A source of pertinent information, forms, and data to ensure prompt actions are taken and that proper notifications and communications are carried out.
4. A record of the completed actions.
5. The mechanism by which emergency preparedness will be maintained at all times.

9.6 PHYSICAL SECURITY PLAN

The purpose of the security program for the Oconee Nuclear Station ISFSI is to establish and maintain a physical security program that has the capabilities for the protection of spent fuel stored in the NUHOMS-24P system.

Additional information regarding the security program for the ISFSI is contained in a separate enclosure, that is withheld from public disclosure in accordance with 10CFR 2.790(d) and 10CFR 73.21. This enclosure addresses the Physical Security Plan, Safeguards Contingency Plan, Design for Physical Security and Guard Training Plan.

9.7 REFERENCES

1. Oconee Nuclear Station Final Safety Analysis Report (FSAR)

CHAPTER 10. OPERATING CONTROLS AND LIMITS

The ISFSI will basically operate as a passive system requiring minimal surveillance. However, there are some operating controls and limits which will apply. These controls and limits which are listed below are discussed in detail in the following corresponding sections of this chapter. Other items which must be controlled such as those related to fuel movement and loading are based on normal operation and postulated accidents as discussed in Chapter 4, "Storage System" on page 4-1 and Chapter 8, "Accident Analyses" on page 8-1, respectively, of this report.

10.1 PROPOSED OPERATING CONTROLS AND LIMITS

Operating limits and controls may be found in Reference 2 on page 10-11.

10.2 DEVELOPMENT OF OPERATING CONTROLS AND LIMITS

This section provides an overview and general bases for the operating controls and limits specified in this report. Reference 2 on page 10-11 provides the specifications associated with the operation of the Oconee ISFSI to ensure the protection of the public's health and safety.

10.2.1 FUNCTIONAL AND OPERATING LIMITS, MONITORING INSTRUMENTS AND LIMITING CONTROL SETTINGS

The Oconee ISFSI utilizes the NUHOMS-24P system which is a passive design. Therefore, with the exception of the limit placed on the translational force exerted on the DSC by the hydraulic ram, no monitoring instruments or limiting control settings are utilized at the ISFSI facility. Long term operating variables such as HSM storage temperatures and confinement integrity will be controlled through observance of the operational control and limit specifications described in Reference 2 on page 10-11.

Another control which falls under the Oconee Station's 10CFR50 operating license is a restriction on minimum cooling time for fuel stored in certain locations of the spent fuel pools during cask handling operations. These restrictions ensure that any radioactivity releases remain below regulatory guidelines in the event of an in-pool cask drop accident.

10.2.2 LIMITING CONDITIONS FOR OPERATION

10.2.2.1 Equipment

Limiting conditions for the Oconee ISFSI equipment are specified in Reference 2 on page 10-11. In addition, the ram hydraulic system will be pre-set to insure that translational loads on a DSC during movement into the HSM are automatically limited to a maximum of 20,000 lbs. (Override control will be available to hydraulic ram operator for use during off-normal remedial action if needed.)

10.2.2.2 Technical Conditions And Characteristics

The following technical conditions and characteristics are required for the NUHOMS-24P system:

1. Boron Concentration in DSC Moderator
2. DSC Vacuum Pressure During Drying
3. DSC Helium Backfill Pressure
4. DSC Helium Leak Rate
5. DSC Dye Penetrant Test of Closure Welds
6. Fuel Assembly Retrieval and Inspection
7. DSC Surface Contamination
8. DSC Draining Requirements

A description of the bases for selecting the above conditions and characteristics is detailed in Reference 2 on page 10-11. The overall technical and operational considerations are further described in Section 10.2.2.2 of Reference 1 on page 10-11.

10.2.3 SURVEILLANCE REQUIREMENTS

Surveillance Requirements for the Oconee ISFSI are specified in Reference 2 on page 10-11.

10.2.4 DESIGN FEATURES

Changes to site specific design features important to safety are not anticipated for the Oconee ISFSI. Design features of the NUHOMS-24P system important to safe operation are outlined in Section 10.2.4 of Reference 1 on page 10-11 and in Reference 2 on page 10-11. Changes to any of these design features will be implemented only after appropriate regulatory review and approval.

10.2.5 ADMINISTRATIVE CONTROLS

Use of existing and proposed Duke Power Company organizational and administrative systems and procedures, record keeping, review, audit and reporting requirements (i.e. Duke Power Company Administrative Policy Manual, Oconee Nuclear Station Directives, Operating Procedures, etc.) will be used to ensure that the operations involved in the storage of spent fuel at the Oconee ISFSI are performed in a safe manner. This includes both the selection of assemblies qualified for ISFSI storage, and the verification of assembly identification numbers prior to and after placement into individual storage canisters.

10.2.5.1 Qualification of Spent Fuel

Figure 10-1 on page 10-10 represents the fuel assembly acceptance criteria for spent fuel placement and storage in the DSC. Fuel assembly qualification is based on the requirements for criticality control, decay heat removal, structural integrity, and radiological protection. Criticality control and decay heat removal capabilities are defined by three variables shown in Figure 10-1 on page 10-10: (1) initial assembly enrichment, (2) final assembly burnup, and (3) spent fuel cooling period. Control of these three administrative procedures, as described below.

For the NUHOMS-24P subcriticality is assumed for fuel assemblies meeting the 4.0 wt% enrichment limit of Reference 2 on page 10-11 when the DSC is filled with water borated to at least 1810 ppm (as required by Reference 2 on page 10-11) or when the DSC is drained. To ensure subcriticality in the postulated event that the DSC is filled with demineralized, unborated water, the burnup requirements of Figure 10-1 on page 10-10 are specified for any permissible initial enrichment.

Procedures currently in place for special nuclear materials accountability and record keeping will be used to verify initial fuel assembly enrichment and burnup levels at discharge. New fuel enrichments and initial uranium isotopics are recorded from the DOE/NKC Form 741's and stored in both a database file and on duplicate paper copies of the Form 741's. Individual fuel assembly burnups are also stored in the special nuclear materials database. These values are generated by the Oconee Operator Aided Computer utilizing thermal energy production data determined by in-core flux mapping. Burnup and initial enrichment values from special nuclear material accountability records will be compared to Figure 10-1 on page 10-10 to verify that the reactivity level is acceptable for DSC loading and storage of each irradiated fuel assembly. Actual qualification procedures may utilize a tabular version of the enrichment-burnup curves which will allow for each linear interpolation between a number of data points. While this enrichment vs. burnup method for reactivity verification will routinely be used and required by procedures, Duke Power reserves the right to rely on other NRC-accepted analytical methods to qualify fuel assemblies in special cases.

For decay heat control, only those irradiated assemblies which do not exceed a decay heat level of 0.66 kw will qualify for loading into the DSC. Decay heat loadings at or below this level ensure that peak pin clad temperatures are maintained within acceptable levels. Since individual fuel assembly decay heat levels are a function of both the discharge burnup and the decay time, procedural controls will be used to verify these parameters prior to fuel assembly loading.

For the Oconee fuel design and routine operating histories, the decay time necessary to achieve a .66 kw decay heat level is generally 7.5 years. The variation in required cooling time is a very strong function of discharge burnup and a very weak function of initial enrichment. It is acceptable to store fuel assemblies cooled less than 10 years provided that decay heat production is no more than 0.66 Kw for each fuel assembly and that neutron and gamma source terms for the DSC are verified not to exceed certain values specified in Reference 2 on page 10-11.

As mentioned previously, special nuclear materials accountability records will be used to verify fuel assembly burnup. These records will also be used to verify spent fuel decay time. The individual assembly burnup and decay time will then be compared to Figure 10-1 on page 10-10 for DSC loading qualification purposes.

To ensure structural integrity of the spent fuel to be loaded into the DSC, station records of all damaged assemblies will be reviewed. A damaged fuel assembly and component database has been compiled which incorporates previous sipping, ultrasonic (UT) testing, and visual observation. This database will be examined as a part of the dry storage qualification process to verify that assemblies with gross structural or gross cladding damage are not included.

If the reactivity, decay heat, cooling time structural integrity, and dose limits criteria are all met, then approval for dry storage for a given assembly will be documented. This documentation will subsequently be referenced through procedures at the station prior to loading fuel into the DSC.

10.2.5.2 Spent Fuel Identification

Administrative controls will be utilized to avoid fuel misplacement. Information on fuel assembly qualification for dry storage will be documented and transmitted to fuel handling personnel. Prior to any transfer of a fuel assembly in the DSC, specific DSC loading procedures will require a review of assembly documentation. This will be followed by an independent visual verification of the assembly identification number by two individuals. These procedures ensure that the correct (approved) fuel assembly is being accessed and loaded into the DSC. As a final check, all assembly identification numbers will be checked after the DSC has been fully loaded with 24 assemblies.

10.3 OPERATIONAL CONTROL AND LIMIT SPECIFICATION

Functional and Operating Limits, Monitoring Instruments and Limiting Control Settings; Limiting Conditions for Operations; and Surveillance Requirements are specified in Reference 2 on page 10-11.

10.3.1 FIGURES




Figure 10-1.
Fuel Assembly Acceptance Criteria Cooling Period > 10 Years

10.4 REFERENCES

1. Topical Report for the Nutech Horizontal Modular Storage (NUHOMS-24P) System for Irradiated Nuclear Fuel, NUH-002, Revision 1A, July 1989
2. Duke Power Company Special Nuclear Materials License SNM-2503, Docket No. 72-4 for the Oconee Independent Spent Fuel Storage Installation, as amended January 29, 1990

CHAPTER 11. QUALITY ASSURANCE

Duke Power Company maintains full responsibility for assuring that its nuclear power plants are designed, constructed, tested and operated in conformance with good engineering practices, applicable regulatory requirements and specified design bases and in a manner to protect the public health and safety. To this end Duke has established and implemented a quality assurance program which conforms to the criteria established in Appendix B to 10CFR Part 50, "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants" and to approved industry standards such as ANSI N45.2-1977 and ANSI N18.7-1977 and corresponding daughter standards, or to equivalent alternatives.

The activities associated with the Independent Spent Fuel Storage Installation (ISFSI) will be governed by the applicable portions of the Duke Power Company Quality Assurance Program. This Quality Assurance Program is described in the Duke Power Company Topical Report, DUKE-1-A. The Topical Report provides the current quality assurance program description for Oconee, McGuire, and Catawba Nuclear Stations, Docket Nos. 50-269, 50-270, 50-287, 50-369, 50-370, 50-413, and 50-414.

Additional, the Topical Report describes the Quality Assurance Program for those systems, components, items, and services which have been determined to be safety related. In addition, Duke's Quality Assurance Program provides a method of applying a graded Quality Assurance Program to certain non-safety related systems, components, items, and services. This method involves defining a Quality Assurance "Condition" for each level of quality assurance required. These will be designated as "QA Condition _____." The following conditions have been defined:

QA Condition 1 covers those systems and their attendant components, items, and services which have been determined to be safety related. These systems are detailed in the Safety Analysis Report applicable to each nuclear station. The Topical Report applies in its entirety to systems, components, items, and services identified as QA Condition 1.

QA Condition 2 covers those systems and their attendant components, items, and structures important to the management and containment of liquid, gaseous, and solid radioactive waste.

QA Condition 3 covers those systems, components, items, and services which are important to fire protection as defined in the Hazards Analysis for each station. The Hazards Analysis is in response to Appendix A of NRC Branch Technical Position APCS 9.5-1.

QA Condition 4 covers those seismically designed restrained systems, components, and structures whose continued functions are not required during and after the seismic event. The general scope of these systems, components, and structures, identified as Seismic Category II (SCII) are defined in Regulatory Guide 1.29, Seismic Design Classification.