



CHARLES CENTER • P.O. BOX 1475 • BALTIMORE, MARYLAND 21203-1475

CALVERT CLIFFS NUCLEAR POWER PLANT DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

January 10, 1990

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

SUBJECT: Auxiliary Boiler Water Discharge, December 18, 1989

Dear Sirs/Madames:

Attached you will find a copy of the letter to the State of Maryland describing a non-compliance auxiliary boiler water discharge event at Calvert Cliffs Nuclear Power Plant which occurred on December 18, 1989. We are required by our NPDES permit for Calvert Cliffs to report to the State any non-compliance event.

If you have any questions regarding the attached, please call me at (301) 260-4905.

Sincerely,

B. Frank Sears
Supervisor, Water Treatment

BFS:dag

cc: Document Control Desk



CHARLES CENTER • P.O. BOX 1475 • BALTIMORE, MARYLAND 21203-1475

CALVERT CLIFFS NUCLEAR POWER PLANT DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

January 10, 1990

Mr. John Beazley
Maryland Department of Environment
2900 Broening Highway
Baltimore, Maryland 21224

Dear Mr. Beazley:

This letter is to inform you of a non-compliance condition that occurred at Calvert Cliffs Nuclear Power Plant.

On December 18, 1989, the auxiliary boiler blown down to the Chesapeake Bay via outfall 001, monitoring point 103. Over an approximately 1 hour period, 6000 gallons of auxiliary boiler water was discharged. The total suspended solids of this batch discharge was 43.0 mg/liter which was less than our daily maximum limit of 100 mg/liter. However, since this was the only discharge for the month, our monthly average of 30 mg/liter was exceeded.

No impact upon the receiving water was observed or is expected.

If you have questions regarding this information, please feel free to call me, 301/260-4905.

Sincerely,

B. Frank Sears
Supervisor, Water Treatment

BFS:dag

cc: NRC Resident Inspector



CHARLES CENTER • P.O. BOX 1475 • BALTIMORE, MARYLAND 21203-1475

CALVERT CLIFFS NUCLEAR POWER PLANT DEPARTMENT
CALVERT CLIFFS NUCLEAR POWER PLANT
LUSBY, MARYLAND 20657

January 10, 1990

Mr. John Beazley
Maryland Department of Environment
2500 Broening Highway
Baltimore, Maryland 21224

Dear Mr. Beazley:

This letter is to inform you of a non-compliance condition that occurred at Calvert Cliffs Nuclear Power Plant.

On December 18, 1989, the auxiliary boiler blown down to the Chesapeake Bay via outfall 001, monitoring point 103. Over an approximately 1 hour period, 6000 gallons of auxiliary boiler water was discharged. The total suspended solids of this batch discharge was 43.0 mg/liter which was less than our daily maximum limit of 100 mg/liter. However, since this was the only discharge for the month, our monthly average of 30 mg/liter was exceeded.

No impact upon the receiving water was observed or is expected.

If you have questions regarding this information, please feel free to call me, 301/260-4905.

Sincerely,

B. Frank Sears
Supervisor, Water Treatment

BFS:dag

cc: NRC Resident Inspector