

# BALTIMORE GAS AND ELECTRIC COMPANY

P.O. BOX 1475

BALTIMORE, MARYLAND 21203

NUCLEAR POWER DEPARTMENT  
CALVERT CLIFFS NUCLEAR POWER PLANT  
LUSBY, MARYLAND 20687

July 21, 1982

Division of Sewerage  
Inspection and Compliance Program  
Office of Environmental Programs,  
Room 2A4  
201 West Preston Street  
Baltimore, Maryland 21201

Attention: Mr. Ronald Parise

Re: Maryland State Discharge  
Permit No. 74-DP-0187A and  
NPDES Permit No. MD 0002399

Dear Mr. Parise:

On June 2, 1982 weekly coliform analysis from Outfall 101 revealed a concentration of 79 mpn/100 mL, above the permit specification of 70 mpn/100 mL. At this point in time, the operator was unaware of the permit violation and no changes in plant operation were implemented. This condition was corrected by the June 9, 1982 routine weekly sample.

A cause for the apparent violation is unknown and because of the above suggested scenario, cannot be ascertained. The operator will be re-instructed of the permit specifications to insure a similar event does not occur.

Very truly yours,

*L B Russell*  
L. B. Russell  
Plant Superintendent

LBR/GEB/fcb

9201270303 920116  
PDR ADDCK 05000317  
S PDR