

Official

November 1, 1991

Docket Nos. 50-325, 50-324  
License Nos. DPR-71, DPR-62

Carolina Power and Light Company  
ATTN: Mr. Lynn W. Eury  
Executive Vice President  
Power Supply  
P. O. Box 1551  
Raleigh, NC 27602

Gentlemen:

SUBJECT: ACCEPTANCE OF CHANGES TO THE QUALITY ASSURANCE PROGRAM FOR THE  
BRUNSWICK STEAM ELECTRIC PLANT, UNITS 1 AND 2

We have completed our review of the changes addressed in your letter, dated July 25, 1991. We concluded that the changes, Enclosures 1, 2 and 3, are acceptable and your program continues to satisfy 10 CFR 50, Appendix B requirements.

Our understanding is that the requested changes affect QA for the fire protection systems only. You plan to delete the commitment to have QA/QC assure that acceptance tests are specified in plant modifications prior to the fire protection equipment being declared operable. In its place you plan to add the requirements of section 17.2.11, Test Control of the FSAR. We consider this an acceptable substitute.

Any questions you may have concerning this review should be directed to F. Jape of my staff (404) 331-4182.

Sincerely,

Original signed by  
Stuart Rubin/for

Albert F. Gibson, Director  
Division of Reactor Safety

cc: R. B. Starkey, Jr.  
Vice President  
Brunswick Nuclear Project  
P. O. Box 10429  
Southport, NC 28461

(cc cont'd - See page 2)

9201280014 911101  
PDR ADOCK 05000324  
P PDR

IE01

November 1, 1991

(cc cont'd)

J. W. Spencer  
Plant General Manager  
Brunswick Steam Electric Plant  
P. O. Box 10429  
Southport, NC 28461

Mr. H. Ray Starling  
Manager - Legal Department  
P. O. Box 1551  
Raleigh, NC 27602

Mr. Kelly Holden  
Board of Commissioners  
P. O. Box 249  
Bolivia, NC 28422

Chrys Baggett  
State Clearinghouse  
Budget and Management  
116 West Jones Street  
Raleigh, NC 27603

Dayne H. Brown, Director  
Division of Radiation Protection  
N. C. Department of Environmental,  
Commerce & Natural Resources  
P. O. Box 27687  
Raleigh, NC 27611-7687

H. A. Cole  
Special Deputy Attorney General  
State of North Carolina  
P. O. Box 629  
Raleigh, NC 27602

Robert P. Gruber  
Executive Director  
Public Staff - NCUC  
P. O. Box 29520  
Raleigh, NC 27626-0520

bcc: Document Control Desk  
H. Christensen, RII  
T. Le, NRR  
F. Jape  
Engineering Branch Reading File

(bcc cont'd - See page 3)

(bcc cont'd)  
NRC Resident Inspector  
U.S. Nuclear Regulatory Commission  
Star Rte. 1, Box 208  
Southport, NC 28461

RII:DRS

*for*  
MThomas:scr  
10/27/91

RII:DRS

*79*  
FLeape  
10/31/91

RII:DRS

*CS*  
CJulian  
10/31/91

RII:DRP

*W*  
DVerrelli  
10/31/91