



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401-1927
Telephone (612) 330-5500

January 21, 1992

U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

10 (FR Part 50
Section 50.90

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

License Amendment Request Dated January 21, 1992
Change Monthly Surveillance Testing for ESF Equipment
to the IST Frequency

Attached is a request for a change in the Technical Specifications, Appendix A of the Operating License for the Prairie Island Nuclear Generating Plant. This request is submitted in accordance with the provisions of 10 CFR Part 50, Section 50.90.

This amendment changes Engineered Safeguards Features Equipment surveillance frequency intervals from monthly to that required by the ASME Code, Section XI, Inservice Testing Program.

Exhibit A contains a description of the proposed changes, the reasons for requesting the changes, and a Safety Evaluation/Determination of Significant Hazards Consideration. Exhibit B contains marked up Prairie Island Technical Specification pages. Exhibit C contains revised Prairie Island Technical Specification pages.


9201280028 920121
PDR ADOCK 05000282
PDR

AD-17

USNRC
January 21, 1992
Page 2

Northern States Power Company

Please contact us if you require further information related to this request.



Thomas M Parker
Manager
Nuclear Support Services

c: Regional Administrator-III, NRC
NRC Project Manager, NRC
Resident Inspector, NRC
MPCA
Attn: Lr Raymond Thron
J E Silberg

Attachments:

Affidavit
Exhibit A - Evaluation of Proposed Changes
Exhibit B - Marked Up Prairie Island Technical Specification Pages
Exhibit C - Revised Prairie Island Technical Specification Pages