

NORTH ANNA NUCLEAR POWER STATION, UNITS 1 AND 2

CONTROL OF HEAVY LOADS - PHASE I

SAFETY EVALUATION REPORT

I. Introduction

As a result of Generic Task A-36, "Control of Heavy Loads Near Spent Fuel," NUREG-0612, "Control of Heavy Loads at Nuclear Power Plants," was developed. Following the issuance of NUREG-0612, a generic letter dated December 22, 1980, was sent to all operating plants, applicants for operating licenses and holders of construction permits requesting that responses be prepared to indicate the degree of compliance with the guidelines of NUREG-0612. The responses were made in two stages. The first response (Phase I) was to identify the load handling equipment within the scope of NUREG-0612 and to describe the associated load paths, procedures, operator training, special and general purpose lifting devices, the maintenance, testing and repair of equipment and the handling equipment specifications. The second response (Phase II) was intended to show that either single-failure-proof handling equipment was not needed or that single-failure-proof equipment had been provided. This safety evaluation report contains the staff's evaluation of Phase I. An evaluation of Phase II will be the subject of future correspondence.

By letter dated December 22, 1980, the Virginia Electric and Power Company (VEPCO), the licensee for North Anna was requested to review their provisions for handling and control of heavy loads at North Anna to determine the extent to which the guidelines of NUREG-0612 are presently satisfied and to discuss and commit to mutually agreeable changes and modifications that would be required in order to fully satisfy the guidelines.

II. NRC Review and Evaluation

The staff and its consultant, the Franklin Research Center (FRC), have reviewed VEPCO submittals for North Anna.

As a result of its review, FRC has issued a revised Technical Evaluation Report (TER) dated May 14, 1984. This TER is a part of our Phase I SER for NUREG-0612. The staff has reviewed the TER and concurs with its findings that the guidelines in NUREG-0612, Sections 5.1.1 and 5.3 have been satisfied. We therefore conclude that Phase I for North Anna, Units 1 and 2 is acceptable.

TECHNICAL EVALUATION REPORT

CONTROL OF HEAVY LOADS (C-10)

VIRGINIA ELECTRIC AND POWER COMPANY

NORTH ANNA POWER STATION UNITS 1 AND 2

NRC DOCKET NO. 50-338, 50-339

FRC PROJECT C5506

NRC TAC NO. 47112, 47113

FRC ASSIGNMENT 13

NRC CONTRACT NO. NRC-03-81-130

FRC TASKS 372, 373

Prepared by

Franklin Research Center
20th and Race Streets
Philadelphia, PA 19103

Author: C. R. Bomberger
F. W. Vosbury
FRC Group Leader: I. H. Sargent

Prepared for

Nuclear Regulatory Commission
Washington, D.C. 20555

Lead NRC Engineer: A. Singh

May 8, 1984

Revised May 14, 1984

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

~~8445/11145P(27)~~



Franklin Research Center

A Division of The Franklin Institute

The Benjamin Franklin Parkway, Phila., Pa. 19103 (215) 448-1000

TECHNICAL EVALUATION REPORT

CONTROL OF HEAVY LOADS (C-10)

VIRGINIA ELECTRIC AND POWER COMPANY

NORTH ANNA POWER STATION UNITS 1 AND 2

NRC DOCKET NO. 50-338, 50-339

FRC PROJECT C5506

NRC TAC NO. 47112, 47113

FRC ASSIGNMENT 13

NRC CONTRACT NO. NRC-03-81-130

FRC TASKS 372, 373

Prepared by

Franklin Research Center
20th and Race Streets
Philadelphia, PA 19103

Author: C. R. Bomberger
F. W. Vosbury
FRC Group Leader: I. H. Sargent

Prepared for

Nuclear Regulatory Commission
Washington, D.C. 20555

Lead NRC Engineer: A. Singh

May 8, 1984
Revised May 14, 1984

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

Prepared by:

C. R. Bomberger
Principal Author
Date: 5/7/84

Reviewed by:

I. H. Sargent
Group Leader
Date: 5/7/84

Approved by:

J. P. Carfagna
Department Director
Date: 5-8-84



Franklin Research Center

A Division of The Franklin Institute

The Benjamin Franklin Parkway, Phila. Pa. 19103 (215) 448-1000

CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1	INTRODUCTION	1
	1.1 Purpose of Review	1
	1.2 Generic Background	1
	1.3 Plant-Specific Background	2
2	EVALUATION	4
	2.1 General Guidelines	4
	2.2 Interim Protection Measures.	18
3	CONCLUSION	21
	3.1 General Provisions for Load Handling	21
	3.2 Interim Protection Measures.	21
4	REFERENCES	23

FOREWORD

This Technical Evaluation Report was prepared by Franklin Research Center under a contract with the U.S. Nuclear Regulatory Commission (Office of Nuclear Reactor Regulation, Division of Operating Reactors) for technical assistance in support of NRC operating reactor licensing actions. The technical evaluation was conducted in accordance with criteria established by the NRC.

Mr. C. R. Bomberger, Mr. F. W. Vosbury, and Mr. I. H. Sargent contributed to the technical preparation of this report through a subcontract with WESTEC Services, Inc.

1. INTRODUCTION

1.1 PURPOSE OF REVIEW

This technical evaluation report documents the review of general load handling policy and procedures at Virginia Electric and Power Company's (VEPCO) North Anna Power Station Units 1 and 2. This evaluation was performed with the following objectives:

- o to assess conformance to the general load handling guidelines of NUREG-0612, "Control of Heavy Loads at Nuclear Power Plants" [1], Section 5.1.1
- o to assess conformance to the interim protection measures of NUREG-0612, Section 5.3.

1.2 GENERIC BACKGROUND

Generic Technical Activity Task A-36 was established by the U.S. Nuclear Regulatory Commission (NRC) staff to systematically examine staff licensing criteria and the adequacy of measures in effect at operating nuclear power plants to ensure the safe handling of heavy loads and to recommend necessary changes to these measures. This activity was initiated by a letter issued by the NRC staff on May 17, 1978 [2] to all power reactor licensees, requesting information concerning the control of heavy loads near spent fuel.

The results of Task A-36 were reported in NUREG-0612, "Control of Heavy Loads at Nuclear Power Plants." The staff's conclusion from this evaluation was that existing measures to control the handling of heavy loads at operating plants, although providing protection from certain potential problems, do not adequately cover the major causes of load handling accidents and should be upgraded.

In order to upgrade measures for the control of heavy loads, the staff developed a series of guidelines designed to achieve a two-phase objective using an accepted approach or protection philosophy. The first portion of the objective, achieved through a set of general guidelines identified in NUREG-0612, Section 5.1.1, is to ensure that all load handling systems at

nuclear power plants are designed and operated such that their probability of failure is uniformly small and appropriate for the critical tasks in which they are employed. The second portion of the staff's objective, achieved through guidelines identified in NUREG-0612, Sections 5.1.2 through 5.1.5, is to ensure that, for load handling systems in areas where their failure might result in significant consequences, either (1) features are provided, in addition to those required for all load handling systems, to ensure that the potential for a load drop is extremely small (e.g., a single-failure-proof crane) or (2) conservative evaluations of load handling accidents indicate that the potential consequences of any load drop are acceptably small. Acceptability of accident consequences is quantified in NUREG-0612 into four accident analysis evaluation criteria.

The approach used to develop the staff guidelines, based on defense-in-depth, was to ensure that all load handling systems are designed and operated so that their probability of failure is appropriately small. The intent of the guidelines is to ensure that licensees of all operating nuclear power plants perform the following:

- o define safe load travel paths through procedures and operator training so that, to the extent practical, heavy loads are not carried over or near irradiated fuel or safe shutdown equipment
- o provide sufficient operator training, handling system design, load handling instructions, and equipment inspection to ensure reliable operation of the handling system.

Staff guidelines resulting from the foregoing are tabulated in Section 5 of NUREG-0612. Section 6 of NUREG-0612 recommended that a program be initiated to ensure that these guidelines are implemented at operating plants.

1.3 PLANT-SPECIFIC BACKGROUND

On December 22, 1980, the NRC issued a letter [3] to VEPCO, the Licensee for North Anna Power Station, requesting that the Licensee review provisions for the handling and control of heavy loads, evaluate these provisions with respect to the guidelines of NUREG-0612, and provide additional information to be used for an independent determination of conformance to these guidelines.

On December 22, 1981 [4] and March 22, 1982 [5], VEPCO responded to this request. A draft technical evaluation report (TER) was prepared based on this information and was informally transmitted to the Licensee for review and comment. In response to the draft TER, VEPCO submitted additional information on October 18, 1982 [6]. On October 22, 1982, a telephone conference call was conducted with representatives of NRC, FRC, and VEPCO to discuss unresolved issues. As a result of this call, additional information was forwarded by VEPCO on December 15, 1982 [7], July 12, 1983 [8], and March 30, 1984 [9] which has been incorporated into this final technical evaluation.

2. EVALUATION

This section presents a point-by-point evaluation of load handling provisions at North Anna Units 1 and 2 with respect to NRC staff guidelines provided in NUREG-0612. Separate subsections are provided for both the general guidelines of NUREG-0612, Section 5.1.1 and the interim measures of NUREG-0612, Section 5.3. In each case, the guideline or interim measure is presented, Licensee-provided information is summarized and evaluated, and a conclusion as to the extent of compliance, including recommended additional action where appropriate, is presented. These conclusions are summarized in Table 2.1.

2.1 GENERAL GUIDELINES

The NRC has established seven general guidelines to provide the defense-in-depth appropriate for the safe handling of heavy loads. They are identified under the following topics in Section 5.1.1 of NUREG-0612:

- Guideline 1 - Safe Load Paths
- Guideline 2 - Load Handling Procedures
- Guideline 3 - Crane Operator Training
- Guideline 4 - Special Lifting Devices
- Guideline 5 - Lifting Devices (Not Specially Designed)
- Guideline 6 - Cranes (Inspection, Testing, and Maintenance)
- Guideline 7 - Crane Design.

These seven guidelines should be satisfied for all overhead handling systems and programs in order to handle heavy loads in the vicinity of the reactor vessel, near spent fuel in the spent fuel pool, or in other areas where a load drop may damage safe shutdown systems.

Table 2.1. North Anna Units 1 and 2/NUREG-0612 Compliance Matrix

Heavy Loads	Weight or Capacity (tons)	Guideline 1 Safe Load Paths	Guideline 2 Procedures	Guideline 3 Crane Operator Training	Guideline 4 Special Lifting Devices	Guideline 5 Slings	Guideline 6 Crane - Test and Inspection	Guideline 7 Crane Design	Interim Measure 1 Technical Specifications	Interim Measure 6 Special Attention
1. Containment										
Polar Cranes	140/50	--	--	R	--	--	C	C	--	--
- Reactor Vessel Lifting Rig	6.0	C	R	--	R	--	--	--	--	C
- RV Head	127.2	C	R	--	--	--	--	--	--	C
- RV Internals Lifting Rig	7.2	C	R	--	R	--	--	--	--	C
- RV Upper Internals	53.5	C	R	--	--	C	--	--	--	C
- RV Lower Internals	131.5	C	R	--	--	C	--	--	--	C
- CBD Missile Shield	33.3	C	R	--	--	C	--	--	--	C
- RV Seal Ring	7.5	C	R	--	--	C	--	--	--	C
- Reactor Coolant Pump Motor	39.0	C	R	--	R	--	--	--	--	C
- Floor Concrete Hatches	1-20	C	R	--	--	C	--	--	--	C
- RV Inspection Tool	5.0	C	R	--	--	C	--	--	--	C
- Reactor Containment Recirc Fan	2.8	C	R	--	--	C	--	--	--	C

C = Licensee action complies with NUREG-0612 Guideline.
 -- = Not applicable.
 R = Licensee has proposed revisions or modifications which, when implemented, will be in compliance with NUREG-0612 Guideline.

Table 2.1 (Cont.)

Heavy Loads	Weight or Capacity (tons)	Guideline 1 Safe Load Paths	Guideline 2 Procedures	Guideline 3 Crane Operator Training	Guideline 4 Special Lifting Devices	Guideline 5 Slings	Guideline 6 Crane - Test and Inspection	Guideline 7 Crane Design	Interim Measure 1 Technical Specifications	Interim Measure 6 Special Attention
2. Containment Annulus Crane	5.0	--	--	R	--	--	C	C	--	--
- Various Loads up to Rated Capacity		C	R	--	--	C	--	--	--	--
3. RHR Pump Monorails	3.0	--	--	R	--	--	C	C	--	--
- RHR Pump Motors	3.0	C	R	--	--	C	--	--	--	--
4. Auxiliary Building Material Handling Monorails	12.0	--	--	R	--	--	C	C	--	--
- Filter Casks	4.0	C	R	--	--	C	--	--	--	--
5. New Fuel Bridge Crane	5.0	--	--	R	--	--	C	C	--	C
- Various Loads up to Rated Capacity	4.0	C	R	--	--	C	--	--	--	--
6. Fuel Building Movable Platform		--	--	R	--	--	C	C	C	--
- Spent Fuel Cavity Gate	1.8	C	R	--	--	C	--	--	C	--

2.1.1 Overhead Heavy Load Handling Systems

a. Summary of Licensee Statements and Conclusions

The Licensee reviewed all load handling systems capable of carrying a heavy load (approximately 2500 pounds) and classified them into one of two groups:

- Group I Heavy load handling systems from which a load drop may result in damage to any system required for plant shutdown or decay heat removal, taking no credit for interlocks, technical specifications, operating procedures, detailed structural analyses, or system redundancy.
- Group II Heavy load handling systems excluded from Group I based on determination by inspection that there is sufficient physical separation between any load-impact point and any system needed for plant shutdown or decay heat removal.

Table 2.2 lists all handling systems the Licensee classified as Group I, and Table 2.3 lists all handling systems the Licensee classified as Group II, along with reasons for excluding each system from compliance with NUREG-0612.

b. Evaluation, Conclusion, and Recommendation

The Licensee's determination of those cranes and hoists which must comply with NUREG-0612 is consistent with NRC guidelines. The remaining cranes and hoists have been justifiably excluded due to either (1) physical separation from equipment required for plant shutdown or decay heat removal or (2) classification of the handling system as a sole-purpose system used only when the equipment required for plant shutdown or decay heat removal has been placed out of service.

2.1.2 Safe Load Paths [Guideline 1, NUREG-0612, Section 5.1.1(1)]

"Safe load paths should be defined for the movement of heavy loads to minimize the potential for heavy loads, if dropped, to impact irradiated fuel in the reactor vessel and in the spent fuel pool, or to impact safe shutdown equipment. The path should follow, to the extent practical, structural floor members, beams, etc., such that if the load is dropped, the structure is more likely to withstand the impact. These load paths

Table 2.2. Group I Load Handling Systems

Containment Polar Crane (1-MH-CR-1)
 Containment Annulus Crane (1-MH-CR-19)
 RER Pump Monorails
 Auxiliary Building Material Handling System Monorails (1-MH-CR-8A & B, -9B)
 New Fuel Bridge Crane (1-MH-CR-20)
 Fuel Building Movable Platform with Hoists (1-MH-FH-13)

Table 2.3. Group II Load Handling Systems

A. Load handling systems excluded due to physical separation from safety-related or plant shutdown equipment:

Recirculation Spray Pump Hoists (1-MH-CR-39 A & B)
 Auxiliary Building Bridge Crane (1-MH-CR-9A)
 Auxiliary Building Jib Crane
 Fuel Building Trolley (1-MH-CR-15)
 Decontamination Building Trolley (1-MH-CR-28)
 Solid Waste Crane (1-MH-CR-36)
 Solid Fill Area Crane (1-MH-CR-37)
 Turbine Building Overhead Crane (1-MH-CR-2)
 Steam Generator Feed Pump Trolley (1-MH-CR-6)
 Condenser Waterbox Hoists (1-MH-CR-10A & B)
 Feedwater Heater Hoists (1-MH-CR-17A & B)
 Machine Shop Monorails (1-MH-CR-11A & B)
 Machine Shop Bridge Crane (1-MH-CR-24)
 Machine Shop Monorail (1-MH-CR-38)
 Trash Basket Monorail and Hoist (1-MH-CR-26)

B. Load handling systems excluded because they are sole-purpose systems capable of lifting loads over a single train of components and are used only when the equipment is out of service for maintenance:

Charging Pump Monorails (1-MH-CR-7)
 Emergency Diesel Generator Monorails

should be defined in procedures, shown on equipment layout drawings, and clearly marked on the floor in the area where the load is to be handled. Deviations from defined load paths should require written alternative procedures approved by the plant safety review committee."

a. Summary of Licensee Statements and Conclusions

The Licensee stated that load paths were identified for the Group I overhead handling systems, taking into account the location of plant equipment needed for plant shutdown or decay heat removal, and conservatively adding the effects of possible load swings. Each item of plant equipment was evaluated to determine whether damage from a load drop could prevent achieving and maintaining a safe shutdown condition. For the overhead load handling systems which were inaccessible to walkdown inspection (due to plant operation or high radiation), design drawings were reviewed to determine whether a load drop could potentially damage the equipment required for plant shutdown or decay heat removal.

The Licensee noted that this identification of safe load paths assumed that the structural integrity of the floors is maintained following the postulated load drops. A structural analysis was performed for the floor over which heavy loads travel and maximum lift heights were established to correspond with the floor capacities.

Current plant procedures require that deviations to safe load paths be reviewed by station supervisory personnel with a followup review by the station nuclear safety and operating committee.

The Licensee took exception to the Guideline 1 requirement to mark safe load paths on the operating floors and noted:

"Safe load paths will not be marked on the floor in the area where the load is to be handled. Safe load path sketches will be defined in procedures and made available to all crane operators. Since a majority of the reactor containment operating floor consists of removable hatches and mechanical equipment and is covered with herculite during outages, safe load path markings are impractical. Safe load path sketches which are simple, descriptive and readily available to operators will better serve to define safe load paths."

In lieu of marking load paths on floors, supervisory personnel review the load path with the operators prior to a lift being made and a signalman then guides the operator along the load path during the lift operation. The duties of these individuals are clearly defined in the appropriate maintenance and administrative procedures.

b. Evaluation

Development of load paths in the containment building meets the intent of Guideline 1. The use of floor structural integrity combined with maximum lift heights to determine acceptable safe load paths is consistent with the intent of this guideline.

In the fuel building, use of exclusion areas is acceptable on the basis that the areas of concern are relatively small and the creation of load paths would excessively limit the movement of loads.

Deviations from load paths are acceptably handled on the basis that prior approval is required and that the additional procedures and changes prepared receive at least two levels of supervisory review.

Although safe load paths are not marked at North Anna Units 1 and 2, the object of providing a visual aid for operators is accomplished by having supervisory personnel review the procedure with the operator and providing a signalman to guide the operator. The duties of the supervisors and signalman relative to safe load handling are clearly defined in procedures.

c. Conclusion and Recommendation

Safe load paths in use at North Anna Units 1 and 2 are consistent with the requirements of Guideline 1.

2.1.3 Load Handling Procedures [Guideline 2, NUREG-0612, Section 5.1.1(2)]

"Procedures should be developed to cover load handling operations for heavy loads that are or could be handled over or in proximity to irradiated fuel or safe shutdown equipment. At a minimum, procedures should cover handling of those loads listed in Table 3-1 of NUREG-0612.

These procedures should include: identification of required equipment; inspections and acceptance criteria required before movement of load; the steps and proper sequence to be followed in handling the load; defining the safe load path; and other special precautions."

a. Summary of Licensee Statements and Conclusions

The Licensee provided a tabulation of heavy loads periodically handled by the containment polar cranes and a summary of loads carried by the other Group I handling systems. Specific sections of M.D. ADM-9.1, "Control of Heavy Loads in the Reactor Containment - 291 Level," are identified for most of the heavy loads in the containment. Procedures for the Group I handling systems have been developed and contain the information specified in Guideline 2, were approved by the Station Nuclear Safety and Operating Committee, and have been implemented.

c. Evaluation and Conclusion

Procedures in use at North Anna Power Station Units 1 and 2 are consistent with the criteria of Guideline 2.

2.1.4 Crane Operator Training [Guideline 3, NUREG-0612, Section 5.1.1(3)]

"Crane operators should be trained, qualified and conduct themselves in accordance with Chapter 2-3 of ANSI B30.2-1976, 'Overhead and Gantry Cranes' [10]."

a. Summary of Licensee Statements and Conclusions

Crane operations at North Anna Power Station Units 1 and 2 are handled by either maintenance or operations department personnel. Current maintenance department procedures require that crane operators be trained and qualified according to ANSI B30.2-1976. The Licensee stated that crane operators from the operations department are selected by the refueling senior reactor operator/coordinator. Each crane operator receives the following instructions:

1. "He must read, understand and sign the sign off sheet of the master refueling procedure, OP 4.1, covering the manipulator crane and the fuel building bridge and trolley crane.

2. Practice walk-throughs are conducted on all fuel handling equipment. A dummy fuel assembly is used to simulate actual fuel.
3. All equipment is tested and is verified to be in calibration prior to use.
4. Procedures are provided for the following cranes:
 - (a) Manipulator Crane
 - (b) Fuel Building Bridge and Trolley Crane
 - (c) New Fuel Crane
 - (d) Spent Fuel Crane.
5. Safe load paths and restricted areas are outlined in the appropriate procedure.
6. Each operator whom the SRO feels operates the equipment in a safe manner will be certified on the crew training check off sheet indicating what equipment he may operate and a copy of which will be in his training record."

The Licensee stated that operator conduct is monitored on a continuing basis.

b. Evaluation and Conclusion

The crane operator training program at North Anna Power Station Units 1 and 2 is consistent with the criteria of Guideline 3.

2.1.5 Special Lifting Devices [Guideline 4, NUREG-0612, Section 5.1.1(4)]

"Special lifting devices should satisfy the guidelines of ANSI N14.6-1978, 'Standard for Special Lifting Devices for Shipping Containers Weighing 10,000 Pounds (4500 kg) or More for Nuclear Materials' [11]. This standard should apply to all special lifting devices which carry heavy loads in areas as defined above. For operating plants certain inspections and load tests may be accepted in lieu of certain material requirements in the standard. In addition, the stress design factor stated in Section 3.2.1.1 of ANSI N14.6 should be based on the combined maximum static and dynamic loads that could be imparted on the handling device based on characteristics of the crane which will be used. This is in lieu of the guideline in Section 3.2.1.1 of ANSI N14.6 which bases the stress design factor on only the weight (static load) of the load and of the intervening components of the special handling device."

a. Summary of License Statements and Conclusions

The Licensee stated that special lifting devices used for reactor vessel heads, reactor internals, and reactor coolant pump motors are standard lifting devices designed and supplied by Westinghouse for these specific functions.

The special lifting devices were designed such that the design stress would not exceed one-fifth of the ultimate material strength. The design, fabrication, and quality assurance requirements were defined on detailed manufacturing drawings and purchase order documents. An initial load test followed by nondestructive surface examination of critical welds was performed for the reactor vessel head and internals lift rigs. All of the tensile and shear stresses meet the ANSI design criteria.

These devices are not, however, in strict compliance with the ANSI N14.6-1978 requirements for acceptance testing, maintenance, and continuing compliance, as noted in the following exceptions:

1. All three lifting devices were initially load tested to 100%, vice 150%, followed by the appropriate nondestructive testing after site assembly and prior to initial use within the plant.
2. Annual testing per ANSI requires that either a 150% load test or dimensional, visual, and nondestructive testing be performed; it is noted that a 150% load test is impractical since these devices are located in the containment. However, plant procedures presently require that each device, its welds, and any bolted joints be visually inspected prior to use and immediately after lifting the load. In addition, a load cell is used with the reactor vessel head and internals lift rigs for continuous monitoring during all lifting and lowering.

To ensure more reliability and a higher level of confidence in the continuing compliance with ANSI N14.6-1978, the Licensee has instituted a nondestructive examination (NDE) program which will provide for inspection and NDE of all critical welds and critical parts over a normal inservice inspection interval of 10 years.

Based upon the preceding discussion, the Licensee concluded that:

1. all tensile and shear stresses meet the ANSI N14.6-1978 design criteria

2. the ANSI requirements for design, fabrication, and quality assurance are generally in agreement with those used for the devices
3. although not in strict compliance with ANSI requirements, the load tests and nondestructive tests performed following assembly demonstrates the acceptability of these devices. Present station procedures meet the intent of ANSI N14.6-1978 regarding verification of continuing compliance.

b. Evaluation

Although not in strict compliance with the criteria of ANSI N14.6-1978, it is apparent from the Licensee's response that the special lifting devices at North Anna Units 1 and 2 will provide a degree of load handling reliability consistent with that specified by this guideline. Sufficient information has been provided to verify that design margins satisfy the ANSI criteria. Further, it appears that adequate records exist that prove that the devices were assembled and fabricated in a manner which provides for a quality device. It is agreed that this proof of workmanship is sufficient to preclude a need for load tests in excess of 100% of rated load.

Lastly, the Licensee's programs for scheduled periodic maintenance and inspection appear to be adequate to demonstrate the continued reliability of these devices and are in accordance with the provisions of ANSI N14.6-1978. It is also agreed that relaxation of the frequency of NDE is acceptable based upon the limited use of these devices.

c. Conclusion

Design, proof of workmanship, and programs which assure continued reliability of special lifting devices at North Anna Units 1 and 2 are consistent with the criteria of Guideline 4.

2.1.6 Lifting Devices (Not Specially Designed) [Guideline 5, NUREG-0612, Section 5.1.1(5)]

"Lifting devices that are not specially designed should be installed and used in accordance with the guidelines of ANSI B30.9-1971, 'Slings' [12]. However, in selecting the proper sling, the load used should be the sum

of the static and maximum dynamic load. The rating identified on the sling should be in terms of the 'static load' which produces the maximum static and dynamic load. Where this restricts slings to use on only certain cranes, the slings should be clearly marked as to the cranes with which they may be used."

a. Summary of Licensee Statements and Conclusions

The North Anna maintenance procedure for the reactor containment polar crane (M.M. ADM-4.0) requires that slings comply with ANSI B30.9-1971. Evaluation of sling capacity indicates that dynamic load constitutes a small percentage of the total load imposed on the slings; therefore, the sling's ratings can be safely expressed in terms of the maximum static load only. Slings have been clearly marked to reflect their loading capacities and use restrictions.

b. Evaluation

The Licensee's program for non-special lifting devices (slings) is satisfactory on the basis that slings are required to comply with ANSI B30.9-1971. Further information has been provided by the Licensee which indicates that dynamic loads are a reasonably small percentage of the static load. Therefore, based upon the Licensee findings, dynamic load considerations may be disregarded.

c. Conclusion

Selection and use of slings at North Anna Units 1 and 2 is consistent with Guideline 5.

2.1.7 Cranes (Inspection, Testing, and Maintenance) [Guideline 6, NUREG-0612, Section 5.1.1(6)]

"The crane should be inspected, tested, and maintained in accordance with Chapter 2-2 of ANSI B30.2-1976, 'Overhead and Gantry Cranes,' with the exception that tests and inspections should be performed prior to use where it is not practical to meet the frequencies of ANSI B30.2 for periodic inspection and test, or where frequency of crane use is less than the specified inspection and test frequency (e.g., the polar crane inside a PWR containment may only be used every 12 to 18 months during

refueling operations, and is generally not accessible during power operation. ANSI B30.2, however, calls for certain inspections to be performed daily or monthly. For such cranes having limited usage, the inspections, test, and maintenance should be performed prior to their use).

a. Summary of Licensee Statements and Conclusions

ANSI B30.2-1976 has been invoked by the Licensee in the following maintenance procedures for Group I cranes at the North Anna Power Station:

MMP-P-MA-1	"Reactor Containment Cranes and Associated Lifting Equipment"
MMP-P-MH-3	"Frequent and Periodic Inspection of Bridge Cranes"
MMP-P-MH-5	"Frequent and Periodic Inspection of Gantry Cranes"
M.D. ADM-9.1	"Control of Heavy Loads in Reactor Containment-291 Fuel."

b. Evaluation

Based upon the fact that the Licensee has not taken exception with implementing Chapter 2-2 of ANSI B30.2-1976, procedures in use satisfy ANSI requirements for crane inspection, testing, and maintenance.

c. Conclusion

Crane inspection, testing, and maintenance programs at North Anna Units 1 and 2 are consistent with Guideline 6.

2.1.8 Crane Design [Guideline 7, NUREG-0612, Section 5.1.1(7)]

"The crane should be designed to meet the applicable criteria and guidelines of Chapter 2-1 of ANSI B30.2-1976, 'Overhead and Gantry Cranes,' and of CMAA-70, 'Specifications for Electric Overhead Traveling Cranes' [13]. An alternative to a specification in ANSI B30.2 or CMAA-70 may be accepted in lieu of specific compliance if the intent of the specification is satisfied."

a. Summary of Licensee Statements and Conclusions

The Licensee stated:

"The reactor containment polar crane and turbine room cranes are designed to the Electric Overhead Crane Institute Specification 61 - "Specifications for Electric Overhead Traveling Cranes" (EOCI-61) that was in effect at the time of manufacture of cranes. These specifications are the predecessors of CMAA-70 now in effect and are similar.

The primary difference between the EOICI-61 and CMAA-70 specifications are changes in the design of bridge girders. These changes reflected in the CMAA-70 specification allow the use of higher allowable stresses for the better grade materials available today and also provide new design formulas. These changes are a result of advancements in the state of the art of girder structural design, allowing the use of lighter, more efficient structures and do not increase the conservatism in the design from the older EOICI-61 specification.

The North Anna cranes, hoists, and trolleys are designed in accordance with the requirements of ANSI B30.2-1967, which was the applicable edition for design requirements when the cranes were manufactured."

The Licensee verified that the polar cranes meet all of the 14 revised requirements of CMAA-70.

b. Evaluation

The cranes at North Anna Units 1 and 2 satisfy, to a considerable extent, the criteria of Guideline 7 on the basis that the cranes were procured to the accepted industrial standard at the time of manufacture; in addition, the Licensee has verified that the current design is in compliance with the more restrictive requirements of CMAA-70.

c. Conclusion and Recommendation

Design of cranes at the North Anna Power Station is consistent with the criteria of Guideline 7 on the basis of compliance with EOICI-61 criteria and the Licensee's verification that crane design is compatible with revised CMAA-70 requirements.

2.2 INTERIM PROTECTION MEASURES

The NRC has established six interim protection measures to be implemented at operating nuclear power plants to provide reasonable assurance that no heavy loads will be handled over the spent fuel pool and that measures exist to reduce the potential for accidental load drops to impact on fuel in the core or spent fuel pool. Four of the six interim measures of the report consist of general Guideline 1, Safe Load Paths; Guideline 2, Load Handling Procedures; Guideline 3, Crane Operator Training; and Guideline 6, Cranes (Inspection, Testing, and Maintenance). The two remaining interim measures cover the following criteria:

1. Heavy load technical specifications
2. Special review for heavy loads handled over the core.

The status of the Licensee's implementation and the evaluation of these interim protection measures are summarized in the succeeding paragraphs of this section.

2.2.1 Technical Specifications [Interim Protection Measure 1, NUREG-0612, Section 5.3]

"Licenses for all operating reactors not having a single-failure-proof overhead crane in the fuel storage pool area should be revised to include a specification comparable to Standard Technical Specification 3.9.7, 'Crane Travel - Spent Fuel Storage Pool Building,' for PWR's and Standard Technical Specification 3.9.6.2, 'Crane Travel,' for BWR's, to prohibit handling of heavy loads over fuel in the storage pool until implementation of measures which satisfy the guidelines of Section 5.1."

a. Evaluation

Review of North Anna Power Station's Technical Specifications reveals that Technical Specification 3.9.7 for both Units 1 and 2 prohibits loads in excess of 2500 lb from travel over irradiated fuel in the spent fuel pool.

b. Conclusion

North Anna Power Station complies with this interim protection measure.

2.2.2 Administrative Controls [Interim Protection Measures 2, 3, 4, and 5, NUREG-0612, Sections 5.3(2)-5.3(5)]

"Procedural or administrative measures [including safe load paths, load handling procedures, crane operator training, and crane inspection]... can be accomplished in a short time period and need not be delayed for completion of evaluations and modifications to satisfy the guidelines of Section 5.1 of [NUREG-0612]."

a. Summary of Licensee Statements and Conclusions

Summaries of Licensee statements and conclusions are contained in discussions of the respective general guidelines in Sections 2.1.2, 2.1.3, 2.1.4, and 2.1.7.

b. Evaluations, Conclusions, and Recommendations

Evaluations, conclusions, and recommendations are contained in discussions of the respective general guidelines in Sections 2.1.2, 2.1.3, 2.1.4, and 2.1.7.

2.2.3 Special Reviews for Heavy Loads Over the Core [Interim Protection Measure 6, NUREG-0612, Section 5.3(1)]

"Special attention should be given to procedures, equipment, and personnel for the handling of heavy loads over the core, such as vessel internals or vessel inspection tools. This special review should include the following for these loads: (1) review of procedures for installation of rigging or lifting devices and movement of the load to assure that sufficient detail is provided and that instructions are clear and concise; (2) visual inspections of load bearing components of cranes, slings, and special lifting devices to identify flaws or deficiencies that could lead to failure of the component; (3) appropriate repair and replacement of defective components; and (4) verify that the crane operators have been properly trained and are familiar with specific procedures used in handling these loads, e.g., hand signals, conduct of operations, and content of procedures."

a. Summary of Licensee Statements and Conclusions

The Licensee stated that, prior to each refueling outage, the cranes, slings, and lifting devices are inspected and repaired or replaced in accordance with plant procedures.

In addition, a review of procedures and operator training is under evaluation. Appropriate procedures will be generated or modified as necessary to meet the requirements of the general guidelines of NUREG-0612 prior to the next refueling or movement of individual heavy loads.

b. Evaluation and Conclusion

North Anna Units 1 and 2 comply with Interim Protection Measure 6.

3. CONCLUSION

This summary is provided to consolidate the results of the evaluation contained in Section 2 concerning individual NRC staff guidelines into an overall evaluation of heavy load handling at North Anna Units 1 and 2. Overall conclusions and recommended Licensee actions, where appropriate, are provided with respect to both general provisions for load handling (NUREG-0612, Section 5.1.1) and completion of the staff recommendations for interim protection (NUREG-0612, Section 5.3).

3.1 GENERAL PROVISIONS FOR LOAD HANDLING

The NRC staff has established seven guidelines concerning provisions for handling heavy loads in the area of the reactor vessel, near stored spent fuel, or in other areas where an accidental load drop could damage equipment required for safe shutdown or decay heat removal. The intent of these guidelines is twofold. A plant conforming to these guidelines will have developed and implemented, through procedures and operator training, safe load travel paths such that, to the maximum extent practical, heavy loads are not carried over or near irradiated fuel or safe shutdown equipment. A plant conforming to these guidelines will also have provided sufficient operator training, handling system design, load handling instructions, and equipment inspection to ensure reliable operation of the handling system. As detailed in Section 2, it has been found that load handling operations at North Anna Units 1 and 2 can be expected to be conducted in a reliable manner consistent with the staff's objectives as expressed in these guidelines.

3.2 INTERIM PROTECTION MEASURES

The NRC staff has established certain measures (NUREG-0612, Section 5.3) that should be initiated to provide reasonable assurance that handling of heavy loads will be performed in a safe manner until final implementation of the general guidelines of NUREG-0612, Section 5.1, is complete. Specified measures include the implementation of a technical specification to prohibit the handling of heavy loads over fuel in the storage pool; compliance with

Guidelines 1, 2, 3, and 6 of NUREG-0612, Section 5.1.1; a review of load handling procedures and operator training; and a visual inspection program, including component repair or replacement as necessary of cranes, slings, and special lifting devices to eliminate deficiencies that could lead to component failure. Evaluation of information provided by the Licensee indicates these actions have been satisfactorily implemented at the North Anna Power Station.

4. REFERENCES

1. NUREG-0612
"Control of Heavy Loads at Nuclear Power Plants"
NRC, July 1980
2. V. Stello, Jr. (NRC)
Letter to all Licensees
Subject: Request for Additional Information on Control of Heavy Loads
Near Spent Fuel
May 17, 1978
3. NRC
Letter to VEPCO
Subject: Request for Review of Heavy Load Handling
December 22, 1980
4. R. H. Leasburg (VEPCO)
Letter to H. R. Denton (NRC)
Subject: Control of Heavy Loads
December 22, 1981
5. R. H. Leasburg (VEPCO)
Letter to H. R. Denton (NRC)
Subject: Control of Heavy Loads
March 22, 1982
6. R. H. Leasburg (VEPCO)
Letter to H. R. Denton (NRC)
Subject: NUREG-0612, Control of Heavy Loads
October 18, 1982
7. W. L. Stewart (VEPCO)
Letter to H. R. Denton (NRC)
Subject: NUREG-0612, Control of Heavy Loads
December 15, 1982
8. W. L. Stewart (VEPCO)
Letter to H. R. Denton (NRC)
Subject: Control of Heavy Loads
July 12, 1983
9. W. L. Stewart (VEPCO)
Letter to H. R. Denton (NRC)
Subject: Control of Heavy Loads
July 12, 1983

10. ANSI B30.2-1976
"Overhead and Gantry Cranes"
11. ANSI N14.6-1978
"Standard for Lifting Devices for Shipping Containers Weighing 10,000
Pounds (4500 kg) or More for Nuclear Materials"
12. ANSI B30.9-1971
"Slings"
13. CMAA-70
"Specifications for Electric Overhead Traveling Cranes"
1975