

MAY 22 1984

Docket Nos. 50-387/NPF-14
50-388/NPF-22

Pennsylvania Power & Light Company
ATTN: Mr. Bruce D. Kenyon
Vice-President
Nuclear Operations
2 North Ninth Street
Allentown, Pennsylvania 18101

Gentlemen:

Subject: Inspection 50-387/84-14; 50-388/84-16

This transmits the findings of the routine NRC inspection of Susquehanna Steam Electric Station, Units 1 and 2, by Messrs. R. H. Jacobs and L. R. Plisco on April 1 - May 7, 1984. Those findings have been discussed with Mr. D. Thompson of your staff.

This inspection noted that certain manual containment isolation valves (i.e. valves used for local leak rate testing) which are required to be locked closed, were found closed but not locked. You are required to reply to this violation in accordance with the enclosed Notice of Violation (Appendix A).

This inspection also reviewed the recurring RCIC turbine overspeed trips experienced on Unit 1 during the last year. Although you have taken conservative action to increase the surveillance frequency, increased management attention towards correction of the deficiency may be warranted.

This transmittal will be made public unless you notify this office, within 10 days of the date of this letter that you intend to request withholding of information under 10 CFR 2.790(b)(1). That notification may be made to the Supervisor, Files, Mail and Records, USNRC Region I, at (215) 337-5223.

The reply identified in Appendix A is not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL-511.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:

Richard W. Starostecki, Director
Division of Project and Resident
Programs

8406080125 840522
PDR ADOCK 05000387
G PDR

1E01
||

OFFICE	RI: DPRP	RI: DPRP	RI: DPRP	RI: DPRP		
SURNAME	Jacobs/ba	McCabe	Greenman	Starostecki		
DATE	5/14	5/14	5/16/84	5/19		

Enclosures:

1. Appendix A, Notice of Violation
2. Combined NRC Inspection Report
50-387/84-14; 50-388/84-16

cc w/encls:

Norman W. Curtis, Vice-President, Engineering and Construction - Nuclear
A. R. Sabol, Manager, Nuclear Quality Assurance
W. E. Barberich, Licensing Engineer
H. W. Keiser, Superintendent of Plant
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encls:

Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encls)
Director, DETP
DPRP Section Chief
R. Perch, NRR
E. Kelly
F. Paulitz

OFFICE ▶							
SURNAME ▶							
DATE ▶							