)时.

1) Rod to w.T. 61Ke

December 30, 1991

PRELIMINARY MOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE PNG-11-91-84

This preliminary notification constitute. EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region II staff on this date.

FACILITY: Entergy Operations, Inc.
Grand Gulf Unit 1
Docket No. 50-416
Port Gibson, MS 39150

Licensee Emergency Classification:
Notification of Unusual Event
Alert
Site Area Emergency
General Emergency
X Not Applicable

SUBJECT: UMPLANMED SHUTDOWN TO EXCEED 72-HOURS

On December 29, 1991, due to reactor recirculation pump 'B' coupling vertical and horizontal vibration phase angle readings trending up, the plant commenced a reactor shutdown. Vibration amplitudes have not significantly increased, however, the vertical and horizontal phase angle has changed approximately 70 degrees. Because of previous experience with shalt cracking, and as a matter of prudence, management decided to shut down the unit starting at 1200 (noon) 12/29/91 to replace the '3' pump shaft. The plant is expected to be at cold shutdown condition on December 30, 1991 at approximately 1600. The NRC Resident inspectors will monitor the licensee's activities on site.

The NRC resident inspectors were notified of this information at noon on December 29, 1991.

This information is current as of December 30, 1991, 0815 hours.

CONTACT: R. Wright - 841-0345

## DISTRIBUTION:

OE

One White M'land Nat'l Flint North Bank Bldg MAIL TO: DCS (Original IE 34) Regions IRM Chairman Selin Region I DOT (Transportation Only) Comm. Rogers 016 Region II Comm. Curtiss Chairman Selin 1236 ALUD Region III FAX TO: 01G /2:38 INPO /2:40 Comm. Remick NRC Ops Ctr Region IV Comm. de Planque Region V LICENSEE (Corporate) -/2:40 OGC Phillips Bldg OCA Nicholson Lane and site GPA/SLITP/PA RII Resident /2:45 ACRS EDO PM. NRR NRR L Street ASLAP NMSS

5520: 12/30/91 @ \_\_\_\_\_TO REGIONS AND HO

9201280147 911230 PDR I&E PNO-II-91-084 PDR \*\*\*\*\*\*\*

IF 34