

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

May 31, 1984

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4

Re: Catawba Nuclear Station
Docket Nos. 50-413 and 50-414

Dear Mr. Denton:

On May 21 and 22, 1984, representatives from Duke Power, Westinghouse, and BBC, Brown Boveri, Inc. met with the NRC Staff to discuss resolution of outstanding items in the area of Seismic Qualification of Equipment for Catawba Unit 1. The attached report documents the resolutions which were agreed upon during this meeting.

The following items remain open:

1. Two Westinghouse items involving analysis on the RHR pump/motor. These analyses are being performed by the pump vendor and will be available by mid-June 1984.
2. One Duke item involving the seismic qualification of the Duke built electrical isolation system for the Westinghouse reactor protection system cabinets. The documentation of this resolution will be completed before fuel load with the bolt torque verification and shimming to be completed before initial criticality.

The seismic qualification program for safety-related equipment located in Catawba Unit 1 is essentially complete. Duke Power Company herewith confirms that the Catawba Unit 1 safety-related equipment (reference FSAR Tables 3.9.3-13, 3.9.3-14 and 3.10-1) is seismically qualified in accordance with the Catawba FSAR commitments.

Very truly yours,

H. B. Tucker
Hal B. Tucker

ROS/php

Attachment

8406080237 840531
PDR ADOCK 05000413
E PDR

300
A044 11

Mr. Harold R. Denton, Director
May 31, 1984
Page 2

cc: Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

NRC Resident Inspector
Catawba Nuclear Station

Mr. Charlie Hohmayer
Department of Nuclear Energy
Building 129
Brookhaven National Laboratory
Upton, New York 11973

Mr. Robert Guild, Esq.
Attorney-at-Law
P. O. Box 12097
Charleston, South Carolina 29412

Palmetto Alliance
2135½ Devine Street
Columbia, South Carolina 29205

Mr. Jesse L. Riley
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28207