

Original concurrence to be returned to
Distribution: FBrown SS 396

JUN 01 1984

Dockets 30-19101 (50-327/328)
30-19102 (50-259/260/296)

PDR LPDRs DVassallo, ORB2
NMSS R/F RClark, ORB 2
FCAF R/F EAdamsan, LB4
LCRouse CStahl
FSturz RRawsen
PLoysen RPerlis
IE Reg II RECunningham
LA File DRChappell

Docket No. 30-19102 (50-259/260/296)
License No. 01-08165-14

Docket No. 30-19101 (50-327/328)
License No. 41-08165-14

Tennessee Valley Authority
ATTN: Mr. Hugh G. Parris
Manager of Power
500 Chestnut Street, Tower II
Chattanooga, Tennessee 37401

Gentlemen:

This is in reply to L. M. Mills letter of May 1, 1984, which informed us of TVA's intentions for temporary use of interim low-level radioactive waste storage facilities at Browns Ferry and Sequoyah Nuclear Power Plants.

The requirement for a quarterly sampling program of two control resin liners was intended to ensure long-term container integrity throughout the five-year interim storage period of the license. Clearly, TVA's interpretation of the license, to temporarily store (less than two months) resin liners without initiating a control liner monitoring program, is valid and consistent with the intent of the license.

Sincerely,

Original signed by
Leland C. Rouse

Leland C. Rouse, Chief
Advanced Fuel and Spent Fuel
Licensing Branch
Division of Fuel Cycle and
Material Safety

0A7

OFFICE	FCAF	FCAF			
SURNAME	FSturz: FIB	LCRouse	8406080270	840601	
DATE	74205	Leland C. Rouse	PDR ADDCK 05000259	PDR	
	5/21/84	01/84	X		