

MAY 31 1984

Mr. Murray R. Edelman
Vice President - Nuclear Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Dear Mr. Edelman:

Subject: Transmittal of Updated Status of Unresolved Safety Issues
in Appendix C to the Safety Evaluation Report for the Perry
Nuclear Power Plant (Units 1 and 2)

Enclosed for your information is a summary of the status of changes in the resolution of Unresolved Safety Issues contained in Appendix C to the Perry Safety Evaluation Report (NUREG-0887), which we propose to address in specific detail in the next Perry Safety Evaluation Report Supplement.

If there are any questions, please have your staff contact the Perry Project Manager, John J. Stefano.

Sincerely,

ORIGINAL SIGNED BY:

B. J. Youngblood, Chief
Licensing Branch No. 1
Division of Licensing

Enclosure: As stated

cc: See next page

DISTRIBUTION:

Docket File

NRC PDR

L PDR

NSIC

PRC System

LB#1 R/F

JStefano

MRushbrook

OELD

ACRS (16)

EJordan

NGrace

FSchroeder

KKniel

NSu

LB#1:DL

JStefano:kab

5/31/84

LB#1:DL

BJYoungblood

5/31/84

MAY 31 1984

PERRY

Mr. Murray R. Edelman
Vice President, Nuclear Group
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

cc: Jay Silberg, Esq.
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N. W.
Washington, D. C. 20006

Donald H. Hauser, Esq.
The Cleveland Electric Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

Resident Inspector's Office
U. S. Nuclear Regulatory Commission
Parmly at Center Road
Perry, Ohio 44081

U. S. Nuclear Regulatory Commission
Mr. James G. Keppler, Regional
Administrator, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Donald T. Ezzone, Esq.
Assistant Prosecuting Attorney
105 Main Street
Lake County Administration Center
Painesville, Ohio 44077

Ms. Sue Hiatt
OCRE Interim Representative
8275 Munson
Mentor, Ohio 44060

Terry J. Lodge, Esq.
618 N. Michigan Street
Suite 105
Toledo, Ohio 43624

John G. Cardinal, Esq.
Prosecuting Attorney
Ashtabula County Courthouse
Jefferson, Ohio 44047

SUMMARY OF THE STATUS CHANGES OF THE
UNRESOLVED SAFETY ISSUES IDENTIFIED IN APPENDIX C FOR PERRY

<u>Task</u>	<u>Status</u>
A-1, Water Hammer	This issue has been resolved by issuance of NUREG-0927, Rev. 1, "Evaluation of Water Hammer Occurrence in Nuclear Power Plants."
A-11, Reactor Vessel Material Toughness	This issue has been resolved by issuance of NUREG-0744, "Resolution of the Task A-11, Reactor Vessel Materials Toughness Safety Issue," Vols. I and II, Revision 1.
A-46, Seismic Qualification of Equipment in Operating Plants	The scope of Task A-46 is limited to dealing with seismic qualification of equipment in operating plants. In addition, Perry was designed on the basis of current seismic design criteria, and commitments for seismic equipment qualification are in accordance with the latest codes and standards. Therefore, the issue related to Task A-46 is not applicable for Perry.