

JUN 06 1984

Florida Power Corporation
ATTN: Mr. W. S. Wilgus
Vice President Nuclear Operations
P. O. Box 14042, M.A.C. H-2
St. Petersburg, FL 33733

Gentlemen:

SUBJECT: REPORT NO. 50-302/84-05

Thank you for your responses of April 6, and May 24, 1984, to our Notice of Violation issued on March 8, 1984, concerning activities conducted at your Crystal River facility. We have evaluated your responses and found that they meet the requirements of 10 CFR 2.201. We will examine the implementation of your corrective actions during future inspections.

With respect to your response concerning the April 22, 1983, failure to control access to the protected area, 10 CFR 73.71(c) clearly categorizes the event as a "Moderate loss of physical security effectiveness" and, as such, is reportable to the NRC. To emphasize our concern over this access control failure, your attention is directed to our Enforcement Policy revised on March 8, 1984, which now classifies such an event as a Severity Level III violation in the absence of mitigating circumstances. I would expect your staff to be made aware of these matters.

We appreciate your cooperation in this matter.

Sincerely,

James P. O'Reilly
Regional Administrator

cc: E. M. Howard, Director
Site Nuclear Operations
P. F. McKee, Nuclear Plant Manager
G. R. Westafer, Manager
Nuclear Operations Licensing
and Fuel Management

bcc: IE File
NMSS/SGPL
NRR/DL/SSF-B
Document Control Desk, 016
NRC Resident Inspector
State of Florida

RII
WJTobin:bhg
6/4/84

RII
DMcGuire
6/4/84

RII
KBarr
6/4/84

RII
JMPuckett
6/4/84

RII
JRStohr
6/4/84

RII
VPanciera
6/5/84

RII
HCDance
6/5/84

RII
RCLewis
6/5/84

B406110201 B40606
PDR ADOCK 05000302
PDR

IE-04
//