

January 21, 1992

Docket Nos. 50-254
and 50-265

Mr. Thomas J. Kovach
Nuclear Licensing Manager
Commonwealth Edison Company - Suite 300
OPUS West III
1400 OPUS Place
Downers Grove, Illinois 60515

Dear M. J. Kovach:

SUBJECT: OPERABILITY DETERMINATION (TME) ASSOCIATED WITH QUAD CITIES
STATION 250V DC BATTERY (NOS. M82526 AND M82527)

Your letter of December 20, 1991, providing a recent 250V DC battery load profile, an operability determination, and commitments associated with upgrading the 250V DC battery system. I have reviewed the information contained in this letter and has no objection to proceeding as described. Implementation of all the commitments identified in Attachment A to the December 20, 1991, letter should result in a significant increase in the reliability and reserve capacity of the 250V DC battery systems at Quad Cities Station. It is requested that you provide written notification of any scheduler changes associated with these commitments and when all the modifications have been fully implemented.

Sincerely,

Original Signed By:

Leonard N. Olshan, Project Manager
Project Directorate III-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

<u>Docket File</u>	NRC & Local PDRs	BBoger	JZwolinski
RBarrv.tt	CMoore	LOlshan	OGC (15B18)
EJordan MNBB 3701	FRosa 7E4	ACRS(10) P315	PDIII-2 r/f
PDIII-2 gray	BClayton, RIII		

OFC	: LAY/PDIII-2	: PM/PDIII-2	: SELB	: D/PDIII-2
NAME	: CMoore	: LOlshan:rc	: FRosa	: RBarrvett
DATE	: 1/14/92	: 1/14/92	: 1/21/92	: 1/21/92

OFFICIAL RECORD COPY

Document Name: KOVACH M82526/527

9201290103 920121
PDR ADOCK 05000254
P PDR

NRC FILE CENTER COPY

DF01 / 10

January 21, 1992

Docket Nos. 50-254
and 50-265

Mr. Thomas J. Kovach
Nuclear Licensing Manager
Commonwealth Edison Company - Suite 300
OPUS West III
1400 OPUS Place
Downers Grove, Illinois 60515

Dear Mr. Kovach:

SUBJECT: OPERABILITY DETERMINATION AND COMMITMENTS ASSOCIATED WITH QUAD CITIES
STATION 250V DC BATTERY SYSTEM (TAC NOS. M82526 AND M82527)

Your letter of December 20, 1991, presented the most recent 250V DC battery load profile, an operability determination, and commitments associated with upgrading the 250V DC battery system. The staff has reviewed the information contained in this letter and has no objection to your proceeding as described. Implementation of all the commitments identified in Attachment A to the December 20, 1991, letter should result in a significant increase in the reliability and reserve capacity of the 250V DC battery systems at Quad Cities Station. It is requested that you provide written notification of any scheduler changes associated with these commitments and when all the modifications have been fully implemented.

Sincerely,

Original Signed By:

Leonard N. Olshan, Project Manager
Project Directorate III-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File	NRC & Local PDRs	BBoger	JZwolinski
RBarrett	CMoore	LOlshan	OGC (15B18)
EJordan MNBB 3701	FRosa 7E4	ACRS(10) P315	PDIII-2 r/f
PDIII-2 gray	BClayton, RIII		

OFC	:LAX/DPDIII-2	:PM/DPDIII-2	:SELB <i>FR</i>	:D/DPDIII-2	:
NAME	: <i>CMoore</i>	:LOlshan:rc	:FRosa	:RBarrett	:
DATE	:1/14/92	:1/14/92	:1/14/92	:1/14/92	:

OFFICIAL RECORD COPY
Document Name: KOVACH M82526/527

Mr. Thomas J. Kovach
Commonwealth Edison Company

Quad Cities Nuclear Power Station
Unit Nos. 1 and 2

cc:

Mr. Stephen E. Shelton
Vice President
Iowa-Illinois Gas and
Electric Company
P. O. Box 4350
Davenport, Iowa 52808

Michael I. Miller, Esq.
Sidley and Austin
One First National Plaza
Chicago, Illinois 60690

Mr. Richard Bax
Station Manager
Quad Cities Nuclear Power Station
22710 206th Avenue North
Cordova, Illinois 61242

Resident Inspector
U. S. Nuclear Regulatory Commission
22712 206th Avenue North
Cordova, Illinois 61242

Chairman
Rock Island County Board
of Supervisors
1504 3rd Avenue
Rock Island County Office Bldg.
Rock Island, Illinois 61201

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road, Bldg. #4
Glen Ellyn, Illinois 60137

Robert Neumann
Office of Public Counsel
State of Illinois Center
100 W. Randolph
Suite 11-300
Chicago, Illinois 60601