



Callaway Plant

January 23, 1992

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

ULNRC-2548  
TAC No. M79971

Gentlemen:


CALLAWAY PLANT  
DOCKET NUMBER 50-483  
REVISION TO TECHNICAL SPECIFICATION 3.4.6.2  
REACTOR COOLANT SYSTEM PRESSURE ISOLATION VALVES

- References: 1) ULNRC-2377 dated March 15, 1991  
2) ULNRC-2463 dated August 15, 1991

Reference 1 transmitted an application for amendment to Facility Operating License Number NPF-30 for Callaway Plant. This amendment application requested a revision to Technical Specification 3/4.4.6 and associated Bases to change the allowed leakage limit for reactor coolant system pressure isolation valves. Reference 2 provided additional information in support of this amendment.

The attachment to this letter supplements the discussion provided in the amendment request. If you have any additional questions, please contact us.

Very truly yours,

  
Alan C. Passwater

ACP/lrj

Attachments

9201290141 920123  
PDR ADOCK 05000483  
P PDR

*Handwritten initials/signature*

STATE OF MISSOURI )  
                              )       S S  
CALLAWAY COUNTY    )

Alan C. Passwater, of lawful age, being first duly sworn upon oath says that he is Manager, Licensing and Fuels (Nuclear) for Union Electric Company; that he has read the foregoing document and knows the content thereof; that he has executed the same for and on behalf of said company with full power and authority to do so; and that the facts therein stated are true and correct to the best of his knowledge, information and belief.

By Alan C. Passwater  
Alan C. Passwater  
Manager, Licensing & Fuels  
Nuclear

SUBSCRIBED and sworn to before me this 23<sup>rd</sup> day of January, 1992.

Timmy J. Lamons  
TIMMY J. LAMONS  
My commission expires: Oct 5, 1994

ULNRC-2548

cc: T. A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Dr. J. O. Cermak  
CFA, Inc.  
18225-A Flower Hill Way  
Gaithersburg, MD 20879-5334

R. C. Knop  
Chief, Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Bruce Bartlett  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
RR#1  
Stedman, Missouri 65077

L. R. Wharton (2)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop 13E21  
11555 Rockville Pike  
Rockville, MD 20852

Manager, Electric Department  
Missouri Public Service Commission  
P. O. Box 360  
Jefferson City, MO 65102

Ron Kucera  
Department of Natural Resources  
P. O. Box 176  
Jefferson City, MO 65102

ATTACHMENT 1

The following discussion is submitted in support of an amendment request to Technical Specification 3.4.6.2.

- Item 1      Union Electric will commit to the leakage trending provisions of ASME Section XI Subsection IWV-3427(b), Summer 1980, Winter 1981 Addendum. In addition, the Callaway Pump and Valve Program with respect to Relief Request #V05 will be revised to reflect this change, as appropriate.
  
- Item 2      Union Electric is revising proposed Technical Specification 3.4.6.2.f to limit leakage for valves which are 2 inch or smaller to 0.5 gpm per nominal inch of valve size. This change subjects all the valves addressed in this specification to the same requirements. Revised Technical Specification pages which reflect this change are attached.