

JUN 5 1984

DMB 016

Docket Nos. 50-277/278

Mr. Edward G. Bauer, Jr.
Vice President and General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

SUBJECT: RESPONSE TO NUREG-0737, ITEM II.K.3.18,
ADS MODIFICATION

Re: Peach Bottom Atomic Station, Units 2 and 3

By letter of June 3, 1983, the NRC requested Philadelphia Electric Company to comply with the requirements of NUREG-0737, Item II.K.3.18 by choosing between two alternative modifications that the staff found acceptable.

As a result, Philadelphia Electric Company submitted a letter dated July 15, 1983, that commits the utility to modifying the ADS logic by eliminating the high drywell pressure permissive and adding a manual inhibit switch. This modification was found acceptable by the staff in its Safety Evaluation enclosed in its letter of June 3, 1983.

Based on your July 15, 1983 commitment, we consider this issue to be closed.

Sincerely,

George W. Rivenbark, Acting Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page

~~DISTRIBUTION~~
~~Docket File~~
NRC PDR
Local PDR

ORB#4 Rdg
DEisenhut
OELD
RIngram

GGears
RBevan
ELJordan
JNGrace

ACRS (10)
Gray File

DL:ORB#4
RIngram:ajs
06/1/84

DL:ORB#4
GGears
06/1/84

DL:ORB#2
RBevan RBB
06/5/84

DL:ORB#4
GRivenbark
06/5/84

B406110429 B40605
PDR ADOCK 05000277
P PDR

Philadelphia Electric Company

cc w/enclosure(s):

Eugene J. Bradley
Philadelphia Electric Company
Assistant General Counsel
2301 Market Street
Philadelphia, Pennsylvania 19101

Troy B. Conner, Jr.
1747 Pennsylvania Avenue, N.W.
Washington, D. C. 20006

Thomas A. Deming, Esq.
Assistant Attorney General
Department of Natural Resources
Annapolis, Maryland 21401

Philadelphia Electric Company
ATTN: Mr. R. Fleishmann
Peach Bottom Atomic
Power Station
Delta, Pennsylvania 17314

Albert R. Steel, Chairman
Board of Supervisors
Peach Bottom Township
R. D. #1
Delta, Pennsylvania 17314

Allen R. Blough
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Peach Bottom Atomic Power Station
P. O. Box 399
Delta, Pennsylvania 17314

Mr. Thomas E. Murley, Regional Administrator
U. S. Nuclear Regulatory Commission, Region I
Office of Inspection and Enforcement
631 Park Avenue
King of Prussia, Pennsylvania 19406

Regional Radiation Representative
EPA Region III
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

M. J. Cooney, Superintendent
Generation Division - Nuclear
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Mr. R. A. Heiss, Coordinator
Pennsylvania State Clearinghouse
Governor's Office of State Planning
and Development
P. O. Box 1323
Harrisburg, Pennsylvania 17120

Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Department of
Environmental Resources
P. O. Box 2063
Harrisburg, Pennsylvania 17120



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 5, 1984

Docket Nos. 50-277/278

Mr. Edward G. Bauer, Jr.
Vice President and General Counsel
Philadelphia Electric Company
2301 Market Street
Philadelphia, Pennsylvania 19101

Dear Mr. Bauer:

SUBJECT: RESPONSE TO NUREG-0737, ITEM II.K.3.18,
ADS MODIFICATION

Re: Peach Bottom Atomic Station, Units 2 and 3

By letter of June 3, 1983, the NRC requested Philadelphia Electric Company to comply with the requirements of NUREG-0737, Item II.K.3.18 by choosing between two alternative modifications that the staff found acceptable.

As a result, Philadelphia Electric Company submitted a letter dated July 15, 1983, that commits the utility to modifying the ADS logic by eliminating the high drywell pressure permissive and adding a manual inhibit switch. This modification was found acceptable by the staff in its Safety Evaluation enclosed in its letter of June 3, 1983.

Based on your July 15, 1983 commitment, we consider this issue to be closed.

Sincerely,

A handwritten signature in cursive script that reads "George W. Rivenbark".

George W. Rivenbark, Acting Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page