

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) LaSalle County Station Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 7 4	PAGE (3) 1 OF 0 2
--	--------------------------------------	----------------------

TITLE (4)
Loss of Positive Control on High Radiation Gate

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
0 5	2 1	8 4	8 4	0 2 2	0 0	0 6	0 7	8 4	N/A		0 5 0 0 0
									N/A		0 5 0 0 0

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

OPERATING MODE (9) 1	20.402(b)	20.406(e)	50.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10) 0 3 7	20.406(a)(1)(i)	50.36(a)(1)	50.73(a)(2)(v)	73.71(e)
	20.406(a)(1)(ii)	50.36(a)(2)	50.73(a)(2)(vii)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)
	20.406(a)(1)(iii)	X 50.73(a)(2)(i)	50.73(a)(2)(viii)(A)	
	20.406(a)(1)(iv)	50.73(a)(2)(ii)	50.73(a)(2)(viii)(B)	
	20.406(a)(1)(v)	50.73(a)(2)(iii)	50.73(a)(2)(ix)	

LICENSEE CONTACT FOR THIS LER (12)

NAME William Eisele, Health Physicist, Extension 666	TELEPHONE NUMBER
	AREA CODE: 8 1 5 3 5 7 - 6 7 6 1

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPROS
A	Z Z	Z 9 9 9	Z 9 9 9	N					

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

Door 213 controlling access to area behind the Unit 2 Turbine Shield Walls (High Radiation Area) was found to be open. This door is the Southeast entrance wire mesh gate. This loss of positive control is contrary to Technical Specification 6.1.1. and 10 CFR 20.203. The gate was secured at 1724 hours at the time of discovery.

B405120011 B40607
PDR ADOCK 05000374
S PDR

IE22

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) LaSalle County Station Unit 2	DOCKET NUMBER (2) 0 5 0 0 0 3 7 4 8 4	EVENT NUMBER (8)			PAGE (3)	
		YEAR	SEQUENTIAL NUMBER	REVISION NUMBER		
		84	022	010	02	OF 02

TEXT (if more space is required, use additional NRC Form 366A's) (17)

I. EVENT DESCRIPTION

On May 21, 1984, at 1724 hours, while conducting plant rounds, a Health Physicist found Door 213 to be open. Door 213 is a wire mesh gate, and is the southeast entrance to the area behind the Unit 2 Turbine Shield Walls. The area behind these walls was posted as a High Radiation Area at the time of the event. During this time period, Unit 2 was at 37% power. This loss of positive control over access into this High Radiation Area is contrary to Technical Specification 6.1.1. and 10 CFR 20.203.

II. CAUSE

The cause of this event is personnel error. Two Maintenance Mechanics opened the gate to carry lumber into the Unit 2 Turbine area at 1715 hours. Neither individual apparently ensured that the gate closed and locked after passing through the entrance.

III. PROBABLE CONSEQUENCES OF THE OCCURRENCE

The door was only open for 9 minutes without positive control. To date, no individual at LaSalle County Station has received a whole body or extremity dose equivalent in excess of the regulatory limits specified in 10 CFR 20.101 as a result of this occurrence. The Direct Reading Dosimeter Log indicates that the highest dose equivalent recorded for the day in question was 44 mrem, which is less than the allowable daily administrative limit of 50 mrem. The impact of this event is therefore considered to be minimal in terms of dose equivalent to station personnel.

IV. CORRECTIVE ACTION

When the door was found to be open, it was promptly closed and secured. Security was contacted to determine what individuals had passed through the door. It was determined that High Radiation Key Card 9002 had been punched into the card reader controlling access through Door 213. This key card was traced to the two Maintenance Mechanics discussed previously.

V. PREVIOUS OCCURRENCES

While there have been previous unsecured high radiation doors, the only LER was 373/84-25-00.

VI. NAME AND TELEPHONE NUMBER OF PREPARER

W.F. Eisele, (815)357-6761, Extension 666.



Commonwealth Edison
LaSalle County Nuclear Station
Rural Route #1, Box 220
Marseilles, Illinois 61341
Telephone 815/357-6761

June 7, 1984

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Dear Sir:

Reportable Occurrence Report #84-022-00, Docket #050-374 is being submitted to your office in accordance with 10CFR 50.73.

G.J. Diederich
Superintendent
LaSalle County Station

GJD/MLD/ph

Enclosure

cc: NRC, Regional Director
INPO-Records Center
File/NRC

IEZZ
11