

Log # TXX-92030 File # 10010 Ref. # 10CFR2.102

TUFLECTRIC

January 24, 1992

William J. Cahill, Jr. Group Vice President

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D. C. 20555

SUBJECT:

COMANCHE PEAK STEAM ELECTRIC STATION (CPSES) UNIT 1

DOCKET NO. 50-445

REQUEST FOR ADDITIONAL INFORMATION FOR THE FIRST 10-YEAR INTERVAL UNIT 1 INSERVICE INSPECTION (ISI) PROGRAM PLAN

Gentlemen:

TU Electric has assembled the information requested by the NRC staff and EG&G Idaho during a teleconference on October 4, 1991. The information requested is enclosed. The information includes:

- Enclosure (1) -The Augmented Inservice Inspection (ISI) Plan, TU Electric, Comanche Peak Steam Electric Station. Revision 0:
- Enclosure (2) CPSES/FSAR pages 1A(N)-75 and 1A(N)-76 dated July 31, 1937, which describes the CPSES commitment with respect to compliance with U.S. NRC Regulatory Guide 1.150;
- Enclosure (3) Westinghouse Nuclear Service Division Technical Bulletin NSD-TB-'5-1 dated 01/31/75 concerning the Reactor Coolant Pump Thermal Barrier.
- TU Electric Inservice Inspection Boundary Diagram Enclosure (4) for the Component Cooling Water System, Sheets 11 and 12.

The Augmented ISI Plan is maintained and updated on site and the latest approved revision is always available for NRC audit or inspection.

EG&G Idaho asked if the component cooling water piping, designed for reactor coolant pressure, is included in relief request D-1. Our response is that the relief request D-1 is for the reactor coolant pump thermal barrier and does not apply to the component cooling water system piping which is attached (flanged) to the thermal barrier. Therefore the Component Cooling Water piping will be tested as described in the ISI Program Plan.

190004

460 N. Olive Street L.B. 81 Dallas, Texas 75201

TXX-92030 Page 2 of 2 Should you need any additional information concerning the ASME Section XI ISI Program Plan, please let us know.

William J. Cahill, Jr.

By: Boge & Walker

Manager of Nuclear Licensing

CEJ/gj Enclosures

c: Mr. R. D. Martin, Region IV (clo) Resident Inspectors CPSES (2 clo) Mr. Boyd Brown EG&G Idaho (w/enclosures) Mr. T. A. Bergman (w/enclosure 1)