

AUGMENTED INSERVICE
INSPECTION PLAN

TU ELECTRIC
COMANCHE PEAK STEAM ELECTRIC STATION

Revision 0

Prepared: Dick Zell 10/11/90
Approved: Mrs. Neva L. Hall 10/12/90

AUGMENTED INSERVICE INSPECTION PLAN

The purpose of this document is to identify and describe various regulatory and CPSES commitments involving the performance of periodic non-destructive examinations (NDE) other than those addressed in ASME Section XI (i.e., augmented inservice inspection). A separate section is provided for each major activity. Within each section the following information is provided:

- a. Governing Document
- b. Exam Items & Boundaries
- c. NDE Method and Schedule
- d. Acceptance Criteria
- e. Special Reports

NOTE: Where ASME Section XI is used in this document, the Edition and Addenda shall be as referenced in the CPSES Unit 1 Inservice Inspection Plan.

TABLE OF CONTENTS

<u>SECTION</u>		<u>PAGES</u>
1	REACTOR COOLANT PUMP FLYWHEELS	2
2	SAFETY INJECTION PUMP SHROUD	2
3	PENETRATION SEALS	1
4	FLUX THIMBLE TUBES	2
5	MAIN & STEAM AND FEEDWATER BREAK EXCLUSION PIPING EXAMINATION TABLES	1 29

REACTOR COOLANT PUMP
FLYWHEELS

Each reactor coolant pump flywheel shall be subject to the examinations described in Section C.4.b. of Regulatory Guide 1.14, Revision 1, August 1975 (Ref. FSAR R123.8 and Tech. Spec. 4.4.10). These examinations shall consist of an in-place ultrasonic examination of the areas of higher stress concentration at the bore and keyway at approximately 3-year periods. Additionally, the exposed surfaces of each flywheel shall be subject to a liquid penetrant examination along with a complete ultrasonic examination at approximately 10-year intervals. Examination procedures and personnel shall be in accordance with IWA-2200 of Section XI to the extent practical.

The schedule for examinations shall be coincident with the inservice inspection periods and intervals described in ASME Section XI.

The acceptance limit for flaw size based upon the maximum design overspeed is 1.15 in. (Ref. WCAP-8163). All flaws detected shall be recorded for evaluation and monitored for growth rate.

No special reports are required for this activity unless examination and evaluation indicate that the 1.15 in. flaw size limit has been or will be exceeded during the service life of the flywheel. Should this occur the NRC shall be notified (Ref. Reg. Guide 1.14 c.4.b.(5)). Records of the examinations shall be maintained with the applicable work order.

Summary Discussion

- a. Governing Document - Regulatory Guide 1.14 Rev. 1.
- b. Exam Items and Boundaries - Each reactor coolant pump flywheel.
- c. NDE Method and Schedule - An in-place ultrasonic examination of the bore and keyway at 3-year intervals and a liquid penetrant examination of exposed surfaces and a complete ultrasonic examination at 10-year intervals.
- d. Acceptance Criteria - No flaws greater than 1.15 in.
- e. Special Reports - The NRC shall be notified should the maximum flaw size be exceeded, or expect to be exceeded, during the service life.

AISI PLAN
R.C. PUMP FLYWHEEL SECTION

TAG #	EXAM	INTERVAL (10-YEAR) PERIOD (40 MONTH)	1	1	2	3	1	2	2	3	1	3	2	3	1	4	2	3
			1	2	3	1	2	2	3	1	3	2	3	1	4	2	3	
TBX-RCPGPC-01	UT OF BORE & KEYWAY		X	X			X	X			X	X			X	X		
	PT EXPOSED SURFACES				X				X				X				X	
	UT COMPLETE VOLUME				X				X				X					X
TBX-RCPGPC-02	UT OF BORE & KEYWAY		X	X			X	X			X	X			X	X		
	PT EXPOSED SURFACES				X			X				X			X			X
	UT COMPLETE VOLUME				X			X				X			X			X
TBX-RCPGPC-03	UT OF BORE & KEYWAY		X	X			X	X			X	X			X	X		
	PT EXPOSED SURFACES				X			X				X			X			X
	UT COMPLETE VOLUME				X			X				X			X			X
TBX-RCPGPC-04	UT OF BORE & KEYWAY		X	X			X	X			X	X			X	X		
	PT EXPOSED SURFACES				X			X				X			X			X
	UT COMPLETE VOLUME				X			X				X			X			X

SAFETY INJECTION PUMP SHROUD

Visible linear indications on the shroud that separates and supports the diffuser vanes and return guide vanes have been found on the type pump utilized as the safety injection pump at Comanche Peak. These indications exceed the designer-permitted 1/16 in. maximum. The pump supplier (Pacific Pumps) has evaluated the significance of these indications and determined they have no adverse affects upon the operability of the pumps (Ref. NUREG-0797 Supplement 12).

Pacific Pumps has proposed a field inspection program which is prudent to implement. This program has been supplemented by the NRC and is described in NUREG-0797 Supplement 12.

The program requires a visual and surface examination of the shroud section of the intermediate cover during normal or emergency maintenance at approximately 10-year intervals (pump disassembly solely for this examination is not required). A log of all indications is to be maintained, with indications having a depth greater than 1.0 in. in the radial direction to be reported to Pacific Pumps.

Summary Discussion

- a. Governing Document - Supplemental Safety Evaluation Report 12.
- b. Exam Items and Boundaries - Shroud section of the safety injection pumps intermediate cover.
- c. NDE Method and Schedule - Visual and surface examination during normal or emergency maintenance at approximately 10-year intervals.
- d. Acceptance Criteria - All indications shall be recorded with evaluation being on a case-by-case basis.
- e. Special Reports - All indications exceeding 1.0 in. in the radial direction shall be reported to Pacific Pumps.

AISI PLAN
SI PUMP SHROUD SECTION

TAG #	INTERVAL				INDICATION NOTED?
	1ST	2ND	3RD	4TH	
TBX-SIAPSI-01					
TBX-SIAPSI-02					

NOTE: EXAM DATE TO BE INPUT UNDER APPROPRIATE 10-YEAR INTERVAL.

FLUX THIMBLE TUBES

Westinghouse reactors containing bottom mounted instrumentation (BMI) flux thimble tubes have experienced wear due to flow induced vibration in the reactor vessel. These thimble tubes provide a pathway for the neutron flux detectors and extend from the seal table into the fuel assembly area. These tubes are closed within the vessel but open at the seal table. Therefore, these tubes constitute a portion of the reactor coolant system pressure boundary.

In response to this issue, the NRC issued Information Notice 87-44 (9/87), with Supplement (3/88), and Bulletin 88-09 (7/88). Bulletin 88-09 requested an inspection program to monitor thimble tube performance be implemented with the program to include acceptance criterion, inspection methodology and frequency. Letter TXX-89781 provides a response to this bulletin and describes the intention of TU Electric to comply with the bulletins requirements.

The augmented inservice inspection shall include a full length examination, within the limitations of probe travel, of all 58 thimble tubes using standard eddy current testing (ET) techniques. Supplementary techniques or methods may be used for further evaluation. These examinations shall be conducted during the first refueling outage with subsequent examinations to be determined by the results obtained during the first examination.

Acceptance criteria for this activity is as follows:

- | | |
|------------------|--|
| $W \leq 20$ | : No action required |
| $20 < W \leq 59$ | : Evaluate repositioning of thimble tube |
| $59 < W$ | : Cap thimble tube location |

Where W is the percent of wall loss linearly extrapolated to the end of the next fuel cycle.

$$W = \frac{\text{current \% wall loss}}{\# \text{ of previous fuel cycles}}$$

In accordance with TXX-89781 a special report shall be issued to the NRC within thirty days of completion of all thimble tube examinations conducted during an outage. Each report shall describe the tubes examined and the results, as a minimum.

Summary Discussion:

- a. Governing Document - NRC Bulletin 88-09, CPSES-9006199.
- b. Exam Items and Boundaries - All 58 thimble tubes to the extent possible of the full length.
- c. NDE Method and Schedule - ET during the first outage, with subsequent examinations determined by the results of the first examination.
- d. Acceptance Criteria - See above discussion.
- e. Special Reports - A special report will be issued to the NRC within 30 days of completion of each thimble tube inspection.

<u>TUBE ID</u>	<u>LAST EXAM DATE</u>	<u>W</u>	<u>COMMENTS</u>
A-9			
A-11			
B-3			
B-6			
B-8			
B-13			
C-5			
C-7			
C-8			
D-3			
D-8			
D-10			
D-12			
D-14			
E-5			
E-9			
E-11			
F-1			
F-3			
F-7			
F-8			
F-14			
G-5			
G-9			
G-12			
H-2			
H-3			
H-4			
H-6			
H-11			
H-13			
H-15			
J-1			
J-7			
J-8			
J-10			
J-14			
K-2			
K-6			
K-12			
L-5			
L-8			
L-10			
L-11			
L-13			
L-15			
M-7			
N-2			
N-4			
N-6			
N-8			
N-13			
N-14			
P-4			
P-9			
R-6			
R-8			
R-11			

MAIN STEAM AND FEEDWATER BREAK
EXCLUSION PIPING

Main Steam and Feedwater piping located in the safeguards building which has been designated as "break exclusion piping" in FSAR Section 3.6.B, is to be examined in accordance with Auxiliary Systems Branch 3-1 (Ref. FSAR 6.6.8). This shall consist of an ultrasonic examination, to the extent practical, of all circumferential and longitudinal piping welds, except as may be exempted by ASME Section XI. ASME Section XI allows exemption from examination for piping 4" and less.

The augmented inservice inspection shall include all welds and portions thereof which meet the above criteria but which are not selected for examination as delineated in the ASME Section XI Inservice Inspection Plan. These examinations shall be distributed such that each weld or portion thereof is examined once during each 10-year inservice inspection interval.

Examination procedures and personnel shall be in accordance with the rules of ASME Section XI.

No special reports are required for this activity. Records of the examinations shall be maintained with the applicable work order.

Results of these examinations shall be evaluated against the acceptance criteria provided in ASME Section XI, IWC-3000.

Summary Discussion

- a. Governing Document - Auxiliary Systems Branch 3-1, FSAR 6.6.8
- b. Exam Items and Boundaries - All non-exempt circumferential and longitudinal welds in the Main Steam and Feedwater systems contained within the break exclusion zones, which are not scheduled to be examined as part of the Section XI inservice inspection program.
- c. NDE Method and Schedule - Ultrasonic examination once per 10-year interval. The specific schedule by refueling outage is attached.
- d. Acceptance Criteria - ASME Section XI, IWC-3000.
- e. Special Reports - None

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION AREA IDENTIFICATION	ITEM NO	ASME SEC. XI	CATEOY NDE	ITEM NO METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR
									FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
						1	2	3	1	2	3	

MAIN STEAM 32-MS-1-001-1303-2

107200	TBX-2-2100-16 PIPE TO PIPE R108 877SB	C-F-2 CS.51	UT	1 - - - - 2 - - - - 3 - - - - 4 - - - -	X - - - - + + + + + + + + + + + +	- - - - - - - - - - - - - - - -	88	TDLR VERIFICATION BOUNDARY. **TBX-33**
107250	TBX-2-2100-16L LONG. SEAM R108 877SB	C-F-2 CS.52	UT	1 - - - - 2 - - - - 3 - - - - 4 - - - -	X - - - - + + + + + + + + + + + +	- - - - - - - - - - - - - - - -	88	100% FROM WELD 16 TO 21, TDLR VERIFICATION BOUNDARY. **TBX-33**
107700	TBX-2-2100-21 PIPE TO PIPE R108 877SB	C-F-2 CS.51	UT	1 - - - - 2 - - - - 3 - - - - 4 - - - -	X - - - - + + + + + + + + + + + +	- - - - - - - - - - - - - - - -	88	TDLR VERIFICATION BOUNDARY. **TBX-33**
108000	TBX-2-2100-24 PIPE TO VALVE R108 877SB	C-F-2 CS.51	UT	1 - - - - 2 - - - - 3 - - - - 4 - - - -	X - - - - + + + + + + + + + + + +	- - - - - - - - - - - - - - - -	82	TDLR VERIFICATION BOUNDARY. **TBX-33**
108050	TBX-2-2100-24L LONG. SEAM R108 877SB	C-F-2 CS.52	UT	1 - - - - 2 - - - - 3 - - - - 4 - - - -	X - - - - + + + + + + + + + + + +	- - - - - - - - - - - - - - - -	88	100% FROM WELD 21 TO 24, TDLR VERIFICATION BOUNDARY. **TBX-33**

MAIN STEAM MS-25 (DRIP POT)

108100	TBX-2-2100-25 BRANCH CONNECTION R108 876SB	C-F-2 CS.51	UT	1 - - - - 2 - - - - 3 - - - - 4 - - - -	X - - - - + + + + + + + + + + + +	- - - - - - - - - - - - - - - -	88	TDLR VERIFICATION BOUNDARY. **TBX-22**
108200	TBX-2-2100-26 PIPE TO CAP R108 874SB	C-F-2 CS.51	UT	1 - - - - 2 - - - - 3 - - - - 4 - - - -	X - - - - + + + + + + + + + + + +	- - - - - - - - - - - - - - - -	82	TDLR VERIFICATION BOUNDARY. **TBX-22**

DATE: 09/19/91

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

PAGE: 2

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	EXAMINATION AREA ITEM NO.	INSPECTION INTERVAL ASME SEC. XI	PLAN STATUS						PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**	
			FIRST PERIOD			SECOND PERIOD				
			CATGY	NDE	OUTAGE	1	2	3		

MAIN STEAM 8-MS-1-257-1303-2

108300	TBX-2-2100-27	C-F-2	UT	1	-	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY.
	BRANCH CONNECTION TO PIPE	C5.51		2	-	-	-	-	-	-		
	R108 E7SSB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-17**

108400	TBX-2-2100-28	C-F-2	UT	1	-	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY.
	PIPE TO VALVE	C5.51		2	-	-	-	-	-	-		
	R108 881SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-17**

108600	TBX-2-2100-29	C-F-2	UT	1	-	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY.
	VALVE TO PIPE	C5.51		2	-	-	-	-	-	-		
	R108 883SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-17**

108700	TBX-2-2100-30	C-F-2	UT	1	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
	PIPE TO ELBOW	C5.51		2	-	-	-	-	-	-		
	R108 22088			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-17**

108800	TBX-2-2100-31	C-F-2	UT	1	-	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY.
	ELBOW TO PIPE	C5.51		2	-	-	-	-	-	-		
	R108 885SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-17**

108900	TBX-2-2100-32	C-F-2	UT	1	-	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY.
	PIPE TO VALVE	C5.51		2	-	-	-	-	-	-		
	R108 885SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-17**

MAIN STEAM 6-2003-2

109000	TBX-2-2100-33	C-F-2	UT	1	-	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY.
	BRANCH CONNECTION TO FLANGE	C5.51		2	-	-	-	-	-	-		
	R108 878SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-36**

DATE: 09/19/91

HIGH ENERGY LINE BREAK UNIT 1
 INSERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

PAGE: 3

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	EXAMINATION ITEM NO	ASME SEC. XI	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR		
			CATEGORICAL NDE			FIRST PERIOD	SECOND PERIOD	THIRD PERIOD			
			OUTAGE	1 2 3	1 2 3	1 2 3	1 2 3	1 2 3			

MAIN 1 AM 6-2003-2

109100 TBX-2-2100-34 C-F-2 UT 1 - + - - X - - - - 88 TDLR VERIFICATION BOUNDARY.
 BRANCH CONNECTION TO FLANGE C5.51 2 - + - - - - - - - -
 R108 878SB 3 - + - - - - - - - -
 4 - + - - - - - - - - **TBX-36**

109200 TBX-2-2100-35 C-F-2 UT 1 - + - - X - - - - 88 TDLR VERIFICATION BOUNDARY.
 BRANCH CONNECTION TO FLANGE C5.51 2 - + - - - - - - - -
 R108 878SB 3 - + - - - - - - - -
 4 - + - - - - - - - - **TBX-36**

109300 TBX-2-2100-36 C-F-2 UT 1 - + - - X - - - - 88 TDLR VERIFICATION BOUNDARY.
 BRANCH CONNECTION TO FLANGE C5.51 2 - + - - - - - - - -
 R108 878SB 3 - + - - - - - - - -
 4 - + - - - - - - - - **TBX-36**

MAIN STEAM 32-MS-1-001-1303-2

111000 TBX-2-2100-48 C-F-2 UI 1 - + - - X - - - - 86
 VALVE 1J MOMENT RESTRAINT C5.51 2 - + - - - - - - - -
 R108 877SB 3 - + - - - - - - - -
 4 - + - - - - - - - - **TBX-33**

FEEDWATER 18-F 1303-2

112300 TBX-2-2101-13 C-F-2 UT 1 + - - X - - - - 88 TDLR VERIFICATION BOUNDARY.
 PIPE TO PIPE C5.51 2 - + - - - - - - - -
 R100A856SB 3 - + - - - - - - - -
 4 - + - - - - - - - - **TBX-21**

112400 TBX-2-2101-14 C-F-2 UT 1 - + - X - - - - 88 TDLR VERIFICATION BOUNDARY.
 PIPE TO PIPE C5.51 2 - + - - - - - - - -
 R100A856SB 3 - + - - - - - - - -
 4 - + - - - - - - - - **TBX-21**

DATE: 09/12/91

HIGH ENERGY LINE BREAK UNIT 1
 INSERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

PAGE: 4

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	EXAMINATION ITEM NO.	INSPECTION INTERVAL ASME SEC. XI	NDE ITEM NO. METH	PLAN STATUS						PRESERVICE YEAR INSTRUCTIONS
				OUTAGE			FIRST PER100	SECOND PER100	THIRD PER100	
				1	2	3	1	2	3	

FEEDWATER 18-FW-1-036-2003-2

112500 TBX-2-2101-15 C-F-2 UT 1 - - + X - - - - - - 82 TDLR VERIFICATION BOUNDARY.
 PIPE TO VALVE CS.51 2 - - + - - - - - -
 R100AB56SB 3 - - + - - - - - -
 4 - - + - - - - - - **TBX-38**

112700 TBX-2-2101-16 C-F-2 UT 1 - - + X - - - - - - 82
 VALVE TO PIPE CS.51 2 - - + - - - - - -
 R100AB56SB 3 - - + - - - - - -
 4 - - + - - - - - - **TBX-38**

112800 TBX-2-2101-17 C-F-2 UT 1 - - + - X - - - - - - 86
 PIPE TO VALVE CS.51 2 - - + - - - - - -
 R100AB56SB 3 - - + - - - - - -
 4 - - + - - - - - - **TBX-38**

112900 TBX-2-2101-18 C-F-2 UT 1 - - + - X - - - - - - 86
 VALVE TO PIPE CS.51 2 - - + - - - - - -
 R100AB56SB 3 - - + - - - - - -
 4 - - + - - - - - - **TBX-38**

113000 TBX-2-2101-19 C-F-2 UT 1 - - + - X - - - - - - 86
 PIPE TO MOMENT RESTRAINT CS.51 2 - - + - - - - - -
 R100AB56SB 3 - - + - - - - - -
 4 - - + - - - - - - **TBX-38**

FEEDWATER 6-FW-1-091-2003-2

113200 TBX-2-2102-2 C-F-2 UT 1 - - + - X - - - - - - 88
 BRANCH CONNECTION TO PIPE CS.51 2 - - + - - - - - -
 R100AC57SB 3 - - + - - - - - -
 4 - - + - - - - - - **TBX-34**

113300 TBX-2-2102-3 C-F-2 UT 1 - - + - X - - - - - - 82
 PIPE TO VALVE CS.51 2 - - + - - - - - -
 R100AB60SB 3 - - + - - - - - -
 4 - - + - - - - - - **TBX-34**

DATE: 09/19/91

HIGH ENERGY LINE BREAK UNIT 1
 INSERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

PAGE: 5

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	EXAMINATION AREA CATEGORY	ASME SEC. XI	NDE ITEM NO. METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR
							FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
				1	2	3	1	2	3	
<u>FEEDWATER 6-FW-1-091-2003-2</u>										
13500	TBX-2-2102-4 VALVE TO PI-2 R100A861SB	C-F-2 CS.51	UT	1	-	-	X	-	-	82
				2	-	-	-	-	-	
				3	-	-	-	-	-	
				4	-	-	-	-	-	**TBX-34**
113600	TBX-2-2102-5 PIPE TO ELBOW R100A861SB	C-F-2 CS.51	UT	1	-	-	X	-	-	88
				2	-	-	-	-	-	
				3	-	-	-	-	-	
				4	-	-	-	-	-	**TBX-34**
113700	TBX-2-2102-6 ELBOW TO PIPE R100A862SB	C-F-2 CS.51	UT	1	-	-	X	-	-	88
				2	-	-	-	-	-	
				3	-	-	-	-	-	
				4	-	-	-	-	-	**TBX-34**
113800	TBX-2-2102-7 PIPE TO ELBOW R100A862SB	C-F-2 CS.51	UT	1	-	-	X	-	-	88
				2	-	-	-	-	-	
				3	-	-	-	-	-	
				4	-	-	-	-	-	**TBX-34**
113900	TBX-2-2102-8 ELBOW TO PIPE R100A862SB	C-F-2 CS.51	UT	1	-	-	X	-	-	88
				2	-	-	-	-	-	
				3	-	-	-	-	-	
				4	-	-	-	-	-	**TBX-34**
114000	TBX-2-2102-9 PIPE TO VALVE R100A862SB	C-F-2 CS.51	UT	1	-	-	X	-	-	88
				2	-	-	-	-	-	
				3	-	-	-	-	-	
				4	-	-	-	-	-	**TBX-34**
114100	TBX-2-2102-10 VALVE TO PIPE R100A862SB	C-F-2 CS.51	UT	1	-	-	X	-	-	82 TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-	
				3	-	-	-	-	-	
				4	-	-	-	-	-	**TBX-34**

DATE: 09/19/91

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

PAGE: 6

SUMMARY EXAMINATION AREA NUMBER	IDENTIFICATION	ITEM NO. /METH	ASME SEC. XI	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR	
							FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
				CAT/GY	NDE	OUTAGE	1	2	3		
<u>FEEDWATER 6-FW-1-DPS-1203-2</u>											
114200	TBX-2-2102-11 PIPE TO PIPE R100AB62SB	C-F-2 CS,51	UT	1	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
114300	TBX-2-2102-12 PIPE TO VALVE R100AB62SB	C-F-2 CS,51	UT	1	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY, **TBX-35**
114500	TBX-2-2102-13 VALVE TO PIPE R100AB62SB	C-F-2 CS,51	UT	1	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
114600	TBX-2-2102-14 PIPE TO TEE R100AB62SB	C-F-2 CS,51	UT	1	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
114700	TBX-2-2102-15 TEE TO PIPE R100AB62SB	C-F-2 CS,51	UT	1	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
114800	TBX-2-2102-16 PIPE TO ELBOW R100AB62SB	C-F-2 CS,51	UT	1	-	-	X	-	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
114900	TBX-2-2102-17 ELBOW TO PIPE R100AB63SB	C-F-2 CS,51	UT	1	-	-	X	-	-	82	TDLR VERIFICATION BOUNDARY, **TBX-35**

DATE: 09/19/91

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

PAGE 2 - 7

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION AREA IDENTIFICATION	ITEM NO.	ASME SEC. XI	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE TEST INSTRUCTIONS **CALIBRATION BLOCK**
				CATEGORICAL NDE			FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
				ITEM NO.	METH	1 2 3	1 2 3	1 2 3	1 2 3	
<u>FEEDWATER 6-FW-1-095-1303-2</u>										
115000	TBX-2-2102-18 PIPE TO ELBOW R100AB66BSB		C-F-2 CS.51	UT	1 - + +	X - +	- + +	- + +	- + +	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
115100	TBX-2-2102-19 ELBOW TO PIPE R100AB669SB		C-F-2 CS.51	UT	1 - + +	X - +	- + +	- + +	- + +	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
115200	TBX-2-2102-20 PIPE TO ELBOW R100AB669SB		C-F-2 CS.51	UT	1 - + +	X - +	- + +	- + +	- + +	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
115300	TBX-2-2102-21 ELBOW TO PIPE R100AB66BSB		C-F-2 CS.51	UT	1 - + +	X - +	- + +	- + +	- + +	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
115400	TBX-2-2102-22 PIPE TO ELBOW R100AB665SB		C-F-2 CS.51	UT	1 - + +	X - +	- + +	- + +	- + +	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
115500	TBX-2-2102-23 ELBOW TO PIPE R100AB664SB		C-F-2 CS.51	UT	1 - + +	X - +	- + +	- + +	- + +	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
115600	TBX-2-2102-24 PIPE TO ELBOW R100AB664SB		C-F-2 CS.51	UT	1 - + +	X - +	- + +	- + +	- + +	BB TDLR VERIFICATION BOUNDARY, **TBX-35**

HIGH ENERGY LINE BREAK UNIT 1
 INSERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI	CATEOY ITEM NO	NDE METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR	
								FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
					OUTAGE			1 2 3	1 2 3	1 2 3		
<u>FEEDWATER 6-FW-1-095-1303-2</u>												
115700	TBX-2-2102-25 ELBOW TO PIPE R100AB64SB	C-F-2 CS.51	UT	1 - + -	X - -	- - -	- - -	1 2 3	1 2 3	1 2 3	88	TDLR VERIFICATION BOUNDARY **TBX-35**
115800	TBX-2-2102-26 PIPE TO PIPE R100AB64SB	C-F-2 CS.51	UT	1 - + -	X - -	- - -	- - -	1 2 3	1 2 3	1 2 3	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
<u>MAIN STEAM 32-MS-1-002-1303-2</u>												
122600	TBX-1-2200-15 PIPE TO PIPE R108 877SB	C-F-2 CS.51	UT	1 - + -	- - -	- X -	- X -	1 2 3	1 2 3	1 2 3	88	TDLR VERIFICATION BOUNDARY, **TBX-33**
122650	TBX-2-2200-15L LONG. SEAM R108 877SB	C-F-2 CS.52	UT	1 - + -	- X -	- X -	- X -	1 2 3	1 2 3	1 2 3	88	100% FROM WELD 15 TO 20, TDLR VERIFICATION BOUNDARY, **TBX-33**
123100	TBX-1-2200-20 PIPE TO PIPE R108 877SB	C-F-2 CS.51	UT	1 - + -	- - -	- X -	- X -	1 2 3	1 2 3	1 2 3	88	TDLR VERIFICATION BOUNDARY, **TBX-33**
123400	TBX-1-2200-23 PIPE TO VALVE R108 877SB	C-F-2 CS.51	UT	1 - + -	- - -	- X -	- X -	1 2 3	1 2 3	1 2 3	82	TDLR VERIFICATION BOUNDARY, **TBX-33**
123450	TBX-2-2200-23L LONG. SEAM R108 877SB	C-F-2 CS.52	UT	1 - + -	- - -	- X -	- X -	1 2 3	1 2 3	1 2 3	82	100% FROM WELD 20 TO 23, TDLR VERIFICATION BOUNDARY **TBX-33**

HIGH ENERGY LINE BREAK UNIT 1
 INSERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ASME SEC. XI	CATGTY NDE ITEM NO METH	INSPECTION INTERVAL	PLAN STATUS			PRESERVICE YEAR
				FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
				OUTAGE			
				1 2 3	1 2 3	1 2 3	**CALIBRATION BLOCK**

MAIN STEAM MS-24 (DRIP POT)

123500	TBX-1-2200-24	C-F-2	UT	1 - - -	- - -	- X -	88	TDLR VERIFICATION BOUNDARY.
	BRANCH CONNECTION TO PIPE	C5.51		2 - - -	- - -	- - -		
	R10B 8765B			3 - - -	- - -	- - -		
				4 - - -	- - -	- - -		**TBX-22**

MAIN STEAM B-HS-1-240-7a03-2

123700	TBX-1-2200-26	C-F-2	UT	1 - - -	- - -	- X -	88	TDLR VERIFICATION BOUNDARY.
	BRANCH CONNECTION TO PIPE	C5.51		2 - - -	- - -	- - -		
	R10B 8785B			3 - - -	- - -	- - -		
				4 - - -	- - -	- - -		**TBX-17**

123800	TBX-1-2200-27	C-F-2	UT	1 - - -	- - -	- X -	88	TDLR VERIFICATION BOUNDARY.
	PIPE TO VALVE	C5.51		2 - - -	- - -	- - -		
	R10B 8815B			3 - - -	- - -	- - -		
				4 - - -	- - -	- - -		**TBX-17**

124000	TBX-1-2200-28	C-F-2	UT	1 - - -	- - -	- X -	88	TDLR VERIFICATION BOUNDARY.
	VALVE TO PIPE	C5.51		2 - - -	- - -	- - -		
	R10B 8835B			3 - - -	- - -	- - -		
				4 - - -	- - -	- - -		**TBX-17**

124100	TBX-1-2200-29	C-F-2	UT	1 - - -	- - -	- X -	85	TDLR VERIFICATION BOUNDARY.
	PIPE TO ELBOW	C5.51		2 - - -	- - -	- - -		
	R10B 8835B			3 - - -	- - -	- - -		
				4 - - -	- - -	- - -		**TBX-17**

124200	TBX-1-2200-30	C-F-2	UT	1 - - -	- - -	- X -	88	TDLR VERIFICATION BOUNDARY.
	ELBOW TO PIPE	C5.51		2 - - -	- - -	- - -		
	R10B 8855B			3 - - -	- - -	- - -		
				4 - - -	- - -	- - -		**TBX-17**

124300	TBX-2-2200-31	C-F-2	UT	1 - - -	- - -	- X -	88	TDLR VERIFICATION BOUNDARY.
	PIPE TO VALVE	C5.51		2 - - -	- - -	- - -		
	R10B 8855B			3 - - -	- - -	- - -		
				4 - - -	- - -	- - -		**TBX-17**

**HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS**

SUMMARY NUMBER	EXAMINATION AREA IDENTIFICATION	ITEM NO	ASME SEC. XI	CATGY	NDE	ITEM NO METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR
							OUTAGE			FIRST	SECOND	THIRD	
							PERIOD	PERIOD	PERIOD				
							1 2 3	1 2 3	1 2 3				INSTRUCTIONS **CALIBRATION BLOCK**

MAIN STEAM 6-2003-2

124500 TBX-2-2200-33 C-F-2 UT 1 - - + - + - - X - 88 TDLR VERIFICATION BOUNDARY,
 BRANCH CONNECTION TO FLANGE CS,51 2 - - + - + - - X -
 R10B 878SB 3 - - + - + - - X -
 4 - - + - + - - X - **TBX-36**

124600 TBX-2-2200-34 C-F-2 UT 1 - - + - + - - X - 88 TDLR VERIFICATION BOUNDARY,
 BRANCH CONNECTION TO FLANGE CS,51 2 - - + - + - - X -
 R10B 878SB 3 - - + - + - - X -
 4 - - + - + - - X - **TBX-36**

124700 TBX-2-2200-35 C-F-2 UT 1 - - + - + - - X - 88 TDLR VERIFICATION BOUNDARY,
 BRANCH CONNECTION TO FLANGE CS,51 2 - - + - + - - X -
 R10B 878SB 3 - - + - + - - X -
 4 - - + - + - - X - **TBX-36**

124800 TBX-2-2200-36 C-F-2 UT 1 - - + - + - - X - 88 TDLR VERIFICATION BOUNDARY,
 BRANCH CONNECTION TO FLANGE CS,51 2 - - + - + - - X -
 R10B 878SB 3 - - + - + - - X -
 4 - - + - + - - X - **TBX-36**

MAIN STEAM 32-MS-1-002-1303-2

126300 TBX-2-2200-47 C-F-2 UT 1 - - + - + - - X - 86
 VALVE TO MOMENT RESTRAINT CS,51 2 - - + - + - - X -
 R10B 877SB 3 - - + - + - - X -
 4 - - + - + - - X - **TBX-33**

FEEDWATER 18-FW-1-018-1303-2

129100 TBX-2-2201-28 C-F-2 UT 1 X - - + - + - - X - 88 TDLR VERIFICATION BOUNDARY,
 PIPE TO PIPE CS,51 2 - - + - + - - X -
 R100A856SB 3 - - + - + - - X -
 4 - - + - + - - X - **TBX-21**

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	EXAMINATION AREA ITEM NO. METH	ASME SEC. XI	CATGTY NDE	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR		
							FIRST PERIOD	SECOND PERIOD	THIRD PERIOD			
				1	2	3	1	2	3	1	2	3

FEEDWATER 1B-FW-1-018-1303-2

129200	TBX-2-2201-29 PIPE TO PIPE R100A856SB	C-F-2 C5.51	UT	1 X - +	- - +	- - +	- - +	- - +	- - +	88	TDLR VERIFICATION BOUNDARY.
				2 + - +	- - +	- - +	- - +	- - +	- - +		
				3 + - +	- - +	- - +	- - +	- - +	- - +		
				4 + - +	- - +	- - +	- - +	- - +	- - +		**TBX-21**

FEEDWATER 1B-1-FW-035-2003-2

129300	TBX-2-2201-30 PIPE TO VALVE R100A856SB	C-F-2 C5.51	UT	1 X - +	- - +	- - +	- - +	- - +	- - +	82	TDLR VERIFICATION BOUNDARY.
				2 + - +	- - +	- - +	- - +	- - +	- - +		
				3 + - +	- - +	- - +	- - +	- - +	- - +		
				4 + - +	- - +	- - +	- - +	- - +	- - +		**TBX-38**

129400	TBX-2-2201-31 VALVE TO PIPE R100A856SB	C-F-2 C5.51	UT	1 X - +	- - +	- - +	- - +	- - +	- - +	82	
				2 + - +	- - +	- - +	- - +	- - +	- - +		
				3 + - +	- - +	- - +	- - +	- - +	- - +		
				4 + - +	- - +	- - +	- - +	- - +	- - +		**TBX-38**

129500	TBX-2-2201-32 PIPE TO VALVE R100A856SB	C-F-2 C5.51	UT	1 X - +	- - +	- - +	- - +	- - +	- - +	82	
				2 + - +	- - +	- - +	- - +	- - +	- - +		
				3 + - +	- - +	- - +	- - +	- - +	- - +		
				4 + - +	- - +	- - +	- - +	- - +	- - +		**TBX-38**

129600	TBX-2-2201-33 VALVE TO PIPE R100A856SB	C-F-2 C5.51	UT	1 X - +	- - +	- - +	- - +	- - +	- - +	88	
				2 + - +	- - +	- - +	- - +	- - +	- - +		
				3 + - +	- - +	- - +	- - +	- - +	- - +		
				4 + - +	- - +	- - +	- - +	- - +	- - +		**TBX-38**

FEEDWATER 6-FW-1-092-2003-2

129900	TBX-2-2202-2 BRANCH CONNECTION TO PIPE R100A857SB	C-F-2 C5.51	UT	1 X - +	- - +	- - +	- - +	- - +	- - +	88	
				2 + - +	- - +	- - +	- - +	- - +	- - +		
				3 + - +	- - +	- - +	- - +	- - +	- - +		
				4 + - +	- - +	- - +	- - +	- - +	- - +		**TBX-34**

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI	CATEQ NDE ITEM NO METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR INSTRUCTIONS
							FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
				1	2	3	1	2	3	

FEEDWATER 6-FW-1-092-2003-2

130000	TBK-2-2202-3 PIPE TO VALVE R100A860SB	C-F-2 CS,51	UT	1 X - + -	- + -	- + -	- + -	- + -	- + -	88 **TBX-34**
130200	TBX-2-2202-4 VALVE TO PIPE R100A861SB	C-F-2 CS,51	UT	1 X - + -	- + -	- + -	- + -	- + -	- + -	88 **TBX-34**
130300	TBX-2-2202-5 PIPE TO ELBOW R100A862SB	C-F-2 CS,51	UT	1 X - + -	- + -	- + -	- + -	- + -	- + -	82 **TBX-34**
130400	TBX-2-2202-6 ELBOW TO PIPE R100A863SB	C-F-2 CS,51	UT	1 X - + -	- + -	- + -	- + -	- + -	- + -	88 **TBX-34**
130500	TBX-2-2202-7 PIPE TO ELBOW R100A863SB	C-F-2 CS,51	UT	1 X - + -	- + -	- + -	- + -	- + -	- + -	88 **TBX-34**
130600	TBX-2-2202-8 ELBOW TO PIPE R100K363SB	C-F-2 CS,51	UT	1 X - + -	- + -	- + -	- + -	- + -	- + -	88 **TBX-34**
130800	TBX-2-2202-10 VALVE TO PIPE R100A863SB	C-F-2 CS,51	UT	1 X - + -	- + -	- + -	- + -	- + -	- + -	88 TDLR VERIFICATION BOUNDARY, **TBX-34**

**HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS**

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION AREA IDENTIFICATION	ITEM NO	ASME SEC. XI CATG# NDE ITEM NO METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**	
							FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
				1	2	3	1	2	3		
FEEDWATER 6-TW-1-096-1303-2											
130900	TBX-2-2202-11 PIPE TO PIPE R100AB63SB		C-F-2 CS,51	UT	1	X	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
					2	-	-	-	-	-	
					3	-	-	-	-	-	
					4	-	-	-	-	-	
131000	TBX-2-2202-12 PIPE TO VALVE R100AB63SB		C-F-2 CS,51	UT	1	X	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
					2	-	-	-	-	-	
					3	-	-	-	-	-	
					4	-	-	-	-	-	
131100	TBX-2-2202-13 VALVE TO PIPE R100AB63SB		C-F-2 CS,51	UT	1	X	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
					2	-	-	-	-	-	
					3	-	-	-	-	-	
					4	-	-	-	-	-	
131200	TBX-2-2202-14 PIPE TO TEE R100AB63SB		C-F-2 CS,51	UT	1	X	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
					2	-	-	-	-	-	
					3	-	-	-	-	-	
					4	-	-	-	-	-	
131300	TBX-2-2202-15 TEE TO PIPE R100AB63SB		C-F-2 CS,51	UT	1	X	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
					2	-	-	-	-	-	
					3	-	-	-	-	-	
					4	-	-	-	-	-	
131400	TBX-2-2202-16 PIPE TO ELBOW R100AB63SB		C-F-2 CS,51	UT	1	X	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
					2	-	-	-	-	-	
					3	-	-	-	-	-	
					4	-	-	-	-	-	
131500	TBX-2-2202-17 ELBOW TO PIPE R100AB64SB		C-F-2 CS,51	UT	1	X	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
					2	-	-	-	-	-	
					3	-	-	-	-	-	
					4	-	-	-	-	-	

HIGH ENERGY LINE BREAK UNIT 1
 IN-SERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ITEM NO	ASME SEC. XI	CATGY NDE	ITEM NO METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR	
								FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
					1	2	3	1	2	3		
<u>FEEDWATER 6-FW-1-096-1303-2</u>												
131600	TBX-2-2202-18	C-F-2	UT	1 X	-	-	-	-	-	-	82	TDLR VERIFICATION BOUNDARY.
	PIPE TO ELBOW	C5.51		2	-	-	-	-	-	-		
	R100A868SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-35**
131700	TBX-2-2202-19	C-F-2	UT	1 X	-	-	-	-	-	-	88	TDLR VERIFICATION BOUNDARY.
	ELBOW TO PIPE	C5.51		2	-	-	-	-	-	-		
	R100A870SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-35**
131800	TBX-2-2202-20	C-F-2	UT	1 X	-	-	-	-	-	-	88	TDLR VERIFICATION BOUNDARY.
	PIPE TO ELBOW	C5.51		2	-	-	-	-	-	-		
	R100A870SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-35**
131900	TBX-2-2202-21	C-F-2	UT	1 X	-	-	-	-	-	-	88	TDLR VERIFICATION BOUNDARY.
	ELBOW TO PIPE	C5.51		2	-	-	-	-	-	-		
	R100A868SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-35**
132000	TBX-2-2202-22	C-F-2	UT	1 X	-	-	-	-	-	-	88	TDLR VERIFICATION BOUNDARY.
	PIPE TO ELBOW	C5.51		2	-	-	-	-	-	-		
	R100A865SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-35**
132100	TBX-2-2202-23	C-F-2	UT	1 X	-	-	-	-	-	-	88	TDLR VERIFICATION BOUNDARY.
	ELBOW TO PIPE	C5.51		2	-	-	-	-	-	-		
	R100A864SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-35**
132200	TBX-2-2202-24	C-F-2	UT	1 X	-	-	-	-	-	-	88	TDLR VERIFICATION BOUNDARY.
	PIPE TO ELBOW	C5.51		2	-	-	-	-	-	-		
	R100A864SB			3	-	-	-	-	-	-		
				4	-	-	-	-	-	-		**TBX-35**

HIGH ENERGY LINE BREAK UNIT 1
 INSERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION IDENTIFICATION	ASME SEC. XI	NODE NO. METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR	
							FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
				1	2	3	1	2	3		
<u>FEEDWATER 6-FW-1-096-1303-2</u>											
132300	TBX-2-2202-25 ELBOW TO PIPE R100AB64SB	C-F-2 CS.51	UT	1	X	-	-	-	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-		
				3	-	-	-	-	-		
				4	-	-	-	-	-		**TBX-35**
132400	TBX-2-2202-26 PIPE TO PIPE R100AB64SB	C-F-2 CS.51	UT	1	X	-	-	-	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-		
				3	-	-	-	-	-		
				4	-	-	-	-	-		**TBX-35**
<u>MAIN STEAM 32-MS-1-003-1303-2</u>											
141600	TBX-2-2300-25 PIPE TO PIPE R10B 877SB	C-F-2 CS.51	UT	1	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-		
				3	-	-	-	-	-		
				4	-	-	-	-	-		**TBX-33**
141650	TBX-2-2300-25L LONG. SEAM R10B 877SB	C-F-2 CS.52	UT	1	-	-	-	X	-	88	100% FROM WELD 25 TO 29. TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-		
				3	-	-	-	-	-		
				4	-	-	-	-	-		**TBX-33**
142000	TBX-2-2300-29 PIPE TO PIPE R10B 877SB	C-F-2 CS.51	UT	1	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-		
				3	-	-	-	-	-		
				4	-	-	-	-	-		**TBX-33**
142400	TBX-2-2300-33 PIPE TO VALVE R10B 877SB	C-F-2 CS.51	UT	1	-	-	-	X	-	82	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-		
				3	-	-	-	-	-		
				4	-	-	-	-	-		**TBX-33 *
142450	TBX-2-2300-33L LONG. SEAM R10B 877SB	C-F-2 CS.52	UT	1	-	-	-	X	-	88	100% FROM WELD 29 TO 33. TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-		
				3	-	-	-	-	-		
				4	-	-	-	-	-		**TBX-33**

**HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS**

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION IDENTIFICATION	ASME SEC. XI	CATEGY	NDE	PLAN STATUS						PRESERVICE YEAR
					OUTAGE			PERIOD			
					ITEM NO	METH	1	2	3	1	2

MAIN STEAM MS-023 (DRIP POT)

142600	TBX-2-2300-34 BRANCH CONNECTION TO PIPE R108 876SB	C-F-2 CS.51	UT	1 2 3 4	- - - +	- - - +	X - - -	- - - +	- - - +	- - - +	88	TDLR VERIFICATION BOUNDARY. **TBX-22**
--------	--	----------------	----	------------------	------------------	------------------	------------------	------------------	------------------	------------------	----	---

142700	TBX-2-2300-35 PIPE TO CAP R108 873SB	C-F-2 CS.51	UT	1 2 3 4	- - - +	- - - +	X - - -	- - - +	- - - +	- - - +	82	TDLR VERIFICATION BOUNDARY. **TBX-22**
--------	--	----------------	----	------------------	------------------	------------------	------------------	------------------	------------------	------------------	----	---

MAIN STEAM B-MS-1-223-1303-2

142900	TBX-2-2300-37 PIPE TO VALVE R108 880B	C-F-2 CS.51	UT	1 2 3 4	- - - +	- - - +	X - - -	- - - +	- - - +	- - - +	88	TDLR VERIFICATION BOUNDARY. **TBX-17**
--------	---	----------------	----	------------------	------------------	------------------	------------------	------------------	------------------	------------------	----	---

143100	TBX-2-2300-38 VALVE TO PIPE R108 883SB	C-F-2 CS.51	UT	1 2 3 4	- - - +	- - - +	X - - -	- - - +	- - - +	- - - +	88	TDLR VERIFICATION BOUNDARY. **TBX-17**
--------	--	----------------	----	------------------	------------------	------------------	------------------	------------------	------------------	------------------	----	---

143200	TBX-2-2300-39 PIPE TO ELBOW R108 884SB	C-F-2 CS.51	UT	1 2 3 4	- - - +	- - - +	X - - -	- - - +	- - - +	- - - +	88	TDLR VERIFICATION BOUNDARY. **TBX-17**
--------	--	----------------	----	------------------	------------------	------------------	------------------	------------------	------------------	------------------	----	---

143300	TBX-2-2300-40 ELBOW TO PIPE R108 885SB	C-F-2 CS.51	UT	1 2 3 4	- - - +	- - - +	X - - -	- - - +	- - - +	- - - +	88	TDLR VERIFICATION BOUNDARY. **TBX-17**
--------	--	----------------	----	------------------	------------------	------------------	------------------	------------------	------------------	------------------	----	---

143400	TBX-2-2300-41 PIPE TO VALVE R108 885SB	C-F-2 CS.51	UT	1 2 3 4	- - - +	- - - +	X - - -	- - - +	- - - +	- - - +	88	TDLR VERIFICATION BOUNDARY. **TBX-17**
--------	--	----------------	----	------------------	------------------	------------------	------------------	------------------	------------------	------------------	----	---

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION IDENTIFICATION	ITEM NO.	METHOD	CATEOY	NDE	SEC. XI	ASME	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR
											FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
								1	2	3	1	2	3	

MAIN STEAM 6-2003-2

143500	TBX-2-2300-42	C-F-2	UT	1	-	-	-	X	-	-	-	-	-	88	TDLR VERIFICATION BOUNDARY,
	BRANCH CONNECTION TO FLANGE	C5.51		2	-	-	-	-	-	-	-	-	-		
	R10B 878SB			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**TBX-36**
143600	TBX-2-2300-43	C-F-2	UT	1	-	-	-	-	X	-	-	-	-	88	TDLR VERIFICATION BOUNDARY,
	BRANCH CONNECTION TO FLANGE	C5.51		2	-	-	-	-	-	-	-	-	-		
	R10B 878SB			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**TBX-36**
143700	TBX-2-2300-44	C-F-2	UT	1	-	-	-	-	X	-	-	-	-	88	TDLR VERIFICATION BOUNDARY,
	BRANCH CONNECTION TO FLANGE	C5.51		2	-	-	-	-	-	-	-	-	-		
	R10B 878SB			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**TBX-36**
143800	TBX-2-2300-45	C-F-2	UT	1	-	-	-	-	X	-	-	-	-	88	TDLR VERIFICATION BOUNDARY,
	BRANCH CONNECTION TO FLANGE	C5.51		2	-	-	-	-	-	-	-	-	-		
	R10B 878SB			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**TBX-36**
143900	TBX-2-2300-46	C-F-2	UT	1	-	-	-	-	X	-	-	-	-	88	TDLR VERIFICATION BOUNDARY,
	BRANCH CONNECTION TO FLANGE	C5.51		2	-	-	-	-	-	-	-	-	-		
	R10B 878SB			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**TBX-36**

MAIN STEAM 32-HS-1-003-1303-2

146200	TBX-2-2300-68	C-F-2	UT	1	-	-	-	-	X	-	-	-	-	86	
	VALVE TO MOMENT RESTRAINT	C5.51		2	-	-	-	-	-	-	-	-	-		
	R10B 877SB			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**TBX-33**

FEEDWATER 18-FW-1-017-1303-2

148800	TBX-2-2301-24	C-F-2	UT	1	X	-	-	-	-	-	-	-	-	88	TDLR VERIFICATION BOUNDARY,
	PIPE TO PIPE	C5.51		2	-	-	-	-	-	-	-	-	-		
	R100A856SB			3	-	-	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-	-	-		**TBX-21**

HIGH EN/PGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	CATEOY NOE ITEM NO METH	ASME SEC. XI	OUTAGE	PLAN STATUS			PRESENCE YEAR
				FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
				1 2 3	1 2 3	1 2 3	

FEEDWATER 1B-FW-1-017-1303-2

148900	TBX-2-2301-25 PIPE TO PIPE R100A8565B	C-F-2 CS.51	UT	1 X - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	88 **TBX-21**
--------	---	----------------	----	--	--	--	------------------

FEEDWATER 1B-FW-1-034-2003-2

149000	TBX-2-2301-26 PIPE TO VALVE R100A8565B	C-F-2 CS.51	UT	1 X - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	82 **TBX-18**
--------	--	----------------	----	--	--	--	------------------

149100	TBX-2-2301-27 VALVE TO PIPE R100A8565B	C-F-2 CS.51	UT	1 X - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	82 **TBX-38**
--------	--	----------------	----	--	--	--	------------------

149300	TBX-2-2301-28 PIPE TO VALVE R100A8565B	C-F-2 CS.51	UT	1 X - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	82 **TBX-30**
--------	--	----------------	----	--	--	--	------------------

149400	TBX-2-2301-29 VALVE TO PIPE R100A8565B	C-F-2 CS.51	UT	1 X - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	82 **TBX-38**
--------	--	----------------	----	--	--	--	------------------

149500	TBX-2-2301-30 PIPE TO MOMENT RESTRAINT R100A8565B	C-F-2 CS.51	UT	1 X - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	82 **TBX-38**
--------	---	----------------	----	--	--	--	------------------

FEEDWATER 6-FW-1-093-2003-2

149700	TBX-2-2302-2 BRANCH CONNECTION TO PIPE R100A8575B	C-F-2 CS.51	UT	1 X - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	82 **TBX-34**
--------	---	----------------	----	--	--	--	------------------

DATE: 09/19/91

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

PAGE: 19

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION IDENTIFICATION	ITEM NO.	ASME SEC. XI CATQY	NDE	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR INSTRUCTIONS
								FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
					1	2	3	1	2	3	
											CALIBRATION BLOCK

FEEDWATER 6-TW-1-093-2003-2

149800	TBX-2-2302-3 PIPE TO VALVE R100AB60E1	C-F-2 C5.51	UT	1 X 2 - 3 - 4 -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	88 **TBX-34**
149900	TBX-2-2302-4 VALVE TO PIPE R100AB61SB	C-F-2 C5.51	UT	1 X 2 - 3 - 4 -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	88 **TBX-34**
150000	TBX-2-2302-5 PIPE TO ELBOW R100AB62SB	C-F-2 C5.51	UT	1 X 2 - 3 - 4 -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	88 **TBX-34**
150100	TBX-2-2302-6 ELBOW TO PIPE R100AB63SB	C-F-2 C5.51	UT	1 X 2 - 3 - 4 -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	88 **TBX-34**
150200	TBX-2-2302-7 PIPE TO ELBOW R100AB63SB	C-F-2 C5.51	UT	1 X 2 - 3 - 4 -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	88 **TBX-34**
150300	TBX-2-2302-8 ELBOW TO PIPE R100AB63SB	C-F-2 C5.51	UT	1 X 2 - 3 - 4 -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	88 **TBX-34**
150500	TBX-2-2302-10 VALVE TO PIPE R100AB63SB	C-F-2 C5.51	UT	1 X 2 - 3 - 4 -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	- - - - - - - - - - - -	82 TDLR VERIFICATION BOUNDARY, **TBX-34**

DATE: 09/19/91

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

PAGE: 20

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ITEM NO	ASME SEC. XI	CATGY NDE	PLAN STATUS						PRESERVICE TEST INSTRUMENTS **CALIBRATION BLOCK**	
				OUTAGE			FIRST PERIOD				
				1	2	3	1	2	3		

FEEDWATER 6-FW-1-097-1303-2

150600	TBX-2-2302-11	C-F-2 CS,51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**
	PIPE TO PIPE			2	-	-	-	-	-		
	R100A863SB			3	-	-	-	-	-		
				4	-	-	-	-	-		
150700	TBX-2-2302-12	C-F-2 CS,51	UT	1	X	-	-	-	-	B2	TDLR VERIFICATION BOUNDARY, **TBX-35**
	PIPE TO VALVE			2	-	-	-	-	-		
	R100A863SB			3	-	-	-	-	-		
				4	-	-	-	-	-		
150800	TBX-2-2302-13	C-F-2 CS,51	UT	1	X	-	-	-	-	B2	TDLR VERIFICATION BOUNDARY, **TBX-35**
	VALVE TO PIPE			2	-	-	-	-	-		
	R100A863SB			3	-	-	-	-	-		
				4	-	-	-	-	-		
150900	TBX-2-2302-14	C-F-2 CS,51	UT	1	X	-	-	-	-	BB	LR VERIFICATION BOUNDARY, **TBX-35**
	PIPE TO TEE			2	-	-	-	-	-		
	R100A863SB			3	-	-	-	-	-		
				4	-	-	-	-	-		
151000	TBX-2-2302-15	C-F-2 CS,51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**
	TEE TO PIPE			2	-	-	-	-	-		
	R100A863SB			3	-	-	-	-	-		
				4	-	-	-	-	-		
151100	TBX-2-2302-16	C-F-2 CS,51	UT	1	X	-	-	-	-	B2	TDLR VERIFICATION BOUNDARY, **TBX-35**
	PIPE TO ELBOW			2	-	-	-	-	-		
	R100A863SB			3	-	-	-	-	-		
				4	-	-	-	-	-		
151200	TBX-2-2302-17	C-F-2 CS,51	UT	1	X	-	-	-	-	B2	TDLR VERIFICATION BOUNDARY, **TBX-35**
	ELBOW TO PIPE			2	-	-	-	-	-		
	R100A864SB			3	-	-	-	-	-		
				4	-	-	-	-	-		

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI	PLAN STATUS						PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**	
			OUTAGE			FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
			CATGY	NDE	ITEM NO	METH				
			1	X	2					

FEEDWATER 6-FW-1-097-1303-2

151300	TBX-2-2302-18 PIPE TO ELBOW R100A869SB	C-F-2 C5.51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**
151400	TBX-2-2302-19 ELBOW TO PIPE R100A870SB	C-F-2 C5.51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**
151500	TBX-2-2302-20 PIPE TO ELBOW R100A870SB	C-F-2 C5.51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**
151600	TBX-2-2302-21 ELBOW TO PIPE R100A869SB	C-F-2 C5.51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**
151700	TBX-2-2302-22 PIPE TO ELBOW R100A865SB	C-F-2 C5.51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**
151800	TBX-2-2302-23 ELBOW TO PIPE R100A864SB	C-F-2 C5.51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**
151900	TBX-2-2302-24 PIPE TO ELBOW R100A864SB	C-F-2 C5.51	UT	1	X	-	-	-	-	BB	TDLR VERIFICATION BOUNDARY, **TBX-35**

DATE: 09/19/91

**HIGH ENERGY LIP BREAK UNIT 1
INSERVICE INSPECT. LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS**

PAGE: 22

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION IDENTIFICATION	ITEM NO	ASME SEC. XI	CATGDY NDE	ITEM NO	METH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR
										FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
							1	2	3	1	2	3	
							-	-	-	-	-	-	
<u>FEEDWATER 6-FW-1-097-1303-2</u>													
1*2000	TBX-2-2302-25 ELBOW TO PIPE R100AB64SB		C-F-2 UT CS.51	1 X - - - - -	2 - - - - -	3 - - - - -	4 - - - - -	-	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
152100	TBX-2-2302-26 PIPE TO PIPE R100AB64SB		C-F-2 UT CS.51	1 X - - - - -	2 - - - - -	3 - - - - -	4 - - - - -	-	-	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-35**
<u>MAIN STEAM 32-MS-1-004-1303-2</u>													
160500	TBX-2-2400-18 PIPE TO PIPE R108 877SB		C-F-2 UT CS.51	1 - - - - -	2 - - - - -	3 - - - - -	4 - - - - -	-	X -	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-33**
160550	TBX-2-2400-18L LONG. SEAM R108 877RB		C-F-2 UT CS.52	1 - - - - -	2 - - - - -	3 - - - - -	4 - - - - -	-	X -	-	-	-	BB 100% FROM WELD 18 TO 22, TDLR VERIFICATION BOUNDARY, **TBX-33**
160900	TBX-2-2400-22 PIPE TO PIPE R108 877SB		C-F-2 UT CS.51	1 - - - - -	2 - - - - -	3 - - - - -	4 - - - - -	-	X -	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-33**
161350	TBX-2-2400-26L LONG. SEAM R108 877RB		C-F-2 UT CS.52	1 - - - - -	2 - - - - -	3 - - - - -	4 - - - - -	-	X -	-	-	-	BB 100% FROM 22 TO 26, TDLR VERIFICATION BOUNDARY, **TBX-33**
<u>MAIN STEAM MS-26 (DRIP POT)</u>													
161400	TBX-2-2400-27 BRANCH CONNECTION TO PIPE R108 876SB		C-F-2 UT CS.51	1 - - - - -	2 - - - - -	3 - - - - -	4 - - - - -	-	X -	-	-	-	BB TDLR VERIFICATION BOUNDARY, **TBX-22**

DATE: 09/19/91

HIGH ENERGY LINE BREAK UNIT 3
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

PAGE 3 23

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS			PRE-SERVICE YEAR
	ASME	SEC. XI	FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
	CAT#	NDE	- - -	O U T A G E	- - -	INSTRUCTIONS **CALIBRATION BLOCK**
	ITEM NO.	METH	1 2 3	1 2 3	1 2 3	

MAN STEAM MS-26 (081P POT)

161500 TBX-2-2400-28 C-F-2 UT 1 - - - - - - X - 88 TDLR VERIFICATION BOUNDARY,
 PIPE TO CAP C5.51 2 - - - - - - X - -
 R108 8745B 3 - - - - - - X - -
 4 - - - - - - X - - **TBX-2288

MANUAL STEAM 80-005-1-274-1303-2

161700 TBX-2-2400-30 C-E-2 UT 1 - - - - - - X - 88 TDLR VERIFICATION BOUNDARY,
 PIPE TO VALVE CS.51 2 - - - - - - - -
 R108 8815B 3 - - - - - - - -
 4 - - - - - - - - **TBX-17**

162000 TBX-2-2400-32 C-F-2 UT 1 - + - + - X - 88 TDLR VERIFICATION BOUNDARY.
 PIPE TO ELBOW C5.51 2 - + - + - X - + -
 R10B BB4SB 3 - + - + - X - + -
 4 - + - + - X - + - ERTLV-1228

162200 TBX-2-2400-34 C-F-2 UT 1 x + + + + + X - 88 TDLR VERIFICATION BOUNDARY.
PIPE TO VALVE C5.51 2 x + + + + + X -
R10B 885SB 3 x + + + + + X -
4 x + + + + + X - RATCHET 1744

MAIN STREAM A-2003-2

DATE: 09/19/99

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

PRACTICE

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION IDENTIFICATION	INSPECTION INTERVAL		PLAN STATUS			PRESERVICE YEAR				
		ASME SEC. XI		FIRST PERIOD	SECOND PERIOD	THIRD PERIOD					
CATEGORY	NODE	- - - - -	O U T A G E	- - - - -					INSTRUCTIONS		
ITEM NO.	METH	1	2	3	1	2	3	1	2	3	**CALIBRATION BLOCK**

MAIN STREAM 6-2003-2

162500 TBX-2-2400-37 C-F-2 UT 1 - x - - - x - x - 88 TDLR VERIFICATION BOUNDARY.
 BRANCH CONNECTION TO FLANGE CS.51 2 - x - - - x - x -
 R108 9795B 3 - x - - - x - x -
 4 - x - - - x - x - **TBX-36**

162600 TBX-2-2400-38 C-F-2 UT 1 + - + - + + X + 88 TDLR VERIFICATION BOUNDARY,
BRANCH CONNECTION TO FLANGE CS.51 2 + - + - + + X + +
R10B 8799B 3 + - + - + + X + +
4 + - + - + + X + + #TBX-36#

MAIN STEAM 32-MS-1-004-1303-2

163900 TBX-2-2400-51 C-F-2 UT 1 + - - x x x x x x x x x x 86
 PIPE TO MOMENT RESTRAINT U5.51 2 + - - + + + + + + + + + + +
 R10B 8775B 3 + - - x x x x x x x x x x x x
 4 + - - x x x x x x x x x x x x x x
 TBX-33

FEEDWATER 1B-FW-1-020-1303-2

165100 TBX-2-2401-11 C-F-2 UT 1 - - X + - X X - - 88 TDLR VERIFICATION BOUNDARY.
PIPE TO PIPE CS.51 2 - - - + - X - - X - -
R100A856RB 3 - - - + - X - - X - -
4 - - - + - X - - X - - **TBX-21**

HIGH ENERGY LINE BREAK UNIT 1
 INSERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	ASME SEC. XI CATG# NDE ITEM NO METH	INSPECTION INTERVAL	PLAN STATUS			PRESERVICE YEAR INSTRUCTIONS **CALIBRATION BLOCK**	
			OUTAGE				
			FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
			1 2 3	1 2 3	1 2 3		

FEEDWATER 1B-FW-1-020-1303-2

165200	TBX-2-2401-12 PIPE TO PIPE R100AB56RB	C-F-2 UT CS,51	1 - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - - - - - - - - - - - - - - - - -	88 TDLR VERIFICATION BOUNDARY. **TBX-21**
--------	---	-------------------	--	--	--	--

FEEDWATER 1B-FW-1-037-2003-2

165500	TBX-2-2401-15 PIPE TO VALVE R100AB56RB	C-F-2 UT CS,51	1 - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - - - - - - - - - - - - - - - - -	82 **TBX-38**
--------	--	-------------------	--	--	--	----------------------

165600	TBX-2-2401-16 VALVE TO PIPE R100AB56RB	C-F-2 UT CS,51	1 - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - - - - - - - - - - - - - - - - -	88 **TBX-38**
--------	--	-------------------	--	--	--	----------------------

165700	TBX-2-2401-17 PIPE TO MOMENT RESTRAINT R100AB56RB	C-F-2 UT CS,51	1 - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - - - - - - - - - - - - - - - - -	86 **TBX-38**
--------	---	-------------------	--	--	--	----------------------

FEEDWATER 6-FW-1-094-2003-2

165900	TBX-2-2402-2 BRANCH CONNECTION TO PIPE R100AB57SB	C-F-2 UT CS,51	1 - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - - - - - - - - - - - - - - - - -	88 **TBX-34**
--------	---	-------------------	--	--	--	----------------------

166000	TBX-2-2402-3 PIPE TO VALVE R100AB59SB	C-F-2 UT CS,51	1 - - - - - 2 - - - - - 3 - - - - - 4 - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - - - - - - - - - - - - - - - - -	88 **TBX-34**
--------	---	-------------------	--	--	--	----------------------

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	IDENTIFICATION	ASME SEC. XI	CATEOY NDE	ITEM NO. MTH	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR	
								FIRST PERIOD	SECOND PERIOD	THIRD PERIOD		
					1	2	3	1	2	3		
<u>FEEDWATER 6-FW-1-094-2003-2</u>												
166100	TBX-2-2402-6 VALVE TO PIPE R100AB615B	C-F-2 CS.51	UT	1 2 3 4	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - -	- - - -	- - - -	88 **TBX-34**	
166200	TBX-2-2402-5 PIPE TO ELBOW R100AB625B	C-F-2 CS.51	UT	1 2 3 4	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - -	- - - -	- - - -	82 **TBX-34**	
166300	TBX-2-2402-6 ELBOW TO PIPE R100AB635B	C-F-2 CS.51	UT	1 2 3 4	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - -	- - - -	- - - -	88 **TBX-34**	
166400	TBX-2-2402-7 PIPE TO ELBOW R100AB675B	C-F-2 CS.51	UT	1 2 3 4	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - -	- - - -	- - - -	88 **TBX-34**	
166500	TBX-2-2402-8 ELBOW To PIPE R100AB635B	C-F-2 CS.51	UT	1 2 3 4	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - -	- - - -	- - - -	88 **TBX-34**	
166600	TBX-2-2402-9 PIPE TO VALVE R100AB635B	C-F-2 CS.51	UT	1 2 3 4	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - -	- - - -	- - - -	88 **TBX-34**	
166700	TBX-2-2402-10 VALVE TO PIPE R100AB635B	C-F-2 CS.51	UT	1 2 3 4	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	- - - - - - - - - - - - - - - - - - - -	X - - -	- - - -	- - - -	88 TDLR VERIFICATION BOUNDARY. **TBX-34**	

**HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS**

SUMMARY EXAMINATION AREA NUMBER IDENTIFICATION	CATEGY NDE ITEM NO METH	ASME SEC. XI	INSPECTION INTERVAL			PLAN STATUS			PRESERVICE YEAR
						FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
			1	2	3	1	2	3	

FEEDWATER 6-FW-1-098-1303-2

166800	TBX-2-2402-11 PIPE TO PIPE R100AB62SB	C-F-2 CS,51	UT	1	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
166900	TBX-2-2402-12 PIPE TO VALVE R100AB62SB	C-F-2 CS,51	UT	1	-	-	-	-	X	-	82	TDLR VERIFICATION BOUNDARY, **TBX-35**
167000	TBX-2-2402-13 VALVE TO PIPE R100AB62SB	C-F-2 CS,51	UT	1	-	-	-	-	X	-	82	TDLR VERIFICATION BOUNDARY, **TBX-35**
167100	TBX-2-2402-14 PIPE TO TEE R100AB62SB	C-F-2 CS,51	UT	1	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
167200	TBX-2-2402-15 TEE TO PIPE R100AB62SB	C-F-2 CS,51	UT	1	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
167300	TBX-2-2402-16 PIPE TO ELBOW R100AB62SB	C-F-2 CS,51	UT	1	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**
167400	TBX-2-2402-17 ELBOW TO PIPE R100AB63SB	C-F-2 CS,51	UT	1	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY, **TBX-35**

HIGH ENERGY LINE BREAK UNIT 1
INSERVICE INSPECTION LONG TERM PLAN
CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION AREA IDENTIFICATION	ASME SEC. XI	INSPECTION INTERVAL						PLAN STATUS			PRESERVICE YEAR
			OUTAGE			FIRST PERIOD	SECOND PERIOD	THIRD PERIOD				
			CATOG	NDE	ITEM NO	METH	1	2	3	1	2	3

FEEDWATER 6-TW-1-098-1303-2

167500	TBX-2-2402-18 PIPE TO ELBOW R100AB69SB	C-F-2 CS.51	UT	1	-	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-		**TBX-35**
167600	TBX-2-2402-19 ELBOW TO PIPE R100AB70SB	C-F-2 CS.51	UT	1	-	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-		**TBX-35**
167700	TBX-2-2402-20 PIPE TO ELBOW R100AB70SB	C-F-2 CS.51	UT	1	-	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-		**TBX-35**
167800	TBX-2-2402-21 ELBOW TO PIPE R100AB69SB	C-F-2 CS.51	UT	1	-	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-		**TBX-35**
167900	TBX-2-2402-22 PIPE TO ELBOW R100AB65SB	C-F-2 CS.51	UT	1	-	-	-	-	-	X	-	88	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-		**TBX-35**
168000	TBX-2-2402-23 ELBOW TO PIPE R100AB64SB	C-F-2 CS.51	UT	1	-	-	-	-	-	X	-	82	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-		**TBX-35**
168100	TBX-2-2402-24 PIPE TO ELBOW R100AB64SB	C-F-2 CS.51	UT	1	-	-	-	-	-	X	-	82	TDLR VERIFICATION BOUNDARY.
				2	-	-	-	-	-	-	-		
				3	-	-	-	-	-	-	-		
				4	-	-	-	-	-	-	-		**TBX-35**

HIGH ENERGY LINE BREAK UNIT 1
 INSERVICE INSPECTION LONG TERM PLAN
 CLASS 2 SCHEDULED COMPONENTS

SUMMARY EXAMINATION AREA NUMBER	EXAMINATION AREA IDENTIFICATION	INSPECTION INTERVAL ASME SEC. XI	CATEY NDE ITEM NO METH	PLAN STATUS			PRESERVICE YEAR INSTRUCTIONS
				FIRST PERIOD	SECOND PERIOD	THIRD PERIOD	
				1 2 3	1 2 3	1 2 3	**CALIBRATION BLOCK**

FEEDWATER 6-FW-1-098-1303-2

168200	TBX-2-2402-25 ELBOW TO PIPE R100AB645B	G-F-2 UT CS,51	1	- - -	- - -	- - -	X - -	82 TDLR VERIFICATION BOUNDARY, **TBX-35**
			2	- - -	- - -	- - -	- - -	
			3	- - -	- - -	- - -	- - -	
			4	- - -	- - -	- - -	- - -	
<u>FEEDWATER 6-FW-1-098-1303-2</u>								
168300	TBX-2-2402-26 PIPE TO PIPE R100AB645B	G-F-2 UT CS,51	1	- - -	- - -	- - -	X - -	82 TDLR VERIFICATION BOUNDARY, **TBX-35**
			2	- - -	- - -	- - -	- - -	
			3	- - -	- - -	- - -	- - -	
			4	- - -	- - -	- - -	- - -	

<u>Discussion</u>	8
Refer to Appendix 1A(B).	8
<u>Regulatory Guide 1.145</u>	8
Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants	8
<u>Discussion</u>	8
Refer to Appendix 1A(B).	8
<u>Regulatory Guide 1.146</u>	14
Qualification of Quality Assurance Program Audit Personnel for Nuclear Power Plants	14
<u>Discussion</u>	14
Refer to Appendix 1A(B).	14
<u>Regulatory Guide 1.150</u>	46
Ultrasonic Testing of Reactor Vessel Welds During Preservice and Inservice Examinations	46
<u>Discussion</u>	46
The CPSES position on Revision 1 (2/83) of this guide is as follows:	46
Preservice Inspection	46
A partial R.G. 1.150 inspection was performed on Units 1 and 2 reactor vessels in accordance with Reference [21].	46

WNSD

**Westinghouse
Nuclear
Service
Division**

— Enclosure 3 to TXX-92030 —

Technical Bulletin

An advisory notice of a recent technical development pertaining to the installation or operation of Westinghouse-supplied Nuclear Plant equipment. Recipients should evaluate the information and recommendation, and initiate action where appropriate.

P.O. Box 2728, Pittsburgh, PA 15230

SUBJECT	Reactor Coolant Pump Thermal Barrier	Number
System(s)		NSD-TB-75-1
System(s)	Reactor Coolant	Date
Affected Plants	All (Construction and Operating)	S.O.(s)
References	J. A. Fickling ltr. dtd. 12/27/74 (partially quoted below)	Sheet 1 of 1

The reactor coolant pump manufacturer (Westinghouse Electro-Mechanical Division) has advised that the maximum allowable thermal barrier heat exchanger internal (component cooling water side) field hydrostatic test pressure is 225 psi.

"Although we recognize the necessity of testing the adjacent system to high pressures, we must point out that there is no specified or known operating condition where the cooling water pressure inside of the thermal barrier can be more than 150 psi. In fact, for all acceptable pump operating modes, the primary system pressure is greater than the cooling water pressure. For this reason, the thermal barrier heat exchanger is designed for high differential pressures in the direction opposite from that which is imposed by a cooling water side hydro test. To meet conditions which could exist in the event of a heat exchanger leak inside of the pump, the external connections of the heat exchanger are treated as parts of the primary system pressure boundary and are designed for 2500 psi internal pressure in accordance with the ASME Code and subjected to a shop hydro at the appropriate pressure (3750 to 4100 psi depending on the applicable ASME Code Addenda)."

Thus, "Hydrostatic testing of components in the attached cooling system to higher pressures should be performed only with the heat exchanger isolated or disconnected and bypassed".

Additional Information, If Required, may be Obtained from the Originator. Telephone 412 - 255-4646 or (WNSD) 236-4646


V.W. Doutt
V. W. Doutt
Manager

Mechanical Technology


F.C. Wellhofer
F. C. Wellhofer, Manager

Mechanical Technology

Neither Westinghouse Electric Corporation nor its employees make any warranty or representation with respect to the accuracy, completeness or usefulness of the information contained in this report or assume any responsibility for liability or damage which may result from the use of such information.



TO
COOLANT
SYSTEM
SHEET 12



**S1
APERTURE
CARD**

Also Available On
Aperture Card


ILLUSTRATIVE USE ONLY
THIS DIAGRAM DEVELOPED FROM FLOW DIAGRAM
M1-0231-A REV CP-2

TU ELECTRIC
CPSES UNIT 1

INSERVICE INSPECTION
BOUNDARY DIAGRAM


COMPONENT COOLING
WATER SYSTEM
SHEET 11 OF 12

9201290210-01



SI
APERTURE
CARD

Also Available On
Aperture Card



ILLUSTRATIVE USE ONLY

THIS DIAGRAM DEVELOPED FROM FLOW DIAGRAM
M1-0231 SH A REV. CP-2

TU ELECTRIC
CPSES UNIT 1

INSERVICE INSPECTION
BOUNDARY DIAGRAM

COMPONENT COOLING
WATER SYSTEM
SHEET 12 OF 12

9201290210-02