

DMB

JUN 7 1984

Docket No. 50-373  
Docket No. 50-374

Commonwealth Edison Company  
ATTN: Mr. Cordell Reed  
Vice President  
Post Office Box 767  
Chicago, IL 60690

Gentlemen:

Thank you for your letters dated May 18 and May 30, 1984, informing us of the steps you have taken to correct the noncompliances which we brought to your attention in Inspection Report No. 50-373/84-05(DPRP) and 50-374/84-05(DPRP) forwarded by our letter dated April 18, 1984.

In accordance with the discussion on May 31, 1984, between D. Berkman of your LaSalle staff and M. J. Jordan of my staff, we understand that in addition to your commitments in your letters identified above, your staff has reviewed the possibility of adding key annunciator status to the startup and shutdown procedures. The results of your review identified the need to include the 500 psig low pressure ECCS permissive and the 135 psig shutdown cooling isolation annunciators in the startup and shutdown procedures. All additional annunciators needed are presently in the associated procedures.

We will examine these matters during a subsequent inspection.

Your cooperation with us is appreciated.

Sincerely,  
"Original signed by W. D. Shafer"

C. E. Norelius, Director  
Division of Project and  
Resident Programs

cc: D. L. Farrar, Director  
of Nuclear Licensing  
G. J. Diederich, Station  
Superintendent  
R. H. Holyoak, Project Manager

cc w/ltrs dtd 5/18/84 and 5/30/84:  
DMB/Document Control Desk (RIDS)  
Resident Inspector, RIII  
Phyllis Dunton, Attorney  
General's Office, Environmental  
Control Division

RIII  
for *smf* 6/6/84  
Chrisotimos/db  
06/06/84

RIII  
*[Signature]*  
Shafer

RIII  
*[Signature]*  
Norelius

8406120120 840607  
PDR ADOCK 05000373  
Q PDR

TEG 11