


Southern California Edison Company

23 PARKER STREET
IRVINE, CALIFORNIA 92718

January 23, 1992

R. M. ROSENBLUM
MANAGER OF
NUCLEAR REGULATORY AFFAIRS

TELEPHONE
(714) 454-4505

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Gentlemen:


Subject: Docket Nos. 50-361, and 50-362
Special Report
San Onofre Nuclear Generating Station
Units 2 and 3

This report is being submitted in accordance with Technical Specification (TS) 3.3.3.4, Action a, of Facility Operating Licenses NPF-10 and NPF-15 for San Onofre Units 2 and 3 respectively. The TS require Southern California Edison to submit a Special Report when the Meteorological Tower is inoperable for more than 7 days.

At 0815 on January 6, 1992 the Meteorological Tower was declared inoperable when sensors could not be calibrated to the required specifications. The Meteorological Tower was returned to service at 1045 on January 15, 1992 following repair and replacement of the sensors.

If you have any questions, please contact me.

Very truly yours,



cc: J. B. Martin, Regional Administrator, NRC Region V
C. W. Caldwell, NRC Senior Resident Inspector, San Onofre
Units 1, 2&3

250000

9201290338 920123
PDR ADDOCK 05000361
S PDR

JE22 1/0