



Log # Txx-92036
File # 10110
Ref. # 10CFR50.55(e)

January 24, 1992

William J. Cahill, Jr.
Group Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION - UNIT 2
DOCKET NO. 50-446
LINEAR INDICATION IN A 150# FLANGE
SDAR CP-92-02 (INTERIM REPORT)

Gentlemen:

On November 27, 1991, TU Electric discovered a linear indication in a 10-inch 150# flange on a vendor-supplied spool in the Auxiliary Feedwater System. The depth of the indication was such that after it was ground out, the minimum wall thickness in the region was marginally less than the manufacturer's minimum wall.

The reportability evaluation for this issue is continuing and is scheduled for completion on February 27, 1992. The next report on this issue will be submitted upon completion of the evaluation.

Sincerely,

William J. Cahill, Jr.
William J. Cahill, Jr.

By: *Roger D. Walker*
Roger D. Walker
Manager of Nuclear Licensing

cc - Mr. R. D. Martin, Region IV
Mr. M. B. Fields, NRR
Resident Inspectors, CPSES (2)

9201300008 920124
PDR ADDCK 05000446
S PDR

0029
1/0