

**DUKE POWER COMPANY**

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

June 8, 1984

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555


Attention: Ms. E. G. Adensam, Chief  
Licensing Branch No. 4

Re: Catawba Nuclear Station  
Docket Nos. 50-413 and 50-414

Dear Mr. Denton:

Section 13.3.2.8 of Supplement 1 to the Catawba Safety Evaluation Report identified the need for additional information on two-way communications capability between the Technical Support Center (TSC) and the Operations Support Center (OSC). This information is attached.

Very truly yours,



Hal B. Tucker

ROS/php

Attachment

cc: Mr. James P. O'Reilly  
Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

NRC Resident Inspector  
Catawba Nuclear Station

Mr. Robert Guild, Esq.  
Attorney-at-Law  
P. O. Box 12097  
Charleston, South Carolina 29412

Palmetto Alliance  
2135 1/2 Devine Street  
Columbia, South Carolina 29205

Mr. Jesse L. Riley  
Carolina Environmental Study Group  
854 Henley Place  
Charlotte, North Carolina 28207

8406120188 840608  
PDR ADOCK 05000413  
E PDR

AOAS  
1/1

CATAWBA NUCLEAR STATION

EMERGENCY COMMUNICATIONS

June 4, 1984

Technical Support Center to Operations Support Center

There are four possible channels of communications from the TSC to the OSC. These are:

- (1) Plant telephone lines, approximately 40 extensions in the TSC and 3 in the OSC.
- (2) Intercom between TSC-Control Room-OSC and Shift Supervisor's Office.
- (3) Plant page system for emergency use.
- (4) Messengers between TSC and OSC, both are located on the same plant elevation and only about 100 yards apart. Each location has respiratory protective devices, personnel protective clothing, dosimetry, flashlights and enough extra personnel on hand to send messengers if needed.