



UNITED STATES
NUCLEAR REGULATORY COMMISSION

50-267

REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76011

6 JUN 1984

MEMORANDUM FOR: James R. Miller, Chief
ORB-3, NRR

FROM: Eric H. Johnson, Chief
RPB-1, RIV

SUBJECT: REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE - NOTICE
OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO FACILITY
OPERATING LICENSE AND PROPOSED NO SIGNIFICANT HAZARDS
CONSIDERATION DETERMINATION AND OPPORTUNITY FOR A HEARING

Public Service Co. of Colorado, Docket No. 50-267, Fort St. Vrain Nuclear
Generating Station, Platteville, Colorado

Date of amendment request: May 10, 1984

Description of amendment request: The proposed change to the Technical Specifications would modify the secondary coolant activity analysis requirements. The change would: 1) eliminate the need for daily sampling if the activity increases by 25% over an equilibrium value, and 2) require daily sampling and analysis if the activity increases to 10 percent instead of the existing 25 percent of the Limiting Condition for Operation limit and weekly sampling at all other times during reactor operation.

Basis for proposed no significant hazards consideration determination: The Commission has provided guidance concerning the application of these standards by providing certain examples (48 FR 14870). The examples of actions that are considered not likely to involve significant hazards considerations include changes that constitute an additional limitation, restriction, or control not presently included in the Technical Specifications: for example, a more stringent surveillance requirement.

B406120197 B40606
PDR ADOCK 05000267
PDR

H205

Because the proposed changes will impose a more stringent sampling and analysis frequency, we propose to determine that this action involves no significant hazards considerations.

Local Public Document Room location: Greeley Public Library, City Complex Building, Greeley, Colorado

Attorney for licensee : Bryant O'Donnell, Public Service Company of Colorado, P. O. Box 840, Denver, Colorado 80201

NRC Branch Chief: Eric H. Johnson

Eric H. Johnson, Chief
Reactor Project Branch 1

cc: P. C. Wagner
E. M. Haycraft
G. C. Lainas
~~G. M. Trammell~~ T.G. Colburn
P. Kreutzer

[Handwritten signature]
D/RS&P:LA
EHaycraft:jj
5/30/84

RPB-1:PM *[Handwritten initials]*
PCWagner
5/31/84

[Handwritten signature]
RPB-1:SC/SPES
REIreland
6/31/84

[Handwritten signature]
RPB-1:BC
EHJohnson
6/31/84

[Handwritten signature]
RIVatty
WLBrown
6/3/84

[Handwritten signature]
n/DRSP
RPDenise
6/5/84