



NIAGARA MOHAWK POWER CORPORATION / 300 ERIE BOULEVARD WEST, SYRACUSE, N.Y. 13202 / TELEPHONE (315) 474-1511

May 31, 1984

Dr. Thomas E. Murley
Regional Administrator
U. S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406

Re: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Dear Dr. Murley:

In accordance with Information and Enforcement Bulletin 80-13, Niagara Mohawk has visually inspected the Nine Mile Point Unit 1 core spray spargers and associated internal piping during the 1984 refueling and maintenance outage. Our submittal of May 13, 1981 indicated two small cracks existed in the core spray system. Our recent reexamination appears to indicate that the two cracks may be one unique crack. The combined total length of the crack(s), however, remains insignificant (at present, $3/4$ inch + $1/4$ inch). Since no other indications of cracks were found, no corrective action is required at this time. Further, Niagara Mohawk will continue to visually inspect the core spray spargers and associated internal piping during future refueling outages.

Sincerely,

NIAGARA MOHAWK POWER CORPORATION

C. V. Mangan

C. V. Mangan
Vice President

Nuclear Engineering and Licensing

AJP:bd

cc: NRC Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D.C. 20555

Director Nuclear Reactor Regulation
Attention: Mr. Domenic B. Vassallo, Chief
Operating Reactors Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

8406120286 840531
PDR ADOCK 05000220
PDR

1/0 1E 11