

APPENDIX A

NOTICE OF VIOLATION

Public Service Electric and Gas Company  
Salem Nuclear Generating Station, Units 1 and 2

Docket No. 50-272/50-311  
License No. DPR-70/DPR-75

As a result of the inspection conducted on February 27-March 2, 1984, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C) published in the Federal Register on March 9, 1982 (47 FR 9987), the following violation was identified:

- A. An Order Modifying Licensee Effective Immediately, dated May 6, 1983 required that the licensee implement and/or maintain the items specified in their letter dated April 28, 1983. Public Service Electric and Gas Company letter dated April 28, 1983, Item C.8.a.2 requires a review of vendor and Engineering recommendations for post maintenance operability testing and incorporation of necessary changes into departmental documents by January 1984.

Contrary to the above, as of March 2, 1984, the licensee had not performed a review of all vendor documents for safety related equipment for post maintenance operability testing recommendations.

This is a Severity Level IV Violation (Supplement I) applicable to DPR-70 and DPR-75.

Pursuant to the provisions of 10 CFR 2.201, Public Service Electric and Gas Company is hereby required to submit to this office within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the corrective steps which will be taken and the results achieved; (2) the corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

8406120470 840524  
PDR ADOCK 05000272  
PDR  
G