

**TEXAS UTILITIES GENERATING COMPANY**  
SKYWAY TOWER \* 400 NORTH OLIVE STREET, L.B. 81 \* DALLAS, TEXAS 75201

**BILLY R. CLEMENTS**  
VICE PRESIDENT, NUCLEAR OPERATIONS

June 4, 1984  
TXX-4188

Mr. E. H. Johnson, Chief  
Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76012

Docket Nos. 50-445  
50-446

COMANCHE PEAK STEAM ELECTRIC STATION  
CURTAIN FIRE DAMPERS  
QA FILE: CP-84-08, SDAR-132  
FILE NO.: 10110

Dear Mr. Johnson:

On March 9, 1984 we verbally informed your Mr. D. Hunnicutt of a discrepancy with the installation of curtain fire dampers without proper provisions for thermal expansion. We have previously submitted an interim report logged TXX-4140, dated March 30, 1984.

We are continuing our evaluation and anticipate completion by August 13, 1984.

Very truly yours,

*Billy Clements*

BRC:tlg

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection and Enforcement - (15 copies)  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

8406120519 840604  
PDR ADOCK 05000445  
S PDR