

Omaha Public Power District  
444 South 16th Street Mall  
Omaha, Nebraska 68102-2247  
402/636-2000

January 24, 1992  
LIC 92-006R

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station #1-137  
Washington, DC 20555

- References:
1. Docket No. 50-285
  2. Letter from OPPD (K. J. Morris) to NRC (Document Control Desk) dated August 31, 1989 (LIC-89-0815)
  3. Letter from OPPD (K. J. Morris) to NRC (Document Control Desk) dated October 20, 1989 (LIC-89-0947)
  4. Letter from OPPD (W. G. Gates) to NRC (Document Control Desk) dated August 14, 1991 (LIC-91-074R)
  5. Letter from NRC (D. L. Wigginton) to OPPD (W. G. Gates) dated November 25, 1991

Gentlemen:

SUBJECT: Resolution of HED 93 Regarding Single Indicating Lamps

In Reference 5, the NRC found the proposed resolution to HED 93 by Omaha Public Power District (OPPD) to be unacceptable. OPPD held a telephone conference call with the NRC staff on December 20, 1991 to discuss the incandescent lamp administrative control program proposed in Reference 4.

The conversation centered on details of the administrative program proposed by OPPD in Reference 4 and its similarity to the LED lamp replacement program proposed in References 2 and 3. Based on this discussion, the NRC and OPPD agreed that:

1. The administrative incandescent lamp replacement program discussed in Reference 4 will be implemented by May 1, 1992 as an interim measure. No modifications on the subject matter will be implemented during the 1992 refueling outage.
- .. A probability determination of equivalency for administrative control of incandescent lamp replacement can be submitted by OPPD for NRC review.

OPPD intends to perform the determination noted in (2) above and submit it to the NRC by July 1, 1992.

If the NRC finds the administrative control program unacceptable after reviewing the probability plan discussed in (2) above, OPPD will modify the current single indicating lamps during the 1993 refueling outage.

9202030046 920124  
PDR ADOCK 05000285  
P PDR

ADD 1/0

LIC-92-006R  
Page 2

If you should have any questions, please contact me.

Sincerely,



W. G. Gattis  
Division Manager  
Nuclear operations

WGG/sei

c: LeBoeuf, Lamu, Leiby & MacRae  
R. D. Martin, NRC Regional Administrator, Region IV  
D. L. Wigglinton, NRC Senior Project Manager  
R. P. Mullikin, NRC Senior Resident Inspector