

CAROLINA POWER & LIGHT COMPANY

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
OFF-SITE DOSE CALCULATIONAL MANUAL  
(ODCM)

Revision 9

DOCKET NO. 50-261

EFFECTIVE DATE

1/1/95

Reviewed By:

*original signed by*  
Hale E. Young  
PNSC Chairman

Date:

12/30/94

Accepted By:

*original signed by*  
Hale E. Young  
PNSC Chairman

Date:

12/30/94

HBRODCM

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
	TABLE OF CONTENTS.....	i
	LIST OF TABLES.....	ii
	LIST OF FIGURES.....	iv
1.0	INTRODUCTION.....	1-1
2.0	LIQUID EFFLUENTS.....	2-1
2.1	Monitor Alarm Setpoint Determination.....	2-1
2.2	Compliance with 10CFR20 (Liquids).....	2-11
2.3	Compliance with 10CFR50 (Liquids).....	2-16
3.0	GASEOUS EFFLUENTS.....	3-1
3.1	Monitor Alarm Setpoint Determination.....	3-1
3.2	Compliance with 10CFR20 (Gaseous).....	3-15
3.3	Compliance with 10CFR50 (Gaseous).....	3-24
3.4	Methodology for RMS-11 Setpoint (Air Particulate).....	3-73
3.5	Methodology for R-14A Setpoint (Particulate Monitor).....	3-77
3.6	Methodology for R-14B Setpoint (Iodine Monitor).....	3-79
3.7	Methodology for R-22 and R-23 Setpoint Determinations for the Iodine and Particulate Monitors.....	3-80
4.0	RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM.....	4-1
5.0	INTERLABORATORY COMPARISON STUDIES.....	5-1
5.1	Objective.....	5-1
5.2	Program.....	5-1
6.0	TOTAL DOSE (40CFR190 CONFORMANCE).....	6-1
6.1	Compliance with 40CFR190.....	6-1
6.2	Calculations Evaluating Conformance with 40CFR190.....	6-1
6.3	Calculations of Total Body Dose.....	6-2
6.4	Thyroid Dose.....	6-3
6.5	Dose Projects.....	6-3
	APPENDIX A - Meteorological Dispersion Factor Computations.....	A-1
	APPENDIX B - Dose Parameters for Radioiodines, Particulates, and Tritium.....	B-1
	APPENDIX C - Lower Limit of Detectability.....	C-1



LIST OF TABLES

<u>No.</u>	<u>Title</u>	<u>Page</u>
2.3-1	Air Values for the Adult for the H.B. Robinson Steam Electric Plant.....	2-22
3.1-1	Gaseous Source Terms.....	3-13
3.1-2	Dose Factors and Constants.....	3-14
3.2-1	Releases from H.B. Robinson Unit No. 2.....	3-19
3.2-2	Distance to Special Locations for the H.B. Robinson Plant (Mi.).....	3-20
3.2-3	Dose Factors for Noble Gases and Daughters.....	3-21
3.2-4	P <sub>1</sub> Values for a Child for the H.B. Robinson Unit No. 2.....	3-22
3.3-1 thru 3.3-19	R Values for the H.B. Robinson Steam Electric Plant.....	3-35 thru 3-72
4.0-1	H.B. Robinson Radiological Environmental Monitoring Program.....	4-2
A-1	X/Q Values for Long-Term Ground Level Releases at Special Locations (sec/m <sup>3</sup> ).....	A-4
A-2	Depleted X/Q Values for Long-Term Ground Level Releases at Special Locations (sec/m <sup>3</sup> ).....	A-5
A-3	D/Q Values for Long-Term Ground Level Releases at Special Locations (m <sup>-2</sup> ).....	A-6
A-4	X/Q Values for Long-Term Ground Level Releases at Standard Distances (sec/m <sup>3</sup> ).....	A-7
A-5	Depleted X/Q Values for Long-Term Ground Level Releases at Standard Distances (sec/m <sup>3</sup> ).....	A-8
A-6	D/Q Values for Long-Term Ground Level Releases at Standard Distances (m <sup>-2</sup> ).....	A-9
A-7	X/Q Value for Short-Term Ground Level Releases at Special Locations (sec/m <sup>3</sup> ).....	A-10
A-8	Depleted X/Q Values for Short-Term Ground Level Releases at Special Locations (sec/m <sup>3</sup> ).....	A-11

LIST OF TABLES (continued)

<u>No.</u>	<u>Title</u>	<u>Page</u>
A-9	D/Q Values for Short-Term Ground Level Releases at Special Locations ( $m^{-2}$ ).....	A-12
A-10	X/Q Values for Long-Term Mixed Mode Releases at Special Locations ( $sec/m^3$ ).....	A-13
A-11	Depleted X/Q Values for Long-Term Mixed Mode Releases at Special Locations ( $sec/m^3$ ).....	A-14
A-12	D/Q Values for Long-Term Mixed Mode Releases at Special Locations ( $m^{-2}$ ).....	A-15
A-13	X/Q Values for Long-Term Mixed Mode Releases at Standard Distances ( $sec/m^3$ ).....	A-16
A-14	Depleted X/Q Values for Long-Term Mixed Mode Releases at Standard Distances ( $sec/m^3$ ).....	A-17
A-15	D/Q Values for Long-Term Mixed Mode Releases at Standard Distances ( $m^{-2}$ ).....	A-18
A-16	X/Q Values for Short-Term Mixed Mode Releases at Special Locations ( $sec/m^3$ ).....	A-19
A-17	Depleted X/Q Values for Short-Term Mixed Mode Releases at Special Locations ( $sec/m^3$ ).....	A-20
A-18	D/Q Values for Short-Term Mixed Mode Releases at Special Locations ( $m^{-2}$ ).....	A-21
A-19	Robinson Plant Site Information to be Used for Ground Level Calculations with NRC "XOQDOQ" Program.....	A-22
A-20	Robinson Plant Site Information to be Used for Mixed Mode Release Calculations with NRC "XOQDOQ" Program.....	A-25
B-1	Parameters for Cow and Goat Milk Pathways.....	B-15
B-2	Parameters for the Meat Pathway.....	B-16
B-3	Parameters for the Vegetable Pathway.....	B-17
D-1	Liquid Process Monitors.....	D-1
D-2	Gaseous Process Monitors.....	D-2

LIST OF FIGURES

<u>No.</u>	<u>Title</u>	<u>Page</u>
4-1	Radiological Sample Locations Near Site.....	4-9
4-2	Radiological Sample Distant Locations.....	4-10
D-1	H.B. Robinson Liquid Radwaste Effluent System.....	D-3
D-2	H.B. Robinson Gaseous Radwaste Effluent System.....	D-4

## 1.0 INTRODUCTION

The Off-Site Dose Calculation Manual (ODCM) provides the information and methodologies to be used by H. B. Robinson Steam Electric Plant Unit 2 (HBR) to assure compliance with Specifications 3.9.1, 3.9.2, 3.9.3, 3.9.4, 3.9.5, and 3.9.6 of the H. B. Robinson Technical Specifications. These portions are those related to liquid and gaseous radiological effluents. They are intended to show compliance with 10CFR20, Appendix I of 10CFR50, and 40CFR190.

The ODCM is based on "Radiological Effluent Technical Specifications for PWRs (NUREG 0472, Rev. 3, Draft 7), "Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants" (NUREG 0133), and guidance from the United States Nuclear Regulatory Commission (NRC). Specific plant procedures for implementation of this manual are presented in H. B. Robinson Unit 2 Plant Operating Manual. These procedures will be utilized by the operating staff of HBR to assure compliance with technical specifications.

Changes to the ODCM which affect the methodologies showing compliance with 10CFR20, Appendix I of 10 CFR 50, and 40 CFR 190 will be properly reviewed and approved as indicated in the Administrative Control Section of Plant Technical Specifications. Site specific parameters such as vent fractions, dilution water flow rates (gpm), and liquid/gaseous discharge flow rates are listed in this document as typical system values. Actual values derived from actual operating Plant conditions should be used in lieu of these typical values. Specific Plant procedures control the values of the above parameters; therefore, minimizing the need for frequent revisions to the O.D.C.M.

The Semiannual Radioactive Effluent Release Report prepared after July 1 and January 1. of each year will be compiled on the Canberra Nuclear Effluent Management System software. This report will be prepared as outlined in Regulatory Guide 1.21. "Measuring, Evaluating, and Reporting Radioactivity in Solid Waste and Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants" (Revision 1, June 1974) with data summarized on a quarterly basis following the format of Appendix B thereof.

The Semiannual Radioactive Effluent Release Report prepared after January 1 of each year will include an assessment of the radiation doses from radioactive liquid and gaseous effluents using LADTAP and GASPAR software using concurrent meteorology obtained during the report period. This report will be inclusive of the requirements as outlined in the HBR Technical Specifications.



## 2.0 LIQUID EFFLUENTS

### 2.1 MONITOR ALARM SETPOINT DETERMINATION

This methodology determines the monitor alarm setpoint that indicates if the concentration of radionuclides in the liquid effluent released from the site to unrestricted areas exceeds the concentrations specified in 10CFR20, Appendix B, Table II, Column 2, for radionuclides other than dissolved or entrained noble gases or exceeds a concentration  $2 \times 10^{-4}$   $\mu\text{Ci/ml}$  for dissolved or entrained noble gases. Two methodologies may be utilized to calculate monitor alarm setpoints. Section 2.1.1 determines a fixed setpoint based on the worst case assumptions that Cs-134 is the only nuclide being discharged. This is consistent with the limit of 10CFR20, Appendix B, Note 2. Section 2.1.2 methodology determines the setpoint based on the radionuclide mix via analysis prior to release to demonstrate compliance with 10CFR20, Appendix B, limits and may also be used as an alternative method for calculating setpoints.

#### 2.1.1 Setpoint Based on Cs-134

The following method applies to liquid releases via the discharge canal when determining the alarm/trip setpoint for the Condensate Polisher Liquid Waste Monitor (R-37) and the Steam Generator Blowdown Monitor (R-19A, R-19B, and R-19C) during operational conditions when there is no primary to secondary leaks. This methodology complies with Specification 3.9.1.1 of the RETS by satisfying the following equation:

$$\frac{cf}{f + F} \leq C$$

where:

C     "     The effluent concentration limit (Specification 3.9.1.1) implementing 10 CFR 20 for the site in  $\mu\text{Ci/ml}$ .

c - The setpoint, in  $\mu\text{Ci/ml}$ , of the radioactivity monitor measuring the radioactivity concentration in the effluent line prior to dilution and subsequent release; the setpoint represents a value which, if exceeded, would result in concentrations exceeding 10 times the limits of 10CFR20 in the unrestricted area.

f - The waste effluent flow rate in gpm.

F - The dilution water flow rate in gpm.

2.1.1.1 Determine c (the effluent monitor setpoint) in [ $\mu\text{Ci/ml}$ ] for each of the dilution water flow rates.

$$\text{where: } c = \frac{C(F + f)}{f} (S)$$

where:

C -  $9 \times 10^{-7} \mu\text{Ci/ml}$ , the effluent concentration limit based on 10CFR20, Appendix B, for Cs-134.

F - Dilution water flow rate (gpm).  
- 160,000 gpm from one circulating water pump<sup>1</sup>, Unit 2.  
- 250,000 gpm from two circulating water pumps<sup>1</sup>, Unit 2.  
- 400,000 gpm from three circulating water pumps<sup>1</sup>, Unit 2.

or

- 50,000 gpm from one circulating water pump<sup>2</sup>, Unit 1.  
- 80,000 gpm from two circulating water pumps<sup>2</sup>, Unit 1.  
f - The maximum acceptable discharge flow rate prior to dilution (gpm).  
- 60 gpm for the Waste Disposal System Liquid Effluent Monitor<sup>3</sup>.

- 160 gpm for each Steam Generator Blowdown Monitor.
- 130 gpm for each Steam Generator Blowdown Monitor while draining a steam generator.
- 300 gpm for the Condensate Polisher Liquid Waste Monitor.

- S - 0.5, safety factor used as a conservatism to assure that the radionuclide concentrations are less than the limits specified in 10CFR20, Appendix B, at the point of discharge.

2.1.1.2 Determine CR (calculated monitor count rate in corrected counts per minute [ccpm]) attributed to the radionuclides for each of the dilution water flow rates.

CR - (c) (E)

- E - The applicable effluent monitor efficiency located in the Plant Operating Manual, Volume 15, Curve Book. Use the radioactivity concentration "c" to find CR.

2.1.1.3 Determine SP (the monitor alarm/trip setpoint including background [cpm] for each of the dilution water flow rates.

$$SP = (T_s)(CR) + Bkg$$

where:

- $T_s$  - Fraction of the radioactivity from the site that may be released via the monitored pathway to ensure that the site boundary limit is not exceeded due to simultaneous releases from several pathways.

- .16 for each Steam Generator Blowdown Monitor (R-19A, R-19B, and R-19C).

- .25 for the Condensate Polisher Liquid Waste (R-37).

Bkg - the monitor background.

## 2.1.2

Setpoint Based on an Analysis of Liquid Prior to Discharge

The following method applies to liquid releases via the discharge canal when determining the alarm setpoint for the Waste Disposal System Liquid Effluent Monitor (R-18), the Steam Generator Blowdown Monitors (R-19A, R-19B, and R-19C), and the Condensate Polisher Liquid Waste Monitor (R-37) when an analysis of the activity of the principal gamma emitters has been made prior to or during the release.

2.1.2.1 Determine  $D_{req}$  (the minimum acceptable dilution factor):

$$D_{req} = D_{req,g} + D_{req,ng}$$

$$D_{req,g} = \frac{\sum_{i=ng} \frac{C_i}{ECL_i}}{(S) (R_{max})}$$

$$D_{req,ng} = \frac{\sum_{i=ng} \frac{C_i}{ECL_i}}{(S) (R_{max})}$$

where:

$D_{req,g}$  - required dilution factor for gamma-emitters.

$D_{req,ng}$  - required dilution factor for non-gamma-emitters  
(Gross Alpha, H-3, Sr-89, Sr-90, and Fe-55).

$ECL_i$  - effluent concentration limit of nuclide i in  $\mu\text{Ci/ml}$ .

- $C_i$  - the concentration of nuclide  $i$  in  $\mu\text{Ci/ml}$ .
- $S$  - 0.5, a safety factor used for conservatism to assure that the radionuclide concentrations are less than the limits specified in 10 CFR Part 20 Appendix B, at the point of discharge.
- $R_{\text{max}}$  - The maximum ECL ratio limit.

2.1.2.2 Determine the maximum waste flow,  $R_{\text{CWMAX}}$ :

$$R_{\text{CWMAX}} = \frac{(F_{\text{avail}})(F_{\text{alloc}})}{(D_{\text{req}} - 1.0)}$$

- $F_{\text{avail}}$  - Available dilution flow in gpm.
  - 160,000 gpm from one circulating water pump<sup>1</sup>, Unit 2.
  - 250,000 gpm from two circulating water pumps<sup>1</sup>, Unit 2.
  - 400,000 gpm from three circulating water pumps<sup>1</sup>, Unit 2.
  - or
  - 50,000 gpm from one circulating water pump<sup>2</sup>, Unit 1.
  - 80,000 gpm from two circulating water pumps<sup>2</sup>, Unit 1.
- $F_{\text{alloc}}$  - Fraction of the radioactivity from the site that may be released via the monitored pathway to ensure that the site boundary limit is not exceeded due to simultaneous releases from more than one pathway.
  - 0.25 for the Waste Disposal System Liquid Effluent Monitor (R-18).
  - 0.16 for each of the Steam Generator Blowdown Monitor (R-19A, R-19B or R-19C).
  - 0.25 for the Condensate Polisher Liquid Waste (R-37).

If it is determined that  $\frac{F_{\text{avail}} + F_{\text{waste}}}{(D_{\text{req}})(F_{\text{waste}})} < 1$ , the release cannot be made.

Reevaluate the discharge flowrate prior to dilution and/or dilution flow rates.

If  $\frac{F_{\text{avail}} + F_{\text{waste}}}{(D_{\text{req}})(F_{\text{waste}})} > 1$ , the release can be made.



2.1.2.3 Determine the setpoint adjustment factor,  $S_{adj}$  :

$$S_{adj} = \frac{\frac{((F_{alloc})(F_{avail}) + F_{waste})}{F_{waste}} - D_{req,ng}}{D_{req,g}}$$

- $F_{waste}$  - Waste flow anticipated for this release (gpm).
- 60 gpm for the Waste Disposal System Liquid Effluent Monitor<sup>3</sup>.
- 160 gpm for each Steam Generator Blowdown Monitor.
- 130 gpm for each Steam Generator Blowdown Monitor while draining a steam generator.
- 300 gpm for the Condensate Polisher Liquid Waste Monitor.

2.1.2.4 Determine  $S_{max}$  monitor alarm setpoint in  $\mu\text{Ci/ml}$ :

$$S_{max} (\mu\text{Ci/ml}) = (S_{adj})(\Sigma C_i)$$

- $C_i$  - All gamma-emitting nuclides ( $\mu\text{Ci/ml}$ ).

2.1.2.5 Determine the monitor alarm setpoint ( $S_{maxcpm}$ ) in CPM:

$$S_{maxcpm} = (S_{max})(E_m) + Bkg$$

- $E_m$  - The applicable effluent monitor efficiency based on  $S_{max}$  from the efficiency curves located in the Plant Operating Manual, Volume 15, Curve Book.

- $Bkg$  - The monitor background in CPM.

(Left blank intentionally for future revisions)

(Left blank intentionally for future revisions)

(Left blank intentionally for future revisions)

SECTION 2.1 REFERENCES

1. Carolina Power & Light Company Drawing Number G-190825. Using the System Q-H Curve for Emergency Low Water Level.
2. Carolina Power & Light Company, Darlington County S.E. Plant. 1960-182 MW Installation, Unit 1. SYSTEM HEAD CURVES Unit 1 Circulating Water System Draining Quosig.
3. H.B. Robinson Electric Plant Unit 2, Updated Final Safety Analysis Report.



## 2.2 COMPLIANCE WITH 10CFR20 (LIQUIDS)

Liquid effluents from H.B. Robinson Unit 2 (HBR) will occur both continuously and on a batch basis. The following sections discuss the methodology which will be utilized by the HBR to show compliance with 10CFR20.

2.2.1 Continuous Releases

Steam generator blowdown may be a continuous release from HBR. During release periods grab samples will be taken of steam generator blowdown and analyzed for I-131, fission, activation, and corrosion products as outlined in Table 4.10-1 of the Technical Specification for HBR. These samples are then composited at a rate using the following equation:

$$V_{up} = V_{cp} [V_a/V_t]$$

where:

- $V_{up}$  = Volume to be replaced/updated (milliliters)
- $V_{cp}$  = Volume of the composite (milliliters)
- $V_a$  = Actual volume released from grab sample (gallons)
- $V_t$  = Total waste volume (gallons) released to date, including volume  $V_a$ , within the compositing period.

Compliance with 10CFR20 during actual release is established through the steam generator blowdown effluent monitor alarm setpoint. This setpoint is based upon Cs-134 as noted in Section 2.1. However, if a continuous release should occur in which the effluent monitor alarm setpoint is exceeded, then actual compliance with 10CFR20 may be determined utilizing the actual radionuclide mix and the following equation:

$$Conc_i = \frac{C_{ic} V_c}{V_{dc}} \quad (2.2-1)$$

where:

$Conc_i$  = Concentration of radionuclide "i" at the unrestricted area,  $\mu Ci/ml$ ;

$C_{ic}$  = Concentration of radionuclide "i" in the continuous release,  $\mu Ci/ml$ ;

$V_c$  = Volume of continuous effluent released, gal;

$V_{dc}$  = Volume of dilution flow during release, gal.

### 2.2.2 Batch Releases

Batch releases will occur during normal operation. When this does occur at HBR, a continuous release will usually be occurring at the same time. However, during certain shutdown conditions, only batch releases may occur at HBR. Therefore, both situations are treated here to provide the methodology to show compliance with 10CFR20.

#### 2.2.2.1 Prerelease

The radioactivity content of each batch release will be determined prior to release in accordance with Table 4.10-1 of the technical specifications for HBR. HBR will show compliance with 10CFR20 in the following manner:

For the case where only a batch release is to occur, the concentration of the various radionuclides in the batch release, determined in accordance with Table 4.10-1 of the technical specifications for HBR, is multiplied by the ratio of the maximum release rate of the potential batch release to the dilution flow rate to obtain the concentration at the unrestricted area. This calculation is shown in the following equation:

$$Conc_i = \frac{C_{ib} R_b}{D_{fr} T_m} \quad (2.2-2)$$

where:

- $Conc_i$  - Concentration of radionuclide "i" at the unrestricted area,  $\mu\text{Ci/ml}$ ;
- $C_{ib}$  - Concentration of radionuclide "i" in the potential batch release,  $\mu\text{Ci/ml}$ ;
- $R_b$  - Release rate of the potential batch release, gpm;
- $D_{fr}$  - The dilution flow rate based upon the number of circulating water pumps in service during the release, gpm.
- $T_m$  - Fraction of dilution flow allocated to this release.

The concentration in the unrestricted area is compared to the concentrations in Appendix B, Table II, Column 2, of 10CFR20. Before release may occur, the mixture of radionuclides released must be of such concentration that Equation 2.2-3 is met.

$$\sum_i (Conc_i/EC_i) \leq 1 \quad (2.2-3)$$

where:

- $EC_i$  - Effluent Concentration Limit of radionuclide "i" from Appendix B, Table II, Column 2 of 10CFR20,  $\mu\text{Ci/ml}$ .

For those cases where batch releases may be occurring at the same time that continuous releases are occurring, the concentration in the unrestricted area will be calculated by the following equation:

$$Conc_i = \frac{C_{ib} R_b + C_{ic} R_c}{D_{fr} \sum T_m} \quad (2.2-4)$$

where:

- $R_c$  - Maximum continuous liquid effluent release rate, gpm.
- $\sum T_m$  - Summation of allocation fractions for these concurrent releases

The mixture of radionuclides released must be of such concentrations that Equation 2.2-3 must be met.

For HBR, the liquid radwaste effluent line discharges to the circulating water system. Therefore, the dilution flow rate ( $D_{fr}$ ) is a function of the number of circulating water pumps operating. Unit 2 of the H.B. Robinson Steam Electric Plant has three circulating water pumps. Pump curves show that with three pumps operating, the circulating water flow is 400,000 gpm, with two pumps--250,000 gpm, and with one pump--160,000 gpm. Unit 1 of the H.B. Robinson Steam Electric Plant has two circulating water pumps. The circulating water flow is 50,000 gpm with one pump and 80,000 gpm with two pumps. At least one circulating water pump must be operating during any liquid waste discharge.

Batch releases from the HBR liquid radwaste system may occur from the waste condensate tanks, the monitor tanks, and the steam generators (during drainage). Continuous release may occur from Steam Generator Blowdown and the Condensate Polisher Liquid Waste. The maximum administrative release rate ( $R_b$ ) is 160 gpm for each of the steam generators, 60 gpm from the monitor and waste condensate tanks, and 300 gpm for the Condensate Polisher Liquid Wastes, and 130 for each of the steam generators during drainage.

#### 2.2.2.2 Postrelease

The Steam Generation Blowdown Monitor (R-19A, R-19B, and R-19C), the Waste Disposal System Liquid Monitor (R-18), and the Condensate Polisher Liquid Waste Monitor (R-37) setpoint will each be limited to 50 percent of the 10CFR20 limits. These setpoints will ensure that 10CFR20 limits are met. However, because they are based upon a given mix, the possibility exists that the alarm trip setpoints may be exceeded, while 10CFR20 limits are not exceeded. The following methodology is provided to determine whether actual releases exceeded 10CFR20 limits.

The concentration of each radionuclide in the unrestricted area following release from a batch tank will be calculated in the following manner:

For the case where only batch releases are occurring, the total activity of radionuclide "i" released is divided by the actual dilution flow to obtain the concentration in the unrestricted area. This calculation is shown in the following equation:

$$Conc_{ik} = \frac{C_{ikb} V_{kb}}{V_{kd}} \quad (2.2-5)$$

where:

- Conc<sub>ik</sub> - The concentration of radionuclide "i" at the unrestricted area during release k,  $\mu\text{Ci/ml}$ ;
- C<sub>ikb</sub> - Concentration of radionuclide "i" in the batch release k,  $\mu\text{Ci/ml}$ ;
- V<sub>kb</sub> - Volume of batch release k, gal;
- V<sub>kd</sub> - Actual volume of dilution flow during release k, gal.

To show compliance with 10CFR20, the following relationship must hold:

$$\Sigma_i (Conc_{ik} / EC_i) \leq 1 \quad (2.2-6)$$

The actual dilution volume during release k (V<sub>kd</sub>) is calculated by the following equation:

$$V_{kd} = 60 \Sigma_k (D_{fr}) t_k \quad (2.2-7)$$

where:

- 60 - Conversion factor, min/hr;
- t<sub>k</sub> - Duration of release k, hr;



$D_{kr}$  = Dilution flow rate from circulating water pumps during release  
k, gpm.

The circulating water pump flow rates were given in Section 2.2.2.1 above.

For the case where a batch release is occurring at the same time that a continuous release is occurring, the compliance with 10CFR20 limits may be determined by the following equation:

$$CONC_{ik} = \frac{C_{ikb} V_{kb} + C_{ikc} V_{kc}}{V_{kd}} \quad (2.2-8)$$

where:

$C_{ikc}$  = Concentration of radionuclide "i" in continuous releases during release period k,  $\mu\text{Ci/ml}$ ;

$V_{kc}$  = Volume of continuous release during period k, gal.

Calculated concentrations are to be compared to the concentration in Appendix B, Table II, Column 2, of 10CFR20.

## 2.3 COMPLIANCE WITH 10CFR50

### 2.3.1 Cumulation of Doses

The dose contribution from the release of liquid effluents will be calculated once per month, and a cumulative summation of these total body and any organ doses should be maintained for each calendar quarter. The dose contribution for all batch releases will be calculated using the following equation:

$$D_{td} = \sum_k \sum_i A_{it} t_{kb} C_{ikb} F_{kb} \quad (2.3-1)$$

where:

- $D_{rb}$  - The cumulative dose commitment to the total body or any organ  $r$ , from batch liquid effluents, mrem;
- $t_{kb}$  - The length of time of batch release  $k$  over which  $C_{ikb}$  and  $F_{kb}$  are averaged for each batch liquid release, hours;
- $C_{ikb}$  - The average concentration of radionuclide "i" in undiluted batch liquid effluent during batch release  $k$ ,  $\mu\text{Ci/ml}$ ;
- $A_{1r}$  - The site-related ingestion dose commitment factor to the total body or any organ  $r$  for each identified principal gamma and beta emitter, mrem/hr per  $\mu\text{Ci/ml}$ ;
- $F_{kb}$  - The near-field average dilution factor for  $C_{ikb}$  during any batch liquid effluent release  $k$ . Defined as the ratio of the volume of undiluted liquid waste released to the product of the dilution volume from the site discharge structure to unrestricted receiving waters times 1.0. (1.0 is the site-specific applicable factor for the mixing effect of the HBR discharge structure as defined in NUREG-0133, October 1978).
- $$= \frac{V_{kb}}{V_{kd} \times 1.0}$$

Where  $V_{kb}$  and  $V_{kd}$  are as defined in Equation 2.2-5.

The dose factor  $A_{1r}$  was calculated for an adult for each isotope using the following equation:

$$A_{1r} = 1.14 \times 10^5 (21BF_1) DF_{1r} \quad (2.3-2)$$

where:

$$1.14 \times 10^5 = 10^6 \frac{\text{pCi}}{\mu\text{Ci}} \times 10^3 \frac{\text{ml}}{\text{l}} \times \frac{1 \text{ yr}}{8760 \text{ hr}}$$

- 21 - Adult fish consumption rate from Table E-5 of Regulatory Guide 1.109, Revision 1, kg/yr;
- $BF_i$  - Bioaccumulation factor for radionuclide "i" in fish from Table A-1 of Regulatory Guide 1.109, Revision 1, pCi/kg per pCi/l;
- $DF_{i,r}$  - Dose conversion factor for radionuclide "i" for adults for a particular organ  $r$  from Table E-11 of Regulatory Guide 1.109, Revision 1, mrem/pCi.

The potable water pathway does not exist either within Lake Robinson or downstream of the Lake Robinson dam. Therefore, the potable water term was excluded from the calculation of  $A_{i,r}$  values. Table 2.3-1 presents  $A_{i,r}$  values for an adult at HBR.

As noted in Section 2.2.2, steam generator blowdown is continuously released from HBR. The dose from continuous releases will be calculated using the following equation:

$$D_{rc} = \sum_k \sum_i A_{i,r} t_{kc} C_{ikc} F_{kc} \quad (2.3-3)$$

where:

- $D_{rc}$  - The cumulative dose commitment to the total body or any organ  $r$ , from liquid effluents for continuous releases, mrem;
- $t_{kc}$  - The length of time of continuous release period  $k$  over which  $C_{ikc}$  and  $F_{kc}$  are averaged for all continuous liquid releases, hours;
- $C_{ikc}$  - The average concentration of radionuclide "i" in undiluted liquid effluent during continuous release period  $k$  from any continuous liquid release,  $\mu\text{Ci/ml}$ ;

$F_{kc}$  - The near-field average dilution factor for  $C_{ikc}$  during continuous liquid effluent release  $k$ . Defined as the ratio of the volume of undiluted liquid waste released to the product of the dilution volume from the site discharge structure to unrestricted receiving water times 1.0. (1.0 is the site-specific applicable factor for the mixing effect of the HBR discharge structure as defined in NUREG-0133, October 1978).

$$F_{kc} = \frac{V_{kc}}{V_{kd} \times 1.0}$$

Where  $V_{kc}$  and  $V_{kd}$  are, as defined in Equations 2.2-8 and 2.2-5 respectively, only now distinguished for continuous releases.

The sum of the cumulative dose from all batch and continuous releases for a quarter are compared to one half the design objectives for total body and any organ. The sum of the cumulative doses from all batch and continuous releases for a calendar year are compared to the design objective doses. The following relationships should hold for HBR to show compliance with Technical Specification 3.9.2.1 of the technical specifications for H.B. Robinson Unit 2.

For the calendar quarter,

$$D_r \leq 1.5 \text{ mrem total body} \quad (2.3-4)$$

$$D_r \leq 5 \text{ mrem any organ} \quad (2.3-5)$$

For the calendar year,

$$D_r \leq 3 \text{ mrem total body} \quad (2.3-6)$$

$$D_r \leq 10 \text{ mrem any organ} \quad (2.3-7)$$

where:

- $D_r$  - Cumulative total dose to any organ  $r$  or the total body from continuous and batch releases, mrem;
- $D_{rb} + D_{rc}$

The quarterly limits given above represent one half the annual design objective of Section II.A of Appendix I of 10CFR50. If any of the limits in Expressions 2.3-4 through 2.3-7 are exceeded, a special report pursuant to Technical Specification 6.9.3.2 must be filed with the NRC. This report complies with Section IV.A, of Appendix I of 10CFR50.

### 2.3.2 Projection of Doses

Doses resulting from the release of liquid effluents will be projected once per 31 days. These projections will include a safety margin, based upon expected operational conditions, which will take into consideration both planned and unplanned releases.

Projected dose will be calculated as follows:

$$PD = \frac{31 (DA + DB)}{(TE)} + M \quad (2.3-8)$$

where:

- PD - projected doses in mrem.
- DA - dose accumulated during current quarter in mrem.
- DB - projected dose from this release.
- TE - time elapsed in quarter in days.
- M - safety margin in mrem.

If the projected doses exceed 0.2 mrem to the whole body or 0.6 mrem to any organ when averaged over a calendar quarter, the liquid radwaste equipment will be operated to reduce the radioactive materials in the liquid effluent.

(Left blank intentionally).



TABLE 2.3-1  
 A<sub>17</sub> VALUES for the ADULT for the H.B. ROBINSON STEAM ELECTRIC PLANT  
 (mrem/hr per  $\mu\text{Ci}/\text{ml}$ )

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-LLI</u>	<u>Skin</u>
H-3	0.00E+00	2.27E-01	2.27E-01	2.27E-01	2.27E-01	2.27E-01	2.27E-01	2.27E-01
F-18	2.30E-02	2.13E-02	2.15E-02	2.13E-02	2.13E-02	2.13E-02	2.13E-02	2.51E-02
NA-24	1.35E+02	1.35E+02	1.35E+02	1.35E+02	1.35E+02	1.35E+02	1.35E+02	7.45E-01
CR-51	2.51E-01	2.51E-01	1.49E+00	9.94E-01	5.25E-01	1.90E+00	3.13E+02	2.96E-01
MN-54	7.45E+01	4.45E+03	9.09E+02	7.45E+01	1.38E+03	7.45E+01	1.35E+04	8.74E+01
MN-56	4.86E-02	2.23E-01	7.94E-02	4.86E-02	2.69E-01	4.86E-02	5.60E+00	5.74E-02
FE-55	6.59E+02	4.55E+02	1.06E+02	0.00E+00	0.00E+00	2.54E+02	2.61E+02	0.00E+00
FE-59	1.04E+03	2.42E+03	9.38E+02	1.47E+01	1.47E+01	6.88E+02	8.04E+03	1.72E+01
CO-57	1.01E+01	2.89E+01	4.49E+01	1.01E+01	1.01E+01	1.01E+01	5.41E+02	1.11E+01
CO-58	2.04E+01	1.09E+02	2.19E+02	2.04E+01	2.04E+01	2.04E+01	1.81E+03	2.39E+01
CO-60	1.16E+03	1.41E+03	1.72E+03	1.16E+03	1.16E+03	1.16E+03	5.98E+03	1.36E+03
NI-65	1.88E-01	3.83E-02	2.62E-02	1.60E-02	1.60E-02	1.60E-02	5.83E-01	1.86E-02
CU-64	3.26E-02	2.73E+00	1.30E+00	3.26E-02	6.83E+00	3.26E-02	2.30E+02	3.70E-02
ZN-65	2.32E+04	7.37E+04	3.33E+04	4.02E+01	4.93E+04	4.02E+01	4.64E+04	4.62E+01
BR-82	1.15E+00	1.15E+00	1.42E+03	1.15E+00	1.15E+00	1.15E+00	1.63E+03	1.33E+00
BR-83	2.62E-04	2.62E-04	3.87E-02	2.62E-04	2.62E-04	2.62E-04	5.56E-02	3.81E-04
BR-84	1.09E-02	1.09E-02	1.09E-02	1.09E-02	1.09E-02	1.09E-02	1.09E-02	1.27E-02
RB-86	4.83E-01	9.75E+04	4.54E+04	4.83E-01	4.83E-01	4.83E-01	1.92E+04	5.52E-01
RB-88	1.78E-03	1.78E-03	1.78E-03	1.78E-03	1.78E-03	1.78E-03	1.78E-03	2.03E-03
RB-89	6.61E-03	6.61E-03	6.61E-03	6.61E-03	6.61E-03	6.61E-03	6.61E-03	7.93E-03
SR-89	2.19E+04	1.16E-03	6.27E+02	1.16E-03	1.16E-03	1.16E-03	3.51E+03	1.35E-03
SR-90	5.45E+05	0.00E+00	1.34E+05	0.00E+00	0.00E+00	0.00E+00	1.58E+04	0.00E+00
SR-91	7.09E+01	1.16E-01	2.98E+00	1.16E-01	1.16E-01	1.16E-01	3.37E+02	1.35E-01
SR-92	3.76E-01	4.18E-02	5.62E-02	4.18E-02	4.18E-02	4.18E-02	6.66E+00	4.64E-02
Y-91M	5.39E-03	5.39E-03	5.39E-03	5.39E-03	5.39E-03	5.39E-03	5.39E-03	6.24E-03
Y-91	8.41E+00	5.77E-02	2.81E-01	5.77E-02	5.77E-02	5.77E-02	4.60E+03	6.49E-02
Y-92	1.02E-02	9.70E-03	9.72E-03	9.70E-03	9.70E-03	9.70E-03	8.09E+00	1.15E-02
Y-93	4.08E-02	9.86E-03	1.07E-02	9.86E-03	9.86E-03	9.86E-03	9.82E+02	1.35E-02
ZR-95	1.34E+01	1.32E+01	1.32E+01	1.32E+01	1.33E+01	1.32E+01	2.55E+02	1.53E+01
ZR-97	1.64E-01	1.60E-01	1.60E-01	1.59E-01	1.61E-01	1.59E-01	3.11E+02	1.85E-01
NB-95	4.46E+02	2.51E+02	1.39E+02	7.35E+00	2.49E+02	7.35E+00	1.48E+06	8.65E+00
NB-97	9.47E-03	9.47E-03	9.47E-03	9.47E-03	9.47E-03	9.47E-03	1.29E-02	1.11E-02
MO-99	2.15E-01	8.06E+01	1.55E+01	2.15E-01	1.82E+02	2.15E-01	1.86E+02	2.49E-01
TC-99M	1.05E-02	1.15E-02	3.01E-02	9.90E-03	3.40E-02	1.07E-02	9.47E-01	1.13E-02
TC-101	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.09E-03	1.22E-03

TABLE 2.3-1 (continued)

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-LLI</u>	<u>Skin</u>
RU-103	1.02E+01	5.82E+00	7.70E+00	5.82E+00	2.25E+01	5.82E+00	5.15E+02	6.79E+00
RU-105	4.29E-02	3.42E-02	3.77E-02	3.42E-02	1.47E-01	3.42E-02	5.36E+00	3.88E-02
RU-106	8.85E+01	2.27E+01	3.10E+01	2.27E+01	1.50E+02	2.27E+01	4.28E+03	2.72E+01
AG-110M	1.86E+02	1.86E+02	1.85E+02	1.85E+02	1.86E+02	1.85E+02	5.17E+02	2.16E+02
SN-113	2.00E+03	7.80E+01	1.90E+03	2.80E+01	5.75E+01	7.66E-01	3.50E+04	2.19E+00
SB-124	3.88E+01	3.23E+01	3.48E+01	3.22E+01	3.22E+01	3.73E+01	2.21E+02	3.71E+01
SB-125	1.30E+02	1.26E+02	1.27E+02	1.26E+02	1.26E+02	1.29E+02	1.73E+02	1.42E+02
TE-129M	1.08E+04	4.03E+03	1.71E+03	3.71E+03	4.51E+04	1.06E+00	5.44E+04	1.24E+00
TE-129	1.43E-03	1.42E-03	1.42E-03	1.42E-03	1.49E-03	1.41E-03	1.42E-03	1.67E-03
TE-131M	9.54E+02	4.67E+02	3.89E+02	7.39E+02	4.72E+03	4.32E-01	4.63E+04	5.09E-01
TE-132	1.95E+03	1.26E+03	1.19E+03	1.40E+03	1.22E+04	2.28E-01	5.98E+04	2.68E-01
I-131	1.38E+02	1.97E+02	1.13E+02	6.44E+04	3.38E+02	9.25E-01	5.27E+01	1.12E+00
I-132	7.23E-02	8.11E-02	7.19E-02	5.61E-01	8.95E-02	6.70E-02	6.96E-02	7.88E-02
I-133	2.31E+01	4.01E+01	1.23E+01	5.87E+03	6.98E+01	1.32E-01	3.60E+01	1.60E-01
I-134	2.40E-02	2.40E-02	2.40E-02	2.40E-02	2.40E-02	2.40E-02	2.40E-02	2.85E-02
I-135	1.42E+00	3.50E+00	1.38E+00	2.22E+02	5.54E+00	1.36E-01	3.94E+00	1.59E-01
CS-134	2.98E+05	7.10E+05	5.80E+05	3.69E+02	2.30E+05	7.66E+04	1.28E+04	4.30E+02
CS-136	2.96E+04	1.17E+05	8.42E+04	8.12E+00	6.51E+04	8.93E+03	1.33E+04	9.20E+00
CS-137	3.83E+05	5.23E+05	3.43E+05	5.55E+02	1.78E+05	5.95E+04	1.07E+04	6.47E+02
CS-138	1.93E-02	1.93E-02	1.93E-02	1.93E-02	1.93E-02	1.93E-02	1.93E-02	2.21E-02
BA-139	5.70E-03	5.69E-03	5.69E-03	5.69E-03	5.69E-03	5.69E-03	5.70E-03	6.41E-03
BA-140	1.86E+02	1.34E+00	1.32E+01	1.10E+00	1.18E+00	1.24E+00	3.81E+02	1.26E+00
BA-142	2.41E-03	2.41E-03	2.41E-03	2.41E-03	2.41E-03	2.41E-03	2.41E-03	2.75E-03
LA-140	1.13E+00	1.08E+00	1.05E+00	1.03E+00	1.03E+00	1.03E+00	3.67E+03	1.17E+00
LA-142	4.09E-02	4.09E-02	4.09E-02	4.09E-02	4.09E-02	4.09E-02	4.16E-02	4.90E-02
CE-141	7.57E-01	7.50E-01	7.37E-01	7.35E-01	7.42E-01	7.35E-01	5.75E+01	8.28E-01
CE-143	1.27E-01	1.89E+00	1.25E-01	1.24E-01	1.25E-01	1.24E-01	6.62E+01	1.41E-01
CE-144	4.91E+00	4.23E+00	3.80E+00	3.74E+00	4.03E+00	3.74E+00	3.98E+02	4.32E+00
PR-144	9.87E-05	9.87E-05	9.87E-05	9.87E-05	9.87E-05	9.87E-05	9.87E-05	1.13E-04
HF-181	1.33E+01	1.06E+01	1.09E+01	1.06E+01	1.06E+01	1.06E+01	2.12E+02	1.50E+01
W-187	1.48E+02	1.23E+02	4.32E+01	1.26E-01	1.26E-01	1.26E-01	4.04E+04	1.47E-01
NP-239	1.13E-01	9.41E-02	9.31E-02	9.20E-02	9.85E-02	9.20E-02	4.29E+02	1.06E-01

(Left blank intentionally).

### 3.0 GASEOUS EFFLUENTS

#### 3.1 MONITOR ALARM SETPOINT DETERMINATION

This methodology determines the monitor alarm setpoint if the dose rate in the unrestricted areas due to radionoble gases in the gaseous effluent released from the site to areas at and beyond the site boundary exceeds 500 mrem/year to the whole body or exceeds 3000 mrem/year to the skin using a conservative mix (GALE Code).

The methodology described in Section 3.1.2 provides an alternative means to determine monitor alarm setpoints when an analysis is performed prior to release.

##### 3.1.1 Setpoint Based on Conservative Radionuclide Mix (Ground and Mixed Mode Releases)

Releases through the steam generator flash tank vent can only occur through this vent when significant primary-to-secondary leakage exists within the steam generators and the blowdown is not going through heat recovery. Detection of primary-to-secondary leakage is accomplished most effectively by continuously monitoring the condenser vacuum pump vent (R-15). Steam generator blowdown is continuously monitored by R-19A, R-19B, and R-19C as a liquid pathway. The condenser vacuum pump vent discharges via plant vent which is monitored by R-14.

The following method applies to gaseous releases via the plant vent when determining the high-alarm setpoint for the plant vent gas monitor (R-14C) and the Fuel Handling Basement Exhaust Monitor (R-20), using the GALE code during the following operational conditions:

- Continuous release via the plant vent (R-14C).
- Continuous release via the Fuel Handling Basement Exhaust (R-20).



- 3.1.1.1 Determine the "mix" (noble gas radionuclides and composition) of the gaseous effluent.

Determine  $S_i$ , the fraction of the total noble gas radioactivity in the gaseous effluent comprised by noble gas radionuclide "i," for each individual noble gas radionuclide in the gaseous effluent or use the  $S_i$  from Table 3.1-1 when using GALE Code.

$$S_i = \frac{A_i}{\sum_i A_i} \quad (3.1-1)$$

- $A_i$  - The radioactivity of noble gas radionuclide "i" in the gaseous effluent from Table 3.1-1.

- 3.1.1.2 Determine the  $Q_m$ , the maximum acceptable total release rate [ $\mu\text{Ci}/\text{sec}$ ] of all noble gas radionuclides in the gaseous effluent based upon the whole body exposure limit of 500 mrem/year by:

$$Q_m = \frac{500}{(\overline{X/Q}) \sum_i K_i S_i} \quad (3.1-2)$$

- $(\overline{X/Q})$  - The highest calculated annual average relative dispersion factor for any area at or beyond the unrestricted area boundary for all sectors ( $\text{sec}/\text{m}^3$ ).

- 8.1 E-5  $\text{sec}/\text{m}^3$  (Continuous Ground Release) from Table A-1, Appendix A.
- 9.9 E-7  $\text{sec}/\text{m}^3$  (Mixed Mode Release) from Table A-10, Appendix A.

- $K_i$  - The total whole body dose factor due to gamma emissions from noble gas radionuclide "i" ( $\text{mrem}/\text{yr}/\mu\text{Ci}/\text{m}^3$ ) from Table 3.1-2.

- 3.1.1.3 Determine  $Q_m$ , the maximum acceptable release rate [ $\mu\text{Ci}/\text{sec}$ ] of all gas radionuclides in the gaseous effluent based upon the skin exposure limit of 3000 mrem/yr by:

$$Q_m = \frac{3000}{(X/Q) \sum_i [(L_i + 1.1 M_i) S_i]} \quad (3.1-3)$$

$L_i + 1.1M_i$  = The total skin dose factor due to emissions from noble gas radionuclide "i" (mrem/yr/ $\mu\text{Ci}/\text{m}^3$ ) from Table 3.1-2.

- 3.1.1.4 Determine  $C_m$ , the maximum acceptable total radioactivity concentration [ $\mu\text{Ci}/\text{cc}$ ] of all noble gas radionuclides in the gaseous effluent.

$$C_m = \frac{2.12 E^{-3} Q_m}{F} (T_m) (SF) \quad (3.1-4)$$

NOTE: Use the lower of the  $Q_m$  values obtained in Sections 3.1.1.2 and 3.1.1.3. This will protect both the skin and total body from being exposed to the limit.

where:

- $T_m$  = Fraction of the radioactivity from the site that may be released via the monitored pathway to ensure that the site boundary limit is not exceeded due to simultaneous releases from several pathways.
- = 0.92 for Plant Vent Gas Monitor (R-14C).
  - = 0.05 for the Fuel Handling Basement Exhaust Monitor (R-20).



- F - The maximum acceptable effluent flow rate at the point of release (cfm).
- 60,600 cfm for plant vent.
- 10,200 cfm for the fuel-handling building.
- 2.12 E-3 - Unit conversion constant to convert  $\mu\text{Ci}/\text{sec}/\text{cfm}$  to  $\mu\text{Ci}/\text{cc}$ .

$$\left[ \frac{\text{sec} - \text{ft}^3}{\text{min} - \text{cc}} \right]$$

- SF - An engineering factor used to provide a margin of safety for cumulated measurement uncertainties. = 0.5
- 3.1.1.5 Determine CR, the calculated monitor count rate above background attributed to the noble gas radionuclides [cpm], by:

$$\text{CR} = (C_m) (E_m) \quad (3.1-5)$$

where:

- $E_m$  - Obtained from the applicable effluent monitor efficiency curve located in the Plant Operating Manual, Volume 15, Curve Book. Use the radioactivity concentration " $C_m$ " to find CR.
- 3.1.1.6 Determine the HSP, the monitor high-alarm setpoint including background [cpm], by:

$$\text{HSP} = \text{CR} + \text{background} \quad (3.1-6)$$

3.1.2 Setpoint Based on Sample Analysis Prior to Release

The following method applies to gaseous releases when determining the high-alarm setpoint with prior sample analysis and using the maximum acceptable effluent flow rate at the point of release. The method applies to the following conditions.

Batch Releases

- Containment purge.\*
- Containment pressure relief.
- Waste gas decay tanks.

Continuous Releases

- Plant vent.
  - Fuel handling basement exhaust.
  - Environmental and Radiation Control Building Hood Exhaust.
  - Containment purge.
  - Radwaste Building exhaust vent.
- \* Batch containment purge is considered as 1 volume of containment air removed.

3.1.2.1 Determine  $R_1$ , the noble gas release rate [ $\mu\text{Ci}/\text{sec}$ ] for radionuclide "i":

$$R_1 = 472 (C_1) (F) \quad (3.1-7)$$

where:

472 = A conversion factor to convert cfm to cc/sec.

$C_1$  = The radioactivity concentration of noble gas radionuclide "i" from analysis of gaseous effluent ( $\mu\text{Ci}/\text{cc}$ ) from the Plant Vent (stack), Fuel Handling Basement Exhaust, Environmental & Radiation Control (E&RC) Building Hood Exhaust, Radwaste Building Exhaust Vent and the Containment Vessel when R-12 is sampling from the Containment. If there are no isotopes identified in the sample, the EC for Xe-133 may be used as an actual value for the purpose of the setpoint calculation.

Containment Purge--

$(\mu\text{Ci}/\text{cc}_1 \text{ from analysis of Containment Vent})(0.366) + (\mu\text{Ci}/\text{cc}_1 \text{ from analysis of Plant Vent})(0.634)$

Containment Pressure Relief--

$(\mu\text{Ci}/\text{cc}_1 \text{ from analysis of Containment Vent})(0.040) + (\mu\text{Ci}/\text{cc}_1 \text{ from analysis of Plant Vent})(0.960)$

Waste Gas Decay Tanks--

$(\mu\text{Ci}/\text{cc}_1 \text{ from analysis of WGDT})(0.0016) + (\mu\text{Ci}/\text{cc}_1 \text{ from analysis of Plant Vent})(0.9984)$

Waste Gas Decay Tanks during Containment Purge--

( $\mu\text{Ci}/\text{cc}_i$  from analysis of WGDT) (0.0010) +  
 ( $\mu\text{Ci}/\text{cc}_i$  from analysis of Plant Vent) (0.633) +  
 ( $\mu\text{Ci}/\text{cc}_i$  from analysis of C.V.) (0.366)

0.366	=	Dilution correction factor for C.V. Purge	=	$\frac{35,000 \text{ CFM}}{(60,600 + 35,000) \text{ CFM}}$
0.634	=	Dilution correction factor for Plant Vent during C.V. Purge	=	$\frac{60,600 \text{ CFM}}{(60,600 + 35,000) \text{ CFM}}$
0.040	=	Dilution correction factor for C.V. Pressure Relief	=	$\frac{2500^* \text{ CFM}}{(60,600 + 2500^*) \text{ CFM}}$
0.960	=	Dilution correction factor for Plant Vent during C.V. Pressure Relief	=	$\frac{60,600 \text{ CFM}}{(60,600 + 2500^*) \text{ CFM}}$
0.0016	=	Dilution correction factor for Waste Gas Decay Tank	=	$\frac{100 \text{ CFM}}{(60,600 + 100) \text{ CFM}}$
0.9984	=	Dilution correction factor for Plant Vent during WGDT Release	=	$\frac{60,600 \text{ CFM}}{(60,600 + 100) \text{ CFM}}$
0.0010	=	Dilution correction factor for Waste Gas Decay Tank during a Continuous C.V. Purge and Plant Vent Release	=	$\frac{100 \text{ CFM}}{(60,600 + 35,000 + 100) \text{ CFM}}$
0.633	=	Dilution correction factor for Plant Vent during a Continuous C.V. Purge and Plant Vent Release	=	$\frac{60,600 \text{ CFM}}{(60,600 + 35,000 + 100) \text{ CFM}}$
0.366	=	Dilution correction factor for Continuous C.V. Purge during WGDT Release	=	$\frac{35,000 \text{ CFM}}{(60,600 + 35,000 + 100) \text{ CFM}}$

- F - The maximum acceptable effluent flow rate at the point of release (CFM)
- 60,600 CFM for the plant vent
  - 10,200 CFM for the fuel handling basement exhaust
  - 11,500 CFM for the E&RC building hood exhaust
  - 15,000 CFM for the Radwaste Building exhaust vent
  - 95,600 CFM for the containment vessel purge plus plant vent
  - 63,100 CFM for the containment vessel pressure relief
  - 60,700 CFM for the waste gas decay tank
  - 95,700 CFM for the waste gas decay tank during a continuous containment vessel purge
  - 35,000 CFM for containment vessel purge or continuous release
  - 2500 CFM for containment vessel pressure relief releases

\*2500 CFM--Refer to Appendix B.4 for additional information

3.1.2.2 Determine the monitor alarm setpoint based on total body and skin dose rate:

a. Determine dose rate for total body (mrem/yr).

$$DR_{TB} = (\bar{X}/Q) \sum_i K_i R_i \quad (3.1-8)$$

where:

$\bar{X}/Q$  - The highest calculated annual average relative dispersion factor for any area at or beyond the unrestricted area boundary for all sectors ( $\text{sec}/\text{m}^3$ ) from Appendix A.

- 8.1 E-5  $\text{sec}/\text{m}^3$  (continuous ground release) from Table A-1, Appendix A. To be conservative this can be used for all releases.

- 9.9 E-7  $\text{sec}/\text{m}^3$  (continuous mixed mode release) from Table A-10, Appendix A, only with upper wind speeds of  $\leq 9$  mph.

- 5.1 E-5  $\text{sec}/\text{m}^3$  (batch ground release) from Table A-7, Appendix A.

- 2.9 E-6  $\text{sec}/\text{m}^3$  (batch mixed mode release) from Table A-16, Appendix A.

$K_i$  - The total whole body dose factor due to gamma emissions from noble gas radionuclide "i" ( $\text{mrem}/\text{yr}/\mu\text{Ci}/\text{m}^3$ ) from Table 3.1-2.

b. Determine dose rate for skin (mrem/yr).

$$DR_{SK} = \bar{X}/Q \sum_i (L_i + 1.1 M_i) R_i \quad (3.1-9)$$



where:

$L_1 + 1.1 M_1 =$  The total skin dose factor for noble gas emission "i" radionuclide (mrem/yr/ $\mu\text{Ci}/\text{m}^3$ ) from Table 3.1-2

c. Determine the noble gas emission Projected Dose Rate Ratio (PDRR) for Total Body and Skin.

$$PDRR_{TB} = \frac{DR_{TB}}{500} \quad (3.1-10)$$

$$PDRR_{SKIN} = \frac{DR_{SKIN}}{3000} \quad (3.1-11)$$

500 - The allowable total body dose rate due to noble gas gamma emissions in mrem/yr.

3000 - The allowable skin dose rate due to noble gas beta emissions in mrem/yr.

d. Determine the maximum monitor setpoint concentration ( $\mu\text{Ci}/\text{cc}$ ) for total body and skin.

$$\text{Maximum Monitor Total Body Setpoint} = \frac{(\sum_i Ci)}{(PDRR_{TB})} (SF) (T_m) \quad (3.1-12)$$

$$\text{Maximum Monitor Skin Setpoint} = \frac{(\sum_i Ci)}{(PDRR_{SKIN})} (SF) (T_m) \quad (3.1-13)$$

where:

- SF - An engineering factor used to provide a margin of safety for cumulative uncertainties of measurements.
- .5
- $T_m$  - Fraction of the radioactivity from the site that may be released via the monitored pathway to ensure that the site boundary limit is not exceeded due to simultaneous releases from several pathways.
- 0.92 for the Plant Vent Gas Monitor (R-14C).
- 0.05 for the Fuel Handling Basement Exhaust Monitor (R-20).
- 0.01 for other potential release points.
- 0.01 for the E&RC Building Hood Exhaust Monitor (R-22).
- 0.01 for the Radwaste Building exhaust vent Monitor (R-23).
- 0.81 for C.V. releases via R-11 and R-12  
[This indicates 0.81 of 10CFR20 limits for Containment releases and is also monitored by R-14C.  $0.92 = 0.81 + 0.11$  (Normal Plant Releases)]
- e. Determine the maximum monitor setpoint (CPM) for total body ( $S_t$ ) and skin ( $S_s$ ).
- $S_t$  - (Maximum total body setpoint in  $\mu\text{Ci/cc}$ ) (monitor efficiency)  
+ Bkg (3.1-14)

$S_s$  - (Maximum skin setpoint in  $\mu\text{Ci/cc}$ ) (monitor efficiency) + Bkg  
(3.1-15)

Monitor efficiency - Obtained from the applicable effluent monitor efficiency curve located in the Plant Operating Manual, Volume 15, Curve Book. Use the radioactivity concentration ( $\mu\text{Ci/cc}$ ) to find (CPM).

Bkg - The monitor background.

f. Determine the actual gaseous monitor setpoint:

The setpoints that were determined based on the dose rate limits to the total body ( $S_t$ ) and to the skin ( $S_s$ ) are compared and the lesser value is used as the actual setpoint.

TABLE 3.1-1

GASEOUS SOURCE TERMS<sup>1</sup>

Radionuclide	Plant Vent Release <sup>1</sup>		Condenser Vacuum Pump Vent <sup>2</sup>		Containment Purge or Pressure Relief		Gas Decay Tanks <sup>3</sup>	
	A <sub>i</sub> (Ci/yr)	S <sub>i</sub>	A <sub>i</sub> (Ci/yr)	S <sub>i</sub>	A <sub>i</sub> (Ci/yr)	S <sub>i</sub>	A <sub>i</sub> (Ci/yr)	S <sub>i</sub>
Kr-85m	2.0E0	5.26E-2	1.0E0	4.35E-2	0.00	0.00	0.00	0.00
Kr-85	0.00	0.00	0.00	0.00	0.00	0.00	1.6E2	8.00E-1
Kr-87	1.0E0	2.63E-2	0.00	0.00	0.00	0.00	0.00	0.00
Kr-88	3.0E0	7.89E-2	2.0E0	8.70E-2	1.0E0	2.90E-3	0.00	0.00
Xe-131m	0.00	0.00	0.00	0.00	1.0E0	2.90E-3	9.0E0	4.50E-2
Xe-133m	0.00	0.00	0.00	0.00	4.0E0	1.16E-2	0.00	0.00
Xe-133	2.8E1	7.37E-1	1.8E+1	7.83E-1	3.1E2	8.99E-1	3.1E1	1.55E-1
Xe-135	4.0E0	1.05E-1	2.0E0	8.70E-2	4.0E0	1.16E-2	0.00	0.00
Ar-41	0.00	0.00	0.00	0.00	2.5E1	7.25E-2	0.00	0.00
TOTAL	3.8E1		2.3E1		3.45E2		2.0E2	

<sup>\*</sup>Source terms are based upon GALE Code (not actual releases) from the evaluation of H.B. Robinson Unit 2 to demonstrate conformance to the design objectives of 10CFR50, Appendix I, Table 2-4. These values are only for routine releases and not for a complete inventory of gases in an emergency.

<sup>1</sup>These values are used to determine the monitor alarm setpoints for the Plant Vent Gas Monitor (R-14C).

<sup>2</sup>These values are used to determine the monitor alarm setpoint for the Condenser Vacuum Pump Vent Monitor (R-15). R-15 is a process monitor and its effluents are monitored by R-14A, R-14B and R-14C. This column is intentionally left for reference.

<sup>3</sup>These values are used to determine the monitor alarm setpoint for the Fuel Handling Basement Exhaust Monitor (R-20).

TABLE 3.1-2

DOSE FACTORS AND CONSTANTS\*

Radionuclide	Total Whole Body Dose Factor ( $K_1$ ) (mrem/yr/ $\mu$ Ci/m <sup>3</sup> )	Total Skin Dose Factor ( $L_1 + 1.1 M_1$ ) (mrem/yr/ $\mu$ Ci/m <sup>3</sup> )
Kr-83m	7.56E-2	2.12E1
Kr-85m	1.17E3	2.81E3
Kr-85	1.61E1	1.36E3
Kr-87	5.92E3	1.65E4
Kr-88	1.47E4	1.91E4
Kr-89	1.66E4	2.91E4
Kr-90	1.56E4	2.52E4
Xe-131m	9.15E1	6.48E2
Xe-133m	2.51E2	1.35E3
Xe-133	2.94E2	6.94E2
Xe-135m	3.12E3	4.41E3
Xe-135	1.81E3	3.97E3
Xe-137	1.42E3	1.39E4
Xe-138	8.83E3	1.43E4
Xe-139	0.00	0.00
Ar-41	8.84E3	1.29E4

\*Regulatory Guide 1.109, October 1977, Table B-1, times (1.0 E6 pCi/ $\mu$ Ci).

## 3.2 COMPLIANCE WITH 10CFR20 (GASEOUS)

3.2.1 Noble Gases

The gaseous effluent monitors setpoints are utilized to show compliance with 10CFR20 for noble gases. However, because they are based upon a conservative mix of radionuclides, the possibility exists that the setpoints could be exceeded and yet 10CFR20 limits may actually be met. Therefore, the following methodology has been provided in the event that if the alarm trip setpoints are exceeded, a determination may be made as to whether the actual releases have exceeded 10CFR20.

The dose rate in unrestricted areas resulting from noble gas effluents is limited to 500 mrem/year to the total body and 3000 mrem/year to the skin. Based upon NUREG 0133, the following are used to show compliance with 10CFR20.

$$\sum_i K_i [ (\overline{X/Q})_v \dot{Q}_{iv} + (\overline{X/Q})_g \dot{Q}_{ig} ] \leq 500 \text{ mrem/yr} \quad (3.2-1)$$

$$\sum_i (L_i + 1.1 M_i) [ (\overline{X/Q})_v \dot{Q}_{iv} + (\overline{X/Q})_g \dot{Q}_{ig} ] \leq 3000 \text{ mrem/yr} \quad (3.2-2)$$

where:

$(\overline{X/Q})_v$  - Annual average relative dilution for plant vent releases at the site boundary,  $\text{sec/m}^3$ .

- From Table A-1 for ground level releases used for additional conservatism.

- From Table A-10 for mixed mode releases.

$(\overline{X/Q})_g$  - Annual average relative dilution for the Fuel Handling Basement Exhaust, the Environmental and Radiation Control Building Exhaust, and Radwaste Building Exhaust releases at the site boundary,  $\text{sec/m}^3$ .

- From Table A-1 for ground level releases.



- $K_i$  - The total body dose factor due to gamma emissions for noble gas radionuclide "i," mrem/year per  $\mu\text{Ci}/\text{m}^3$ .
- $L_i$  - The skin dose factor due to beta emissions for noble gas radionuclide "i," mrem/year per  $\mu\text{Ci}/\text{m}^3$ .
- $M_i$  - The air dose factor due to gamma emissions for noble gas radionuclide "i," mrad/year per  $\mu\text{Ci}/\text{m}^3$ .
- 1.1 - The ratio of the tissue to air absorption coefficients over the energy range of the photon of interest, mrem/mrad (reference NUREG 0133, October 1978).
- $\dot{Q}_{ie}$  - The release rate of noble gas radionuclide "i" in gaseous effluents from the radwaste building exhaust vent, fuel handling basement exhaust, and the environmental and radiation control building hood exhaust,  $\mu\text{Ci}/\text{sec}$ .
- $\dot{Q}_{iv}$  - The release rate of noble gas radionuclide "i" in gaseous effluents from the plant vent  $\mu\text{Ci}/\text{sec}$ .

The determination of limiting location for implementation of 10CFR20 for noble gases is a function of the radionuclide mix, release rate, and the meteorology. For the most limiting location, the radionuclide mix will be based on sample analysis of the effluent gases.

The X/Q value utilized in the equations for implementation of 10CFR20 is based upon the maximum long-term annual average ( $\overline{X/Q}$ ) in the unrestricted area. Table 3.2-2 presents the distances from HBR to the nearest area for each of the 16 sectors as well as to the nearest residence, vegetable garden, cow, goat, and beef animal. Long-term annual average ( $\overline{X/Q}$ ) values for the HBR release points to the special locations in Table 3.2-2 are presented in Appendix A. A description of their derivation is also provided in this appendix.

To select the limiting location, the highest annual average  $\overline{X/Q}$  value for the ground level releases and the mixed mode releases was used. Since mixed mode releases may not necessarily decrease with distance (i.e., the site boundary may not have the highest  $\overline{X/Q}$  value), long-term annual average ( $\overline{X/Q}$ ) values, calculated at the midpoint of 10 standard distances as given in Appendix A were also considered. For HBR, mixed mode release X/Q values decrease with distance for all directions except the WNW, NW, and NNW so that the maximum site boundary X/Q is usually greater at the site boundary than at distances greater than the site boundary. In addition, the maximum site boundary X/Q for both the ground level and mixed mode releases occurs at the SSE site boundary. Therefore, the limiting location for implementation of 10CFR20 for noble gases is the SSE site boundary.

Values for  $K_1$ ,  $L_1$ , and  $M_1$ , which were used in the determination of the limiting location and which are to be used by HBR in Expressions 3.2-1 and 3.2-2 to show compliance with 10CFR20, are presented in Table 3.2-3. These values were taken from Table B-1 of NRC Regulatory Guide 1.109, Revision 1. The values have been multiplied by  $1.0 \text{ E}6$  to convert picocuries to microcuries for use in Expressions 3.2-1 and 3.2-2.

### 3.2.2 Radiiodines, Particulates, and Tritium

The dose rate in an unrestricted area resulting from the release of radioiodines, tritium, and particulates with half-lives  $\geq 8$  days is limited to 1500 mrem/yr to any organ. Based upon NUREG 0133, the following is used to show compliance with 10CFR20.

$$\sum_i P_{i,r} [ (\overline{X/Q})_v \dot{Q}_{iv} + (\overline{X/Q})_o \dot{Q}_{io} ] \leq 1500 \text{ mrem/yr} \quad (3.2-3)$$

- $\dot{Q}_{i,v}$  - Release rate of radionuclide "i" from the plant vent,  $\mu\text{Ci}/\text{sec}$ .
- $\dot{Q}_{i,e}$  - Release rate of radionuclide "i" from the radwaste building exhaust vent, fuel handling building basement exhaust, and environmental and radiation control building exhaust  $\mu\text{Ci}/\text{sec}$ .
- $(\overline{X/Q})_v$  - Annual average relative dilution for plant vent releases at the site boundary,  $\text{sec}/\text{m}^3$ .
- $(\overline{X/Q})_e$  - Annual average relative dilution for fuel handling building basement exhaust, environmental and radiation control building exhaust, and radwaste building exhaust vent releases at the site boundary,  $\text{sec}/\text{m}^3$ .
- $P_{iI}$  - The dose parameter for Iodine-131, Iodine-133, tritium, and all radionuclides in particulate form with half-lives greater than 8 days for the inhalation pathway only in the most restrictive sector in  $\text{mrem}/\text{yr}$  per  $\mu\text{Ci}/\text{m}^3$ . The dose factor is based on the most restrictive group (child) and most restrictive organ at the SITE BOUNDARY (see Table 3.2-4).

where:

In the calculation to show compliance with 10CFR20, only the inhalation is considered. A description of the methodology used in calculating the  $P_i$  values is presented in Appendix B. Compliance with 10CFR20 is achieved if the dose rate via inhalation pathway to a child is  $\leq 1500$   $\text{mrem}/\text{year}$ .

TABLE 3.2-1

RELEASES FROM H.B. ROBINSON UNIT NO. 2\*  
 (Ci/yr)

Isotope	Plant Vent (Q <sub>v</sub> )	Condenser Vacuum Pump Vent (Q <sub>e</sub> )	Total
Kr-85m	2.0E0	1.0E0	3.0E0
Kr-85	1.6E2	0.00	1.6E2
Kr-87	1.0E0	0.00	1.0E0
Kr-88	4.0E0	2.0E0	6.0E0
Xe-131m	1.0E1	0.00	1.0E1
Xe-133m	4.0E0	0.00	4.0E0
Xe-133	3.7E2	1.8E1	3.9E2
Xe-135	8.0E0	2.0E0	1.0E1
I-131	3.6E-2	2.3E-2	5.9E-2
I-133	5.4E-2	3.4E-2	9.8E-2
Mn-54	4.7E-3	0.00	4.7E-3
Fe-59	1.6E-3	0.00	1.6E-3
Co-58	1.6E-2	0.00	1.6E-2
Co-60	7.3E-3	0.00	7.3E-3
Sr-89	3.4E-4	0.00	3.4E-4
Sr-90	6.3E-5	0.00	6.3E-5
Cs-134	4.7E-3	0.00	4.7E-3
Cs-137	7.8E-3	0.00	7.8E-3

\*Calculations based upon GALE Code and do not reflect actual release data from the Evaluation Conformance to the Design Objectives of 10CFR50, Appendix I. These values are only for routine releases and not for a complete inventory of gases in an emergency. Condenser vacuum pump vent is intentionally left in for reference.

TABLE 3.2-2

DISTANCE TO SPECIAL LOCATIONS FOR THE  
 H.B. ROBINSON PLANT (MILES)

<u>Sector</u>	<u>Site Boundary</u>	<u>Milk Cow</u>	<u>Milk Goat</u>	<u>Meat Animal</u>	<u>Nearest Resident</u>	<u>Nearest Garden</u>
NNE	1.26	-	-	1.65	1.3	1.4
NE	1.01	-	-	1.16	1.2	1.3
ENE	0.86	-	-	2.41	0.9	2.2
E	0.61	4.2	-	3.12	0.8	2.8
ESE	0.50	-	-	1.99	0.6	0.6
SE	0.29	-	-	-	0.3	0.3
SSE	0.26	-	-	-	0.3	0.3
S	0.28	-	-	2.32	0.3	0.4
SSW	0.29	-	-	2.08	0.3	0.5
SW	0.36	-	2.5*	2.27	0.4	0.5
WSW	0.36	-	-	2.69	0.4	0.6
W	0.50	-	-	3.97	0.6	0.6
WNW	0.55	-	-	4.07	0.7	0.9
NW	1.23	-	-	1.60	1.3	1.3
NNW	1.89	-	-	2.84	2.9	3.0
N	1.94	-	-	2.93	2.9	2.9

---

\*Milk is not presently used for human consumption.

TABLE 3.2-3

DOSE FACTORS FOR NOBLE GASES AND DAUGHTERS\*

Radionuclide	Total Body Dose Factor $K_1$ (mrem/yr per $\mu\text{Ci}/\text{m}^3$ )	Skin Dose Factor $L_1$ (mrem/yr per $\mu\text{Ci}/\text{m}^3$ )	Gamma Air Dose Factor $M_1$ (mrad/yr per $\mu\text{Ci}/\text{m}^3$ )	Beta Air Dose Factor $N_1$ (mrad/yr per $\mu\text{Ci}/\text{m}^3$ )
Kr-83m	7.56E-02	---	1.93E+01	2.88E+02
Kr-85m	1.17E+03	1.46E+03	1.23E+03	1.97E+03
Kr-85	1.61E+01	1.34E+03	1.72E+01	1.95E+03
Kr-87	5.92E+03	9.3E+03	6.17E+03	1.03E+04
Kr-88	1.47E+04	2.37E+03	1.52E+04	2.93E+03
Kr-89	1.66E+04	1.01E+04	1.73E+04	1.06E+04
Kr-90	1.56E+04	7.29E+03	1.63E+04	7.83E+03
Xe-131m	9.15E+01	4.76E+02	1.56E+02	1.11E+03
Xe-133m	2.51E+02	9.94E+02	3.27E+02	1.48E+03
Xe-133	2.94E+02	3.06E+02	3.53E+02	1.05E+03
Xe-135m	3.12E+03	7.11E+02	3.36E+03	7.39E+02
Xe-135	1.81E+03	1.86E+03	1.92E+03	2.46E+03
Xe-137	1.42E+03	1.22E+04	1.51E+03	1.27E+04
Xe-138	8.83E+03	4.13E+03	9.21E+03	4.75E+03
Ar-41	8.84E+03	2.69E+03	9.30E+03	3.28E+03

\*The listed dose factors are for radionuclides that may be detected in gaseous effluents.



TABLE 3.2-4  
 P<sub>i</sub> VALUES for a CHILD for the  
 H.B. ROBINSON UNIT NO. 2<sup>1</sup>

Nuclide	P <sub>i</sub> Bone	P <sub>i</sub> Liver	P <sub>i</sub> T.Body	P <sub>i</sub> Thyroid	P <sub>i</sub> Kidney	P <sub>i</sub> Lung	P <sub>i</sub> GI-Tract	P <sub>i</sub> Skin
H-3	0.00E+00	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03
F-18	6.96E+03	0.00E+00	6.85E+02	0.00E+00	0.00E+00	0.00E+00	1.25E+03	0.00E+00
NA-24	1.61E+04	1.61E+04	1.61E+04	1.61E+04	1.61E+04	1.61E+04	1.61E+04	0.00E+00
CR-51	0.00E+00	0.00E+00	1.54E+02	8.55E+01	2.43E+01	1.70E+04	1.08E+03	0.00E+00
MN-54	0.00E+00	4.29E+04	9.51E+03	0.00E+00	1.00E+04	1.58E+06	2.29E+04	0.00E+00
MN-56	0.00E+00	1.66E+00	3.12E-01	0.00E+00	1.67E+00	1.31E+04	1.23E+05	0.00E+00
FE-55	4.74E+04	2.52E+04	7.77E+03	0.00E+00	0.00E+00	1.11E+05	2.87E+03	0.00E+00
FE-59	2.07E+04	3.34E+04	1.67E+04	0.00E+00	0.00E+00	1.27E+06	7.07E+04	0.00E+00
CO-57	0.00E+00	9.03E+02	1.07E+03	0.00E+00	0.00E+00	5.07E+05	1.32E+04	0.00E+00
CO-58	0.00E+00	1.77E+03	3.16E+03	0.00E+00	0.00E+00	1.11E+06	3.44E+04	0.00E+00
CO-60	0.00E+00	1.31E+04	2.26E+04	0.00E+00	0.00E+00	7.07E+06	9.62E+04	0.00E+00
NI-65	2.99E+00	2.96E-01	1.64E-01	0.00E+00	0.00E+00	8.18E+03	8.40E+04	0.00E+00
CU-64	0.00E+00	1.99E+00	1.07E+00	0.00E+00	6.03E+00	9.58E+03	3.67E+04	0.00E+00
ZN-65	4.26E+04	1.13E+05	7.03E+04	0.00E+00	7.14E+04	9.95E+05	1.63E+04	0.00E+00
BR-82	0.00E+00	0.00E+00	2.09E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	4.74E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	5.48E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	1.98E+05	1.14E+05	0.00E+00	0.00E+00	0.00E+00	7.99E+03	0.00E+00
RB-88	0.00E+00	5.62E+02	3.66E+02	0.00E+00	0.00E+00	0.00E+00	1.72E+01	0.00E+00
RB-89	0.00E+00	3.45E+02	2.90E+02	0.00E+00	0.00E+00	0.00E+00	1.8E+00	0.00E+00
SR-89	5.99E+05	0.00E+00	1.72E+04	0.00E+00	0.00E+00	2.16E+06	1.67E+05	0.00E+00
SR-90	1.01E+08	0.00E+00	6.44E+06	0.00E+00	0.00E+00	1.48E+07	3.43E+05	0.00E+00
SR-91	1.21E+02	0.00E+00	4.59E+00	0.00E+00	0.00E+00	5.33E+04	1.74E+05	0.00E+00
SR-92	1.31E+01	0.00E+00	5.25E-01	0.00E+00	0.00E+00	2.40E+04	2.42E+05	0.00E+00
Y-91M	5.07E-01	0.00E+00	1.84E-02	0.00E+00	0.00E+00	2.81E+03	1.72E+03	0.00E+00
Y-91	9.14E+05	0.00E+00	2.44E+04	0.00E+00	0.00E+00	2.63E+06	1.84E+05	0.00E+00
Y-92	2.04E+01	0.00E+00	5.81E-01	0.00E+00	0.00E+00	2.39E+04	2.39E+05	0.00E+00
Y-93	1.86E+02	0.00E+00	5.11E+00	0.00E+00	0.00E+00	7.44E+04	3.89E+05	0.00E+00
ZR-95	1.90E+05	4.18E+04	3.70E+04	0.00E+00	5.96E+04	2.23E+06	6.11E+04	0.00E+00
ZR-97	1.88E+02	2.72E+01	1.60E+01	0.00E+00	3.88E+01	1.13E+05	3.51E+05	0.00E+00

<sup>1</sup> (a) NUREG 0133, Section 5.2.1.1 (Calculation of P<sub>i</sub> (Inhalation)).

(b) Regulatory Guide 1.109 Table E-5, Table E-9 (Breathing Rate Constant and Inhalation dose factors).

(c) Units are mrem/yr per  $\mu\text{Ci}/\text{m}^3$ .

TABLE 3.2-4 (continued)

<u>Nuclide</u>	<u>P<sub>i</sub> Bone</u>	<u>P<sub>i</sub> Liver</u>	<u>P<sub>i</sub> T.Body</u>	<u>P<sub>i</sub> Thyroid</u>	<u>P<sub>i</sub> Kidney</u>	<u>P<sub>i</sub> Lung</u>	<u>P<sub>i</sub> GI-Tract</u>	<u>P<sub>i</sub> Skin</u>
NB-95	2.35E+04	9.18E+03	6.55E+03	0.00E+00	8.62E+03	6.14E+05	3.70E+04	0.00E+00
NB-97	4.29E-01	7.70E-02	3.50E-02	0.00E+00	8.55E-02	3.42E+03	2.78E+16	0.00E+00
MO-99	0.00E+00	1.72E+02	4.25E+01	0.00E+00	3.92E+02	1.35E+05	1.27E+05	0.00E+00
TC-99M	1.78E-03	3.48E-03	5.77E-02	0.00E+00	5.07E-02	9.51E+02	4.81E+03	0.00E+00
TC-101	8.10E-05	8.51E-05	1.08E-03	0.00E+00	1.45E-03	5.85E+02	1.63E+01	0.00E+00
RU-103	2.79E+03	0.00E+00	1.07E+03	0.00E+00	7.03E+03	6.62E+05	4.48E+04	0.00E+00
RU-105	1.53E+00	0.00E+00	5.55E-01	0.00E+00	1.34E+00	1.59E+04	9.95E+04	0.00E+00
RU-106	1.36E+05	0.00E+00	1.69E+04	0.00E+00	1.84E+05	1.43E+07	4.29E+05	0.00E+00
AG-110M	1.69E+04	1.14E+04	9.14E+03	0.00E+00	2.12E+04	5.48E+06	1.00E+05	0.00E+00
SN-113	8.99E+03	2.90E+02	9.81E+03	1.19E+02	2.03E+02	3.40E+05	7.44E+03	0.00E+00
SB-124	5.74E+04	7.40E+02	2.00E+04	1.26E+02	0.00E+00	3.24E+06	1.64E+05	0.00E+00
SB-125	9.84E+04	7.59E+02	2.07E+04	9.10E+01	0.00E+00	2.32E+06	4.03E+04	0.00E+00
TE-129M	1.92E+04	6.85E+03	3.04E+03	6.33E+03	5.03E+04	1.76E+06	1.82E+05	0.00E+00
TE-129	9.77E-02	3.50E-02	2.38E-02	7.14E-02	2.57E-01	2.93E+03	2.55E+04	0.00E+00
TE-131M	1.34E+02	5.92E+01	5.07E+01	9.77E+01	4.00E+02	2.06E+05	3.08E+05	0.00E+00
TE-132	4.81E+02	2.72E+02	2.63E+02	3.17E+02	1.77E+03	3.77E+05	1.38E+05	0.00E+00
I-131	4.81E+04	4.81E+04	2.73E+04	1.62E+07	7.88E+04	0.00E+00	2.84E+03	0.00E+00
I-132	2.12E+03	4.07E+03	1.88E+03	1.94E+05	6.25E+03	0.00E+00	3.20E+03	0.00E+00
I-133	1.66E-04	2.03E+04	7.70E+03	3.85E+06	3.38E+04	0.00E+00	5.48E+03	0.00E+00
I-134	1.17E+03	2.16E+03	9.95E+02	5.07E+04	3.30E+03	0.00E+00	9.55E+02	0.00E+00
I-135	4.92E+03	8.73E+03	4.14E+03	7.92E+05	1.34E+04	0.00E+00	4.44E+03	0.00E+00
CS-134	6.51E+05	1.01E+06	2.25E+05	0.00E+00	3.30E+05	1.21E+05	3.85E+03	0.00E+00
CS-136	6.51E+04	1.71E+05	1.16E+05	0.00E+00	9.55E+04	1.45E+04	4.18E+03	0.00E+00
CS-137	9.07E+05	8.25E+05	1.28E+05	0.00E+00	2.82E+05	1.04E+05	3.62E+03	0.00E+00
CS-138	6.33E+02	8.40E+02	5.55E+02	0.00E+00	6.22E+02	6.81E+01	2.70E+02	0.00E+00
BA-139	1.84E+00	9.84E-04	5.36E-02	0.00E+00	8.62E-04	5.77E+03	5.77E+04	0.00E+00
BA-140	7.40E+04	6.48E+01	4.33E+03	0.00E+00	2.11E+01	1.74E+06	1.02E+05	0.00E+00
BA-142	4.99E-02	3.60E-05	2.79E-03	0.00E+00	2.91E-05	1.64E+03	2.74E+00	0.00E+00
LA-140	6.44E+02	2.25E+02	7.55E+01	0.00E+00	0.00E+00	1.83E+05	2.26E+05	0.00E+00
LA-142	1.29E+00	4.11E-01	1.29E-01	0.00E+00	0.00E+00	8.70E+03	7.59E+04	0.00E+00
CE-141	3.92E+04	1.95E+04	2.90E+03	0.00E+00	8.55E+03	5.44E+05	5.66E+04	0.00E+00
CE-143	3.66E+02	1.99E+02	2.87E+01	0.00E+00	8.36E+01	1.15E+05	1.27E+05	0.00E+00
CE-144	5.77E+06	2.12E+06	3.61E+05	0.00E+00	1.17E+06	1.20E+07	3.89E+05	0.00E+00
PR-144	5.96E-02	1.85E-02	3.00E-03	0.00E+00	9.77E-03	1.57E+03	1.97E+02	0.00E+00
HF-181	8.33E+04	3.28E+02	8.47E+03	2.76E+02	2.63E+02	7.96E+05	5.29E+04	0.00E+00
W-187	1.63E+01	9.66E+00	4.33E+00	0.00E+00	0.00E+00	4.11E+04	9.10E+04	0.00E+00
NP-239	4.66E+02	3.34E+01	2.35E+01	0.00E+00	9.73E+01	5.81E+04	6.40E+04	0.00E+00

3.3 COMPLIANCE WITH 10CFR50 (GASEOUS)

3.3.1 Noble Gases

3.3.1.1 Cumulation of Doses

Based upon NUREG 0133, the air dose in the unrestricted area due to noble gases released in gaseous effluents can be determined by the following equations:

$$D_{\gamma} = 3.17 \times 10^{-8} \sum_i M_i [(\overline{X/Q})_{\nu} \overline{D}_{i\nu} + (\overline{X/Q})_{\nu} \overline{q}_{i\nu} + (\overline{X/Q})_{\circ} \overline{D}_{i\circ}] \quad (3.3-1)$$

$$D_{\beta} = 3.17 \times 10^{-8} \sum_i N_i [(\overline{X/Q})_{\nu} \overline{D}_{i\nu} + (\overline{X/Q})_{\nu} \overline{q}_{i\nu} + (\overline{X/Q})_{\circ} \overline{D}_{i\circ}] \quad (3.3-2)$$

where:

- $D_{\gamma}$  - The air dose from gamma radiation, mrad.
- $D_{\beta}$  - The air dose from beta radiation, mrad.
- $M_i$  - The air dose factor due to gamma emissions for each identified noble gas radionuclide "i," mrad/year per  $\mu\text{Ci}/\text{m}^3$ .
- $N_i$  - The air dose factor due to beta emissions for each identified noble gas radionuclide "i," mrad/year per  $\mu\text{Ci}/\text{m}^3$ .
- $(\overline{X/Q})_{\nu}$  - The annual average dilution for areas at or beyond the unrestricted area boundary for long-term plant vent releases (> 500 hrs/year),  $\text{sec}/\text{m}^3$ .
  - From Table A-1 for ground level releases used for conservatism.

- From Table A-10 for mixed mode releases.
- $(\bar{X}/q)_v$  - The dilution for areas at or beyond the unrestricted area boundary for short-term plant vent releases ( $\leq 500$  hours/year),  $\text{sec}/\text{m}^3$ .
  - From Table A-1 for ground level continuous release for conservatism.
  - From Table A-7 for ground level releases.
  - From Table A-16 for mixed mode releases.
- $(\bar{X}/Q)_a$  - Annual average relative dilution for fuel handling basement exhaust, the environmental and radiation control building exhaust, and radwaste building exhaust vent releases at the site boundary, ( $> 500$  hours/year),  $\text{sec}/\text{m}^3$ .
  - From Table A-1 for ground level releases;
- $q_{iv}$  - The average release of noble gas radionuclide "i" in gaseous releases for short-term plant releases ( $\leq 500$  hours/year),  $\mu\text{Ci}$ ;
- $\bar{Q}_{ia}$  - The average release of noble gas radionuclide "i" in gaseous releases for long-term fuel handling basement exhaust, the environmental and radiation control building exhaust, and radwaste building exhaust ( $> 500$  hours/year),  $\mu\text{Ci}$ ;
- $\bar{Q}_{iv}$  - The average release of noble gas radionuclide "i" in gaseous effluents for long-term vent releases ( $> 500$  hours/year),  $\mu\text{Ci}$ ;
- $3.17 \times 10^{-8}$  - The inverse of the number of seconds in a year  $(\text{sec}/\text{year})^{-1}$ .

At HBR the limiting location is 0.26 miles SSE. Based upon the tables presented in Appendix A, substitution of the short-term X/Q value into Equation 3.3-1 yields lower dose value than the long-term X/Q values been used. In order to be conservative, for purposes of this document only, long-term annual average  $(\bar{X}/Q)$



values will be used. Should the calculated doses exceed 10CFR50 limits, recalculation of doses may be performed using short-term X/Q values for batch releases.

To select the limiting location, the highest annual average  $\overline{X/Q}$  value for ground level and mixed mode releases and the highest short-term X/Q value for ground level and mixed mode releases were considered. Since mixed mode releases may increase and then decrease with distance (i.e., the site boundary may not have the highest X/Q value), long-term X/Q values were calculated at the midpoint of 10 standard distances as given in Appendix A. The calculated values decreased with the distance for all but the WNW, NW, and NNW sectors. The values for these sectors were not found to be limiting such that the maximum site boundary X/Q for both long-term and short-term ground level and mixed mode releases occurred at the SSE site boundary. The limiting location for implementation of 10CFR20 for noble gases is the SSE site boundary.

Values for  $M_1$  and  $N_1$  which are utilized in the calculation of the gamma air and beta air doses in Equation 3.3-1 to show compliance with 10CFR50 were presented in Table 3.2-3. These values originate from NUREG 0472, Revision 0, and were taken from Table B-1 of the NRC Regulatory Guide 1.109, Revision 1. The values have been multiplied by  $1.0 \text{ E}6$  to convert from picocuries to microcuries.

The following relationship should hold for HBR to show compliance with HBR's Technical Specification 3.9.4.1.

For the calendar quarter:

$$D_7 \leq 5 \text{ mrad} \quad (3.3-3)$$

$$D_9 \leq 10 \text{ mrad} \quad (3.3-4)$$

For the calendar year:

$$D_7 \leq 10 \text{ mrad} \quad (3.3-5)$$

$$D_8 \leq 20 \text{ mrad} \quad (3.3-6)$$

The quarterly limits given above represent one-half of the annual design objectives of Section II.B.1 of Appendix I of 10CFR50. If any of the limits of Equations 3.3-3 through 3.3-6 are exceeded, a special report pursuant to Technical Specification must be filed with the NRC. This report complies with Section IV.A of Appendix I of 10CFR50.

### 3.3.1.2 Projection of Doses

Doses resulting from the release of gaseous effluents will be projected once per 31 days. These projections will include a safety margin based upon expected operational conditions which will take into consideration both planned and unplanned releases.

Projected dose will be calculated as follows:

$$PD = \frac{31 (DA + DB)}{(TE)} + M \quad (3.3-7)$$

where:

- PD - Projected doses in mrem.
- DA - Dose accumulated during current quarter in mrem.
- DB - Projected dose from this release.
- TE - Time elapsed in quarter in days.
- M - Safety margin in mrem.



If the projected doses exceed 0.6 mrad for gamma radiation or 1.3 mrad for beta radiation when averaged over a calendar quarter, the ventilation exhaust treatment system will be operated to reduce releases of radioactive materials.

3.3.2 Radioiodine, Particulates and Tritium

3.3.2.1 Cumulation of Doses

Section II.C of Appendix I of 10CFR50 limits the release of radioiodines and radioactive material in particulate form from each reactor such that estimated annual dose or dose commitment to an individual in an unrestricted area from all pathways of exposure is not in excess of 15 mrem to any organ. Based upon NUREG 0133, the dose to an organ of an individual from radioiodines, tritium, and particulates with half-lives  $\geq 8$  days in gaseous effluents released to unrestricted areas can be determined by the following equation:

$$D_r = 3.17 \times 10^{-8} \sum_i R_{I_i} [(\overline{X/Q})_v Q_{I_v} + (\overline{X/Q})_o Q_{I_o} + (\overline{X/Q})_v q_{I_v}] +$$

$$(R_{I_s} + R_{I_n} + R_{I_v} + R_{I_o}) [(\overline{D/Q})_v Q_{I_v} + (\overline{D/Q})_v q_{I_v} + (\overline{D/Q})_o Q_{I_o}] +$$

$$(R_{T_n} + R_{T_s} + R_{T_r} R_{T_v}) [(\overline{X/Q})_v Q_{T_v} + (\overline{X/Q})_v q_{T_v} + (\overline{X/Q})_o Q_{T_n}] \quad (3.3-8)$$

where:

$D_r$  = Dose to any organ  $r$  from I-131, I-133, particulates with  $\geq 8$  day half-lives, and Tritium in mrem.

- $3.17 \times 10^{-8}$  - The inverse of the number of seconds in a year, (sec/year)<sup>-1</sup>.
- $(\overline{X/Q})_v$  - Annual average relative concentration for plant vent releases (> 500 hrs/yr) sec/m<sup>3</sup>.

  - From Table A-1 for ground level releases for conservatism.
  - From Table A-10 for mixed mode releases.
- $(\overline{X/Q})_e$  - Annual average dilution for radwaste building vent, fuel handling basement exhaust, and the environmental and radiation control building hood exhaust releases (> 500 hours/yr) sec/m<sup>3</sup>.

  - From Table A-1 for ground level releases.
- $(\overline{X/q})_v$  - Annual average relative concentration for plant vent releases (≤ 500 hrs/yr) sec/m<sup>3</sup>.

  - From Table A-7 for ground release.
  - From Table A-16 for mixed mode releases.
- $(\overline{D/Q})_v$  - Annual average deposition factor for plant vent releases (>500 hrs/yr) m<sup>-2</sup>.

  - From Table A-3 for ground level releases for conservatism.
  - From Table A-12 for mixed mode releases.
- $(\overline{D/q})_v$  - Relative deposition factor for short-term plant vent releases (≤ 500 hrs/yr), m<sup>-2</sup>.

  - From Table A-3 for ground level continuous releases for conservatism.
  - From Table A-9 for ground level releases.
  - From Table A-18 for mixed mode releases.
- $(\overline{D/Q})_e$  - Annual average relative deposition factor for radwaste building vent, fuel handling basement exhaust, and the environmental and radiation control building hood exhaust releases (> 500 hrs/ yr), m<sup>-2</sup>.

  - From Table A-3 for ground level releases.

- Q<sub>ie</sub> - Release of radionuclide "i" in gaseous effluents for long-term radwaste building vent, fuel handling basement exhaust, and the environmental and radiation control building hood exhaust releases (> 500 hrs/yr),  $\mu\text{Ci}$ .
- Q<sub>iv</sub> - Release of radionuclide "i" in gaseous effluents for long-term plant vent releases (> 500 hrs/yr),  $\mu\text{Ci}$ .
- q<sub>iv</sub> - Release of radionuclide "i" in gaseous effluents for short-term plant vent releases ( $\leq$  500 hrs/yr),  $\mu\text{Ci}$ .
- R<sub>iG</sub> - Dose factor for an organ for radionuclide "i" for the ground plane exposure pathway, mrem/yr per  $\mu\text{Ci}/\text{sec per m}^{-2}$ .
- R<sub>iI</sub> - Dose factor for an organ for radionuclide "i" for the inhalation pathway, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ .
- R<sub>iV</sub> - Dose factor for an organ for radionuclide "i" for the vegetable pathway, mrem/yr per  $\mu\text{Ci}/\text{m}^2$ .
- R<sub>TV</sub> - Dose factor for an organ for tritium for the vegetable pathway, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ .
- R<sub>TI</sub> - Dose factor for an organ for tritium for the inhalation pathway, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ .
- Q<sub>TV</sub> - Release of tritium in gaseous effluents for long-term plant vent releases (> 500 hrs/yr),  $\mu\text{Ci}$ .
- R<sub>iM</sub> - Dose factor for an organ for radionuclide "i" for the milk exposure pathway, mrem/yr per  $\mu\text{Ci}/\text{sec per m}^2$ .
- R<sub>TM</sub> - Dose factor for an organ for tritium for the milk pathway, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ .
- R<sub>TB</sub> - Dose factor for an organ for tritium for the meat pathway, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ .
- R<sub>iB</sub> - Dose factor for an organ for radionuclide "i" for the meat exposure pathway, mrem/yr per  $\mu\text{Ci}/\text{sec}/\text{m}^{-2}$ .
- Q<sub>Te</sub> - Release of tritium in gaseous effluents for long-term radwaste building vent, fuel handling basement exhaust, and the environmental and radiation control building hood exhaust (>500 hrs/ yr),  $\mu\text{Ci}$ .
- q<sub>rv</sub> - Release of tritium in gaseous effluents for short-term plant vent releases ( $\leq$  500 hrs/yr),  $\mu\text{Ci}$ .

To show compliance with 10CFR50, Equation 3.3-8 is evaluated at the limiting pathway location. At HBR this location is the vegetable garden 0.3 miles in the SSE sector. The critical receptor is a child. Substitution of the appropriate X/Q and D/Q values from tables in Appendix A into Equation 3.3-8 would yield an equation with the short-term X/Q and D/Q values being less than the long-term values. Therefore, for this document, only long-term annual X/Q and D/Q values (i.e., more conservative values) are used.

The determination of a limiting location for implementation of 10CFR50 for radioiodines and particulates is a function of:

1. Radionuclide mix and isotopic release
2. Meteorology
3. Exposure pathway
4. Receptor's age

In the determination of the limiting location, the radionuclide mix of radioiodines and particulates was based upon the source terms calculated using the GALE Code. This mix is presented in Table 3.2-1 as a function of release point. The only source of short-term releases from the plant vent is containment purges. In the determination of the limiting location, all of the exposure pathways, as presented in Table 3.2-2, were evaluated. These include cow milk, goat milk, beef and vegetable ingestion, and inhalation and ground plane exposure. An infant was assumed to be present at all milk pathway locations. A child was assumed to be present at all vegetable garden and beef animal locations. The ground plane exposure pathway was not considered a viable pathway for an infant. Naturally, the inhalation pathway was present everywhere an individual was present. HBR Technical Specification 4.20.2.1 requires that a land-use census survey be conducted on an annual basis. The age groupings at the various receptor locations are also determined during this survey; a new limiting location and receptor age group can result.

For the determination of the limiting location, the highest D/Q values for the vegetable garden, cow milk, and goat milk pathways were selected. The thyroid dose was calculated at each of these locations using the radionuclide mix and releases of Table 3.2-1. Based upon these calculations, it was determined that the limiting receptor pathway is the vegetable/child pathway.

In the determination of the limiting location, annual average D/Q and X/Q values are used. A description of the derivation of the various X/Q and D/Q values is presented in Appendix A.

Short-term and long-term X/Q and D/Q values for ground level releases and for long-term mixed mode releases are provided in tables in Appendix A. They may be utilized if an additional special location arises different from those presented in the special locations of Table 3.2-2.

Tables 3.3-1 through 3.3-19 present  $R_i$  values for the total body, GI-tract, bone, liver, kidney, thyroid, skin, and lung organs for the ground plane, inhalation, cow milk, goat milk, vegetable, and meat ingestion pathways for the infant, child, teen, and adult age groups as appropriate to the pathways. These values were calculated using the methodology described in NUREG 0133 using a grazing period of eight months. A description of the methodology is presented in Appendix B.

The following relationship should hold for HBR to show compliance with HBR Technical Specification 3.9.5.1.



For the calendar quarter:

$$D_r \leq 7.5 \text{ mrem} \quad (3.3-9)$$

For the calendar year:

$$D_r \leq 15 \text{ mrem} \quad (3.3-10)$$

The quarterly limit given above represent one-half the annual design objectives of Section II.C of Appendix I of 10CFR50. If any of the limits of Equations 3.3-9 or 3.3-10 are exceeded, a special report pursuant to Technical Specification must be filed with the NRC. This report complies with Section IV.A of Appendix I of 10CFR50.

### 3.3.2.2 Projection of Doses

Doses resulting from release of radioiodines and particulate effluents will be projected once per 31 days. These projections will include a safety margin based upon expected operational conditions which will take into consideration both planned and unplanned releases.

Projected dose will be calculated as follows:

$$PD = \frac{31 (DA + DB)}{(TE)} + M \quad (3.3-11)$$

where:

- PD - Projected doses in mrem.
- DA - Dose accumulated during current quarter in mrem.
- DB - Projected dose from this release.
- TE - Time elapsed in quarter in days.
- M - Safety margin in mrem.



If the projected doses exceed 1.0 mrem to any organ when averaged over a calendar quarter, the ventilation exhaust treatment system will be operated to reduce releases of radioactive materials.

TABLE 3.3-1  
 R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>  
 (Reference Regulatory Guide 1.109)

PATHWAY - Ground

Nuclide	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-Tract	Skin
F-18	3.96E+05	3.96E+05	3.96E+05	3.96E+05	3.96E+05	3.96E+05	3.96E+05	4.66E+05
NA-24	1.19E+07	1.19E+07	1.19E+07	1.19E+07	1.19E+07	1.19E+07	1.19E+07	1.39E+07
CR-51	4.66E+06	4.66E+06	4.66E+06	4.66E+06	4.66E+06	4.66E+06	4.66E+06	5.51E+06
MN-54	1.39E+09	1.39E+09	1.39E+09	1.39E+09	1.39E+09	1.39E+09	1.39E+09	1.62E+09
MN-56	9.03E+05	9.03E+05	9.03E+05	9.03E+05	9.03E+05	9.03E+05	9.03E+05	1.07E+06
FE-59	2.73E+08	2.73E+08	2.73E+08	2.73E+08	2.73E+08	2.73E+08	2.73E+08	3.21E+08
CO-57	1.88E+08	1.88E+08	1.88E+08	1.88E+08	1.88E+08	1.88E+08	1.88E+08	2.07E+08
CO-58	3.79E+08	3.79E+08	3.79E+08	3.79E+08	3.79E+08	3.79E+08	3.79E+08	4.44E+08
CO-60	2.15E+10	2.15E+10	2.15E+10	2.15E+10	2.15E+10	2.15E+10	2.15E+10	2.53E+10
NI-65	2.97E+05	2.97E+05	2.97E+05	2.97E+05	2.97E+05	2.97E+05	2.97E+05	3.45E+05
CU-64	6.07E+05	6.07E+05	6.07E+05	6.07E+05	6.07E+05	6.07E+05	6.07E+05	6.88E+05
ZN-65	7.47E+08	7.47E+08	7.47E+08	7.47E+08	7.47E+08	7.47E+08	7.47E+08	8.59E+08
BR-82	2.14E+07	2.14E+07	2.14E+07	2.14E+07	2.14E+07	2.14E+07	2.14E+07	2.47E+07
BR-83	4.87E+03	4.87E+03	4.87E+03	4.87E+03	4.87E+03	4.87E+03	4.87E+03	7.08E+03
BR-84	2.03E+05	2.03E+05	2.03E+05	2.03E+05	2.03E+05	2.03E+05	2.03E+05	2.36E+05
RB-86	8.99E+06	8.99E+06	8.99E+06	8.99E+06	8.99E+06	8.99E+06	8.99E+06	1.03E+07
RB-88	3.31E+04	3.31E+04	3.31E+04	3.31E+04	3.31E+04	3.31E+04	3.31E+04	3.78E+04
RB-89	1.23E+05	1.23E+05	1.23E+05	1.23E+05	1.23E+05	1.23E+05	1.23E+05	1.48E+05
SR-89	2.16E+04	2.16E+04	2.16E+04	2.16E+04	2.16E+04	2.16E+04	2.16E+04	2.51E+04
SR-91	2.15E+06	2.15E+06	2.15E+06	2.15E+06	2.15E+06	2.15E+06	2.15E+06	2.51E+06
SR-92	7.77E+05	7.77E+05	7.77E+05	7.77E+05	7.77E+05	7.77E+05	7.77E+05	8.63E+05
Y-91M	1.00E+05	1.00E+05	1.00E+05	1.00E+05	1.00E+05	1.00E+05	1.00E+05	1.16E+05
Y-91	1.07E+06	1.07E+06	1.07E+06	1.07E+06	1.07E+06	1.07E+06	1.07E+06	1.21E+06
Y-92	1.80E+05	1.80E+05	1.80E+05	1.80E+05	1.80E+05	1.80E+05	1.80E+05	2.14E+05
Y-93	1.83E+05	1.83E+05	1.83E+05	1.83E+05	1.83E+05	1.83E+05	1.83E+05	2.51E+05
ZR-95	2.45E+08	2.45E+08	2.45E+08	2.45E+08	2.45E+08	2.45E+08	2.45E+08	2.84E+08
ZR-97	2.96E+06	2.96E+06	2.96E+06	2.96E+06	2.96E+06	2.96E+06	2.96E+06	3.44E+06
NB-95	1.37E+08	1.37E+08	1.37E+08	1.37E+08	1.37E+08	1.37E+08	1.37E+08	1.61E+08
NB-97	1.76E+05	1.76E+05	1.76E+05	1.76E+05	1.76E+05	1.76E+05	1.76E+05	2.07E+05
MO-99	3.99E+06	3.99E+06	3.99E+06	3.99E+06	3.99E+06	3.99E+06	3.99E+06	4.63E+06
TC-99M	1.84E+05	1.84E+05	1.84E+05	1.84E+05	1.84E+05	1.84E+05	1.84E+05	2.11E+05
TC-101	2.04E+04	2.04E+04	2.04E+04	2.04E+04	2.04E+04	2.04E+04	2.04E+04	2.26E+04

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

TABLE 3.3-1 (continued)

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
RU-103	1.08E+08	1.08E+08	1.08E+08	1.08E+08	1.08E+08	1.08E+08	1.08E+08	1.26E+08
RU-105	6.36E+05	6.36E+05	6.36E+05	6.36E+05	6.36E+05	6.36E+05	6.36E+05	7.21E+05
RU-106	4.22E+08	4.22E+08	4.22E+08	4.22E+08	4.22E+08	4.22E+08	4.22E+08	5.07E+08
AG-110M	3.44E+09	3.44E+09	3.44E+09	3.44E+09	3.44E+09	3.44E+09	3.44E+09	4.01E+09
SN-113	1.42E+07	1.42E+07	1.42E+07	1.42E+07	1.42E+07	1.42E+07	1.42E+07	4.08E+07
SB-124	5.98E+08	5.98E+08	5.98E+08	5.98E+08	5.98E+08	5.98E+08	5.98E+08	6.90E+08
SB-125	2.34E+09	2.34E+09	2.34E+09	2.34E+09	2.34E+09	2.34E+09	2.34E+09	2.64E+09
TE-129M	1.98E+07	1.98E+07	1.98E+07	1.98E+07	1.98E+07	1.98E+07	1.98E+07	2.31E+07
TE-129	2.62E+04	2.62E+04	2.62E+04	2.62E+04	2.62E+04	2.62E+04	2.62E+04	3.10E+04
TE-131M	8.03E+06	8.03E+06	8.03E+06	8.03E+06	8.03E+06	8.03E+06	8.03E+06	9.46E+06
TE-132	4.23E+06	4.23E+06	4.23E+06	4.23E+06	4.23E+06	4.23E+06	4.23E+06	4.98E+06
I-131	1.72E+07	1.72E+07	1.72E+07	1.72E+07	1.72E+07	1.72E+07	1.72E+07	2.09E+07
I-132	1.25E+06	1.25E+06	1.25E+06	1.25E+06	1.25E+06	1.25E+06	1.25E+06	1.46E+06
I-133	2.45E+06	2.45E+06	2.45E+06	2.45E+06	2.45E+06	2.45E+06	2.45E+06	2.98E+06
I-134	4.47E+05	4.47E+05	4.47E+05	4.47E+05	4.47E+05	4.47E+05	4.47E+05	5.30E+05
I-135	2.53E+06	2.53E+06	2.53E+06	2.53E+06	2.53E+06	2.53E+06	2.53E+06	2.95E+06
CS-134	6.86E+09	6.86E+09	6.86E+09	6.86E+09	6.86E+09	6.86E+09	6.86E+09	8.00E+09
CS-136	1.51E+08	1.51E+08	1.51E+08	1.51E+08	1.51E+08	1.51E+08	1.51E+08	1.71E+08
CS-137	1.03E+10	1.03E+10	1.03E+10	1.03E+10	1.03E+10	1.03E+10	1.03E+10	1.20E+10
CS-138	3.59E+05	3.59E+05	3.59E+05	3.59E+05	3.59E+05	3.59E+05	3.59E+05	4.10E+05
BA-139	1.06E+05	1.06E+05	1.06E+05	1.06E+05	1.06E+05	1.06E+05	1.06E+05	1.19E+05
BA-140	2.05E+07	2.05E+07	2.05E+07	2.05E+07	2.05E+07	2.05E+07	2.05E+07	2.35E+07
BA-142	4.49E+04	4.49E+04	4.49E+04	4.49E+04	4.49E+04	4.49E+04	4.49E+04	5.11E+04
LA-140	1.92E+07	1.92E+07	1.92E+07	1.92E+07	1.92E+07	1.92E+07	1.92E+07	2.18E+07
LA-142	7.60E+05	7.60E+05	7.60E+05	7.60E+05	7.60E+05	7.60E+05	7.60E+05	9.11E+05
CE-141	1.37E+07	1.37E+07	1.37E+07	1.37E+07	1.37E+07	1.37E+07	1.37E+07	1.54E+07
CE-143	2.31E+06	2.31E+06	2.31E+06	2.31E+06	2.31E+06	2.31E+06	2.31E+06	2.63E+06
CE-144	6.95E+07	6.95E+07	6.95E+07	6.95E+07	6.95E+07	6.95E+07	6.95E+07	8.04E+07
PR-144	1.83E+03	1.83E+03	1.83E+03	1.83E+03	1.83E+03	1.83E+03	1.83E+03	2.11E+03
HF-181	1.96E+08	1.96E+08	1.96E+08	1.96E+08	1.96E+08	1.96E+08	1.96E+08	2.80E+08
W-187	2.35E+06	2.35E+06	2.35E+06	2.35E+06	2.35E+06	2.35E+06	2.35E+06	2.73E+06
NP-239	1.71E+06	1.71E+06	1.71E+06	1.71E+06	1.71E+06	1.71E+06	1.71E+06	1.98E+06

TABLE 3.3-2

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>  
(Reference Regulatory Guide 1.109)

PATHWAY - Vegetation

AGE GROUP - Adult

Nuclide	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-Tract	Skin
H-3	0.00E+00	2.26E+03	2.26E+03	2.26E+03	2.26E+03	2.26E+03	2.26E+03	2.26E+03
F-18	4.22E+00	0.00E+00	4.68E-01	0.00E+00	0.00E+00	0.00E+00	1.25E-01	0.00E+00
NA-24	2.68E+05	2.68E+05	2.68E+05	2.68E+05	2.68E+05	2.68E+05	2.68E+05	0.00E+00
CR-51	0.00E+00	0.00E+00	4.59E+04	2.74E+04	1.01E+04	6.09E+04	1.15E+07	0.00E+00
MN-54	0.00E+00	3.08E+08	5.87E+07	0.00E+00	9.15E+07	0.00E+00	9.42E+08	0.00E+00
MN-56	0.00E+00	1.54E+01	2.74E+00	0.00E+00	1.96E+01	0.00E+00	4.93E+02	0.00E+00
FE-55	2.00E+08	1.38E+08	3.22E+07	0.00E+00	0.00E+00	7.70E+07	7.91E+07	0.00E+00
FE-59	1.24E+08	2.90E+08	1.11E+08	0.00E+00	0.00E+00	8.11E+07	9.68E+08	0.00E+00
CO-57	0.00E+00	1.01E+07	1.88E+07	0.00E+00	0.00E+00	0.00E+00	2.86E+08	0.00E+00
CO-58	0.00E+00	2.99E+07	6.70E+07	0.00E+00	0.00E+00	0.00E+00	6.06E+08	0.00E+00
CO-60	0.00E+00	1.67E+08	3.67E+08	0.00E+00	0.00E+00	0.00E+00	3.13E+09	0.00E+00
NI-65	5.97E+01	7.75E+00	3.54E+00	0.00E+00	0.00E+00	0.00E+00	1.97E+02	0.00E+00
CU-64	0.00E+00	9.19E+03	4.31E+03	0.00E+00	2.32E+04	0.00E+00	7.83E+05	0.00E+00
ZN-65	4.01E+08	1.28E+09	5.77E+08	0.00E+00	8.54E+08	0.00E+00	8.04E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	1.55E+06	0.00E+00	0.00E+00	0.00E+00	1.78E+06	0.00E+00
BR-83	0.00E+00	0.00E+00	3.10E+00	0.00E+00	0.00E+00	0.00E+00	4.47E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	2.21E-11	0.00E+00	0.00E+00	0.00E+00	1.73E-16	0.00E+00
RB-86	0.00E+00	2.21E+08	1.03E+08	0.00E+00	0.00E+00	0.00E+00	4.35E+07	0.00E+00
RB-88	0.00E+00	2.66E-22	1.41E-22	0.00E+00	0.00E+00	0.00E+00	3.67E-33	0.00E+00
RB-89	0.00E+00	2.90E-26	2.04E-26	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
SR-89	9.77E+09	0.00E+00	2.80E+08	0.00E+00	0.00E+00	0.00E+00	1.57E+09	0.00E+00
SR-90	6.71E+11	0.00E+00	1.65E+11	0.00E+00	0.00E+00	0.00E+00	1.94E+10	0.00E+00
SR-91	3.02E+05	0.00E+00	1.22E+04	0.00E+00	0.00E+00	0.00E+00	1.44E+06	0.00E+00
SR-92	4.15E+02	0.00E+00	1.79E+01	0.00E+00	0.00E+00	0.00E+00	8.22E+03	0.00E+00
Y-91M	4.76E-09	0.00E+00	1.84E-10	0.00E+00	0.00E+00	0.00E+00	1.40E-08	0.00E+00
Y-91	4.98E+06	0.00E+00	1.33E+05	0.00E+00	0.00E+00	0.00E+00	2.74E+09	0.00E+00
Y-92	8.96E-01	0.00E+00	2.62E-02	0.00E+00	0.00E+00	0.00E+00	1.57E-04	0.00E+00
Y-93	1.68E+02	0.00E+00	4.65E+00	0.00E+00	0.00E+00	0.00E+00	5.34E-06	0.00E+00
ZR-95	1.14E+06	3.66E+05	2.48E+05	0.00E+00	5.75E+05	0.00E+00	1.16E+09	0.00E+00
ZR-97	3.36E+02	6.78E+01	3.10E+01	0.00E+00	1.02E+02	0.00E+00	2.10E+07	0.00E+00
NB-95	1.40E+05	7.80E+04	4.19E+04	0.00E+00	7.71E+04	0.00E+00	4.73E+08	0.00E+00
NB-97	2.02E-06	5.11E-07	1.87E-07	0.00E+00	5.96E-07	0.00E+00	1.89E-03	0.00E+00
MO-99	0.00E+00	6.18E+06	1.18E+06	0.00E+00	1.40E+07	0.00E+00	1.43E+07	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.



TABLE 3.3-2 (continued)

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	3.10E+00	8.75E+00	1.11E+02	0.00E+00	1.33E+02	4.29E+00	5.18E+03	0.00E+00
TC-101	6.00E-31	8.64E-31	8.47E-30	0.00E+00	1.56E-29	4.41E-31	0.00E+00	0.00E+00
RU-103	4.72E+06	0.00E+00	2.03E+06	0.00E+00	1.80E+07	0.00E+00	5.51E+08	0.00E+00
RU-105	5.30E+01	0.00E+00	2.09E+01	0.00E+00	6.85E+02	0.00E+00	3.24E+04	0.00E+00
RU-106	1.95E+08	0.00E+00	2.47E+07	0.00E+00	3.76E+08	0.00E+00	1.26E+10	0.00E+00
AG-110M	1.13E+07	1.05E+07	6.22E+06	0.00E+00	2.06E+07	0.00E+00	4.27E+09	0.00E+00
SN-113	1.43E+07	5.50E+05	1.35E+07	1.94E+05	4.04E+05	0.00E+00	2.49E+08	0.00E+00
SB-124	1.01E+08	1.91E+06	4.01E+07	2.45E+05	0.00E+00	7.88E+07	2.87E+09	0.00E+00
SB-125	1.34E+08	1.50E+06	3.20E+07	1.37E+05	0.00E+00	1.04E+08	1.48E+09	0.00E+00
TE-129M	2.94E+08	1.10E+08	4.65E+07	1.01E+08	1.23E+09	0.00E+00	1.48E+09	0.00E+00
TE-129	7.52E-04	2.83E-04	1.83E-04	5.77E-04	3.16E-03	0.00E+00	5.68E-04	0.00E+00
TE-131M	9.63E+05	4.71E+05	3.93E+05	7.46E+05	4.77E+06	0.00E+00	4.68E+07	0.00E+00
TE-132	4.58E+06	2.96E+06	2.78E+06	3.27E+06	2.85E+07	0.00E+00	1.40E+08	0.00E+00
I-131	8.07E+07	1.15E+08	6.61E+07	3.78E+10	1.98E+08	0.00E+00	3.04E+07	0.00E+00
I-132	5.57E+01	1.49E+02	5.21E+01	5.21E+03	2.37E+02	0.00E+00	2.80E+01	0.00E+00
I-133	2.08E+06	3.61E+06	1.10E+06	5.31E+08	6.31E+06	0.00E+00	3.25E+06	0.00E+00
I-134	8.84E-05	2.40E-04	8.59E-05	4.16E-03	3.82E-04	0.00E+00	2.09E-07	0.00E+00
I-135	3.85E+04	1.01E+05	3.72E+04	6.65E+06	1.62E+05	0.00E+00	1.14E+05	0.00E+00
CS-134	4.55E+09	1.08E+10	8.84E+09	0.00E+00	3.50E+09	1.16E+09	1.89E+08	0.00E+00
CS-136	4.26E+07	1.68E+08	1.21E+08	0.00E+00	9.36E+07	1.28E+07	1.91E+07	0.00E+00
CS-137	6.64E+09	9.08E+09	5.95E+09	0.00E+00	3.08E+09	1.03E+09	1.76E+08	0.00E+00
CS-138	3.39E-11	6.70E-11	3.32E-11	0.00E+00	4.92E-11	4.86E-12	2.86E-16	0.00E+00
BA-139	2.70E-02	1.93E-05	7.91E-04	0.00E+00	1.80E-05	1.09E-05	4.79E-02	0.00E+00
BA-140	1.28E+08	1.61E+05	8.40E+06	0.00E+00	5.47E+04	9.22E+04	2.64E+08	0.00E+00
LA-140	1.97E+03	9.95E+02	2.63E+02	0.00E+00	0.00E+00	0.00E+00	7.30E+07	0.00E+00
LA-142	1.92E-04	8.75E-05	2.18E-05	0.00E+00	0.00E+00	0.00E+00	6.39E-01	0.00E+00
CE-141	1.94E+05	1.31E+05	1.49E+04	0.00E+00	6.10E+04	0.00E+00	5.02E+08	0.00E+00
CE-143	9.96E+02	7.36E+05	8.15E+01	0.00E+00	3.24E+02	0.00E+00	2.75E+07	0.00E+00
CE-144	3.15E+07	1.32E+07	1.69E+06	0.00E+00	7.81E+06	0.00E+00	1.07E+10	0.00E+00
PR-144	2.36E-26	9.81E-27	1.20E-27	0.00E+00	5.53E-27	0.00E+00	3.40E-33	0.00E+00
HF-181	9.50E+06	5.36E+04	1.08E+06	3.40E+04	4.47E+04	0.00E+00	7.05E+08	0.00E+00
W-187	3.79E+04	3.17E+04	1.11E+04	0.00E+00	0.00E+00	0.00E+00	1.04E+07	0.00E+00
NP-239	1.43E+03	1.40E+02	7.73E+01	0.00E+00	4.37E+02	0.00E+00	2.88E+07	0.00E+00

TABLE 3.3-3

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Vegetation

AGE GROUP - Teen

Nuclide	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-Tract	Skin
H-3	0.00E+00	2.59E+03	2.59E+03	2.59E+03	2.59E+03	2.59E+03	2.59E+03	2.59E+03
F-18	3.83E+00	0.00E+00	4.20E-01	0.00E+00	0.00E+00	0.00E+00	3.45E-01	0.00E+00
NA-24	2.38E+05	2.38E+05	2.38E+05	2.38E+05	2.38E+05	2.38E+05	2.38E+05	0.00E+00
CR-51	0.00E+00	0.00E+00	6.09E+04	3.38E+04	1.34E+04	8.70E+04	1.02E+07	0.00E+00
MN-54	0.00E+00	4.47E+08	8.86E+07	0.00E+00	1.33E+08	0.00E+00	9.16E+08	0.00E+00
MN-56	0.00E+00	1.39E+01	2.48E+00	0.00E+00	1.76E+01	0.00E+00	9.17E+02	0.00E+00
FE-55	3.10E+08	2.20E+08	5.13E+07	0.00E+00	0.00E+00	1.40E+08	9.53E+07	0.00E+00
FE-59	1.76E+08	4.10E+08	1.58E+08	0.00E+00	0.00E+00	1.29E+08	9.70E+08	0.00E+00
CO-57	0.00E+00	1.72E+07	2.89E+07	0.00E+00	0.00E+00	0.00E+00	3.21E+08	0.00E+00
CO-58	0.00E+00	4.24E+07	9.78E+07	0.00E+00	0.00E+00	0.00E+00	5.85E+08	0.00E+00
CO-60	0.00E+00	2.48E+08	5.58E+08	0.00E+00	0.00E+00	0.00E+00	3.23E+09	0.00E+00
NI-65	5.56E+01	7.10E+00	3.23E+00	0.00E+00	0.00E+00	0.00E+00	3.85E+02	0.00E+00
CU-64	0.00E+00	8.33E+03	3.92E+03	0.00E+00	2.11E+04	0.00E+00	6.46E+05	0.00E+00
ZN-65	5.36E+08	1.86E+09	8.68E+08	0.00E+00	1.19E+09	0.00E+00	7.88E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	1.37E+06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	2.91E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	2.01E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	2.75E+08	1.29E+08	0.00E+00	0.00E+00	0.00E+00	4.07E+07	0.00E+00
RB-88	0.00E+00	2.46E-22	1.31E-22	0.00E+00	0.00E+00	0.00E+00	2.11E-29	0.00E+00
RB-89	0.00E+00	2.61E-26	1.84E-26	0.00E+00	0.00E+00	0.00E+00	4.00E-35	0.00E+00
SR-89	1.48E+10	0.00E+00	4.25E+08	0.00E+00	0.00E+00	0.00E+00	1.77E+09	0.00E+00
SR-90	8.33E+11	0.00E+00	2.06E+11	0.00E+00	0.00E+00	0.00E+00	2.34E+10	0.00E+00
SR-91	2.83E+05	0.00E+00	1.12E+04	0.00E+00	0.00E+00	0.00E+00	1.28E+06	0.00E+00
SR-92	3.86E+02	0.00E+00	1.65E+01	0.00E+00	0.00E+00	0.00E+00	9.84E+03	0.00E+00
Y-91M	4.43E-09	0.00E+00	1.69E-10	0.00E+00	0.00E+00	0.00E+00	2.09E-07	0.00E+00
Y-91	7.64E+06	0.00E+00	2.05E+05	0.00E+00	0.00E+00	0.00E+00	3.13E+09	0.00E+00
Y-92	8.42E-01	0.00E+00	2.43E-02	0.00E+00	0.00E+00	0.00E+00	2.31E+04	0.00E+00
Y-93	1.58E+02	0.00E+00	4.33E+00	0.00E+00	0.00E+00	0.00E+00	4.82E+06	0.00E+00
ZR-95	1.67E+06	5.28E+05	3.63E+05	0.00E+00	7.76E+05	0.00E+00	1.22E+09	0.00E+00
ZR-97	3.11E+02	6.15E+01	2.83E+01	0.00E+00	9.33E+01	0.00E+00	1.67E+07	0.00E+00
NB-95	1.89E+05	1.05E+05	5.78E+04	0.00E+00	1.02E+05	0.00E+00	4.49E+08	0.00E+00
NB-97	1.87E-06	4.65E-07	1.70E-07	0.00E+00	5.44E-07	0.00E+00	1.11E-02	0.00E+00
MO-99	0.00E+00	5.67E+06	1.08E+06	0.00E+00	1.30E+07	0.00E+00	1.02E+07	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.



TABLE 3.3-3 (continued)

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	2.73E+00	7.62E+00	9.87E+01	0.00E+00	1.13E+02	4.23E+00	5.00E+03	0.00E+00
TC-101	5.58E-31	7.93E-31	7.79E-30	0.00E+00	1.43E-29	4.83E-31	1.36E-37	0.00E+00
RU-103	6.75E+06	0.00E+00	2.88E+06	0.00E+00	2.38E+07	0.00E+00	5.64E+08	0.00E+00
RU-105	4.93E+01	0.00E+00	1.91E+01	0.00E+00	6.22E+02	0.00E+00	3.98E+04	0.00E+00
RU-106	3.13E+08	0.00E+00	3.94E+07	0.00E+00	6.03E+08	0.00E+00	1.50E+10	0.00E+00
AG-110M	1.63E+07	1.54E+07	9.37E+06	0.00E+00	2.94E+07	0.00E+00	4.33E+09	0.00E+00
SN-113	1.88E+07	7.89E+05	2.00E+07	2.60E+05	5.58E+05	0.00E+00	2.26E+08	0.00E+00
SB-124	1.51E+08	2.78E+06	5.88E+07	3.42E+05	0.00E+00	1.32E+08	3.04E+09	0.00E+00
SB-125	2.11E+08	2.30E+06	4.92E+07	2.01E+05	0.00E+00	1.85E+08	1.64E+09	0.00E+00
TE-129M	4.23E+08	1.57E+08	6.69E+07	1.36E+08	1.77E+09	0.00E+00	1.59E+09	0.00E+00
TE-129	7.04E-04	2.63E-04	1.71E-04	5.03E-04	2.96E-03	0.00E+00	3.85E-03	0.00E+00
TE-131M	8.92E+05	4.28E+05	3.57E+05	6.43E+05	4.46E+06	0.00E+00	3.43E+07	0.00E+00
TE-132	4.16E+06	2.64E+06	2.48E+06	2.78E+06	2.53E+07	0.00E+00	8.35E+07	0.00E+00
I-131	7.67E+07	1.07E+08	5.77E+07	3.14E+10	1.85E+08	0.00E+00	2.13E+07	0.00E+00
I-132	5.02E+01	1.31E+02	4.72E+01	4.43E+03	2.07E+02	0.00E+00	5.73E+01	0.00E+00
I-133	1.93E+06	3.27E+06	9.99E+05	4.57E+08	5.74E+06	0.00E+00	2.48E+06	0.00E+00
I-134	7.99E-05	2.12E-04	7.61E-05	3.53E-03	3.34E-04	0.00E+00	2.79E-06	0.00E+00
I-135	3.48E+04	8.96E+04	3.32E+04	5.77E+06	1.42E+05	0.00E+00	9.93E+04	0.00E+00
CS-134	6.92E+09	1.63E+10	7.55E+09	0.00E+00	5.17E+09	1.97E+09	2.02E+08	0.00E+00
CS-136	4.36E+07	1.72E+08	1.15E+08	0.00E+00	9.35E+07	1.47E+07	1.38E+07	0.00E+00
CS-137	1.06E+10	1.41E+10	4.90E+09	0.00E+00	4.79E+09	1.86E+09	2.00E+08	0.00E+00
CS-138	3.13E-11	6.01E-11	3.01E-11	0.00E+00	4.44E-11	5.16E-12	2.73E-14	0.00E+00
BA-139	2.54E-02	1.79E-05	7.41E-04	0.00E+00	1.69E-05	1.23E-05	2.27E-01	0.00E+00
BA-140	1.38E+08	1.69E+05	8.87E+06	0.00E+00	5.72E+04	1.13E+05	2.12E+08	0.00E+00
LA-140	1.80E+03	8.86E+02	2.36E+02	0.00E+00	0.00E+00	0.00E+00	5.09E+07	0.00E+00
LA-142	1.77E-04	7.85E-05	1.95E-05	0.00E+00	0.00E+00	0.00E+00	2.39E+00	0.00E+00
CE-141	2.79E+05	1.86E+05	2.14E+04	0.00E+00	8.76E+04	0.00E+00	5.32E+08	0.00E+00
CE-143	9.31E+02	6.77E+05	7.56E+01	0.00E+00	3.04E+02	0.00E+00	2.04E+07	0.00E+00
CE-144	5.05E+07	2.09E+07	2.71E+06	0.00E+00	1.25E+07	0.00E+00	1.27E+10	0.00E+00
PR-144	2.22E-26	9.07E-27	1.12E-27	0.00E+00	5.20E-27	0.00E+00	2.44E-29	0.00E+00
HF-181	1.38E+07	7.58E+04	1.54E+06	4.62E+04	6.30E+04	0.00E+00	6.89E+08	0.00E+00
W-187	3.53E+04	2.87E+04	1.01E+04	0.00E+00	0.00E+00	0.00E+00	7.78E+06	0.00E+00
NP-239	1.38E+03	1.31E+02	7.25E+01	0.00E+00	4.10E+02	0.00E+00	2.10E+07	0.00E+00

TABLE 3.3-4

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>  
(Reference Regulatory Guide 1.109)

PATHWAY - Vegetation

AGE GROUP - Child

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	4.01E+03	4.01E+03	4.01E+03	4.01E+03	4.01E+03	4.01E+03	4.01E+03
F-18	6.84E+00	0.00E+00	6.78E-01	0.00E+00	0.00E+00	0.00E+00	1.85E+00	0.00E+00
NA-24	3.72E+05	3.72E+05	3.72E+05	3.72E+05	3.72E+05	3.72E+05	3.72E+05	0.00E+00
CR-51	0.00E+00	0.00E+00	1.16E+05	6.42E+04	1.75E+04	1.17E+05	6.14E+06	0.00E+00
MN-54	0.00E+00	6.54E+08	1.74E+08	0.00E+00	1.83E+08	0.00E+00	5.49E+08	0.00E+00
MN-56	0.00E+00	1.82E+01	4.11E+00	0.00E+00	2.20E+01	0.00E+00	2.64E+03	0.00E+00
FE-55	7.63E+08	4.05E+08	1.25E+08	0.00E+00	0.00E+00	2.29E+08	7.50E+07	0.00E+00
FE-59	3.89E+08	6.30E+08	3.14E+08	0.00E+00	0.00E+00	1.83E+08	6.56E+08	0.00E+00
CO-57	0.00E+00	2.88E+07	5.83E+07	0.00E+00	0.00E+00	0.00E+00	2.36E+08	0.00E+00
CO-58	0.00E+00	6.27E+07	1.92E+08	0.00E+00	0.00E+00	0.00E+00	3.65E+08	0.00E+00
CO-60	0.00E+00	3.77E+08	1.11E+09	0.00E+00	0.00E+00	0.00E+00	2.09E+09	0.00E+00
NI-65	1.02E+02	9.60E+00	5.60E+00	0.00E+00	0.00E+00	0.00E+00	1.18E+03	0.00E+00
CU-64	0.00E+00	1.10E+04	6.63E+03	0.00E+00	2.65E+04	0.00E+00	5.15E+05	0.00E+00
ZN-65	1.03E+09	2.74E+09	1.70E+09	0.00E+00	1.72E+09	0.00E+00	4.81E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	2.10E+06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	5.36E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	3.41E-11	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	4.55E+08	2.80E+08	0.00E+00	0.00E+00	0.00E+00	2.93E+07	0.00E+00
RB-88	0.00E+00	3.39E-22	2.36E-22	0.00E+00	0.00E+00	0.00E+00	1.66E-23	0.00E+00
RB-89	0.00E+00	3.43E-26	3.05E-26	0.00E+00	0.00E+00	0.00E+00	2.99E-28	0.00E+00
SR-89	3.52E+10	0.00E+00	1.01E+09	0.00E+00	0.00E+00	0.00E+00	1.36E+09	0.00E+00
SR-90	1.38E+12	0.00E+00	3.50E+11	0.00E+00	0.00E+00	0.00E+00	1.86E+10	0.00E+00
SR-91	5.20E+05	0.00E+00	1.96E+04	0.00E+00	0.00E+00	0.00E+00	1.15E+06	0.00E+00
SR-92	7.08E+02	0.00E+00	2.84E+01	0.00E+00	0.00E+00	0.00E+00	1.34E+04	0.00E+00
Y-91M	8.12E-09	0.00E+00	2.95E-10	0.00E+00	0.00E+00	0.00E+00	1.59E-05	0.00E+00
Y-91	1.82E+07	0.00E+00	4.86E+05	0.00E+00	0.00E+00	0.00E+00	2.42E+09	0.00E+00
Y-92	1.55E+00	0.00E+00	4.44E-02	0.00E+00	0.00E+00	0.00E+00	4.48E+04	0.00E+00
Y-93	2.91E+02	0.00E+00	7.98E+00	0.00E+00	0.00E+00	0.00E+00	4.34E+06	0.00E+00
ZR-95	3.75E+06	8.25E+05	7.34E+05	0.00E+00	1.18E+06	0.00E+00	8.60E+08	0.00E+00
ZR-97	5.68E+02	8.20E+01	4.84E+01	0.00E+00	1.18E+02	0.00E+00	1.24E+07	0.00E+00
NB-95	4.04E+05	1.57E+05	1.12E+05	0.00E+00	1.48E+05	0.00E+00	2.91E+08	0.00E+00
NB-97	3.41E-06	6.16E-07	2.88E-07	0.00E+00	6.84E-07	0.00E+00	1.90E-01	0.00E+00
SR-91	5.20E+05	0.00E+00	1.96E+04	0.00E+00	0.00E+00	0.00E+00	1.15E+06	0.00E+00
SR-92	7.08E+02	0.00E+00	2.84E+01	0.00E+00	0.00E+00	0.00E+00	1.34E+04	0.00E+00
Y-91M	8.12E-09	0.00E+00	2.95E-10	0.00E+00	0.00E+00	0.00E+00	1.59E-05	0.00E+00
Y-91	1.82E+07	0.00E+00	4.86E+05	0.00E+00	0.00E+00	0.00E+00	2.42E+09	0.00E+00
Y-92	1.55E+00	0.00E+00	4.44E-02	0.00E+00	0.00E+00	0.00E+00	4.48E+04	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
Y-93	2.91E+02	0.00E+00	7.98E+00	0.00E+00	0.00E+00	0.00E+00	4.34E+06	0.00E+00
ZR-95	3.75E+06	8.25E+05	7.34E+05	0.00E+00	1.18E+06	0.00E+00	8.60E+08	0.00E+00
ZR-97	5.68E+02	8.20E+01	4.84E+01	0.00E+00	1.18E+02	0.00E+00	1.24E+07	0.00E+00
NB-95	4.04E+05	1.57E+05	1.12E+05	0.00E+00	1.48E+05	0.00E+00	2.91E+08	0.00E+00
NB-97	3.41E-06	6.16E-07	2.88E-07	0.00E+00	6.84E-07	0.00E+00	1.90E-01	0.00E+00
MO-99	0.00E+00	7.75E+06	1.92E+06	0.00E+00	1.65E+07	0.00E+00	6.41E+06	0.00E+00
TC-99M	4.70E+00	9.21E+00	1.53E+02	0.00E+00	1.34E+02	4.68E+00	5.24E+03	0.00E+00
TC-101	1.03E-30	1.07E-30	1.36E-29	0.00E+00	1.83E-29	5.68E-31	3.41E-30	0.00E+00
RU-103	1.52E+07	0.00E+00	5.83E+06	0.00E+00	3.82E+07	0.00E+00	3.92E+08	0.00E+00
RU-105	9.02E+01	0.00E+00	3.27E+01	0.00E+00	7.93E+02	0.00E+00	5.89E+04	0.00E+00
RU-106	7.54E+08	0.00E+00	9.40E+07	0.00E+00	1.02E+09	0.00E+00	1.17E+10	0.00E+00
AG-110M	3.45E+07	2.33E+07	1.86E+07	0.00E+00	4.34E+07	0.00E+00	2.77E+09	0.00E+00
SN-113	3.60E+07	1.16E+06	3.93E+07	4.75E+05	7.96E+05	0.00E+00	1.44E+08	0.00E+00
SB-124	3.43E+08	4.46E+06	1.20E+08	7.58E+05	0.00E+00	1.91E+08	2.15E+09	0.00E+00
SB-125	4.91E+08	3.79E+06	1.03E+08	4.55E+05	0.00E+00	2.74E+08	1.17E+09	0.00E+00
TE-129M	9.83E+08	2.74E+08	1.53E+08	3.17E+08	2.89E+09	0.00E+00	1.20E+09	0.00E+00
TE-129	1.30E-03	3.64E-04	3.09E-04	9.30E-04	3.81E-03	0.00E+00	8.12E-02	0.00E+00
TE-131M	1.63E+06	5.63E+05	5.99E+05	1.16E+06	5.45E+06	0.00E+00	2.28E+07	0.00E+00
TE-132	7.46E+06	3.30E+06	3.99E+06	4.81E+06	3.07E+07	0.00E+00	3.32E+07	0.00E+00
I-131	1.43E+08	1.44E+08	8.16E+07	4.75E+10	2.36E+08	0.00E+00	1.28E+07	0.00E+00
I-132	8.92E+01	1.64E+02	7.53E+01	7.60E+03	2.51E+02	0.00E+00	1.93E+02	0.00E+00
I-133	3.52E+06	4.35E+06	1.65E+06	8.08E+08	7.25E+06	0.00E+00	1.75E+06	0.00E+00
I-134	1.42E-04	2.64E-04	1.21E-04	6.07E-03	4.03E-04	0.00E+00	1.75E-04	0.00E+00
I-135	6.18E+04	1.11E+05	5.27E+04	9.86E+06	1.71E+05	0.00E+00	8.48E+04	0.00E+00
CS-134	1.56E+10	2.56E+10	5.41E+09	0.00E+00	7.94E+09	2.85E+09	1.38E+08	0.00E+00
CS-136	8.22E+07	2.26E+08	1.46E+08	0.00E+00	1.20E+08	1.79E+07	7.94E+06	0.00E+00
CS-137	2.50E+10	2.39E+10	3.53E+09	0.00E+00	7.79E+09	2.80E+09	1.50E+08	0.00E+00
CS-138	5.69E-11	7.92E-11	5.02E-11	0.00E+00	5.57E-11	5.99E-12	3.65E-11	0.00E+00
BA-139	4.69E-02	2.50E-05	1.36E-03	0.00E+00	2.18E-05	1.47E-05	2.71E+00	0.00E+00
BA-140	2.76E+08	2.42E+05	1.61E+07	0.00E+00	7.87E+04	1.44E+05	1.40E+08	0.00E+00
LA-140	3.24E+03	1.13E+03	3.82E+02	0.00E+00	0.00E+00	0.00E+00	3.16E+07	0.00E+00
LA-142	3.20E-04	1.02E-04	3.20E-05	0.00E+00	0.00E+00	0.00E+00	2.02E+01	0.00E+00
CE-141	6.46E+05	3.22E+05	4.79E+04	0.00E+00	1.41E+05	0.00E+00	4.02E+08	0.00E+00
CE-143	1.71E+03	9.29E+05	1.35E+02	0.00E+00	3.90E+02	0.00E+00	1.36E+07	0.00E+00
CE-144	1.22E+08	3.82E+07	6.50E+06	0.00E+00	2.11E+07	0.00E+00	9.95E+09	0.00E+00
PR-144	4.11E-26	1.27E-26	2.07E-27	0.00E+00	6.73E-27	0.00E+00	2.74E-23	0.00E+00
HF-181	3.12E+07	1.22E+05	3.14E+06	1.03E+05	9.80E+04	0.00E+00	5.18E+08	0.00E+00
W-187	6.41E+04	3.80E+04	1.70E+04	0.00E+00	0.00E+00	0.00E+00	5.34E+06	0.00E+00
NP-239	2.56E+03	1.84E+02	1.29E+02	0.00E+00	5.31E+02	0.00E+00	1.36E+07	0.00E+00



TABLE 3.3-5

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>  
(Reference Regulatory Guide 1.109)

PATHWAY - Meat

AGE GROUP - Adult

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	3.24E+02	3.24E+02	3.24E+02	3.24E+02	3.24E+02	3.24E+02	3.24E+02
NA-24	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	1.39E-03	0.00E+00
CR-51	0.00E+00	0.00E+00	6.30E+03	3.76E+03	1.39E+03	8.36E+03	1.58E+06	0.00E+00
MN-54	0.00E+00	7.33E+06	1.40E+06	0.00E+00	2.18E+06	0.00E+00	2.24E+07	0.00E+00
FE-55	2.28E+08	1.58E+08	3.68E+07	0.00E+00	0.00E+00	8.81E+07	9.06E+07	0.00E+00
FE-59	2.28E+08	5.36E+08	2.05E+08	0.00E+00	0.00E+00	1.50E+08	1.79E+09	0.00E+00
CO-57	0.00E+00	4.01E+06	7.43E+06	0.00E+00	0.00E+00	0.00E+00	1.13E+08	0.00E+00
CO-58	0.00E+00	1.52E+07	3.40E+07	0.00E+00	0.00E+00	0.00E+00	3.07E+08	0.00E+00
CO-60	0.00E+00	5.96E+07	1.31E+08	0.00E+00	0.00E+00	0.00E+00	1.12E+09	0.00E+00
CU-64	0.00E+00	2.80E-07	1.31E-07	0.00E+00	7.05E-07	0.00E+00	2.38E-05	0.00E+00
ZN-65	3.20E+08	1.02E+09	4.60E+08	0.00E+00	6.81E+08	0.00E+00	6.42E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	1.25E+03	0.00E+00	0.00E+00	0.00E+00	1.43E+03	0.00E+00
RB-86	0.00E+00	4.53E+08	2.11E+08	0.00E+00	0.00E+00	0.00E+00	8.94E+07	0.00E+00
SR-89	2.57E+08	0.00E+00	7.37E+06	0.00E+00	0.00E+00	0.00E+00	4.12E+07	0.00E+00
SR-90	1.03E+10	0.00E+00	2.53E+09	0.00E+00	0.00E+00	0.00E+00	2.98E+08	0.00E+00
SR-91	1.58E-10	0.00E+00	6.39E-12	0.00E+00	0.00E+00	0.00E+00	7.53E-10	0.00E+00
Y-91	9.53E+05	0.00E+00	2.55E+04	0.00E+00	0.00E+00	0.00E+00	5.24E+08	0.00E+00
Y-93	4.87E-12	0.00E+00	1.35E-13	0.00E+00	0.00E+00	0.00E+00	1.55E-07	0.00E+00
ZR-95	1.57E+06	5.02E+05	3.40E+05	0.00E+00	7.88E+05	0.00E+00	1.59E+09	0.00E+00
ZR-97	2.11E-05	4.27E-06	1.95E-06	0.00E+00	6.44E-06	0.00E+00	1.32E+00	0.00E+00
NB-95	2.01E+06	1.12E+06	6.02E+05	0.00E+00	1.11E+06	0.00E+00	6.79E+09	0.00E+00
MO-99	0.00E+00	1.01E+05	1.92E+04	0.00E+00	2.28E+05	0.00E+00	2.33E+05	0.00E+00
TC-99M	4.76E-21	1.35E-20	1.71E-19	0.00E+00	2.04E-19	6.59E-21	7.96E-18	0.00E+00
RU-103	9.15E+07	0.00E+00	3.94E+07	0.00E+00	3.49E+08	0.00E+00	1.07E+10	0.00E+00
RU-105	6.30E-28	0.00E+00	2.49E-28	0.00E+00	8.15E-27	0.00E+00	3.86E-25	0.00E+00
RU-106	2.26E+09	0.00E+00	2.85E+08	0.00E+00	4.36E+07	0.00E+00	1.46E+11	0.00E+00
AG-110M	5.57E+06	5.15E+06	3.06E+06	0.00E+00	1.01E+07	0.00E+00	2.10E+09	0.00E+00
SN-113	3.94E+07	1.52E+06	3.73E+07	5.36E+05	1.12E+06	0.00E+00	6.89E+08	0.00E+00
SB-124	1.66E+07	3.14E+05	6.60E+06	4.03E+04	0.00E+00	1.30E+07	4.72E+08	0.00E+00
SB-125	1.51E+07	1.69E+05	3.59E+06	1.53E+04	0.00E+00	1.16E+07	1.66E+08	0.00E+00
TE-129M	1.07E+09	3.99E+08	1.69E+08	3.67E+08	4.46E+09	0.00E+00	5.38E+09	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TE-131M	4.66E+02	2.28E+02	1.90E+02	3.61E+02	2.31E+03	0.00E+00	2.26E+04	0.00E+00
TE-132	1.46E+06	9.44E+05	8.86E+05	1.04E+06	9.09E+06	0.00E+00	4.46E+07	0.00E+00
I-131	1.06E+07	1.51E+07	8.66E+06	4.95E+09	2.59E+07	0.00E+00	3.99E+06	0.00E+00
I-133	3.72E-01	6.47E-01	1.97E-01	9.51E+01	1.13E+00	0.00E+00	5.82E-01	0.00E+00
I-135	4.69E-17	1.23E-16	4.53E-17	8.10E-15	1.97E-16	0.00E+00	1.39E-16	0.00E+00
CS-134	5.18E+08	1.23E+09	1.01E+09	0.00E+00	3.99E+08	1.32E+08	2.16E+07	0.00E+00
CS-136	1.15E+07	4.54E+07	3.27E+07	0.00E+00	2.53E+07	3.46E+06	5.16E+06	0.00E+00
CS-137	7.04E+08	9.63E+08	6.31E+08	0.00E+00	3.27E+08	1.09E+08	1.86E+07	0.00E+00
BA-140	2.75E+07	3.45E+04	1.80E+06	0.00E+00	1.17E+04	1.98E+04	5.66E+07	0.00E+00
LA-140	3.74E-02	1.89E-02	4.99E-03	0.00E+00	0.00E+00	0.00E+00	1.38E+03	0.00E+00
CE-141	1.24E+04	8.37E+03	9.49E+02	0.00E+00	3.89E+03	0.00E+00	3.20E+07	0.00E+00
CE-143	2.03E-02	1.50E+01	1.66E-03	0.00E+00	6.61E-03	0.00E+00	5.61E+02	0.00E+00
CE-144	1.15E+06	4.82E+05	6.19E+04	0.00E+00	2.86E+05	0.00E+00	3.90E+08	0.00E+00
HF-181	1.79E+08	1.01E+06	2.03E+07	6.41E+05	8.41E+05	0.00E+00	1.33E+10	0.00E+00
W-187	2.08E-02	1.74E-02	6.09E-03	0.00E+00	0.00E+00	0.00E+00	5.71E+00	0.00E+00
NP-239	2.61E-01	2.56E-02	1.41E-02	0.00E+00	8.00E-02	0.00E+00	5.26E+03	0.00E+00



(Reference Regulatory Guide 1.109)

PATHWAY - Meat

AGE GROUP - Teen

Nuclide	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-Tract	Skin
H-3	0.00E+00	1.93E+02	1.93E+02	1.93E+02	1.93E+02	1.93E+02	1.93E+02	1.93E+02
NA-24	1.11E-03	1.11E-03	1.11E-03	1.11E-03	1.11E-03	1.11E-03	1.11E-03	0.00E+00
CR-51	0.00E+00	0.00E+00	5.04E+03	2.80E+03	1.10E+03	7.19E+03	8.46E+05	0.00E+00
MN-54	0.00E+00	5.59E+06	1.11E+06	0.00E+00	1.67E+06	0.00E+00	1.15E+07	0.00E+00
FE-55	1.86E+08	1.32E+08	3.07E+07	0.00E+00	0.00E+00	8.35E+07	5.69E+07	0.00E+00
FE-59	1.82E+08	4.25E+08	1.64E+08	0.00E+00	0.00E+00	1.34E+08	1.01E+09	0.00E+00
CO-57	0.00E+00	3.59E+06	6.02E+06	0.00E+00	0.00E+00	0.00E+00	6.70E+07	0.00E+00
CO-58	0.00E+00	1.17E+07	2.69E+07	0.00E+00	0.00E+00	0.00E+00	1.61E+08	0.00E+00
CO-60	0.00E+00	4.62E+07	1.04E+08	0.00E+00	0.00E+00	0.00E+00	6.02E+08	0.00E+00
CU-64	0.00E+00	2.28E-07	1.07E-07	0.00E+00	5.77E-07	0.00E+00	1.77E-05	0.00E+00
ZN-65	2.25E+08	7.82E+08	3.65E+08	0.00E+00	5.00E+08	0.00E+00	3.31E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	9.94E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	3.78E+08	1.78E+08	0.00E+00	0.00E+00	0.00E+00	5.60E+07	0.00E+00
SR-89	2.17E+08	0.00E+00	6.21E+06	0.00E+00	0.00E+00	0.00E+00	2.58E+07	0.00E+00
SR-90	6.68E+09	0.00E+00	1.65E+09	0.00E+00	0.00E+00	0.00E+00	1.88E+08	0.00E+00
SR-91	1.33E-10	0.00E+00	5.29E-12	0.00E+00	0.00E+00	0.00E+00	6.04E-10	0.00E+00
Y-91	8.03E+05	0.00E+00	2.15E+04	0.00E+00	0.00E+00	0.00E+00	3.29E+08	0.00E+00
Y-93	4.11E-12	0.00E+00	1.13E-13	0.00E+00	0.00E+00	0.00E+00	1.26E-07	0.00E+00
ZR-95	1.25E+06	3.96E+05	2.72E+05	0.00E+00	5.82E+05	0.00E+00	9.13E+08	0.00E+00
ZR-97	1.76E-05	3.49E-06	1.61E-06	0.00E+00	5.29E-06	0.00E+00	9.44E-01	0.00E+00
NB-95	1.57E+06	8.72E+05	4.80E+05	0.00E+00	8.45E+05	0.00E+00	3.73E+09	0.00E+00
MO-99	0.00E+00	8.33E+04	1.59E+04	0.00E+00	1.91E+05	0.00E+00	1.49E+05	0.00E+00
TC-99M	3.78E-21	1.05E-20	1.37E-19	0.00E+00	1.57E-19	5.85E-21	6.92E-18	0.00E+00
RU-103	7.45E+07	0.00E+00	3.18E+07	0.00E+00	2.63E+08	0.00E+00	6.22E+09	0.00E+00
RU-105	5.27E-28	0.00E+00	2.05E-28	0.00E+00	6.65E-27	0.00E+00	4.26E-25	0.00E+00
RU-106	1.90E+09	0.00E+00	2.39E+08	0.00E+00	3.66E+09	0.00E+00	9.11E+10	0.00E+00
AG-110M	4.21E+06	3.99E+06	2.43E+06	0.00E+00	7.60E+06	0.00E+00	1.12E+09	0.00E+00
SN-113	2.78E+07	1.16E+06	2.95E+07	3.84E+05	8.23E+05	0.00E+00	3.33E+08	0.00E+00
SB-124	1.36E+07	2.50E+05	5.30E+06	3.08E+04	0.00E+00	1.19E+07	2.74E+08	0.00E+00
SB-125	1.24E+07	1.35E+05	2.89E+06	1.13E+04	0.00E+00	1.09E+07	9.61E+07	0.00E+00
TE-129M	8.96E+08	3.32E+08	1.42E+08	2.89E+08	3.75E+09	0.00E+00	3.36E+09	0.00E+00
TE-131M	3.89E+02	1.86E+02	1.55E+02	2.80E+02	1.94E+03	0.00E+00	1.50E+04	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TE-132	1.19E+06	7.56E+05	7.12E+05	7.97E+05	7.25E+06	0.00E+00	2.40E+07	0.00E+00
I-131	8.78E+06	1.23E+07	6.60E+06	3.59E+09	2.12E+07	0.00E+00	2.43E+06	0.00E+00
I-133	3.11E-01	5.28E-01	1.61E-01	7.37E+01	9.26E-01	0.00E+00	3.99E-01	0.00E+00
I-135	3.82E-17	9.83E-17	3.64E-17	6.32E-15	1.55E-16	0.00E+00	1.09E-16	0.00E+00
CS-134	4.12E+08	9.69E+08	4.50E+08	0.00E+00	3.08E+08	1.18E+08	1.21E+07	0.00E+00
CS-136	8.97E+06	3.53E+07	2.37E+07	0.00E+00	1.92E+07	3.03E+06	2.84E+06	0.00E+00
CS-137	5.85E+08	7.78E+08	2.71E+08	0.00E+00	2.65E+08	1.03E+06	1.11E+07	0.00E+00
BA-140	2.27E+07	2.78E+04	1.46E+06	0.00E+00	9.44E+03	1.87E+04	3.50E+07	0.00E+00
LA-140	3.08E-02	1.51E-02	4.02E-03	0.00E+00	0.00E+00	0.00E+00	8.69E+02	0.00E+00
CE-141	1.04E+04	6.94E+03	7.97E+02	0.00E+00	3.27E+03	0.00E+00	1.98E+07	0.00E+00
CE-143	1.71E-02	1.24E+01	1.39E-03	0.00E+00	5.58E-03	0.00E+00	3.74E+02	0.00E+00
CE-144	9.71E+05	4.02E+05	5.22E+04	0.00E+00	2.40E+05	0.00E+00	2.44E+08	0.00E+00
HF-181	1.47E+08	8.06E+05	1.64E+07	4.91E+05	6.70E+05	0.00E+00	7.33E+09	0.00E+00
W-187	1.75E-02	1.42E-02	4.99E-03	0.00E+00	0.00E+00	0.00E+00	3.85E+00	0.00E+00
NP-239	2.28E-01	2.15E-02	1.19E-02	0.00E+00	6.75E-02	0.00E+00	3.46E+03	0.00E+00

TABLE 3.3-7

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>  
(Reference Regulatory Guide 1.109)

PATHWAY - Meat

AGE GROUP - Child

Nuclide	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-Tract	Skin
H-3	0.00E+00	2.33E+02	2.33E+02	2.33E+02	2.33E+02	2.33E+02	2.33E+02	2.33E+02
NA-24	1.77E-03	1.77E-03	1.77E-03	1.77E-03	1.77E-03	1.77E-03	1.77E-03	0.00E+00
CR-51	0.00E+00	0.00E+00	7.85E+03	4.36E+03	1.19E+03	7.96E+03	4.16E+05	0.00E+00
MN-54	0.00E+00	6.39E+06	1.70E+06	0.00E+00	1.79E+06	0.00E+00	5.37E+06	0.00E+00
FE-55	3.56E+08	1.89E+08	5.85E+07	0.00E+00	0.00E+00	1.07E+08	3.50E+07	0.00E+00
FE-59	3.23E+08	5.23E+08	2.60E+08	0.00E+00	0.00E+00	1.51E+08	5.44E+08	0.00E+00
CO-57	0.00E+00	4.69E+06	9.50E+06	0.00E+00	0.00E+00	0.00E+00	3.85E+07	0.00E+00
CO-58	0.00E+00	1.37E+07	4.18E+07	0.00E+00	0.00E+00	0.00E+00	7.97E+07	0.00E+00
CO-60	0.00E+00	5.49E+07	1.62E+08	0.00E+00	0.00E+00	0.00E+00	3.04E+08	0.00E+00
CU-64	0.00E+00	3.06E-07	1.85E-07	0.00E+00	7.41E-07	0.00E+00	1.44E-05	0.00E+00
ZN-65	3.38E+08	9.00E+08	5.60E+08	0.00E+00	5.67E+08	0.00E+00	1.58E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	1.56E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	5.37E+08	3.30E+08	0.00E+00	0.00E+00	0.00E+00	3.45E+07	0.00E+00
SR-89	4.10E+08	0.00E+00	1.17E+07	0.00E+00	0.00E+00	0.00E+00	1.59E+07	0.00E+00
SR-90	8.64E+09	0.00E+00	2.19E+09	0.00E+00	0.00E+00	0.00E+00	1.16E+08	0.00E+00
SR-91	2.50E-10	0.00E+00	9.42E-12	0.00E+00	0.00E+00	0.00E+00	5.51E-10	0.00E+00
Y-91	1.52E+06	0.00E+00	4.06E+04	0.00E+00	0.00E+00	0.00E+00	2.02E+08	0.00E+00
Y-93	7.73E-12	0.00E+00	2.12E-13	0.00E+00	0.00E+00	0.00E+00	1.15E-07	0.00E+00
ZR-95	2.23E+06	4.90E+05	4.36E+05	0.00E+00	7.01E+05	0.00E+00	5.11E+08	0.00E+00
ZR-97	3.28E-05	4.74E-06	2.80E-06	0.00E+00	6.80E-06	0.00E+00	7.18E-01	0.00E+00
NB-95	2.71E+06	1.06E+06	7.55E+05	0.00E+00	9.92E+05	0.00E+00	1.95E+09	0.00E+00
MO-99	0.00E+00	1.16E+05	2.87E+04	0.00E+00	2.47E+05	0.00E+00	9.58E+04	0.00E+00
TC-99M	6.63E-21	1.30E-20	2.15E-19	0.00E+00	1.89E-19	6.60E-21	7.40E-18	0.00E+00
RU-103	1.35E+08	0.00E+00	5.18E+07	0.00E+00	3.39E+08	0.00E+00	3.48E+09	0.00E+00
RU-105	9.84E-28	0.00E+00	3.57E-28	0.00E+00	8.65E-27	0.00E+00	6.42E-25	0.00E+00
RU-106	3.58E+09	0.00E+00	4.46E+08	0.00E+00	4.83E+09	0.00E+00	5.56E+10	0.00E+00
AG-110M	6.99E+06	4.72E+06	3.77E+06	0.00E+00	8.79E+06	0.00E+00	5.61E+08	0.00E+00
SN-113	4.17E+07	1.34E+06	4.56E+07	5.51E+05	9.23E+05	0.00E+00	1.67E+08	0.00E+00
SB-124	2.46E+07	3.19E+05	8.62E+06	5.43E+04	0.00E+00	1.36E+07	1.54E+08	0.00E+00
SB-125	2.25E+07	1.73E+05	4.71E+06	2.08E+04	0.00E+00	1.25E+07	5.37E+07	0.00E+00
TE-129M	1.69E+09	4.71E+08	2.62E+08	5.44E+08	4.96E+09	0.00E+00	2.06E+09	0.00E+00
TE-131M	7.23E+02	2.50E+02	2.66E+02	5.14E+02	2.42E+03	0.00E+00	1.01E+04	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TE-132	2.18E+06	9.65E+05	1.17E+06	1.41E+06	8.96E+06	0.00E+00	9.71E+06	0.00E+00
I-131	1.63E+07	1.64E+07	9.30E+06	5.41E+09	2.69E+07	0.00E+00	1.46E+06	0.00E+00
I-133	5.78E-01	7.15E-01	2.71E-01	1.33E+02	1.19E+00	0.00E+00	2.88E-01	0.00E+00
I-135	6.91E-17	1.24E-16	5.88E-17	1.10E-14	1.91E-16	0.00E+00	9.47E-17	0.00E+00
CS-134	7.26E+08	1.19E+09	2.51E+08	0.00E+00	3.69E+08	1.33E+08	6.43E+06	0.00E+00
CS-136	1.55E+07	4.26E+07	2.75E+07	0.00E+00	2.27E+07	3.38E+06	1.50E+06	0.00E+00
CS-137	1.08E+09	1.03E+09	1.52E+08	0.00E+00	3.36E+08	1.21E+08	6.45E+06	0.00E+00
BA-140	4.19E+07	3.67E+04	2.45E+06	0.00E+00	1.20E+04	2.19E+04	2.12E+07	0.00E+00
LA-140	5.64E-02	1.97E-02	6.64E-03	0.00E+00	0.00E+00	0.00E+00	5.49E+02	0.00E+00
CE-141	1.96E+04	9.76E+03	1.45E+03	0.00E+00	4.28E+03	0.00E+00	1.22E+07	0.00E+00
CE-143	3.21E-02	1.74E+01	2.52E-03	0.00E+00	7.29E-03	0.00E+00	2.55E+02	0.00E+00
CE-144	1.83E+06	5.74E+05	9.77E+04	0.00E+00	3.18E+05	0.00E+00	1.50E+08	0.00E+00
HF-181	2.66E+08	1.04E+06	2.68E+07	8.75E+05	8.35E+05	0.00E+00	4.42E+09	0.00E+00
W-187	3.24E-02	1.92E-02	8.60E-03	0.00E+00	0.00E+00	0.00E+00	2.69E+00	0.00E+00
NP-239	4.29E-01	3.08E-02	2.16E-02	0.00E+00	8.90E-02	0.00E+00	2.28E+03	0.00E+00



TABLE 3.3-8

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Cow Milk

AGE GROUP - Adult

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	7.63E+02	7.63E+02	7.63E+02	7.63E+02	7.63E+02	7.63E+02	7.63E+02
F-18	4.57E-03	0.00E+00	5.07E-04	0.00E+00	0.00E+00	0.00E+00	1.35E-04	0.00E+00
NA-24	2.45E+06	2.45E+06	2.45E+06	2.45E+06	2.45E+06	2.45E+06	2.45E+06	0.00E+00
CR-51	0.00E+00	0.00E+00	2.55E+04	1.53E+04	5.62E+03	3.39E+04	6.42E+06	0.00E+00
MN-54	0.00E+00	6.71E+06	1.28E+06	0.00E+00	2.00E+06	0.00E+00	2.06E+07	0.00E+00
MN-56	0.00E+00	4.21E-03	7.47E-04	0.00E+00	5.35E-03	0.00E+00	1.34E-01	0.00E+00
FE-55	1.96E+07	1.35E+07	3.15E+06	0.00E+00	0.00E+00	7.54E+06	7.75E+06	0.00E+00
FE-59	2.55E+07	5.99E+07	2.30E+07	0.00E+00	0.00E+00	1.67E+07	2.00E+08	0.00E+00
CO-57	0.00E+00	9.10E+05	1.69E+06	0.00E+00	0.00E+00	0.00E+00	2.57E+07	0.00E+00
CO-58	0.00E+00	3.92E+06	8.79E+06	0.00E+00	0.00E+00	0.00E+00	7.95E+07	0.00E+00
CO-60	0.00E+00	1.30E+07	2.87E+07	0.00E+00	0.00E+00	0.00E+00	2.44E+08	0.00E+00
NI-65	3.76E-01	4.88E-02	2.23E-02	0.00E+00	0.00E+00	0.00E+00	1.24E+00	0.00E+00
CU-64	0.00E+00	2.39E+04	1.12E+04	0.00E+00	6.04E+04	0.00E+00	2.04E+06	0.00E+00
ZN-65	1.23E+09	3.93E+09	1.78E+09	0.00E+00	2.63E+09	0.00E+00	2.47E+09	0.00E+00
BR-82	0.00E+00	0.00E+00	3.27E+07	0.00E+00	0.00E+00	0.00E+00	3.75E+07	0.00E+00
BR-83	0.00E+00	0.00E+00	9.98E-02	0.00E+00	0.00E+00	0.00E+00	1.44E-01	0.00E+00
BR-84	0.00E+00	0.00E+00	1.75E-23	0.00E+00	0.00E+00	0.00E+00	1.37E-28	0.00E+00
RB-86	0.00E+00	2.41E+09	1.12E+09	0.00E+00	0.00E+00	0.00E+00	4.76E+08	0.00E+00
SR-89	1.23E+09	0.00E+00	3.54E+07	0.00E+00	0.00E+00	0.00E+00	1.98E+08	0.00E+00
SR-90	3.89E+10	0.00E+00	9.54E+09	0.00E+00	0.00E+00	0.00E+00	1.12E+09	0.00E+00
SR-91	2.91E+04	0.00E+00	1.17E+03	0.00E+00	0.00E+00	0.00E+00	1.38E+05	0.00E+00
SR-92	4.95E-01	0.00E+00	2.14E-02	0.00E+00	0.00E+00	0.00E+00	9.82E+00	0.00E+00
Y-91M	6.27E-20	0.00E+00	2.43E-21	0.00E+00	0.00E+00	0.00E+00	1.84E-19	0.00E+00
Y-91	7.23E+03	0.00E+00	1.93E+02	0.00E+00	0.00E+00	0.00E+00	3.98E+06	0.00E+00
Y-92	5.64E-05	0.00E+00	1.65E-06	0.00E+00	0.00E+00	0.00E+00	9.88E-01	0.00E+00
Y-93	2.24E-01	0.00E+00	6.19E-03	0.00E+00	0.00E+00	0.00E+00	7.11E+03	0.00E+00
ZR-95	7.89E+02	2.53E+02	1.71E+02	0.00E+00	3.97E+02	0.00E+00	8.02E+05	0.00E+00
ZR-97	4.34E-01	8.76E-02	4.01E-02	0.00E+00	1.32E-01	0.00E+00	2.71E+04	0.00E+00
NB-95	7.23E+04	4.02E+04	2.16E+04	0.00E+00	3.97E+04	0.00E+00	2.44E+08	0.00E+00
NB-97	3.40E-12	8.59E-13	3.14E-13	0.00E+00	1.00E-12	0.00E+00	3.17E-09	0.00E+00
MO-99	0.00E+00	2.48E+07	4.72E+06	0.00E+00	5.62E+07	0.00E+00	5.76E+07	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.



<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	3.35E+00	9.48E+00	1.21E+02	0.00E+00	1.44E+02	4.64E+00	5.61E+03	0.00E+00
RU-103	8.85E+02	0.00E+00	3.81E+02	0.00E+00	3.38E+03	0.00E+00	1.03E+05	0.00E+00
RU-105	8.65E-04	0.00E+00	3.41E-04	0.00E+00	1.12E-02	0.00E+00	5.29E-01	0.00E+00
RU-106	1.64E+04	0.00E+00	2.08E+03	0.00E+00	3.17E+04	0.00E+00	1.06E+06	0.00E+00
AG-110M	4.85E+07	4.49E+07	2.66E+07	0.00E+00	8.82E+07	0.00E+00	1.83E+10	0.00E+00
SN-113	3.87E+06	1.49E+05	3.66E+06	5.26E+04	1.10E+05	0.00E+00	6.77E+07	0.00E+00
SB-124	2.16E+07	4.09E+05	8.58E+06	5.25E+04	0.00E+00	1.68E+07	6.14E+08	0.00E+00
SB-125	1.61E+07	1.80E+05	3.84E+06	1.54E+04	0.00E+00	1.24E+07	1.78E+08	0.00E+00
TE-129M	5.67E+07	2.12E+07	8.98E+06	1.95E+07	2.37E+08	0.00E+00	2.86E+08	0.00E+00
TE-129	2.97E-10	1.12E-10	7.25E-11	2.28E-10	1.25E-09	0.00E+00	2.25E-10	0.00E+00
TE-131M	3.69E+05	1.80E+05	1.50E+05	2.86E+05	1.83E+06	0.00E+00	1.79E+07	0.00E+00
TE-132	2.46E+06	1.59E+06	1.49E+06	1.76E+06	1.53E+07	0.00E+00	7.52E+07	0.00E+00
I-131	2.91E+08	4.16E+08	2.38E+08	1.36E+11	7.13E+08	0.00E+00	1.10E+08	0.00E+00
I-132	1.67E-01	4.47E-01	1.56E-01	1.56E+01	7.12E-01	0.00E+00	8.39E-02	0.00E+00
I-133	3.88E+06	6.74E+06	2.06E+06	9.91E+08	1.18E+07	0.00E+00	6.06E+06	0.00E+00
I-134	2.11E-12	5.72E-12	2.05E-12	9.92E-11	9.10E-12	0.00E+00	4.99E-15	0.00E+00
I-135	1.29E+04	3.38E+04	1.25E+04	2.23E+06	5.42E+04	0.00E+00	3.82E+04	0.00E+00
CS-134	4.45E+09	1.06E+10	8.66E+09	0.00E+00	3.43E+09	1.14E+09	1.85E+08	0.00E+00
CS-136	2.51E+08	9.91E+08	7.14E+08	0.00E+00	5.52E+08	7.56E+07	1.13E+08	0.00E+00
CS-137	5.96E+09	8.15E+09	5.34E+09	0.00E+00	2.77E+09	9.20E+08	1.58E+08	0.00E+00
CS-138	9.72E-24	1.92E-23	9.51E-24	0.00E+00	1.41E-23	1.39E-24	8.19E-29	0.00E+00
BA-139	4.54E-08	3.24E-11	1.33E-09	0.00E+00	3.03E-11	1.84E-11	8.06E-08	0.00E+00
BA-140	2.57E+07	3.23E+04	1.68E+06	0.00E+00	1.10E+04	1.85E+04	5.29E+07	0.00E+00
LA-140	4.52E+00	2.28E+00	6.01E-01	0.00E+00	0.00E+00	0.00E+00	1.67E+05	0.00E+00
LA-142	1.90E-11	8.66E-12	2.16E-12	0.00E+00	0.00E+00	0.00E+00	6.32E-08	0.00E+00
CE-141	4.27E+03	2.85E+03	3.27E+02	0.00E+00	1.34E+03	0.00E+00	1.10E+07	0.00E+00
CE-143	4.16E+01	3.08E+04	3.40E+00	0.00E+00	1.35E+01	0.00E+00	1.15E+06	0.00E+00
CE-144	2.83E+05	1.18E+05	1.52E+04	0.00E+00	7.01E+04	0.00E+00	9.56E+07	0.00E+00
HF-181	8.46E+03	4.77E+01	9.57E+02	3.03E+01	3.97E+01	0.00E+00	6.28E+05	0.00E+00
W-187	6.52E+03	5.45E+03	1.90E+03	0.00E+00	0.00E+00	0.00E+00	1.78E+06	0.00E+00
NP-239	3.67E+00	3.61E-01	1.99E-01	0.00E+00	1.13E+00	0.00E+00	7.41E+04	0.00E+00

TABLE 3.3-9

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Cow Milk

AGE GROUP - Teen

Nuclide	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-Tract	Skin
H-3	0.00E+00	9.93E+02	9.93E+02	9.93E+02	9.93E+02	9.93E+02	9.93E+02	9.93E+02
F-18	8.16E-03	0.00E+00	8.94E-04	0.00E+00	0.00E+00	0.00E+00	7.35E-04	0.00E+00
NA-24	4.27E+06	4.27E+06	4.27E+06	4.27E+06	4.27E+06	4.27E+06	4.27E+06	0.00E+00
CR-51	0.00E+00	0.00E+00	4.46E+04	2.48E+04	9.77E+03	6.36E+04	7.49E+06	0.00E+00
MN-54	0.00E+00	1.12E+07	2.22E+06	0.00E+00	3.34E+06	0.00E+00	2.29E+07	0.00E+00
MN-56	0.00E+00	7.47E-03	1.33E-03	0.00E+00	9.45E-03	0.00E+00	4.91E-01	0.00E+00
FE-55	3.47E+07	2.46E+07	5.74E+06	0.00E+00	0.00E+00	1.56E+07	1.06E+07	0.00E+00
FE-59	4.45E+07	1.04E+08	4.01E+07	0.00E+00	0.00E+00	3.27E+07	2.45E+08	0.00E+00
CO-57	0.00E+00	1.78E+06	2.99E+06	0.00E+00	0.00E+00	0.00E+00	3.32E+07	0.00E+00
CO-58	0.00E+00	6.60E+06	1.52E+07	0.00E+00	0.00E+00	0.00E+00	9.10E+07	0.00E+00
CO-60	0.00E+00	2.20E+07	4.96E+07	0.00E+00	0.00E+00	0.00E+00	2.87E+08	0.00E+00
NI-65	6.88E-01	8.79E-02	4.00E-02	0.00E+00	0.00E+00	0.00E+00	4.76E+00	0.00E+00
CU-64	0.00E+00	4.27E+04	2.01E+04	0.00E+00	1.08E+05	0.00E+00	3.31E+06	0.00E+00
ZN-65	1.90E+09	6.58E+09	3.07E+09	0.00E+00	4.21E+09	0.00E+00	2.79E+09	0.00E+00
BR-82	0.00E+00	0.00E+00	5.68E+07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	1.84E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	3.13E-23	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	4.40E+09	2.07E+09	0.00E+00	0.00E+00	0.00E+00	6.51E+08	0.00E+00
SR-89	2.28E+09	0.00E+00	6.52E+07	0.00E+00	0.00E+00	0.00E+00	2.71E+08	0.00E+00
SR-90	5.49E+10	0.00E+00	1.36E+10	0.00E+00	0.00E+00	0.00E+00	1.54E+09	0.00E+00
SR-91	5.34E+04	0.00E+00	2.12E+03	0.00E+00	0.00E+00	0.00E+00	2.42E+05	0.00E+00
SR-92	9.07E-01	0.00E+00	3.87E-02	0.00E+00	0.00E+00	0.00E+00	2.31E+01	0.00E+00
Y-91M	1.15E-19	0.00E+00	4.39E-21	0.00E+00	0.00E+00	0.00E+00	5.42E-18	0.00E+00
Y-91	1.33E+04	0.00E+00	3.56E+02	0.00E+00	0.00E+00	0.00E+00	5.45E+06	0.00E+00
Y-92	1.04E-04	0.00E+00	3.01E-06	0.00E+00	0.00E+00	0.00E+00	2.86E+00	0.00E+00
Y-93	4.14E-01	0.00E+00	1.13E-02	0.00E+00	0.00E+00	0.00E+00	1.26E+04	0.00E+00
ZR-95	1.38E+03	4.35E+02	2.99E+02	0.00E+00	6.40E+02	0.00E+00	1.00E+06	0.00E+00
ZR-97	7.90E-01	1.56E-01	7.20E-02	0.00E+00	2.37E-01	0.00E+00	4.23E+04	0.00E+00
NB-95	1.23E+05	6.84E+04	3.76E+04	0.00E+00	6.63E+04	0.00E+00	2.92E+08	0.00E+00
NB-97	6.19E-12	1.54E-12	5.61E-13	0.00E+00	1.80E-12	0.00E+00	3.67E-08	0.00E+00
MO-99	0.00E+00	4.48E+07	8.55E+06	0.00E+00	1.03E+08	0.00E+00	8.03E+07	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	5.82E+00	1.62E+01	2.10E+02	0.00E+00	2.42E+02	9.01E+00	1.07E+04	0.00E+00
RU-103	1.57E+03	0.00E+00	6.73E+02	0.00E+00	5.55E+03	0.00E+00	1.31E+05	0.00E+00
RU-105	1.58E-03	0.00E+00	6.13E-04	0.00E+00	1.99E-02	0.00E+00	1.28E+00	0.00E+00
RU-106	3.02E+04	0.00E+00	3.81E+03	0.00E+00	5.83E+04	0.00E+00	1.45E+06	0.00E+00
AG-110M	8.02E+07	7.59E+07	4.61E+07	0.00E+00	1.45E+08	0.00E+00	2.13E+10	0.00E+00
SN-113	5.95E+06	2.49E+05	6.33E+06	8.23E+04	1.76E+05	0.00E+00	7.14E+07	0.00E+00
SB-124	3.86E+07	7.11E+05	1.51E+07	8.75E+04	0.00E+00	3.37E+07	7.78E+08	0.00E+00
SB-125	2.89E+07	3.15E+05	6.75E+06	2.76E+04	0.00E+00	2.54E+07	2.25E+08	0.00E+00
TE-129M	1.04E+08	3.85E+07	1.64E+07	3.35E+07	4.34E+08	0.00E+00	3.90E+08	0.00E+00
TE-129	5.48E-10	2.04E-10	1.33E-10	3.91E-10	2.30E-09	0.00E+00	2.99E-09	0.00E+00
TE-131M	6.71E+05	3.22E+05	2.69E+05	4.84E+05	3.36E+06	0.00E+00	2.58E+07	0.00E+00
TE-132	4.39E+06	2.78E+06	2.62E+06	2.93E+06	2.67E+07	0.00E+00	8.81E+07	0.00E+00
I-131	5.28E+08	7.39E+08	3.97E+08	2.16E+11	1.27E+09	0.00E+00	1.46E+08	0.00E+00
I-132	2.96E-01	7.75E-01	2.78E-01	2.61E+0.	1.22E+00	0.00E+00	3.38E-01	0.00E+00
I-133	7.08E+06	1.20E+07	3.66E+06	1.68E+09	2.11E+07	0.00E+00	9.09E+06	0.00E+00
I-134	3.74E-12	9.93E-12	3.56E-12	1.65E-10	1.56E-11	0.00E+00	1.31E-13	0.00E+00
I-135	2.29E+04	5.91E+04	2.19E+04	3.80E+06	9.33E+04	0.00E+00	6.54E+04	0.00E+00
CS-134	7.73E+09	1.82E+10	8.44E+09	0.00E+00	5.78E+09	2.21E+09	2.26E+08	0.00E+00
CS-136	4.27E+08	1.68E+09	1.13E+09	0.00E+00	9.16E+08	1.44E+08	1.35E+08	0.00E+00
CS-137	1.08E+10	1.44E+10	5.01E+09	0.00E+00	4.89E+09	1.90E+09	2.05E+08	0.00E+00
CS-138	1.76E-23	3.38E-23	1.69E-23	0.00E+00	2.50E-23	2.91E-24	1.54E-26	0.00E+00
BA-139	8.40E-08	5.91E-11	2.45E-09	0.00E+00	5.57E-11	4.07E-11	7.50E-07	0.00E+00
BA-140	4.64E+07	5.68E+04	2.99E+06	0.00E+00	1.93E+04	3.82E+04	7.15E+07	0.00E+00
LA-140	8.11E+00	3.99E+00	1.06E+00	0.00E+00	0.00E+00	0.00E+00	2.29E+05	0.00E+00
LA-142	3.44E-11	1.53E-11	3.80E-12	0.00E+00	0.00E+00	0.00E+00	4.64E-07	0.00E+00
CE-141	7.82E+03	5.22E+03	6.00E+02	0.00E+00	2.46E+03	0.00E+00	1.49E+07	0.00E+00
CE-143	7.65E+01	5.56E+04	6.22E+00	0.00E+00	2.50E+01	0.00E+00	1.67E+06	0.00E+00
CE-144	5.20E+05	2.15E+05	2.80E+04	0.00E+00	1.29E+05	0.00E+00	1.31E+08	0.00E+00
HF-181	1.51E+04	8.32E+01	1.69E+03	5.06E+01	6.91E+01	0.00E+00	7.57E+05	0.00E+00
W-187	1.19E+04	9.72E+03	3.40E+03	0.00E+00	0.00E+00	0.00E+00	2.63E+06	0.00E+00
NP-239	7.01E+00	6.61E-01	3.67E-01	0.00E+00	2.08E+00	0.00E+00	1.06E+05	0.00E+00



TABLE 3.3-10

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Cow Milk

AGE GROUP - Child

Nuclide	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-Tract	Skin
H-3	0.00E+00	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03	1.57E+03
F-18	1.94E-02	0.00E+00	1.92E-03	0.00E+00	0.00E+00	0.00E+00	5.25E-03	0.00E+00
NA-24	8.88E+06	8.88E+06	8.88E+06	8.88E+06	8.88E+06	8.88E+06	8.88E+06	0.00E+00
CR-51	0.00E+00	0.00E+00	9.09E+04	5.05E+04	1.38E+04	9.21E+04	4.82E+06	0.00E+00
MN-54	0.00E+00	1.67E+07	4.46E+06	0.00E+00	4.69E+06	0.00E+00	1.40E+07	0.00E+00
MN-56	0.00E+00	1.30E-02	2.94E-03	0.00E+00	1.57E-02	0.00E+00	1.89E+00	0.00E+00
FE-55	8.71E+07	4.62E+07	1.43E+07	0.00E+00	0.00E+00	2.61E+07	8.56E+06	0.00E+00
FE-59	1.03E+08	1.67E+08	8.31E+07	0.00E+00	0.00E+00	4.84E+07	1.74E+08	0.00E+00
CO-57	0.00E+00	3.04E+06	6.16E+06	0.00E+00	0.00E+00	0.00E+00	2.49E+07	0.00E+00
CO-58	0.00E+00	1.01E+07	3.09E+07	0.00E+00	0.00E+00	0.00E+00	5.88E+07	0.00E+00
CO-60	0.00E+00	3.42E+07	1.01E+08	0.00E+00	0.00E+00	0.00E+00	1.89E+08	0.00E+00
NI-65	1.68E+00	1.58E-01	9.24E-02	0.00E+00	0.00E+00	0.00E+00	1.94E+01	0.00E+00
CU-64	0.00E+00	7.50E+04	4.53E+04	0.00E+00	1.81E+05	0.00E+00	3.52E+06	0.00E+00
ZN-65	3.72E+09	9.91E+09	6.16E+09	0.00E+00	6.24E+09	0.00E+00	1.74E+09	0.00E+00
BR-82	0.00E+00	0.00E+00	1.16E+08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	4.52E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	7.08E-23	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	8.16E+09	5.02E+09	0.00E+00	0.00E+00	0.00E+00	5.25E+08	0.00E+00
SR-89	5.63E+09	0.00E+00	1.61E+08	0.00E+00	0.00E+00	0.00E+00	2.18E+08	0.00E+00
SR-90	9.28E+10	0.00E+00	2.35E+10	0.00E+00	0.00E+00	0.00E+00	1.25E+09	0.00E+00
SR-91	1.31E+05	0.00E+00	4.94E+03	0.00E+00	0.00E+00	0.00E+00	2.89E+05	0.00E+00
SR-92	2.21E+00	0.00E+00	8.88E-02	0.00E+00	0.00E+00	0.00E+00	4.19E+01	0.00E+00
Y-91M	2.80E-19	0.00E+00	1.02E-20	0.00E+00	0.00E+00	0.00E+00	5.49E-16	0.00E+00
Y-91	3.28E+04	0.00E+00	8.78E+02	0.00E+00	0.00E+00	0.00E+00	4.38E+06	0.00E+00
Y-92	2.56E-04	0.00E+00	7.32E-06	0.00E+00	0.00E+00	0.00E+00	7.39E+00	0.00E+00
Y-93	1.02E+00	0.00E+00	2.79E-02	0.00E+00	0.00E+00	0.00E+00	1.51E+04	0.00E+00
ZR-95	3.20E+03	7.04E+02	6.27E+02	0.00E+00	1.01E+03	0.00E+00	7.35E+05	0.00E+00
ZR-97	1.92E+00	2.78E-01	1.64E-01	0.00E+00	3.99E-01	0.00E+00	4.21E+04	0.00E+00
NB-95	2.78E+05	1.08E+05	7.74E+04	0.00E+00	1.02E+05	0.00E+00	2.00E+08	0.00E+00
NB-97	1.50E-11	2.72E-12	1.27E-12	0.00E+00	3.01E-12	0.00E+00	8.38E-07	0.00E+00
MO-99	0.00E+00	8.16E+07	2.02E+07	0.00E+00	1.74E+08	0.00E+00	6.75E+07	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	1.33E+01	2.62E+01	4.34E+02	0.00E+00	3.80E+02	1.33E+01	1.49E+04	0.00E+00
RU-103	3.72E+03	0.00E+00	1.43E+03	0.00E+00	9.37E+03	0.00E+00	9.62E+04	0.00E+00
RU-105	3.86E-03	0.00E+00	1.40E-03	0.00E+00	3.39E-02	0.00E+00	2.52E+00	0.00E+00
RU-106	7.45E+04	0.00E+00	9.29E+03	0.00E+00	1.01E+05	0.00E+00	1.16E+06	0.00E+00
AG-110M	1.74E+08	1.17E+08	9.39E+07	0.00E+00	2.19E+08	0.00E+00	1.40E+10	0.00E+00
SN-113	1.17E+07	3.76E+05	1.28E+07	1.54E+05	2.59E+05	0.00E+00	4.67E+07	0.00E+00
SB-124	9.13E+07	1.18E+06	3.20E+07	2.01E+05	0.00E+00	5.07E+07	5.71E+08	0.00E+00
SB-125	6.87E+07	5.30E+05	1.44E+07	6.36E+04	0.00E+00	3.83E+07	1.64E+08	0.00E+00
TE-129M	2.56E+08	7.14E+07	3.97E+07	8.25E+07	7.51E+08	0.00E+00	3.12E+08	0.00E+00
TE-129	1.35E-09	3.77E-10	3.21E-10	9.64E-10	3.95E-09	0.00E+00	8.41E-08	0.00E+00
TE-131M	1.63E+06	5.65E+05	6.02E+05	1.16E+06	5.47E+06	0.00E+00	2.29E+07	0.00E+00
TE-132	1.05E+07	4.64E+06	5.61E+06	6.76E+06	4.31E+07	0.00E+00	4.67E+07	0.00E+00
I-131	1.28E+09	1.29E+09	7.32E+08	4.26E+11	2.11E+09	0.00E+00	1.15E+08	0.00E+00
I-132	7.01E-01	1.29E+00	5.92E-01	5.97E+01	1.97E+00	0.00E+00	1.52E+00	0.00E+00
I-133	1.72E+07	2.13E+07	8.05E+06	3.95E+09	3.55E+07	0.00E+00	8.57E+06	0.00E+00
I-134	8.87E-12	1.65E-11	7.57E-12	3.79E-10	2.52E-11	0.00E+00	1.09E-11	0.00E+00
I-135	5.43E+04	9.77E+04	4.62E+04	8.66E+06	1.50E+05	0.00E+00	7.45E+04	0.00E+00
CS-134	1.78E+10	2.93E+10	6.17E+09	0.00E+00	9.07E+09	3.25E+09	1.58E+08	0.00E+00
CS-136	9.65E+08	2.65E+09	1.72E+09	0.00E+00	1.41E+09	2.11E+08	9.32E+07	0.00E+00
CS-137	2.60E+10	2.49E+10	3.68E+09	0.00E+00	8.12E+09	2.92E+09	1.56E+08	0.00E+00
CS-138	4.27E-23	5.94E-23	3.77E-23	0.00E+00	4.18E-23	4.50E-24	2.74E-23	0.00E+00
BA-139	2.06E-07	1.10E-10	5.98E-09	0.00E+00	9.62E-11	6.48E-11	1.19E-05	0.00E+00
BA-140	1.12E+08	9.80E+04	6.53E+06	0.00E+00	3.19E+04	5.85E+04	5.67E+07	0.00E+00
LA-140	1.94E+01	6.79E+00	2.29E+00	0.00E+00	0.00E+00	0.00E+00	1.89E+05	0.00E+00
LA-142	8.30E-11	2.64E-11	8.28E-12	0.00E+00	0.00E+00	0.00E+00	5.24E-06	0.00E+00
CE-141	1.93E+04	9.61E+03	1.43E+03	0.00E+00	4.21E+03	0.00E+00	1.20E+07	0.00E+00
CE-143	1.88E+02	1.02E+05	1.47E+01	0.00E+00	4.27E+01	0.00E+00	1.49E+06	0.00E+00
CE-144	1.28E+06	4.02E+05	6.85E+04	0.00E+00	2.23E+05	0.00E+00	1.05E+08	0.00E+00
HF-181	3.59E+04	1.40E+02	3.61E+03	1.18E+02	1.13E+02	0.00E+00	5.96E+05	0.00E+00
W-187	2.89E+04	1.71E+04	7.68E+03	0.00E+00	0.00E+00	0.00E+00	2.40E+06	0.00E+00
NP-239	1.73E+01	1.24E+00	8.71E-01	0.00E+00	3.58E+00	0.00E+00	9.17E+04	0.00E+00



R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Cow Milk

AGE GROUP - Infant

Nuclide	Bone	Liver	T.Body	Thyroid	Kidney	Lung	GI-Tract	Skin
H-3	0.00E+00	2.38E+03	2.38E+03	2.38E+03	2.38E+03	2.38E+03	2.38E+03	2.38E+03
F-18	4.04E-02	0.00E+00	3.45E-03	0.00E+00	0.00E+00	0.00E+00	9.51E-03	0.00E+00
NA-24	1.55E+07	1.55E+07	1.55E+07	1.55E+07	1.55E+07	1.55E+07	1.55E+07	0.00E+00
CR-51	0.00E+00	0.00E+00	1.44E+05	9.40E+04	2.05E+04	1.83E+05	4.20E+06	0.00E+00
MN-54	0.00E+00	3.11E+07	7.05E+06	0.00E+00	6.90E+06	0.00E+00	1.14E+07	0.00E+00
MN-56	0.00E+00	3.19E-02	5.50E-03	0.00E+00	2.74E-02	0.00E+00	2.90E+00	0.00E+00
FE-55	1.05E+08	6.80E+07	1.82E+07	0.00E+00	0.00E+00	3.32E+07	8.63E+06	0.00E+00
FE-59	1.93E+08	3.36E+08	1.33E+08	0.00E+00	0.00E+00	9.94E+07	1.61E+08	0.00E+00
CO-57	0.00E+00	7.10E+06	1.15E+07	0.00E+00	0.00E+00	0.00E+00	2.42E+07	0.00E+00
CO-58	0.00E+00	2.02E+07	5.03E+07	0.00E+00	0.00E+00	0.00E+00	5.03E+07	0.00E+00
CO-60	0.00E+00	6.98E+07	1.65E+08	0.00E+00	0.00E+00	0.00E+00	1.66E+08	0.00E+00
NI-65	3.56E+00	4.03E-01	1.83E-01	0.00E+00	0.00E+00	0.00E+00	3.07E+01	0.00E+00
CU-64	0.00E+00	1.86E+05	8.63E+04	0.00E+00	3.15E+05	0.00E+00	3.83E+06	0.00E+00
ZN-65	5.00E+09	1.71E+10	7.90E+09	0.00E+00	8.31E+09	0.00E+00	1.45E+10	0.00E+00
BR-82	0.00E+00	0.00E+00	1.96E+08	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	9.60E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	1.37E-22	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	2.07E+10	1.02E+10	0.00E+00	0.00E+00	0.00E+00	5.30E+08	0.00E+00
SR-89	1.07E+10	0.00E+00	3.07E+08	0.00E+00	0.00E+00	0.00E+00	2.20E+08	0.00E+00
SR-90	1.01E+11	0.00E+00	2.57E+10	0.00E+00	0.00E+00	0.00E+00	1.26E+09	0.00E+00
SR-91	2.73E+05	0.00E+00	9.87E+03	0.00E+00	0.00E+00	0.00E+00	3.23E+05	0.00E+00
SR-92	4.71E+00	0.00E+00	1.75E-01	0.00E+00	0.00E+00	0.00E+00	5.08E+01	0.00E+00
Y-91M	5.94E-19	0.00E+00	2.03E-20	0.00E+00	0.00E+00	0.00E+00	1.98E-15	0.00E+00
Y-91	6.16E+04	0.00E+00	1.64E+03	0.00E+00	0.00E+00	0.00E+00	4.42E+06	0.00E+00
Y-92	5.44E-04	0.00E+00	1.53E-05	0.00E+00	0.00E+00	0.00E+00	1.04E+01	0.00E+00
Y-93	2.16E+00	0.00E+00	5.90E-02	0.00E+00	0.00E+00	0.00E+00	1.71E+04	0.00E+00
ZR-95	5.69E+03	1.39E+03	9.83E+02	0.00E+00	1.49E+03	0.00E+00	6.91E+05	0.00E+00
ZR-97	4.07E+00	6.99E-01	3.19E-01	0.00E+00	7.04E-01	0.00E+00	4.46E+04	0.00E+00
NB-95	5.19E+05	2.14E+05	1.24E+05	0.00E+00	1.53E+05	0.00E+00	1.81E+08	0.00E+00
NB-97	3.18E-11	6.78E-12	2.45E-12	0.00E+00	5.30E-12	0.00E+00	2.14E-06	0.00E+00
MO-99	0.00E+00	2.09E+08	4.07E+07	0.00E+00	3.12E+08	0.00E+00	6.87E+07	0.00E+00
TC-99M	2.78E+01	5.73E+01	7.37E+02	0.00E+00	6.16E+02	2.99E+01	1.66E+04	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
RU-103	7.54E+03	0.00E+00	2.52E+03	0.00E+00	1.57E+04	0.00E+00	9.17E+04	0.00E+00
RU-105	8.13E-03	0.00E+00	2.74E-03	0.00E+00	5.98E-02	0.00E+00	3.23E+00	0.00E+00
RU-106	1.53E+05	0.00E+00	1.92E+04	0.00E+00	1.81E+05	0.00E+00	1.16E+06	0.00E+00
AG-110M	3.21E+08	2.35E+08	1.55E+08	0.00E+00	3.36E+08	0.00E+00	1.22E+10	0.00E+00
SN-113	1.78E+07	6.79E+05	1.84E+07	2.59E+05	3.65E+05	0.00E+00	3.79E+07	0.00E+00
SB-124	1.76E+08	2.59E+06	5.45E+07	4.67E+05	0.00E+00	1.10E+08	5.43E+08	0.00E+00
SB-125	1.18E+08	1.14E+06	2.43E+07	1.48E+05	0.00E+00	6.83E+07	1.57E+08	0.00E+00
TE-129M	5.25E+08	1.80E+08	8.09E+07	2.02E+08	1.31E+09	0.00E+00	3.14E+08	0.00E+00
TE-129	2.86E-09	9.87E-10	6.69E-10	2.40E-09	7.13E-09	0.00E+00	2.29E-07	0.00E+00
TE-131M	3.45E+06	1.39E+06	1.15E+06	2.82E+06	9.56E+06	0.00E+00	2.34E+07	0.00E+00
TE-132	2.16E+07	1.07E+07	9.98E+06	1.58E+07	6.69E+07	0.00E+00	3.96E+07	0.00E+00
I-131	2.67E+09	3.15E+09	1.38E+09	1.03E+12	3.68E+09	0.00E+00	1.12E+08	0.00E+00
I-132	1.45E+00	2.95E+00	1.05E+00	1.38E+02	3.29E+00	0.00E+00	2.39E+00	0.00E+00
I-133	3.63E+07	5.29E+07	1.55E+07	9.62E+09	6.22E+07	0.00E+00	8.95E+06	0.00E+00
I-134	1.84E-11	3.77E-11	1.34E-11	8.78E-10	4.21E-11	0.00E+00	3.89E-11	0.00E+00
I-135	1.13E+05	2.25E+05	8.19E+04	2.01E+07	2.50E+05	0.00E+00	8.13E+04	0.00E+00
CS-134	2.87E+10	5.36E+10	5.41E+09	0.00E+00	1.38E+10	5.65E+09	1.46E+08	0.00E+00
CS-136	1.88E+09	5.54E+09	2.07E+09	0.00E+00	2.21E+09	4.52E+08	8.42E+07	0.00E+00
CS-137	4.16E+10	4.86E+10	3.45E+09	0.00E+00	1.31E+10	5.29E+09	1.52E+08	0.00E+
CS-138	9.01E-23	1.47E-22	7.10E-23	0.00E+00	7.31E-23	1.14E-23	2.34E-22	0.00E+00
BA-139	4.39E-07	2.91E-10	1.27E-08	0.00E+00	1.75E-10	1.77E-10	2.78E-05	0.00E+00
BA-140	2.30E+08	2.30E+05	1.19E+07	0.00E+00	5.47E+04	1.41E+05	5.66E+07	0.00E+00
LA-140	4.06E+01	1.60E+01	4.11E+00	0.00E+00	0.00E+00	0.00E+00	1.88E+05	0.00E+00
LA-142	1.74E-10	6.40E-11	1.53E-11	0.00E+00	0.00E+00	0.00E+00	1.09E-05	0.00E+00
CE-141	3.82E+04	2.33E+04	2.74E+03	0.00E+00	7.18E+03	0.00E+00	1.20E+07	0.00E+00
CE-143	3.97E+02	2.64E+05	3.01E+01	0.00E+00	7.68E+01	0.00E+00	1.54E+06	0.00E+00
CE-144	1.84E+06	7.52E+05	1.03E+05	0.00E+00	3.04E+05	0.00E+00	1.05E+08	0.00E+00
HF-181	6.86E+04	3.22E+02	6.06E+03	2.73E+02	1.89E+02	0.00E+00	5.62E+05	0.00E+00
W-187	6.08E+04	4.23E+04	1.46E+04	0.00E+00	0.00E+00	0.00E+00	2.49E+06	0.00E+00
NP-239	3.65E+01	3.26E+00	1.84E+00	0.00E+00	6.51E+00	0.00E+00	9.44E+04	0.00E+00

TABLE 3.3-12

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Goat Milk

AGE GROUP - Adult

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	1.56E+03	1.56E+03	1.56E+03	1.56E+03	1.56E+03	1.56E+03	1.56E+03
F-18	5.48E-04	0.00E+00	6.08E-05	0.00E+00	0.00E+00	0.00E+00	1.63E-05	0.00E+00
NA-24	2.93E+05	2.93E+05	2.93E+05	2.93E+05	2.93E+05	2.93E+05	2.93E+05	0.00E+00
CR-51	0.00E+00	0.00E+00	3.06E+03	1.83E+03	6.75E+02	4.06E+03	7.70E+05	0.00E+00
MN-54	0.00E+00	8.06E+05	1.54E+05	0.00E+00	2.40E+05	0.00E+00	2.47E+06	0.00E+00
MN-56	0.00E+00	5.05E-04	8.96E-05	0.00E+00	6.42E-04	0.00E+00	1.61E-02	0.00E+00
FE-55	2.54E+05	1.76E+05	4.10E+04	0.00E+00	0.00E+00	9.80E+04	1.01E+05	0.00E+00
FE-59	3.31E+05	7.79E+05	2.98E+05	0.00E+00	0.00E+00	2.18E+05	2.60E+06	0.00E+00
CO-57	0.00E+00	1.09E+05	2.02E+05	0.00E+00	0.00E+00	0.00E+00	3.09E+06	0.00E+00
CO-58	0.00E+00	4.71E+05	1.05E+06	0.00E+00	0.00E+00	0.00E+00	9.54E+06	0.00E+00
CO-60	0.00E+00	1.56E+06	3.44E+06	0.00E+00	0.00E+00	0.00E+00	2.93E+07	0.00E+00
NI-65	4.51E-02	5.86E-03	2.67E-03	0.00E+00	0.00E+00	0.00E+00	1.49E-01	0.00E+00
CU-64	0.00E+00	2.67E+03	1.25E+03	0.00E+00	6.73E+03	0.00E+00	2.27E+05	0.00E+00
ZN-65	1.48E+08	4.71E+08	2.13E+08	0.00E+00	3.15E+08	0.00E+00	2.97E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	3.93E+06	0.00E+00	0.00E+00	0.00E+00	4.50E+06	0.00E+00
BR-83	0.00E+00	0.00E+00	1.20E-02	0.00E+00	0.00E+00	0.00E+00	1.73E-02	0.00E+00
BR-84	0.00E+00	0.00E+00	2.10E-24	0.00E+00	0.00E+00	0.00E+00	1.65E-29	0.00E+00
RB-86	0.00E+00	2.90E+08	1.35E+08	0.00E+00	0.00E+00	0.00E+00	5.71E+07	0.00E+00
SR-89	2.59E+09	0.00E+00	7.44E+07	0.00E+00	0.00E+00	0.00E+00	4.16E+08	0.00E+00
SR-90	8.16E+10	0.00E+00	2.00E+10	0.00E+00	0.00E+00	0.00E+00	2.36E+09	0.00E+00
SR-91	6.10E+04	0.00E+00	2.46E+03	0.00E+00	0.00E+00	0.00E+00	2.91E+05	0.00E+00
SR-92	1.04E+00	0.00E+00	4.50E-02	0.00E+00	0.00E+00	0.00E+00	2.06E+01	0.00E+00
Y-91M	7.52E-21	0.00E+00	2.91E-22	0.00E+00	0.00E+00	0.00E+00	2.21E-20	0.00E+00
Y-91	8.67E+02	0.00E+00	2.32E+01	0.00E+00	0.00E+00	0.00E+00	4.77E+05	0.00E+00
Y-92	6.77E-06	0.00E+00	1.98E-07	0.00E+00	0.00E+00	0.00E+00	1.19E-01	0.00E+00
Y-93	2.69E-02	0.00E+00	7.43E-04	0.00E+00	0.00E+00	0.00E+00	8.53E+02	0.00E+00
ZR-95	9.47E+01	3.04E+01	2.06E+01	0.00E+00	4.76E+01	0.00E+00	9.62E+04	0.00E+00
ZR-97	5.21E-02	1.05E-02	4.81E-03	0.00E+00	1.59E-02	0.00E+00	3.26E+03	0.00E+00
NB-95	8.67E+03	4.82E+03	2.59E+03	0.00E+00	4.77E+03	0.00E+00	2.93E+07	0.00E+00
NB-97	4.08E-13	1.03E-13	3.76E-14	0.00E+00	1.20E-13	0.00E+00	3.80E-10	0.00E+00
MO-99	0.00E+00	2.98E+06	5.67E+05	0.00E+00	6.75E+06	0.00E+00	6.91E+06	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.



<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	4.03E-01	1.14E+00	1.45E+01	0.00E+00	1.73E+01	5.57E-01	6.73E+02	0.00E+00
RU-103	1.06E+02	0.00E+00	4.58E+01	0.00E+00	4.05E+02	0.00E+00	1.24E+04	0.00E+00
RU-105	1.04E-04	0.00E+00	4.10E-05	0.00E+00	1.34E-03	0.00E+00	6.35E-02	0.00E+00
RU-106	1.97E+03	0.00E+00	2.50E+02	0.00E+00	3.81E+03	0.00E+00	1.28E+05	0.00E+00
AG-110M	5.82E+06	5.38E+06	3.20E+06	0.00E+00	1.06E+07	0.00E+00	2.20E+09	0.00E+00
SN-113	4.64E+05	1.79E+04	4.39E+05	6.31E+03	1.32E+04	0.00E+00	8.12E+06	0.00E+00
SB-124	2.60E+06	4.90E+04	1.03E+06	6.29E+03	0.00E+00	2.02E+06	7.37E+07	0.00E+00
SB-125	1.94E+06	2.16E+04	4.61E+05	1.97E+03	0.00E+00	1.49E+06	2.13E+07	0.00E+00
TE-129M	6.81E+06	2.54E+06	1.08E+06	2.34E+06	2.84E+07	0.00E+00	3.43E+07	0.00E+00
TE-129	3.57E-11	1.34E-11	8.70E-12	2.74E-11	1.50E-10	0.00E+00	2.69E-11	0.00E+00
TE-131M	4.43E+04	2.17E+04	1.80E+04	3.43E+04	2.19E+05	0.00E+00	2.15E+06	0.00E+00
TE-132	2.95E+05	1.91E+05	1.79E+05	2.11E+05	1.84E+06	0.00E+00	9.02E+06	0.00E+00
I-131	3.49E+08	4.99E+08	2.86E+08	1.64E+11	8.56E+08	0.00E+00	1.32E+08	0.00E+00
I-132	2.00E-01	5.36E-01	1.88E-01	1.88E+01	8.54E-01	0.00E+00	1.01E-01	0.00E+00
I-133	4.65E+06	8.09E+06	2.47E+06	1.19E+09	1.41E+07	0.00E+00	7.27E+06	0.00E+00
I-134	2.53E-12	6.87E-12	2.46E-12	1.19E-10	1.09E-11	0.00E+00	5.99E-15	0.00E+00
I-135	1.55E+04	4.06E+04	1.50E+04	2.68E+06	6.51E+04	0.00E+00	4.58E+04	0.00E+00
CS-134	1.34E+10	3.18E+10	2.60E+10	0.00E+00	1.03E+10	3.41E+09	5.56E+08	0.00E+00
CS-136	7.53E+08	2.97E+09	2.14E+09	0.00E+00	1.65E+09	2.27E+08	3.38E+08	0.00E+00
CS-137	1.79E+10	2.45E+10	1.60E+10	0.00E+00	8.30E+09	2.76E+09	4.73E+08	0.00E+00
CS-138	2.91E-23	5.76E-23	2.85E-23	0.00E+00	4.23E-23	4.18E-24	2.46E-28	0.00E+00
BA-139	5.45E-09	3.88E-12	1.60E-10	0.00E+00	3.63E-12	2.20E-12	9.67E-09	0.00E+00
BA-140	3.08E+06	3.87E+03	2.02E+05	0.00E+00	1.32E+03	2.22E+03	6.35E+06	0.00E+00
LA-140	5.42E-01	2.73E-01	7.22E-02	0.00E+00	0.00E+00	0.00E+00	2.00E+04	0.00E+00
LA-142	2.28E-12	1.04E-12	2.59E-13	0.00E+00	0.00E+00	0.00E+00	7.58E-09	0.00E+00
CE-141	5.12E+02	3.46E+02	3.93E+01	0.00E+00	1.61E+02	0.00E+00	1.32E+06	0.00E+00
CE-143	4.99E+00	3.69E+03	4.09E-01	0.00E+00	1.63E+00	0.00E+00	1.38E+05	0.00E+00
CE-144	3.39E+04	1.42E+04	1.82E+03	0.00E+00	8.41E+03	0.00E+00	1.15E+07	0.00E+00
HF-181	1.01E+03	5.73E+00	1.15E+02	3.63E+00	4.77E+00	0.00E+00	7.53E+04	0.00E+00
W-187	7.82E+02	6.54E+02	2.29E+02	0.00E+00	0.00E+00	0.00E+00	2.14E+05	0.00E+00
NP-239	4.41E-01	4.34E-02	2.39E-02	0.00E+00	1.35E-01	0.00E+00	8.89E+03	0.00E+00

TABLE 3.3-13

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Goat Milk

AGE GROUP - Teen

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	2.03E+03	2.03E+03	2.03E+03	2.03E+03	2.03E+03	2.03E+03	2.03E+03
F-18	9.79E-04	0.00E+00	1.07E-04	0.00E+00	0.00E+00	0.00E+00	8.82E-05	0.00E+00
NA-24	5.12E+05	5.12E+05	5.12E+05	5.12E+05	5.12E+05	5.12E+05	5.12E+05	0.00E+00
CR-51	0.00E+00	0.00E+00	5.35E+03	2.97E+03	1.17E+03	7.64E+03	8.99E+05	0.00E+00
MN-54	0.00E+00	1.34E+06	2.66E+05	0.00E+00	4.00E+05	0.00E+00	2.75E+06	0.00E+00
MN-56	0.00E+00	8.96E-04	1.59E-04	0.00E+00	1.13E-03	0.00E+00	5.90E-02	0.00E+00
FE-55	4.51E+05	3.20E+05	7.46E+04	0.00E+00	0.00E+00	2.03E+05	1.38E+05	0.00E+00
FE-59	5.78E+05	1.35E+06	5.21E+05	0.00E+00	0.00E+00	4.25E+05	3.19E+06	0.00E+00
CO-57	0.00E+00	2.14E+05	3.58E+05	0.00E+00	0.00E+00	0.00E+00	3.99E+06	0.00E+00
CO-58	0.00E+00	7.92E+05	1.83E+06	0.00E+00	0.00E+00	0.00E+00	1.09E+07	0.00E+00
CO-60	0.00E+00	2.64E+06	5.95E+06	0.00E+00	0.00E+00	0.00E+00	3.44E+07	0.00E+00
NI-65	8.25E-02	1.05E-02	4.80E-03	0.00E+00	0.00E+00	0.00E+00	5.72E-01	0.00E+00
CU-64	0.00E+00	4.75E+03	2.24E+03	0.00E+00	1.20E+04	0.00E+00	3.69E+05	0.00E+00
ZN-65	2.27E+08	7.90E+08	3.68E+08	0.00E+00	5.05E+08	0.00E+00	3.34E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	6.82E+06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	2.21E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	3.75E-24	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	5.28E+08	2.48E+08	0.00E+00	0.00E+00	0.00E+00	7.81E+07	0.00E+00
SR-89	4.78E+09	0.00E+00	1.37E+08	0.00E+00	0.00E+00	0.00E+00	5.69E+08	0.00E+00
SR-90	1.15E+11	0.00E+00	2.85E+10	0.00E+00	0.00E+00	0.00E+00	3.24E+09	0.00E+00
SR-91	1.12E+05	0.00E+00	4.46E+03	0.00E+00	0.00E+00	0.00E+00	5.08E+05	0.00E+00
SR-92	1.90E+00	0.00E+00	8.12E-02	0.00E+00	0.00E+00	0.00E+00	4.85E+01	0.00E+00
Y-91M	1.38E-20	0.00E+00	5.26E-22	0.00E+00	0.00E+00	0.00E+00	6.50E-19	0.00E+00
Y-91	1.59E+03	0.00E+00	4.28E+01	0.00E+00	0.00E+00	0.00E+00	6.54E+05	0.00E+00
Y-92	1.25E-05	0.00E+00	3.62E-07	0.00E+00	0.00E+00	0.00E+00	3.43E-01	0.00E+00
Y-93	4.96E-02	0.00E+00	1.36E-03	0.00E+00	0.00E+00	0.00E+00	1.52E+03	0.00E+00
ZR-95	1.66E+02	5.22E+01	3.59E+01	0.00E+00	7.68E+01	0.00E+00	1.21E+05	0.00E+00
ZR-97	9.48E-02	1.88E-02	8.64E-03	0.00E+00	2.84E-02	0.00E+00	5.08E+03	0.00E+00
NB-95	1.48E+04	8.20E+03	4.52E+03	0.00E+00	7.95E+03	0.00E+00	3.51E+07	0.00E+00
NB-97	7.43E-13	1.84E-13	6.73E-14	0.00E+00	2.16E-13	0.00E+00	4.40E-09	0.00E+00
MO-99	0.00E+00	5.38E+06	1.03E+06	0.00E+00	1.23E+07	0.00E+00	9.63E+06	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.



<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	6.98E-01	1.95E+00	2.52E+01	0.00E+00	2.90E+01	1.08E+00	1.28E+03	0.00E+00
RU-103	1.89E+02	0.00E+00	8.07E+01	0.00E+00	6.66E+02	0.00E+00	1.58E+04	0.00E+00
RU-105	1.90E-04	0.00E+00	7.36E-05	0.00E+00	2.39E-03	0.00E+00	1.53E-01	0.00E+00
RU-106	3.63E+03	0.00E+00	4.57E+02	0.00E+00	7.00E+03	0.00E+00	1.74E+05	0.00E+00
AG-110M	9.62E+06	9.10E+06	5.54E+06	0.00E+00	1.74E+07	0.00E+00	2.56E+09	0.00E+00
SN-113	7.14E+05	2.99E+04	7.59E+05	9.88E+03	2.12E+04	0.00E+00	8.57E+06	0.00E+00
SB-124	4.63E+06	8.53E+04	1.81E+06	1.05E+04	0.00E+00	4.04E+06	9.33E+07	0.00E+00
SB-125	3.46E+06	3.78E+04	8.10E+05	3.31E+03	0.00E+00	3.04E+06	2.69E+07	0.00E+00
TE-129M	1.25E+07	4.62E+06	1.97E+06	4.02E+06	5.21E+07	0.00E+00	4.68E+07	0.00E+00
TE-129	6.57E-11	2.45E-11	1.60E-11	4.69E-11	2.76E-10	0.00E+00	3.59E-10	0.00E+00
TE-131M	8.06E+04	3.86E+04	3.22E+04	5.81E+04	4.03E+05	0.00E+00	3.10E+06	0.00E+00
TE-132	5.27E+05	3.34E+05	3.14E+05	3.52E+05	3.20E+06	0.00E+00	1.06E+07	0.00E+00
I-131	6.34E+08	8.87E+08	4.76E+08	2.59E+11	1.53E+09	0.00E+00	1.75E+08	0.00E+00
I-132	3.55E-01	9.30E-01	3.34E-01	3.13E+01	1.47E+00	0.00E+00	4.05E-01	0.00E+00
I-133	8.50E+06	1.44E+07	4.40E+06	2.01E+09	2.53E+07	0.00E+00	1.09E+07	0.00E+00
I-134	4.49E-12	1.19E-11	4.28E-12	1.99E-10	1.88E-11	0.00E+00	1.57E-13	0.00E+00
I-135	2.75E+04	7.09E+04	2.63E+04	4.56E+06	1.12E+05	0.00E+00	7.85E+04	0.00E+00
CS-134	2.32E+10	5.46E+10	2.53E+10	0.00E+00	1.73E+10	6.62E+09	6.79E+08	0.00E+00
CS-136	1.28E+09	5.05E+09	3.39E+09	0.00E+00	2.75E+09	4.33E+08	4.06E+08	0.00E+00
CS-137	3.24E+10	4.31E+10	1.50E+10	0.00E+00	1.47E+10	5.70E+09	6.14E+08	0.00E+00
CS-138	5.29E-23	1.02E-22	5.08E-23	0.00E+00	7.50E-23	8.72E-24	4.61E-26	0.00E+00
BA-139	1.01E-08	7.09E-12	2.94E-10	0.00E+00	6.69E-12	4.89E-12	8.99E-08	0.00E+00
BA-140	5.56E+06	6.82E+03	3.58E+05	0.00E+00	2.31E+03	4.58E+03	8.58E+06	0.00E+00
LA-140	9.73E-01	4.78E-01	1.27E-01	0.00E+00	0.00E+00	0.00E+00	2.75E+04	0.00E+00
LA-142	4.12E-12	1.83E-12	4.56E-13	0.00E+00	0.00E+00	0.00E+00	5.57E-08	0.00E+00
CE-141	9.39E+02	6.27E+02	7.20E+01	0.00E+00	2.95E+02	0.00E+00	1.79E+06	0.00E+00
CE-143	9.18E+00	6.68E+03	7.46E-01	0.00E+00	3.00E+00	0.00E+00	2.01E+05	0.00E+00
CE-144	6.24E+04	2.58E+04	3.35E+03	0.00E+00	1.54E+04	0.00E+00	1.57E+07	0.00E+00
HF-181	1.82E+03	9.98E+00	2.03E+02	6.08E+00	8.29E+00	0.00E+00	9.08E+04	0.00E+00
W-187	1.43E+03	1.17E+03	4.09E+02	0.00E+00	0.00E+00	0.00E+00	3.16E+05	0.00E+00
NP-239	8.42E-01	7.94E-02	4.41E-02	0.00E+00	2.49E-01	0.00E+00	1.28E+04	0.00E+00

TABLE 3.3-14

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Goat Milk

AGE GROUP - Child

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	3.20E+03	3.20E+03	3.20E+03	3.20E+03	3.20E+03	3.20E+03	3.20E+03
F-18	2.33E-03	0.00E+00	2.31E-04	0.00E+00	0.00E+00	0.00E+00	6.30E-04	0.00E+00
NA-24	1.07E+06	1.07E+06	1.07E+06	1.07E+06	1.07E+06	1.07E+06	1.07E+06	0.00E+00
CR-51	0.00E+00	0.00E+00	1.09E+04	6.05E+03	1.65E+03	1.11E+04	5.79E+05	0.00E+00
MN-54	0.00E+00	2.01E+06	5.35E+05	0.00E+00	5.63E+05	0.00E+00	1.69E+06	0.00E+00
MN-56	0.00E+00	1.56E-03	3.53E-04	0.00E+00	1.89E-03	0.00E+00	2.26E-01	0.00E+00
FE-55	1.13E+06	6.00E+05	1.86E+05	0.00E+00	0.00E+00	3.40E+05	1.11E+05	0.00E+00
FE-59	1.34E+06	2.17E+06	1.08E+06	0.00E+00	0.00E+00	6.29E+05	2.26E+06	0.00E+00
CO-57	0.00E+00	3.65E+05	7.39E+05	0.00E+00	0.00E+00	0.00E+00	2.99E+06	0.00E+00
CO-58	0.00E+00	1.21E+06	3.71E+06	0.00E+00	0.00E+00	0.00E+00	7.06E+06	0.00E+00
CO-60	0.00E+00	4.11E+06	1.21E+07	0.00E+00	0.00E+00	0.00E+00	2.27E+07	0.00E+00
NI-65	2.02E-01	1.90E-02	1.11E-02	0.00E+00	0.00E+00	0.00E+00	2.33E+00	0.00E+00
CU-64	0.00E+00	8.35E+03	5.05E+03	0.00E+00	2.02E+04	0.00E+00	3.92E+05	0.00E+00
ZN-65	4.46E+08	1.19E+09	7.40E+08	0.00E+00	7.49E+08	0.00E+00	2.09E+08	0.00E+00
BR-82	0.00E+00	0.00E+00	1.40E+07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	5.42E-02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	8.49E-24	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	9.79E+08	6.02E+08	0.00E+00	0.00E+00	0.00E+00	6.30E+07	0.00E+00
SR-89	1.18E+10	0.00E+00	3.38E+08	0.00E+00	0.00E+00	0.00E+00	4.58E+08	0.00E+00
SR-90	1.95E+11	0.00E+00	4.94E+10	0.00E+00	0.00E+00	0.00E+00	2.62E+09	0.00E+00
SR-91	2.75E+05	0.00E+00	1.04E+04	0.00E+00	0.00E+00	0.00E+00	6.07E+05	0.00E+00
SR-92	4.65E+00	0.00E+00	1.86E-01	0.00E+00	0.00E+00	0.00E+00	8.81E+01	0.00E+00
Y-91M	3.36E-20	0.00E+00	1.22E-21	0.00E+00	0.00E+00	0.00E+00	6.59E-17	0.00E+00
Y-91	3.94E+03	0.00E+00	1.05E+02	0.00E+00	0.00E+00	0.00E+00	5.25E+05	0.00E+00
Y-92	3.07E-05	0.00E+00	8.78E-07	0.00E+00	0.00E+00	0.00E+00	8.87E-01	0.00E+00
Y-93	1.22E-01	0.00E+00	3.35E-03	0.00E+00	0.00E+00	0.00E+00	1.82E+03	0.00E+00
ZR-95	3.85E+02	8.45E+01	7.53E+01	0.00E+00	1.21E+02	0.00E+00	8.82E+04	0.00E+00
ZR-97	2.31E-01	3.33E-02	1.97E-02	0.00E+00	4.79E-02	0.00E+00	5.05E+03	0.00E+00
NB-95	3.34E+04	1.30E+04	9.29E+03	0.00E+00	1.22E+04	0.00E+00	2.40E+07	0.00E+00
NB-97	1.80E-12	3.26E-13	1.52E-13	0.00E+00	3.62E-13	0.00E+00	1.01E-07	0.00E+00
MO-99	0.00E+00	9.79E+06	2.42E+06	0.00E+00	2.09E+07	0.00E+00	8.10E+06	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	1.60E+00	3.14E+00	5.20E+01	0.00E+00	4.56E+01	1.59E+00	1.79E+03	0.00E+00
RU-103	4.47E+02	0.00E+00	1.72E+02	0.00E+00	1.12E+03	0.00E+00	1.15E+04	0.00E+00
RU-105	4.63E-04	0.00E+00	1.68E-04	0.00E+00	4.07E-03	0.00E+00	3.02E-01	0.00E+00
RU-106	8.93E+03	0.00E+00	1.11E+03	0.00E+00	1.21E+04	0.00E+00	1.39E+05	0.00E+00
AG-110M	2.09E+07	1.41E+07	1.13E+07	0.00E+00	2.62E+07	0.00E+00	1.68E+09	0.00E+00
SN-113	1.40E+06	4.52E+04	1.53E+06	1.85E+04	3.10E+04	0.00E+00	5.61E+06	0.00E+00
SB-124	1.10E+07	1.42E+05	3.84E+06	2.42E+04	0.00E+00	6.08E+06	6.85E+07	0.00E+00
SB-125	8.25E+06	6.36E+04	1.73E+06	7.64E+03	0.00E+00	4.60E+06	1.97E+07	0.00E+00
TE-129M	3.07E+07	8.57E+06	4.76E+06	9.90E+06	9.01E+07	0.00E+00	3.74E+07	0.00E+00
TE-129	1.62E-10	4.53E-11	3.85E-11	1.16E-10	4.74E-10	0.00E+00	1.01E-08	0.00E+00
TE-131M	1.96E+05	6.78E+04	7.22E+04	1.39E+05	6.57E+05	0.00E+00	2.75E+06	0.00E+00
TE-132	1.26E+06	5.57E+05	6.73E+05	8.11E+05	5.17E+06	0.00E+00	5.61E+06	0.00E+00
I-131	1.54E+09	1.55E+09	8.78E+08	5.11E+11	2.54E+09	0.00E+00	1.38E+08	0.00E+00
I-132	8.41E-01	1.55E+00	7.11E-01	7.17E+01	2.36E+00	0.00E+00	1.82E+00	0.00E+00
I-133	2.06E+07	2.55E+07	9.66E+06	4.74E+09	4.25E+07	0.00E+00	1.03E+07	0.00E+00
I-134	1.06E-11	1.98E-11	9.09E-12	4.54E-10	3.02E-11	0.00E+00	1.31E-11	0.00E+00
I-135	6.52E+04	1.17E+05	5.55E+04	1.04E+07	1.80E+05	0.00E+00	8.94E+04	0.00E+00
CS-134	5.35E+10	8.78E+10	1.85E+10	0.00E+00	2.72E+10	9.76E+09	4.73E+08	0.00E+00
CS-136	2.89E+09	7.96E+09	5.15E+09	0.00E+00	4.24E+09	6.32E+08	2.80E+08	0.00E+00
CS-137	7.81E+10	7.48E+10	1.10E+10	0.00E+00	2.44E+10	8.77E+09	4.68E+08	0.00E+00
CS-138	1.28E-22	1.78E-22	1.13E-22	0.00E+00	1.25E-22	1.35E-23	8.21E-23	0.00E+00
BA-139	2.48E-08	1.32E-11	7.18E-10	0.00E+00	1.15E-11	7.78E-12	1.43E-06	0.00E+00
BA-140	1.34E+07	1.18E+04	7.84E+05	0.00E+00	3.83E+03	7.01E+03	6.80E+06	0.00E+00
LA-140	2.33E+00	8.14E-01	2.7E-01	0.00E+00	0.00E+00	0.00E+00	2.27E+04	0.00E+00
LA-142	9.95E-12	3.17E-12	9.94E-13	0.00E+00	0.00E+00	0.00E+00	6.29E-07	0.00E+00
CE-141	2.31E+03	1.15E+03	1.71E+02	0.00E+00	5.05E+02	0.00E+00	1.44E+06	0.00E+00
CE-143	2.25E+01	1.22E+04	1.77E+00	0.00E+00	5.12E+00	0.00E+00	1.79E+05	0.00E+00
CE-144	1.54E+05	4.82E+04	8.21E+03	0.00E+00	2.67E+04	0.00E+00	1.26E+07	0.00E+00
HF-181	4.30E+03	1.68E+01	4.33E+02	1.42E+01	1.35E+01	0.00E+00	7.15E+04	0.00E+00
W-187	3.47E+03	2.05E+03	9.22E+02	0.00E+00	0.00E+00	0.00E+00	2.89E+05	0.00E+00
NP-239	2.07E+00	1.49E-01	1.05E-01	0.00E+00	4.30E-01	0.00E+00	1.10E+04	0.00E+00



TABLE 3.3-15

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Goat Milk

AGE GROUP - Infant

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	4.86E+03	4.86E+03	4.86E+03	4.86E+03	4.86E+03	4.86E+03	4.86E+03
F-18	4.85E-03	0.00E+00	4.14E-04	0.00E+00	0.00E+00	0.00E+00	1.14E-03	0.00E+00
NA-24	1.86E+06	1.86E+06	1.86E+06	1.86E+06	1.86E+06	1.86E+06	1.86E+06	0.00E+00
CR-51	0.00E+00	0.00E+00	1.73E+04	1.13E+04	2.46E+03	2.19E+04	5.04E+05	0.00E+00
MN-54	0.00E+00	3.73E+06	8.46E+05	0.00E+00	8.28E+05	0.00E+00	1.37E+06	0.00E+00
MN-56	0.00E+00	3.83E-03	6.60E-04	0.00E+00	3.29E-03	0.00E+00	3.48E-01	0.00E+00
FE-55	1.37E+06	8.84E+05	2.36E+05	0.00E+00	0.00E+00	4.32E+05	1.12E+05	0.00E+00
FE-59	2.50E+06	4.37E+06	1.72E+06	0.00E+00	0.00E+00	1.29E+06	2.09E+06	0.00E+00
CO-57	0.00E+00	8.52E+05	1.39E+06	0.00E+00	0.00E+00	0.00E+00	2.90E+06	0.00E+00
CO-58	0.00E+00	2.42E+06	6.04E+06	0.00E+00	0.00E+00	0.00E+00	6.03E+06	0.00E+00
CO-60	0.00E+00	8.38E+06	1.98E+07	0.00E+00	0.00E+00	0.00E+00	1.99E+07	0.00E+00
NI-65	4.27E-01	4.84E-02	2.20E-02	0.00E+00	0.00E+00	0.00E+00	3.68E+00	0.00E+00
CU-64	0.00E+00	2.08E+04	9.62E+03	0.00E+00	3.51E+04	0.00E+00	4.26E+05	0.00E+00
ZN-65	5.99E+08	2.06E+09	9.48E+08	0.00E+00	9.97E+08	0.00E+00	1.74E+09	0.00E+00
BR-82	0.00E+00	0.00E+00	2.35E+07	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	1.15E-01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	1.64E-23	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	2.48E+09	1.23E+09	0.00E+00	0.00E+00	0.00E+00	6.36E+07	0.00E+00
SR-89	2.25E+10	0.00E+00	6.45E+08	0.00E+00	0.00E+00	0.00E+00	4.62E+08	0.00E+00
SR-90	2.12E+11	0.00E+00	5.40E+10	0.00E+00	0.00E+00	0.00E+00	2.65E+09	0.00E+00
SR-91	5.73E+05	0.00E+00	2.07E+04	0.00E+00	0.00E+00	0.00E+00	6.78E+05	0.00E+00
SR-92	9.89E+00	0.00E+00	3.67E-01	0.00E+00	0.00E+00	0.00E+00	1.07E+02	0.00E+00
Y-91M	7.13E-20	0.00E+00	2.43E-21	0.00E+00	0.00E+00	0.00E+00	2.38E-16	0.00E+00
Y-91	7.40E+03	0.00E+00	1.97E+02	0.00E+00	0.00E+00	0.00E+00	5.30E+05	0.00E+00
Y-92	6.52E-05	0.00E+00	1.83E-06	0.00E+00	0.00E+00	0.00E+00	1.24E+00	0.00E+00
Y-93	2.60E-01	0.00E+00	7.08E-03	0.00E+00	0.00E+00	0.00E+00	2.05E+03	0.00E+00
ZR-95	6.83E+02	1.66E+02	1.18E+02	0.00E+00	1.79E+02	0.00E+00	8.29E+04	0.00E+00
ZR-97	4.89E-01	8.38E-02	3.83E-02	0.00E+00	8.45E-02	0.00E+00	5.35E+03	0.00E+00
NB-95	6.23E+04	2.57E+04	1.48E+04	0.00E+00	1.84E+04	0.00E+00	2.17E+07	0.00E+00
NB-97	3.82E-12	8.14E-13	2.93E-13	0.00E+00	6.36E-13	0.00E+00	2.57E-07	0.00E+00
MO-99	0.00E+00	2.50E+07	4.88E+06	0.00E+00	3.74E+07	0.00E+00	8.24E+06	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
TC-99M	3.33E+00	6.87E+00	8.85E+01	0.00E+00	7.39E+01	3.59E+00	2.00E+03	0.00E+00
RU-103	9.04E+02	0.00E+00	3.02E+02	0.00E+00	1.88E+03	0.00E+00	1.10E+04	0.00E+00
RU-105	9.76E-04	0.00E+00	3.29E-04	0.00E+00	7.17E-03	0.00E+00	3.88E-01	0.00E+00
RU-106	1.84E+04	0.00E+00	2.30E+03	0.00E+00	2.18E+04	0.00E+00	1.40E+05	0.00E+00
AG-110M	3.86E+07	2.81E+07	1.86E+07	0.00E+00	4.03E+07	0.00E+00	1.46E+09	0.00E+00
SN-113	2.13E+06	8.15E+04	2.20E+06	3.10E+04	4.37E+04	0.00E+00	4.55E+06	0.00E+00
SB-124	2.11E+07	3.11E+05	6.54E+06	5.61E+04	0.00E+00	1.32E+07	6.52E+07	0.00E+00
SB-125	1.42E+07	1.37E+05	2.91E+06	1.77E+04	0.00E+00	8.20E+06	1.89E+07	0.00E+00
TE-129M	6.30E+07	2.16E+07	9.71E+06	2.42E+07	1.58E+08	0.00E+00	3.76E+07	0.00E+00
TE-129	3.44E-10	1.18E-10	8.02E-11	2.88E-10	8.56E-10	0.00E+00	2.75E-08	0.00E+00
TE-131M	4.14E+05	1.67E+05	1.38E+05	3.38E+05	1.15E+06	0.00E+00	2.81E+06	0.00E+00
TE-132	2.59E+06	1.28E+06	1.20E+06	1.89E+06	8.02E+06	0.00E+00	4.75E+06	0.00E+00
I-131	3.21E+09	3.78E+09	1.66E+09	1.24E+12	4.41E+09	0.00E+00	1.35E+08	0.00E+00
I-132	1.74E+00	3.54E+00	1.26E+00	1.66E+02	3.95E+00	0.00E+00	2.87E+00	0.00E+00
I-133	4.36E+07	6.35E+07	1.86E+07	1.15E+10	7.46E+07	0.00E+00	1.07E+07	0.00E+00
I-134	2.21E-11	4.52E-11	1.61E-11	1.05E-09	5.05E-11	0.00E+00	4.67E-11	0.00E+00
I-135	1.36E+05	2.70E+05	9.83E+04	2.42E+07	3.00E+05	0.00E+00	9.76E+04	0.00E+00
CS-134	8.62E+10	1.61E+11	1.62E+10	0.00E+00	4.14E+10	1.70E+10	4.37E+08	0.00E+00
CS-136	5.65E+09	1.66E+10	6.21E+09	0.00E+00	6.63E+09	1.35E+09	2.52E+08	0.00E+00
CS-137	1.25E+11	1.46E+11	1.03E+10	0.00E+00	3.92E+10	1.59E+10	4.56E+08	0.00E+00
CS-138	2.70E-22	4.40E-22	2.13E-22	0.00E+00	2.19E-22	3.42E-23	7.03E-22	0.00E+00
BA-139	5.27E-08	3.49E-11	1.53E-09	0.00E+00	2.10E-11	2.12E-11	3.34E-06	0.00E+00
BA-140	2.76E+07	2.76E+04	1.42E+06	0.00E+00	6.56E+03	1.70E+04	6.79E+06	0.00E+00
LA-140	4.87E+00	1.92E+00	4.94E-01	0.00E+00	0.00E+00	0.00E+00	2.25E+04	0.00E+00
LA-142	2.09E-11	7.68E-12	1.84E-12	0.00E+00	0.00E+00	0.00E+00	1.30E-06	0.00E+00
CE-141	4.58E+03	2.80E+03	3.29E+02	0.00E+00	8.62E+02	0.00E+00	1.44E+06	0.00E+00
CE-143	4.77E+01	3.16E+04	3.61E+00	0.00E+00	9.21E+00	0.00E+00	1.85E+05	0.00E+00
CE-144	2.21E+05	9.03E+04	1.24E+04	0.00E+00	3.65E+04	0.00E+00	1.27E+07	0.00E+00
HF-181	8.23E+03	3.87E+01	7.27E+02	3.28E+01	2.27E+01	0.00E+00	6.75E+04	0.00E+00
W-187	7.30E+03	5.08E+03	1.75E+03	0.00E+00	0.00E+00	0.00E+00	2.98E+05	0.00E+00
NP-239	4.38E+00	3.92E-01	2.21E-01	0.00E+00	7.81E-01	0.00E+00	1.13E+04	0.00E+00



TABLE 3.3-16

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Inhalation

AGE GROUP - Adult

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	1.26E+03	1.26E+03	1.26E+03	1.26E+03	1.26E+03	1.26E+03	1.26E+03
F-18	4.99E+03	0.00E+00	5.54E+02	0.00E+00	0.00E+00	0.00E+00	1.48E+02	0.00E+00
NA-24	1.02E+04	1.02E+04	1.02E+04	1.02E+04	1.02E+04	1.02E+04	1.02E+04	0.00E+00
CR-51	0.00E+00	0.00E+00	1.00E+02	5.95E+01	2.28E+01	1.44E+04	3.32E+03	0.00E+00
MN-54	0.00E+00	3.96E+04	6.30E+03	0.00E+00	9.84E+03	1.40E+06	7.74E+04	0.00E+00
MN-56	0.00E+00	1.24E+00	1.83E-01	0.00E+00	1.30E+00	9.44E+03	2.02E+04	0.00E+00
FE-55	2.46E+04	1.70E+04	3.94E+03	0.00E+00	0.00E+00	7.21E+04	6.03E+03	0.00E+00
FE-59	1.18E+04	2.78E+04	1.06E+04	0.00E+00	0.00E+00	1.02E+06	1.88E+05	0.00E+00
CO-57	0.00E+00	6.92E+02	6.71E+02	0.00E+00	0.00E+00	3.70E+05	3.14E+04	0.00E+00
CO-58	0.00E+00	1.58E+03	2.07E+03	0.00E+00	0.00E+00	9.28E+05	1.06E+05	0.00E+00
CO-60	0.00E+00	1.15E+04	1.48E+04	0.00E+00	0.00E+00	5.97E+06	2.85E+05	0.00E+00
NI-65	1.54E+00	2.10E-01	9.12E-02	0.00E+00	0.00E+00	5.60E+03	1.23E+04	0.00E+00
CU-64	0.00E+00	1.46E+00	6.15E-01	0.00E+00	4.62E+00	6.78E+03	4.90E+04	0.00E+00
ZN-65	3.24E+04	1.03E+05	4.66E+04	0.00E+00	6.90E+04	8.64E+05	5.34E+04	0.00E+00
BR-82	0.00E+00	0.00E+00	1.35E+04	0.00E+00	0.00E+00	0.00E+00	1.04E+04	0.00E+00
BR-83	0.00E+00	0.00E+00	2.41E+02	0.00E+00	0.00E+00	0.00E+00	2.32E+02	0.00E+00
BR-84	0.00E+00	0.00E+00	3.13E+02	0.00E+00	0.00E+00	0.00E+00	1.64E-03	0.00E+00
RB-86	0.00E+00	1.35E+05	5.90E+04	0.00E+00	0.00E+00	0.00E+00	1.66E+04	0.00E+00
RB-88	0.00E+00	3.87E+02	1.93E+02	0.00E+00	0.00E+00	0.00E+00	3.34E-09	0.00E+00
RB-89	0.00E+00	2.56E+02	1.70E+02	0.00E+00	0.00E+00	0.00E+00	9.28E-12	0.00E+00
SR-89	3.04E+05	0.00E+00	8.72E+03	0.00E+00	0.00E+00	1.40E+06	3.50E+05	0.00E+00
SR-90	9.92E+07	0.00E+00	6.10E+06	0.00E+00	0.00E+00	9.60E+06	7.22E+05	0.00E+00
SR-91	6.19E+01	0.00E+00	2.50E+00	0.00E+00	0.00E+00	3.65E+04	1.91E+04	0.00E+00
SR-92	6.74E+00	0.00E+00	2.91E-01	0.00E+00	0.00E+00	1.65E+04	4.30E+04	0.00E+00
Y-91M	2.61E-01	0.00E+00	1.02E-02	0.00E+00	0.00E+00	1.92E+03	1.33E+00	0.00E+00
Y-91	4.62E+05	0.00E+00	1.24E+04	0.00E+00	0.00E+00	1.70E+06	3.85E+05	0.00E+00
Y-92	1.03E+01	0.00E+00	3.02E-01	0.00E+00	0.00E+00	1.57E+04	7.35E+04	0.00E+00
Y-93	9.44E+01	0.00E+00	2.61E+00	0.00E+00	0.00E+00	4.85E+04	4.22E+05	0.00E+00
ZR-95	1.07E+05	3.44E+04	2.33E+04	0.00E+00	5.42E+04	1.77E+06	1.50E+05	0.00E+00
ZR-97	9.68E+01	1.96E+01	9.04E+00	0.00E+00	2.97E+01	7.87E+04	5.23E+05	0.00E+00
NB-95	1.41E+04	7.82E+03	4.21E+03	0.00E+00	7.74E+03	5.05E+05	1.04E+05	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
NB-97	2.22E-01	5.62E-02	2.05E-02	0.00E+00	6.54E-02	2.40E+03	2.42E+02	0.00E+00
MG-99	0.00E+00	1.21E+02	2.30E+01	0.00E+00	2.91E+02	9.12E+04	2.48E+05	0.00E+00
TC-99M	1.03E-03	2.91E-03	3.70E-02	0.00E+00	4.42E-02	7.64E+02	4.16E+03	0.00E+00
TC-101	4.18E-05	6.02E-05	5.90E-04	0.00E+00	1.08E-03	3.99E+02	1.09E-11	0.00E+00
RU-103	1.53E+03	0.00E+00	6.58E+02	0.00E+00	5.83E+03	5.05E+05	1.10E+05	0.00E+00
RU-105	7.90E-01	0.00E+00	3.11E-01	0.00E+00	1.02E+00	1.10E+04	4.82E+04	0.00E+00
RU-106	6.91E+04	0.00E+00	8.72E+03	0.00E+00	1.34E+05	9.36E+06	9.12E+05	0.00E+00
AG-110M	1.08E+04	1.00E+04	5.94E+03	0.00E+00	1.97E+04	4.63E+06	3.02E+05	0.00E+00
SN-113	6.86E+03	2.66E+02	6.48E+03	9.28E+01	1.97E+02	2.99E+05	2.48E+04	0.00E+00
SB-124	3.12E+04	5.89E+02	1.24E+04	7.55E+01	0.00E+00	2.48E+06	4.06E+05	0.00E+00
SB-125	5.34E+04	5.95E+02	1.26E+04	5.40E+01	0.00E+00	1.74E+06	1.01E+05	0.00E+00
TE-129M	9.76E+03	4.67E+03	1.58E+03	3.44E+03	3.66E+04	1.16E+06	3.83E+05	0.00E+00
TE-129	4.98E-02	2.39E-02	1.24E-02	3.90E-02	1.87E-01	1.94E+03	1.57E+02	0.00E+00
TE-131M	6.99E+01	4.36E+01	2.90E+01	5.50E+01	3.09E+02	1.46E+05	5.56E+05	0.00E+00
TE-132	2.60E+02	2.15E+02	1.62E+02	1.90E+02	1.46E+03	2.88E+05	5.10E+05	0.00E+00
I-131	2.52E+04	3.58E+04	2.05E+04	1.19E+07	6.13E+04	0.00E+00	6.28E+03	0.00E+00
I-132	1.16E+03	3.26E+03	1.16E+03	1.14E+05	5.18E+03	0.00E+00	4.06E+02	0.00E+00
I-133	8.64E+03	1.48E+04	4.52E+03	2.15E+06	2.58E+04	0.00E+00	8.88E+03	0.00E+00
I-134	6.44E+02	1.73E+03	6.15E+02	2.98E+04	2.75E+03	0.00E+00	1.01E+00	0.00E+00
I-135	2.68E+03	6.98E+03	2.57E+03	4.48E+05	1.11E+04	0.00E+00	5.25E+03	0.00E+00
CS-134	3.73E+05	8.48E+05	7.28E+05	0.00E+00	2.87E+05	9.76E+04	1.04E+04	0.00E+00
CS-136	3.90E+04	1.46E+05	1.10E+05	0.00E+00	8.56E+04	1.20E+04	1.17E+04	0.00E+00
CS-137	4.78E+05	6.21E+05	4.28E+05	0.00E+00	2.22E+05	7.52E+04	8.40E+03	0.00E+00
CS-138	3.31E+02	6.21E+02	3.24E+02	0.00E+00	4.80E+02	4.86E+01	1.86E-03	0.00E+00
BA-139	9.36E-01	6.66E-04	2.74E-02	0.00E+00	6.22E-04	3.76E+03	8.96E+02	0.00E+00
BA-140	3.90E+04	4.90E+01	2.57E+03	0.00E+00	1.67E+01	1.27E+06	2.18E+05	0.00E+00
BA-142	2.63E-02	2.70E-05	1.66E-03	0.00E+00	2.29E-05	1.19E+03	1.57E-16	0.00E+00
LA-140	3.44E+02	1.74E+02	4.58E+01	0.00E+00	0.00E+00	1.36E+05	4.58E+05	0.00E+00
LA-142	6.83E-01	3.10E-01	7.72E-02	0.00E+00	0.00E+00	6.33E+03	2.11E+03	0.00E+00
CE-141	1.99E+04	1.35E+04	1.53E+03	0.00E+00	6.26E+03	3.62E+05	1.20E+05	0.00E+00
CE-143	1.86E+02	1.38E+02	1.53E+01	0.00E+00	6.08E+01	7.98E+04	2.26E+05	0.00E+00
CE-144	3.43E+06	1.43E+06	1.84E+05	0.00E+00	8.48E+05	7.78E+06	8.16E+05	0.00E+00
PR-144	3.01E-02	1.25E-02	1.53E-03	0.00E+00	7.05E-03	1.02E+03	2.15E-08	0.00E+00
HF-181	4.56E+04	2.57E+02	5.15E+03	1.63E+03	2.14E+02	5.98E+05	1.29E+05	0.00E+00
W-187	8.48E+00	7.08E+00	2.48E+00	0.00E+00	0.00E+00	2.90E+04	1.55E+05	0.00E+00
NP-239	2.30E+02	2.26E+01	1.24E+01	0.00E+00	7.00E+01	3.76E+04	1.19E+05	0.00E+00

PATHWAY - Inhalation

AGE GROUP - Teen

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	1.27E+03	1.27E+03	1.27E+03	1.27E+03	1.27E+03	1.27E+03	1.27E+03
F-18	5.22E+03	0.00E+00	5.68E+02	0.00E+00	0.00E+00	0.00E+00	3.11E+02	0.00E+00
NA-24	1.38E+04	1.38E+04	1.38E+04	1.38E+04	1.38E+04	1.38E+04	1.38E+04	0.00E+00
CR-51	0.00E+00	0.00E+00	1.35E+02	7.50E+01	3.07E+01	2.10E+04	3.00E+03	0.00E+00
MN-54	0.00E+00	5.11E+04	8.40E+03	0.00E+00	1.27E+04	1.98E+06	6.68E+04	0.00E+00
MN-56	0.00E+00	1.70E+00	2.52E-01	0.00E+00	1.79E+00	1.52E+04	5.74E+04	0.00E+00
FE-55	3.34E+04	2.38E+04	5.54E+03	0.00E+00	0.00E+00	1.24E+05	6.39E+03	0.00E+00
FE-59	1.59E+04	3.70E+04	1.43E+04	0.00E+00	0.00E+00	1.53E+06	1.78E+05	0.00E+00
CO-57	0.00E+00	9.44E+02	9.20E+02	0.00E+00	0.00E+00	5.86E+05	3.14E+04	0.00E+00
CO-58	0.00E+00	2.07E+03	2.78E+03	0.00E+00	0.00E+00	1.34E+06	9.52E+04	0.00E+00
CO-60	0.00E+00	1.51E+04	1.98E+04	0.00E+00	0.00E+00	8.72E+06	2.59E+05	0.00E+00
NI-65	2.18E+00	2.93E-01	1.27E-01	0.00E+00	0.00E+00	9.36E+03	3.67E+04	0.00E+00
CU-64	0.00E+00	2.03E+00	8.48E-01	0.00E+00	6.41E+00	1.11E+04	6.14E+04	0.00E+00
ZN-65	3.86E+04	1.34E+05	6.24E+04	0.00E+00	8.64E+04	1.24E+06	4.66E+04	0.00E+00
BR-82	0.00E+00	0.00E+00	1.82E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	3.44E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	4.33E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	1.90E+05	8.40E+04	0.00E+00	0.00E+00	0.00E+00	1.77E+04	0.00E+00
RB-88	0.00E+00	5.46E+02	2.72E+02	0.00E+00	0.00E+00	0.00E+00	2.92E-05	0.00E+00
RB-89	0.00E+00	3.52E+02	2.33E+02	0.00E+00	0.00E+00	0.00E+00	3.38E-07	0.00E+00
SR-89	4.34E+05	0.00E+00	1.25E+04	0.00E+00	0.00E+00	2.42E+06	3.71E+05	0.00E+00
SR-90	1.08E+08	0.00E+00	6.68E+06	0.00E+00	0.00E+00	1.65E+07	7.65E+05	0.00E+00
SR-91	8.80E+01	0.00E+00	3.51E+00	0.00E+00	0.00E+00	6.07E+04	2.59E+05	0.00E+00
SR-92	9.52E+00	0.00E+00	4.06E-01	0.00E+00	0.00E+00	2.74E+04	1.19E+05	0.00E+00
Y-91M	3.70E-01	0.00E+00	1.42E-02	0.00E+00	0.00E+00	3.20E+03	3.02E+01	0.00E+00
Y-91	6.61E+05	0.00E+00	1.77E+04	0.00E+00	0.00E+00	2.94E+06	4.09E+05	0.00E+00
Y-92	1.47E+01	0.00E+00	4.29E-01	0.00E+00	0.00E+00	2.68E+04	1.65E+05	0.00E+00
Y-93	1.35E+02	0.00E+00	3.72E+00	0.00E+00	0.00E+00	8.32E+04	5.79E+05	0.00E+00
ZR-95	1.46E+05	4.58E+04	3.15E+04	0.00E+00	6.74E+04	2.69E+06	1.49E+05	0.00E+00
ZR-97	1.38E+02	2.72E+01	1.26E+01	0.00E+00	4.12E+01	1.30E+05	6.30E+05	0.00E+00
NB-95	1.86E+04	1.03E+04	5.66E+03	0.00E+00	1.00E+04	7.51E+05	9.68E+04	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.



<u>Naclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
NB-97	3.14E-01	7.78E-02	2.84E-02	0.00E+00	9.12E-02	3.93E+03	2.17E+03	0.00E+00
MO-99	0.00E+00	1.69E+02	3.22E+01	0.00E+00	4.11E+02	1.54E+05	2.69E+05	0.00E+00
TC-99M	1.38E-03	3.86E-03	4.99E-02	0.00E+00	5.76E-02	1.15E+03	6.13E+03	0.00E+00
TC-101	5.92E-05	8.40E-05	8.24E-04	0.00E+00	1.52E-03	6.67E+02	8.72E-07	0.00E+00
RU-103	2.10E+03	0.00E+00	8.96E+02	0.00E+00	7.43E+03	7.83E+05	1.09E+05	0.00E+00
RU-105	1.12E+00	0.00E+00	4.34E-01	0.00E+00	1.41E+00	1.82E+04	9.04E+04	0.00E+00
RU-106	9.84E+04	0.00E+00	1.24E+04	0.00E+00	1.90E+05	1.61E+07	9.60E+05	0.00E+00
AG-110M	1.38E+04	1.31E+04	7.99E+03	0.00E+00	2.50E+04	6.75E+06	2.73E+05	0.00E+00
SN-113	8.16E+03	3.44E+02	8.64E+03	1.13E+02	2.46E+02	4.26E+05	2.03E+04	0.00E+00
SB-124	4.30E+04	7.94E+02	1.68E+04	9.76E+01	0.00E+00	3.85E+06	3.98E+05	0.00E+00
SB-125	7.38E+04	8.08E+02	1.72E+04	7.04E+01	0.00E+00	2.74E+06	9.92E+04	0.00E+00
TE-129M	1.39E+04	6.58E+03	2.25E+03	4.58E+03	5.19E+04	1.98E+06	4.05E+05	0.00E+00
TE-129	7.10E-02	3.38E-02	1.76E-02	5.18E-02	2.66E-01	3.30E+03	1.62E+03	0.00E+00
TE-131M	9.84E+01	6.01E+01	4.02E+01	7.25E+01	4.39E+02	2.38E+05	6.21E+05	0.00E+00
TE-132	3.60E+02	2.90E+02	2.19E+02	2.46E+02	1.95E+03	4.49E+05	4.63E+05	0.00E+00
I-131	3.54E+04	4.91E+04	2.64E+04	1.46E+07	8.40E+04	0.00E+00	6.49E+03	0.00E+00
I-132	1.59E+03	4.38E+03	1.58E+03	1.51E+05	6.92E+03	0.00E+00	1.27E+03	0.00E+00
I-133	1.22E+04	2.05E+04	6.22E+03	2.92E+06	3.59E+04	0.00E+00	1.03E+04	0.00E+00
I-134	8.88E+02	2.32E+03	8.40E+02	3.95E+04	3.66E+03	0.00E+00	2.04E+01	0.00E+00
I-135	3.70E+03	9.44E+03	3.49E+03	6.21E+05	1.49E+04	0.00E+00	6.95E+03	0.00E+00
CS-134	5.02E+05	1.13E+06	5.49E+05	0.00E+00	3.75E+05	1.46E+05	9.76E+03	0.00E+00
CS-136	5.15E+04	1.94E+05	1.37E+05	0.00E+00	1.10E+05	1.78E+04	1.09E+04	0.00E+00
CS-137	6.70E+05	8.48E+05	3.11E+05	0.00E+00	3.04E+05	1.21E+05	8.48E+03	0.00E+00
CS-138	4.66E+02	8.56E+02	4.46E+02	0.00E+00	6.62E+02	7.87E+01	2.70E-01	0.00E+00
BA-139	1.34E+00	9.44E-04	3.90E-02	0.00E+00	8.88E-04	6.46E+03	6.45E+03	0.00E+00
BA-140	5.47E+04	6.70E+01	3.52E+03	0.00E+00	2.28E+01	2.03E+06	2.29E+05	0.00E+00
BA-142	3.70E-02	3.70E-05	2.27E-03	0.00E+00	3.14E-05	1.91E+03	4.79E-10	0.00E+00
LA-140	4.79E+02	2.36E+02	6.26E+01	0.00E+00	0.00E+00	2.14E+05	4.87E+05	0.00E+00
LA-142	9.60E-01	4.25E-01	1.06E-01	0.00E+00	0.00E+00	1.02E+04	1.20E+04	0.00E+00
CE-141	2.84E+04	1.90E+04	2.17E+03	0.00E+00	8.88E+03	6.14E+05	1.26E+05	0.00E+00
CE-143	2.66E+02	1.94E+02	2.16E+01	0.00E+00	8.64E+01	1.30E+05	2.55E+05	0.00E+00
CE-144	4.89E+06	2.02E+06	2.62E+05	0.00E+00	1.21E+06	1.34E+07	8.64E+05	0.00E+00
PR-144	4.30E-02	1.76E-02	2.18E-03	0.00E+00	1.01E-02	1.75E+03	2.35E-04	0.00E+00
HF-181	6.31E+04	3.47E+02	7.04E+03	2.12E+02	2.90E+02	9.36E+05	1.20E+05	0.00E+00
W-187	1.20E+01	9.76E+00	3.43E+00	0.00E+00	0.00E+00	4.74E+04	1.77E+05	0.00E+00
NP-239	3.38E+02	3.19E+01	1.77E+01	0.00E+00	1.00E+02	6.49E+04	1.32E+05	0.00E+00

(Reference Regulatory Guide 1.109)

PATHWAY - Inhalation

AGE GROUP - Child

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03	1.12E+03
F-18	6.96E+03	0.00E+00	6.85E+02	0.00E+00	0.00E+00	0.00E+00	1.25E+03	0.00E+00
NA-24	1.61E+04	1.61E+04	1.61E+04	1.61E+04	1.61E+04	1.61E+04	1.61E+04	0.00E+00
CR-51	0.00E+00	0.00E+00	1.54E+02	8.55E+01	2.43E+01	1.70E+04	1.08E+03	0.00E+00
MN-54	0.00E+00	4.29E+04	9.51E+03	0.00E+00	1.00E+04	1.58E+06	2.29E+04	0.00E+00
MN-56	0.00E+00	1.66E+00	3.12E-01	0.00E+00	1.67E+00	1.31E+04	1.23E+05	0.00E+00
FE-55	4.74E+04	2.52E+04	7.77E+03	0.00E+00	0.00E+00	1.11E+05	2.87E+03	0.00E+00
FE-59	2.07E+04	3.34E+04	1.67E+04	0.00E+00	0.00E+00	1.27E+06	7.07E+04	0.00E+00
CO-57	0.00E+00	9.03E+02	1.07E+03	0.00E+00	0.00E+00	5.07E+05	1.32E+04	0.00E+00
CO-58	0.00E+00	1.77E+03	3.16E+03	0.00E+00	0.00E+00	1.11E+06	3.44E+04	0.00E+00
CO-60	0.00E+00	1.31E+04	2.26E+04	0.00E+00	0.00E+00	7.07E+06	9.62E+04	0.00E+00
NI-65	2.99E+00	2.96E-01	1.64E-01	0.00E+00	0.00E+00	8.18E+03	8.40E+04	0.00E+00
CU-64	0.00E+00	1.99E+00	1.07E+00	0.00E+00	6.03E+00	9.58E+03	3.67E+04	0.00E+00
ZN-65	4.26E+04	1.13E+05	7.03E+04	0.00E+00	7.14E+04	9.95E+05	1.63E+04	0.00E+00
BR-82	0.00E+00	0.00E+00	2.09E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	4.74E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	5.48E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	1.98E+05	1.14E+05	0.00E+00	0.00E+00	0.00E+00	7.99E+03	0.00E+00
RB-88	0.00E+00	5.62E+02	3.66E+02	0.00E+00	0.00E+00	0.00E+00	1.72E+01	0.00E+00
RB-89	0.00E+00	3.45E+02	2.90E+02	0.00E+00	0.00E+00	0.00E+00	1.89E+00	0.00E+00
SR-89	5.99E+05	0.00E+00	1.72E+04	0.00E+00	0.00E+00	2.16E+06	1.67E+05	0.00E+00
SR-90	1.01E+08	0.00E+00	6.44E+06	0.00E+00	0.00E+00	1.48E+07	3.43E+05	0.00E+00
SR-91	1.21E+02	0.00E+00	4.59E+00	0.00E+00	0.00E+00	5.33E+04	1.74E+05	0.00E+00
SR-92	1.31E+01	0.00E+00	5.25E-01	0.00E+00	0.00E+00	2.40E+04	2.42E+05	0.00E+00
Y-91M	5.07E-01	0.00E+00	1.84E-02	0.00E+00	0.00E+00	2.81E+03	1.72E+03	0.00E+00
Y-91	9.14E+05	0.00E+00	2.44E+04	0.00E+00	0.00E+00	2.63E+06	1.84E+05	0.00E+00
Y-92	2.04E+01	0.00E+00	5.81E-01	0.00E+00	0.00E+00	2.39E+04	2.39E+05	0.00E+00
Y-93	1.86E+02	0.00E+00	5.11E+00	0.00E+00	0.00E+00	7.44E+04	3.89E+05	0.00E+00
ZR-95	1.90E+05	4.18E+04	3.70E+04	0.00E+00	5.96E+04	2.23E+06	6.11E+04	0.00E+00
ZR-97	1.88E+02	2.72E+01	1.60E+01	0.00E+00	3.88E+01	1.13E+05	3.51E+05	0.00E+00
NB-95	2.35E+04	9.18E+03	6.55E+03	0.00E+00	8.62E+03	6.14E+05	3.70E+04	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.



TABLE 3.3-18 (continued)

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T. Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
NB-97	4.29E-01	7.70E-02	3.50E-02	0.00E+00	8.55E-02	3.42E+03	2.78E+16	0.00E+00
MO-99	0.00E+00	1.72E+02	4.25E+01	0.00E+00	3.92E+02	1.35E+05	1.27E+05	0.00E+00
TC-99M	1.78E-03	3.48E-03	5.77E-02	0.00E+00	5.07E-02	9.51E+02	4.81E+03	0.00E+00
TC-101	8.10E-05	8.51E-05	1.08E-03	0.00E+00	1.45E-03	5.85E+02	1.63E+01	0.00E+00
RU-103	2.79E+03	0.00E+00	1.07E+03	0.00E+00	7.03E+03	6.62E+05	4.48E+04	0.00E+00
RU-105	1.53E+00	0.00E+00	5.55E-01	0.00E+00	1.34E+00	1.59E+04	9.95E+04	0.00E+00
RU-106	1.36E+05	0.00E+00	1.69E+04	0.00E+00	1.84E+05	1.43E+07	4.29E+05	0.00E+00
AG-110M	1.69E+04	1.14E+04	9.14E+03	0.00E+00	2.12E+04	5.48E+06	1.00E+05	0.00E+00
SN-113	8.99E+03	2.90E+02	9.81E+03	1.19E+02	2.03E+02	3.40E+05	7.44E+03	0.00E+00
SB-124	5.74E+04	7.40E+02	2.00E+04	1.26E+02	0.00E+00	3.24E+06	1.64E+05	0.00E+00
SB-125	9.84E+04	7.59E+02	2.07E+04	9.10E+01	0.00E+00	2.32E+06	4.03E+04	0.00E+00
TE-129M	1.92E+04	6.85E+03	3.04E+03	6.33E+03	5.03E+04	1.76E+06	1.82E+05	0.00E+00
TE-129	9.77E-02	3.50E-02	2.38E-02	7.14E-02	2.57E-01	2.93E+03	2.55E+04	0.00E+00
TE-131M	1.34E+02	5.92E+01	5.07E+01	9.77E+01	4.00E+02	2.06E+05	3.08E+05	0.00E+00
TE-132	4.81E+02	2.72E+02	2.63E+02	3.17E+02	1.77E+03	3.77E+05	1.38E+05	0.00E+00
I-131	4.81E+04	4.81E+04	2.73E+04	1.62E+07	7.88E+04	0.00E+00	2.84E+03	0.00E+00
I-132	2.12E+03	4.07E+03	1.88E+03	1.94E+05	6.25E+03	0.00E+00	3.20E+03	0.00E+00
I-133	1.66E+04	2.03E+04	7.70E+03	3.85E+06	3.38E+04	0.00E+00	5.48E+03	0.00E+00
I-134	1.17E+03	2.16E+03	9.95E+02	5.07E+04	3.30E+03	0.00E+00	9.55E+02	0.00E+00
I-135	4.92E+03	8.73E+03	4.14E+03	7.92E+05	1.34E+04	0.00E+00	4.44E+03	0.00E+00
CS-134	6.51E+05	1.01E+06	2.25E+05	0.00E+00	3.30E+05	1.21E+05	3.85E+03	0.00E+00
CS-136	6.51E+04	1.71E+05	1.16E+05	0.00E+00	9.55E+04	1.45E+04	4.18E+03	0.00E+00
CS-137	9.07E+05	8.25E+05	1.28E+05	0.00E+00	2.82E+05	1.04E+05	3.62E+03	0.00E+00
CS-138	6.33E+02	8.40E+02	5.55E+02	0.00E+00	6.22E+02	6.81E+01	2.70E+02	0.00E+00
BA-139	1.84E+00	9.84E-04	5.36E-02	0.00E+00	8.62E-04	5.77E+03	5.77E+04	0.00E+00
BA-140	7.40E+04	6.48E+01	4.33E+03	0.00E+00	2.11E+01	1.74E+06	1.02E+05	0.00E+00
BA-142	4.99E-02	3.60E-05	2.79E-03	0.00E+00	2.91E-05	1.64E+03	2.74E+00	0.00E+00
LA-140	6.44E+02	2.25E+02	7.55E+01	0.00E+00	0.00E+00	1.83E+05	2.26E+05	0.00E+00
LA-142	1.29E+00	4.11E-01	1.29E-01	0.00E+00	0.00E+00	8.70E+03	7.59E+04	0.00E+00
CE-141	3.92E+04	1.95E+04	2.90E+03	0.00E+00	8.55E+03	5.44E+05	5.66E+04	0.00E+00
CE-143	3.66E+02	1.99E+02	2.87E+01	0.00E+00	8.36E+01	1.15E+05	1.27E+05	0.00E+00
CE-144	6.77E+06	2.12E+06	3.61E+05	0.00E+00	1.17E+06	1.20E+07	3.89E+05	0.00E+00
PR-144	5.96E-02	1.85E-02	3.00E-03	0.00E+00	9.77E-03	1.57E+03	1.97E+02	0.00E+00
HF-181	8.33E+04	3.28E+02	8.47E+03	2.76E+02	2.63E+02	7.96E+05	5.29E+04	0.00E+00
W-187	1.63E+01	9.66E+00	4.33E+00	0.00E+00	0.00E+00	4.11E+04	9.10E+04	0.00E+00
NP-239	4.66E+02	3.34E+01	2.35E+01	0.00E+00	9.73E+01	5.81E+04	6.40E+04	0.00E+00

TABLE 3.3-19

R VALUES for the H.B. ROBINSON STEAM ELECTRIC PLANT<sup>1</sup>

(Reference Regulatory Guide 1.109)

PATHWAY - Inhalation

AGE GROUP - Infant

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
H-3	0.00E+00	6.47E+02	6.47E+02	6.47E+02	6.47E+02	6.47E+02	6.47E+02	6.47E+02
F-18	5.49E+03	0.00E+00	4.66E+02	0.00E+00	0.00E+00	0.00E+00	8.54E+02	0.00E+00
NA-24	1.06E+04	1.06E+04	1.06E+04	1.06E+04	1.06E+04	1.06E+04	1.06E+04	0.00E+00
CR-51	0.00E+00	0.00E+00	8.95E+01	5.75E+01	1.32E+01	1.28E+04	3.57E+02	0.00E+00
MN-54	0.00E+00	2.53E+04	4.98E+03	0.00E+00	4.98E+03	1.00E+06	7.06E+03	0.00E+00
MN-56	0.00E+00	1.54E+00	2.21E-01	0.00E+00	1.10E+00	1.25E+04	7.17E+04	0.00E+00
FE-55	1.97E+04	1.17E+04	3.33E+03	0.00E+00	0.00E+00	8.69E+04	1.09E+03	0.00E+00
FE-59	1.36E+04	2.35E+04	9.48E+03	0.00E+00	0.00E+00	1.02E+06	2.48E+04	0.00E+00
CO-57	0.00E+00	6.51E+02	6.41E+02	0.00E+00	0.00E+00	3.79E+05	4.86E+03	0.00E+00
CO-58	0.00E+00	1.22E+03	1.82E+03	0.00E+00	0.00E+00	7.77E+05	1.11E+04	0.00E+00
CO-60	0.00E+00	8.02E+03	1.18E+04	0.00E+00	0.00E+00	4.51E+06	3.19E+04	0.00E+00
NI-65	2.39E+00	2.84E-01	1.23E-01	0.00E+00	0.00E+00	8.12E+03	5.01E+04	0.00E+00
CU-64	0.00E+00	1.88E+00	7.74E-01	0.00E+00	3.98E+00	9.30E+03	1.50E+04	0.00E+00
ZN-65	1.93E+04	6.26E+04	3.11E+04	0.00E+00	3.25E+04	6.47E+05	5.14E+04	0.00E+00
BR-82	0.00E+00	0.00E+00	1.33E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-83	0.00E+00	0.00E+00	3.81E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
BR-84	0.00E+00	0.00E+00	4.00E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
RB-86	0.00E+00	1.90E+05	8.82E+04	0.00E+00	0.00E+00	0.00E+00	3.04E+03	0.00E+00
RB-88	0.00E+00	5.57E+02	2.87E+02	0.00E+00	0.00E+00	0.00E+00	3.39E+02	0.00E+00
RB-89	0.00E+00	3.21E+02	2.06E+02	0.00E+00	0.00E+00	0.00E+00	6.82E+01	0.00E+00
SR-89	3.98E+05	0.00E+00	1.14E+04	0.00E+00	0.00E+00	2.03E+06	6.40E+04	0.00E+00
SR-90	4.09E+07	0.00E+00	2.59E+06	0.00E+00	0.00E+00	1.12E+07	1.31E+05	0.00E+00
SR-91	9.56E+01	0.00E+00	3.46E+00	0.00E+00	0.00E+00	5.26E+04	7.34E+04	0.00E+00
SR-92	1.05E+01	0.00E+00	3.91E-01	0.00E+00	0.00E+00	2.38E+04	1.40E+05	0.00E+00
Y-91M	4.07E-01	0.00E+00	1.39E-02	0.00E+00	0.00E+00	2.79E+03	2.35E+03	0.00E+00
Y-91	5.88E+05	0.00E+00	1.57E+04	0.00E+00	0.00E+00	2.45E+06	7.03E+04	0.00E+00
Y-92	1.64E+01	0.00E+00	4.61E-01	0.00E+00	0.00E+00	2.45E+04	1.27E+05	0.00E+00
Y-93	1.50E+02	0.00E+00	4.07E+00	0.00E+00	0.00E+00	7.64E+04	1.67E+05	0.00E+00
ZR-95	1.15E+05	2.79E+04	2.03E+04	0.00E+00	3.11E+04	1.75E+06	2.17E+04	0.00E+00
ZR-97	1.50E+02	2.56E+01	1.17E+01	0.00E+00	2.59E+01	1.10E+05	1.40E+05	0.00E+00
NB-95	1.57E+04	6.43E+03	3.78E+03	0.00E+00	4.72E+03	4.79E+05	1.27E+04	0.00E+00

<sup>1</sup>R Values in units of mrem/yr per micro-Ci/m<sup>3</sup> for inhalation and tritium, and in units of m<sup>2</sup> mrem/yr per micro-Ci/sec for all others.

<u>Nuclide</u>	<u>Bone</u>	<u>Liver</u>	<u>T.Body</u>	<u>Thyroid</u>	<u>Kidney</u>	<u>Lung</u>	<u>GI-Tract</u>	<u>Skin</u>
NB-97	3.42E-01	7.29E-02	2.63E-02	0.00E+00	5.70E-02	3.32E+03	2.69E+04	0.00E+00
MO-99	0.00E+00	1.65E+02	3.23E+01	0.00E+00	2.65E+02	1.35E+05	4.87E+04	0.00E+00
TC-99M	1.40E-03	2.88E-03	3.72E-02	0.00E+00	3.11E-02	8.11E+02	2.03E+03	0.00E+00
TC-101	6.51E-05	8.23E-05	8.12E-04	0.00E+00	9.79E-04	5.84E+02	8.44E+02	0.00E+00
RU-103	2.02E+03	0.00E+00	6.79E+02	0.00E+00	4.24E+03	5.52E+05	1.61E+04	0.00E+00
RU-105	1.22E+00	0.00E+00	4.10E-01	0.00E+00	8.99E-01	1.57E+04	4.84E+04	0.00E+00
RU-106	8.68E+04	0.00E+00	1.09E+04	0.00E+00	1.07E+05	1.16E+07	1.64E+05	0.00E+00
AG-110M	9.98E+03	7.22E+03	5.00E+03	0.00E+00	1.09E+04	3.67E+06	3.30E+04	0.00E+00
SN-113	4.68E+03	1.74E+02	4.89E+03	6.72E+01	9.94E+01	2.30E+05	2.28E+03	0.00E+00
SB-124	3.04E+04	5.56E+02	1.20E+04	1.01E+02	0.00E+00	2.65E+06	3.42E+04	0.00E+00
SB-125	5.17E+04	4.77E+02	1.09E+04	6.23E+00	5.70E-02	3.32E+03	2.69E+04	0.00E+00
TE-129M	1.41E+04	6.09E+03	2.23E+03	5.47E+03	3.18E+04	1.68E+06	6.90E+04	0.00E+00
TE-129	7.88E-02	3.47E-02	1.88E-02	6.75E-02	1.75E-01	3.00E+03	2.63E+04	0.00E+00
TE-131M	1.07E+02	5.50E+01	3.63E+01	8.93E+01	2.65E+02	1.99E+05	1.19E+05	0.00E+00
TE-132	3.72E+02	2.37E+02	1.76E+02	2.79E+02	1.03E+03	3.40E+05	4.41E+04	0.00E+00
I-131	3.79E+04	4.44E+04	1.96E+04	1.48E+07	5.18E+04	0.00E+00	1.06E+03	0.00E+00
I-132	1.69E+03	3.54E+03	1.26E+03	1.69E+05	3.95E+03	0.00E+00	1.90E+03	0.00E+00
I-133	1.32E+04	1.92E+04	5.60E+03	3.56E+06	2.24E+04	0.00E+00	2.16E+03	0.00E+00
I-134	9.21E+02	1.88E+03	6.65E+02	4.45E+04	2.09E+03	0.00E+00	1.29E+03	0.00E+00
I-135	3.86E+03	7.60E+03	2.77E+03	6.96E+05	8.47E+03	0.00E+00	1.83E+03	0.00E+00
CS-134	3.96E+05	7.03E+05	7.45E+04	0.00E+00	1.90E+05	7.97E+04	1.33E+03	0.00E+00
CS-136	4.83E+04	1.35E+05	5.29E+04	0.00E+00	5.64E+04	1.18E+04	1.43E+03	0.00E+00
CS-137	5.49E+05	6.12E+05	4.55E+04	0.00E+00	1.72E+05	7.13E+04	1.33E+03	0.00E+00
CS-138	5.05E+02	7.81E+02	3.98E+02	0.00E+00	4.10E+02	6.54E+01	8.76E+02	0.00E+00
BA-139	1.48E+00	9.84E-04	4.30E-02	0.00E+00	5.92E-04	5.95E+03	5.10E+04	0.00E+00
BA-140	5.60E+04	5.60E+01	2.90E+03	0.00E+00	1.34E+01	1.60E+06	3.84E+04	0.00E+00
BA-142	3.98E-02	3.30E-05	1.96E-03	0.00E+00	1.90E-05	1.55E+03	6.93E+02	0.00E+00
LA-140	5.05E+02	2.00E+02	5.15E+01	0.00E+00	0.00E+00	1.68E+05	8.48E+04	0.00E+00
LA-142	1.03E+00	3.77E-01	9.04E-02	0.00E+00	0.00E+00	8.22E+03	5.95E+04	0.00E+00
CE-141	2.77E+04	1.67E+04	1.99E+03	0.00E+00	5.25E+03	5.17E+05	2.16E+04	0.00E+00
CE-143	2.93E+02	1.93E+02	2.21E+01	0.00E+00	5.64E+01	1.16E+05	4.97E+04	0.00E+00
CE-144	3.19E+06	1.21E+06	1.76E+05	0.00E+00	5.38E+05	9.84E+06	1.48E+05	0.00E+00
PR-144	4.79E-02	1.85E-02	2.41E-03	0.00E+00	6.72E-03	1.61E+03	4.28E+03	0.00E+00
HF-181	5.64E+04	2.66E+02	5.05E+03	2.25E+02	1.58E+02	6.72E+05	1.90E+04	0.00E+00
W-187	1.30E+01	9.02E+00	3.12E+00	0.00E+00	0.00E+00	3.96E+04	3.56E+04	0.00E+00
NP-239	3.71E+02	3.32E+01	1.88E+01	0.00E+00	6.62E+01	5.95E+04	2.49E+04	0.00E+00

## 3.4 METHODOLOGY FOR R-11 SETPOINT (Air Particulate)

Determine the Monitor Alarm Setpoint based on the inhalation pathway to the child. The most restrictive organ "j" will be determined from the following methodology.

## 3.4.1 Determine dose rate for organ "j" (mrem/yr).

$$DR_j = \overline{X/Q} \sum_i R_{ij} Q_i \quad (3.4-1)$$

where:

- $\overline{X/Q}$  - the highest calculated annual average relative dispersion factor for any area at or beyond the unrestricted area boundary for all sectors ( $\text{sec}/\text{m}^3$ ) from Appendix A.
- $8.1\text{E}-5 \text{ sec}/\text{m}^3$  (continuous ground release) from Table A-1, Appendix A.
- $R_{ij}$  - the organ "j" dose factor due to gamma emissions from particulates greater than or equal to 8 day half-life, I-133, I-131, and H-3.
- $Q_i$  - the particulate release rate ( $\mu\text{Ci}/\text{sec}$ ) for radionuclide "i".
- $472 (C_i)(F)$

where:

- 472 - conversion factor to convert CFM to  $\text{cc}/\text{sec}$ .
- $C_i$  - ( $\mu\text{Ci}/\text{cc}_i$  from analysis of containment vessel) (0.366) + (DF) + ( $\mu\text{Ci}/\text{cc}$ , from analysis of Plant Vent) (0.634) when R-11 is sampling the Plant Vent for CV purges.



- $(\mu\text{Ci}/\text{cc}_1$  from analysis of CV) (0.04) + (DF) +  $(\mu\text{Ci}/\text{cc}_1$  from analysis of Plant Vent) (0.960) when RMS-11 sampling from Plant Vent for CV pressure relief.
- $(\mu\text{Ci}/\text{cc}_1$  from analysis of CV) + (DF) when RMS-11 is sampling CV.
- F - 95,600 cfm for CV purge when R-11 is sampling from Plant Vent.
- 35,000 cfm for CV purge when R-11 is sampling from CV.
- 2,500 cfm for CV pressure relief when R-11 is sampling from CV.
- 63,100 cfm for CV pressure relief when R-11 is sampling Plant Vent.
- DF - 1.0 for Tritium
- 10 for Iodines when using charcoal filters
- 100 for Particulates  $\geq$  8 day half-lives when using HEPA Filters.

3.4.2 Determine the particulate emission Projected Dose Rate Ratio (PDRR) for the most critical organ "j".

$$\text{PDRR}_j = \text{DR}_j / 1500 \quad (3.4-2)$$

1500 - the allowable organ dose rate due to particulates with > 8 day half-life, I-131, I-133, H-3 (mrem/year).



3.4.3 Determine the maximum monitor setpoint concentration ( $\mu\text{Ci/cc}$ ) for most critical organ "j".

$$\text{Maximum Monitor Setpoint for Organ "j"} = [(\sum_i C_i) / (PDRR_j)] (SF) (T_m) (TL)$$

where:

- SF - an engineering factor used to provide a margin of safety for cumulative measurement uncertainties = 0.50.
  
- $T_m$  - fraction of the radioactivity from the site that may be released via the monitored pathway to ensure that the site boundary limit is not exceeded due to simultaneous releases from several pathways.
  - 0.81 for R-11 particulate monitor.
  
- TL - total activity /  $\sum_i C_i$  where the total activity is the sum of all detectable particulates from analysis of particulate filter divided by the detectable particulates of  $\geq 8$  day half-lives. If this ratio is not known, use 1.0.
  - 1.0 when R-11 sampling from Plant Vent.

3.4.4 Determine the maximum monitor setpoint (cpm) for the most critical organ "j".

$$\text{Setpoint} = (\text{Maximum organ setpoint in } \mu\text{Ci/cc}) (\text{monitor eff}) \\ + \text{Bkg} \quad (3.4-3)$$

Monitor - obtained from the applicable effluent monitor efficiency curve efficiency located in the POM, Volume 15, Curve Book. Use the radioactivity concentration ( $\mu\text{Ci/cc}$ ) to find cpm.

Bkg - the monitor background (cpm)

3.5 Methodology for R-14A Setpoint (Particulate Monitor)

This section describes the methodology in determining high alarm setpoint for the plant vent monitor (R-14A) based on the inhalation pathway to the child. The most restrictive organ "j" will be determined from a conservative mix (GALE Code).

3.5.1 Determine  $S_i$ , the fraction of the total radioactivity in particulate form in the gaseous effluents comprised by radionuclide "i" for each radionuclide  $i$ : the gaseous effluent from Table 3.2-1.

$$S_i = \frac{A_i}{\sum_i A_i} \quad (3.5-1)$$

where:

$A_i$  - The radioactivity of radioparticulate radionuclide "i" in the gaseous effluent from Table 3.2-1.

3.5.2 Determine  $Q_m$ , the maximum acceptable total release rate [uCi/sec] of all the radioparticulate radionuclides in the gaseous effluent based upon the most restrictive organ "j" exposure limit of 1500 mrem/year by:

$$Q_{m_i} = \frac{1500}{(\overline{X/Q}) \sum_i S_i P_i} \quad (3.5-2)$$

where:

1500 - the maximum allowable dose rate in an unrestricted area in gaseous effluents due to radioparticulates with half lives greater than 8 days, radioiodines and tritium via the inhalation pathway to the child.

$(\overline{X/Q})$  - The highest calculated annual average relative dispersion factor for any area at or beyond the unrestricted area boundary for all sectors ( $\text{sec}/\text{m}^3$ ).

- 8.1E-05  $\text{Sec}/\text{m}^3$  (continuous ground release) from Table A-1, Appendix A.

$Pi_1$  - The dose parameter for I-131, I-133, K-3, and all particulates in particulate form with half lives greater than 8 days for the inhalation pathway only in the most restrictive sector in mrem/year per uCi/m<sup>3</sup>. The dose factor is based on the most restrictive group (child) and most restrictive organ at the SITE BOUNDARY (see Table 3.2-4).

3.5.3 Determine  $Qiv_1$ , fraction of plant stack release rate acquired on filter, by:

$$Qiv_1 = Qm_1 [3.33E-05] \quad (3.5-3)$$

where:

3.33E-05 - fraction of monitor sample rate to plant vent flow rate (2.02 CFM/60,600 CFM)

3.5.4 Determine HCl, maximum acceptable concentration [uCi] accumulated on the filter due to all particulate radionuclides in the gaseous effluents based on the most restrictive organ "j", by:

$$HCl = Qiv_1 (T) \quad (3.5-4)$$

where:

T - time in seconds  
 - 8.64E04 for one day  
 - 6.05E05 for one week

3.5.5 Determine HAC, high alarm concentration [uCi] from particulate radionuclides in gaseous effluents, by:

$$HAC = (HCl) (SF) (Tm) \quad (3.5-5)$$

where:

SF - An engineering factor used to provide a margin of safety for cumulative uncertainties of measurements  
 - 0.5

- T<sub>m</sub> - Fraction of the radioactivity from the site that may be released to ensure the site boundary limit is not exceeded due to simultaneous releases from pathways
- .92 for the Plant Vent Monitor (R-14A).

3.5.6 Determine the HSP, High Alarm Setpoint including background [cpm], by:

$$HSP = (HAC/Em) + BKG \quad (3.5-6)$$

where:

- Em - from monitor efficiency curve located in the Plant Operating Manual Curve Book.

3.6 Methodology for R-14B Setpoint (Iodine Monitor)

This section describes the methodology in determining high alarm setpoint for the plant vent monitor (R-14B) based on the inhalation pathway to the child. The most restrictive organ "j" will be determined from a conservative mix (GALE Code).

3.6.1 Determine Q<sub>mI</sub>, the maximum acceptable release rate [uCi/sec] of I-131 in gaseous effluents based upon the most restrictive organ "j" exposure limit of 1500 mrem/year, by:

$$Q_{mI} = \frac{1500}{(X/Q) Pi_I} \quad (3.6-1)$$

where:

- Pi<sub>I</sub> - The dose parameter for I-131 for the inhalation pathway only in the most restrictive sector in mrem/year per uCi/m<sup>3</sup>. The dose factor is based on the most restrictive group (child) and most restrictive organ at the Site Boundary (see Table 3.2-4).

3.6.2 Determine Q<sub>ivI</sub>, fraction of plant stack release rate acquired on the cartridge, by:

$$Q_{ivI} = Q_{mI}(3.33E-05) \quad (3.6-2)$$



3.6.3 Determine HCI, maximum acceptable concentration [uCi] accumulated on the cartridge due to I-131 in gaseous effluents based on the most restrictive organ "j".

$$HCI = (Qiv_I) (T) \quad (3.6-3)$$

where:

$$\begin{aligned} T &= \text{time in seconds} \\ &= 8.64E04 \text{ for one day} \\ &= 6.05E05 \text{ for one week} \end{aligned}$$

3.6.4 Determine HAC, high alarm concentration [uCi] from I-131 in gaseous effluents, by:

$$HAC = (HCI) (SF) (T_m) \quad (3.6-4)$$

3.6.5 Determine HSP, High Alarm Setpoint including background [cpm], by:

$$HSP = (HAC/Em) + BKG \quad (3.6-5)$$

### 3.7 Methodology for R-22 and R-23 Setpoint Determination for the Iodine and Particulate Monitors

This section describes the methodology in determining high alarm setpoint for the particulate and iodine channels for the Environmental and Radiation Control Building and Radwaste Building exhaust vent (R-22 and R-23, respectively) based on the inhalation pathway to the most restrictive organ and age group (child).

3.7.1 The dose rate in an unrestricted area resulting from the release of radioiodines, tritium, and particulates with half-lives  $\geq 8$  days is limited to 1500 mrem/yr to any organ via inhalation (10CFR20). The iodine and particulate monitor setpoints for R-22 and R-23 are limited to 1.0% of 10CFR20 over one hour period. Therefore, the iodine and particulate channels high alarm shall be set to 1.0% of 10CFR20 for any given hour.

3.7.2 Determine  $Q_1$ , the maximum release rate ( $\mu\text{Ci}/\text{sec}$ ) for Iodine-131 and Cobalt-60 (the most restrictive particulate  $\geq 8$  day half-life) base on the most restrictive organ "j" via inhalation to a child.

$$Q_1 = \frac{15}{(R_1) (\bar{X}/\bar{Q})} \quad (3.7-1)$$

where:

- 15 - 1.0% of the maximum allowable dose rate in an unrestricted area in gaseous effluents due to radioparticulates with half-lives greater than or equal to 8 days, radioiodine, and tritium via the inhalation pathway to the child.
- $R_1$  - The dose factor based on the most restrictive age group (child) and the most restrictive organ (thyroid) for Iodine-131 ( $1.62\text{E}7 \text{ mrem}/\text{yr}/\mu\text{Ci}/\text{m}^3$ ) and lung for Co-60 ( $7.06\text{E}6 \text{ mrem}/\text{yr}/\mu\text{Ci}/\text{m}^3$ ) at the most restrictive location (SITE BOUNDARY).
- $\bar{X}/\bar{Q}$  - Annual average relative dilution for continuous ground level releases for the most restrictive section at the SITE BOUNDARY ( $8.08\text{E}-5 \text{ sec}/\text{m}^3$  for the SSE sector from Table A-1).

Therefore:

$$Q_{1\text{Iodine-131}} = 1.15\text{E}-2 \mu\text{Ci}/\text{sec}$$

$$Q_{1\text{Cobalt-60}} = 2.63\text{E}-2 \mu\text{Ci}/\text{sec}$$

3.7.3 Determine  $S_{C_1}$ , the air particulate filter and charcoal cartridge sample collection rate ( $\mu\text{Ci}/\text{sec}$ ) by:

$$S_{C_1} = Q_1 \frac{f}{F} \quad (3.7-2)$$

where:

- $f$  = sampler flow rate (typically 2.5 CFM for R-22 and 2 CFM for R-23)
- $F$  = Radwaste Building exhaust vent flow rate (15,000 typically)
- = Environmental and Radiation Control Building exhaust vent flow rate (11,500 typically)

Therefore:

The typical Co-60 sample collection rate is  $5.72\text{E-}6 \mu\text{Ci}/\text{sec}$  and  $4.39\text{E-}6 \mu\text{Ci}/\text{sec}$ , for R-22 and R-23, respectively.

The typical I-131 sample collection rate is  $2.5\text{E-}6 \mu\text{Ci}/\text{sec}$  and  $1.91\text{E-}6 \mu\text{Ci}/\text{sec}$  for R-22 and R-23, respectively.

3.7.4 Determine  $Q_{m_1}$ , the setpoint activity ( $\mu\text{Ci}$ ) accumulated on the air particulate filter and charcoal filter for any given hour by:

$$Q_{m_1} = (S_{C_1}) (T) \quad (3.7-3)$$

where:

- $T$  = 3600 sec in an hour.

Therefore:

The typical setpoint activity for the air particulate filter and the charcoal cartridge is:

<u>Monitor</u>	<u>Particulate</u>	<u>Iodine</u>
R-22	2.06E-02	9.00E-03
R-23	1.58E-02	6.88E-03

3.7.5 Determine the HSP, High Alarm Setpoint including background (cpm) by:

$$\text{HSP} = (Q_{m_1}) (E_m) + \text{BKG} \quad (3.7-4)$$

where:

$E_m$  = efficiency of the detector

$\text{BKG}$  = the background of the detector

The above methodology shall be used for the iodine cartridge and air particulate filter setpoint determinations for the Environmental and Radiation Control Building and Radwaste Building exhaust vent. The sampling and building vent flow rates used in the above equations are subject to change and shall be controlled by plant procedures. If or when this occurs, the recalculations of setpoints shall be performed by approved procedures using the above methodology.

(Left blank intentionally)



(Left blank intentionally)

(Left blank intentionally)

(Left blank intentionally)

JUSTIFICATIONS AND CHANGES FOR ODCM, REVISION 10

<u>Page No.</u>	<u>Comments/Justifications for ODCM Revision 10</u>
i	Changed to page ii. The new page i is the List of Effective Pages (LEP).
ii	Renumbered to page iii.
iii	Renumbered to page iv.
iv	Renumbered to page v.
4-2	Was previously page 2 of section 4. Page was renumbered and reformatted into table form.
4-3 thru 4-5	Pages were reformatted into table form.
4-6 thru 4-7	Were previously pages 6 and 7 of section 4. Pages were renumbered and reformatted into table form.
4-9 thru 4-10	Were previously unnumbered pages 9 and 10 of section 4. Pages were numbered and revision number was added.
A-1 thru A-3	The revision number was added to the pages.
A-6	The revision number was added to the page.
A-9 thru A-20	The revision number was added to the pages.
A-22 thru A-27	The revision number was added to the pages and the pages were reformatted into table form.
B-2 thru B-5	The revision number was added to the pages.
B-7	The revision number was added to the page.
B-8	Hand drawn brackets in equation B.2-3 were replaced with computer generated brackets for the equation and the revision number was added to the page.
B-9 thru B-10	The revision number was added to the pages.
B-14	Hand drawn brackets in equation B.2-8 were replaced with computer generated brackets for the equation and the revision number was added to the page.
B-15 thru B-17	The revision number was added to the pages.

CAROLINA POWER & LIGHT COMPANY

H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
OFF-SITE DOSE CALCULATIONAL MANUAL  
(ODCM)

Revision 10

DOCKET NO. 50-261

EFFECTIVE DATE

4/29/95

CONTROLLED  
RECIPIENT  
ID \_\_\_\_\_

Reviewed By:

Dale E. Young  
PNSC Chairman

Date:

4/26/95

Accepted By:

Dale E. Young  
PNSC Chairman

Date:

4/26/95



LIST OF EFFECTIVE PAGES

EFFECTIVE PAGES

REVISION

Cover Sheet	10
LEP	10
Table of Contents	10
List of Tables	10
List of Figures	10
1-1 through 1-2	9
2-1 through 2-24	9
3-1 through 3-83	9
4-1	8
4-2 through 4-7	10
4-8	5
4-9 through 4-10	10
5-1	2
6-1	4
6-2 through 6-3	1
A-1 through A-3	10
A-4 through A-5	1
A-6	10
A-7 through A-8	1
A-9 through A-20	10
A-21	1
A-22 through A-27	10
B-1	3
B-2 through B-5	10
B-6	2
B-7 through B-10	10
B-11 through B-13	1
B-14 through B-17	10
B-18 through B-21	9
B-22	2
C-1 through C-4	4
D-1 through D-4	7

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
	LIST OF EFFECTIVE PAGES .....	i
	TABLE OF CONTENTS.....	ii
	LIST OF TABLES.....	iii
	LIST OF FIGURES.....	v
1.0	INTRODUCTION.....	1-1
2.0	LIQUID EFFLUENTS.....	2-1
2.1	Monitor Alarm Setpoint Determination.....	2-1
2.2	Compliance with 10CFR20 (Liquids).....	2-11
2.3	Compliance with 10CFR50 (Liquids).....	2-16
3.0	GASEOUS EFFLUENTS.....	3-1
3.1	Monitor Alarm Setpoint Determination.....	3-1
3.2	Compliance with 10CFR20 (Gaseous).....	3-15
3.3	Compliance with 10CFR50 (Gaseous).....	3-24
3.4	Methodology for RMS-11 Setpoint (Air Particulate).....	3-73
3.5	Methodology for R-14A Setpoint (Particulate Monitor).....	3-77
3.6	Methodology for R-14B Setpoint (Iodine Monitor).....	3-79
3.7	Methodology for R-22 and R-23 Setpoint Determinations for the Iodine and Particulate Monitors.....	3-80
4.0	RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM.....✓.....	4-1
5.0	INTERLABORATORY COMPARISON STUDIES.....	5-1
5.1	Objective.....	5-1
5.2	Program.....	5-1
6.0	TOTAL DOSE (40CFR190 CONFORMANCE).....	6-1
6.1	Compliance with 40CFR190.....	6-1
6.2	Calculations Evaluating Conformance with 40CFR190.....	6-1
6.3	Calculations of Total Body Dose.....	6-2
6.4	Thyroid Dose.....	6-3
6.5	Dose Projects.....	6-3
	APPENDIX A - Meteorological Dispersion Factor Computations.....	A-1
	APPENDIX B - Dose Parameters for Radioiodines, Particulates, and Tritium.....	B-1
	APPENDIX C - Lower Limit of Detectability.....	C-1

LIST OF TABLES

<u>No.</u>	<u>Title</u>	<u>Page</u>
2.3-1	Air Values for the Adult for the H.B. Robinson Steam Electric Plant.....	2-22
3.1-1	Gaseous Source Terms.....	3-13
3.1-2	Dose Factors and Constants.....	3-14
3.2-1	Releases from H.B. Robinson Unit No. 2.....	3-19
3.2-2	Distance to Special Locations for the H.B. Robinson Plant (Mi.).....	3-20
3.2-3	Dose Factors for Noble Gases and Daughters.....	3-21
3.2-4	$C_1$ Values for a Child for the H.B. Robinson Unit No. 2.....	3-22
3.3-1 thru 3.3-19	R Values for the H.B. Robinson Steam Electric Plant.....	3-35 thru 3-72
4.0-1	H.B. Robinson Radiological Environmental Monitoring Program.....	4-2
A-1	X/Q Values for Long-Term Ground Level Releases at Special Locations (sec/m <sup>3</sup> ).....	A-4
A-2	Depleted X/Q Values for Long-Term Ground Level Releases at Special Locations (sec/m <sup>3</sup> ).....	A-5
A-3	D/Q Values for Long-Term Ground Level Releases at Special Locations (m <sup>-2</sup> ).....	A-6
A-4	X/Q Values for Long-Term Ground Level Releases at Standard Distances (sec/m <sup>3</sup> ).....	A-7
A-5	Depleted X/Q Values for Long-Term Ground Level Releases at Standard Distances (sec/m <sup>3</sup> ).....	A-8
A-6	D/Q Values for Long-Term Ground Level Releases at Standard Distances (m <sup>-2</sup> ).....	A-9
A-7	X/Q Value for Short-Term Ground Level Releases at Special Locations (sec/m <sup>3</sup> ).....	A-10
A-8	Depleted X/Q Values for Short-Term Ground Level Releases at Special Locations (sec/m <sup>3</sup> ).....	A-11

LIST OF TABLES (continued)

<u>No.</u>	<u>Title</u>	<u>Page</u>
A-9	D/Q Values for Short-Term Ground Level Releases at Special Locations ( $m^{-2}$ ).....	A-12
A-10	X/Q Values for Long-Term Mixed Mode Releases at Special Locations ( $sec/m^3$ ).....	A-13
A-11	Depleted X/Q Values for Long-Term Mixed Mode Releases at Special Locations ( $sec/m^3$ ).....	A-14
A-12	L/Q Values for Long-Term Mixed Mode Releases at Special Locations ( $m^{-2}$ ).....	A-15
A-13	X/Q Values for Long-Term Mixed Mode Releases at Standard Distances ( $sec/m^3$ ).....	A-16
A-14	Depleted X/Q Values for Long-Term Mixed Mode Releases at Standard Distances ( $sec/m^3$ ).....	A-17
A-15	D/Q Values for Long-Term Mixed Mode Releases at Standard Distances ( $m^{-2}$ ).....	A-18
A-16	X/Q Values for Short-Term Mixed Mode Releases at Special Locations ( $sec/m^3$ ).....	A-19
A-17	Depleted X/Q Values for Short-Term Mixed Mode Releases at Special Locations ( $sec/m^3$ ).....	A-20
A-18	D/Q Values for Short-Term Mixed Mode Releases at Special Locations ( $m^{-2}$ ).....	A-21
A-19	Robinson Plant Site Information to be Used for Ground Level Calculations with NRC "XOQDOQ" Program.....	A-22
A-20	Robinson Plant Site Information to be Used for Mixed Mode Release Calculations with NRC "XOQDOQ" Program.....	A-25
B-1	Parameters for Cow and Goat Milk Pathways.....	B-15
B-2	Parameters for the Meat Pathway.....	B-16
B-3	Parameters for the Vegetable Pathway.....	B-17
D-1	Liquid Process Monitors.....	D-1
D-2	Gaseous Process Monitors.....	D-2

LIST OF FIGURES

<u>No.</u>	<u>Title</u>	<u>Page</u>
4-1	Radiological Sample Locations Near Site.....	4-9
4-2	Radiological Sample Distant Locations.....	4-10
D-1	H.B. Robinson Liquid Radwaste Effluent System.....	D-3
D-2	H.B. Robinson Gaseous Radwaste Effluent System.....	D-4



Table 4.0-1

H. B. ROBINSON RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Exposure Pathway and/or Sample	Sample Point	Sample Point Description, Distance, and Direction	Sampling and Collection Frequency	Analysis <sup>1</sup> Frequency	Analysis <sup>1</sup>
1. Airborne Particulates and Radioiodines	1.	Florence, S. C. (Control Station) <sup>2</sup> 26 miles ESE @ 119°	Continuous operating sampler with sample collection at least weekly	Weekly	I-131 for Air Cartridges
	2.	Information Center 0.2 miles S @ 180°		Weekly	Gross Beta <sup>3</sup>
	3.	Microwave tower 0.7 mile N @ 5°		Quarterly	Gamma Scan <sup>4</sup> of composite (by location)
	4.	Spillway 0.4 mile ESE @ 110°			
	5.	East Shore of lake across from plant intake Johnson' Landing 0.9 mile ENE @ 73°			
	6.	Information Center 0.3 mile SW @ 214°			
	7.	CP&L Hartsville substation, 6.3 miles ESE @ 109°			
	55.	South of the West Settling Pond .3 miles SSE @ 159°			
2. Direct Radiation	1.	Florence, S. C. (Control Station) <sup>2</sup> 26 miles ESE @ 119°	Continuous measurement with readout at least once per quarter (TLDs)	Quarterly	Gamma Dose <sup>5</sup>

Table 4.0-1 (Continued)

H. B. ROBINSON RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Exposure Pathway and/or Sample	Sample Point	Sample Point Description, Distance, and Direction	Sampling and Collection Frequency	Analysis <sup>1</sup> Frequency	Analysis <sup>1</sup>
2. Direct Radiation (continued)	2.	Information Center 0.2 mile S @ 180°	Continuous measurement with readout at least once per quarter (YLDs)	Quarterly	Gamma Dose <sup>5</sup>
	3.	Microwave tower 0.7 mile N @ 5°			
	4.	Spillway 0.4 mile ESE @ 110°			
	5.	East shore of lake across from plant intake Johnson's landing 0.9 mile ENE @ 73°			
	6.	Information Center 0.3 mile SW @ 214°			
	7.	CP&L Hartsville substation 6.3 miles ESE @ 109°			
	8.	Transmission tower 0.8 mile SSE.			
	9.	Transmission tower 1.0 mile S.			
	10.	The Church of God cemetery 1.0 mile WSW			
	11.	Old Camden Road 1.0 mile SW.			
	12.	Tree 1.2 miles SSW.			

Table 4.0-1 (Continued)

H. B. ROBINSON RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Exposure Pathway and/or Sample	Sample Point	Sample Point Description, Distance, and Direction	Sampling and Collection Frequency	Analysis <sup>1</sup> Frequency	Analysis <sup>1</sup>
2. Direct Radiation (continued)	13.	Tree 1.0 mile W.	Continuous measurement with readout at least once per quarter (TLDs)	Quarterly	Gamma Dose <sup>2</sup>
	14.	Highway 151 at Pine Ridge Church 0.9 mile WNW.			
	15.	Tree directly adjacent to ash pond on CP&L property 1.0 miles NW.			
	16.	Darlington County I.C. Turbine Plant 1.0 mile NNW.			
	17.	1.0 mile down Discharge Canal road at Old Unit One Weir 1.1 miles N.			
	18.	Black Creek 0.7 mile SE.			
	19.	Road #S-16-23 1.0 mile E.			
	20.	Road #S-16-39 1.3 miles ENE.			
	21.	Atkinson's landing 1.4 miles NE.			
	22.	Shady Rest Club 1.9 miles NNE.			
	23.	Road #S-16-39 1.2 miles ESE.			
	24.	Road #S-13-711 5.0 miles NW.			

Table 4.0-1 (Continued)

H. B. ROBINSON RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Exposure Pathway and/or Sample	Sample Point	Sample Point Description, Distance, and Direction	Sampling and Collection Frequency	Analysis <sup>1</sup> Frequency	Analysis <sup>1</sup>
2. Direct Radiation (continued)	25.	Road #S-13-346 4.6 miles NNW.	Continuous measurement with readout at least once per quarter (TLDs)	Quarterly	Gamma Dose <sup>6</sup>
	26.	Road #S-13-346 5.0 miles N.			
	27.	Road #S-13-763 5.0 miles NNE.			
	28.	Road #S-13-39 4.8 miles NE.			
	29.	Road #S-16-20 4.1 mile ENE.			
	30.	Road #S-16-20 4.6 miles E.			
	31.	Lakeshore Drive 4.6 miles ESE.			
	32.	Transmission 4.5 miles SE.			
	33.	Road #S-16-493 4.6 miles SSE.			
	34.	Transmission pole on Road #S-16-772 4.6 miles S.			

Table 4.0-1 (Continued)

H. B. ROBINSON RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM


Exposure Pathway and/or Sample	Sample Point	Sample Point Description, Distance, and Direction	Sampling and Collection Frequency	Analysis <sup>1</sup> Frequency	Analysis <sup>1</sup>
2. Direct Radiation (continued)	35.	Power pole on Road #S-31-51 4.4 miles SSW.	Continuous measurement with readout at least once per quarter (TLDs)	Quarterly	Gamma Dose <sup>5</sup>
	36.	Power pole 3/4 mile down paved road off Road #S-16-85. 4.7 miles SW.			
	37.	Transmission tower 5.0 miles WSW.			
	38.	Road S-16-231 next to Union Church 4.9 miles W.			
	39.	Power Pole 5.0 miles WNW.			
	55.	South of the West Settling Pond .3 miles SSE @ 159°			
3. Waterborne a. Surface Water	40.	Black Creek at Road 1623 0.6 mile ESE (Indicator).	Composite sample <sup>6</sup> over one-month period	Monthly	Gamma Scan <sup>4</sup> H-3
	41.	Black Creek (Control Station) <sup>2</sup> 7.2 miles NNW.			
b. Groundwater	40.	Artesian well 0.6 miles ESE.	Grab Sample	Monthly	Gamma Scan <sup>4</sup> H-3
	42.	Unit 1 deep well			
	43.	Unit 2 deep well			
c. Drinking water		Not required <sup>7</sup>			
d. Shoreline Sediment	44.	East Shore of Lake, Shady Rest Club 1.9 miles NNE.	Semiannually	Semiannually	Gamma Scan <sup>4</sup>



Table 4.0-1 (Continued)

H. B. ROBINSON RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

Exposure Pathway and/or Sample	Sample Point	Sample Point Description, Distance, and Direction	Sampling and Collection Frequency	Analysis <sup>1</sup> Frequency	Analysis <sup>1</sup>
4. Ingestion a. Milk	54.	Auburndale Farm, 10 miles E.	Semimonthly when animals are on pasture; monthly @ other times	Semimonthly when animals are on pasture; monthly @ other times	Gamma Scan <sup>4</sup> and I-131 analysis semi-monthly when animals are on pasture; monthly @ other times
	63.	Cunningham Farm 18.4 miles ESE (Control Station for milk).			
		Indicator Milk Sample Location (There are no milk samples available within 8 Km of Plant. The following broad-leaf vegetation are to be sampled and analyzed.)			
Broadleaf	50.	SSE Close to Site Boundary <sup>3</sup> .	Monthly when available (3 different kinds of broad-leaf vegetation)	Each sample	Gamma Scan <sup>4</sup> I-131
	51.	SSW Close to Site Boundary <sup>3</sup> .			
	52.	≥10 miles W, near Bethune (Control Station for Broad-leaf Vegetation).			
b. Fish	45.	Site varies within lake Robinson	Semiannually (collect comparable species at all three locations)	Each sample	Gamma Scan <sup>4</sup> Edible portion
	46.	Prestwood lake 4.9 miles ESE.			
	47.	Bee Lake (Control station) <sup>2</sup> 13 miles NW or May Lake 12.5 miles NNW.			
c. Food Products leafy vegetables	54.	Auburndale Plantation <sup>6</sup> 10.1 miles E. (One sample of each principal class of irrigated food products).	Annual at harvest	Each sample	Gamma Scan <sup>4</sup>






FIGURE 4-2  
RADIOLOGICAL SAMPLE  
DISTANT LOCATIONS

Rev. 10

4-10

HBRODCM

APPENDIX A  
METEOROLOGICAL DISPERSION FACTOR COMPUTATIONS

Carolina Power & Light Company (CP&L) engaged the services of Dames & Moore to assess the transport and dispersion of the effluent in the atmosphere as outlined in Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants, NUREG 0133 (USNRC 1978). The methodology for this assessment was based on guidelines presented in Regulatory Guide (RG) 1.111, Revision 1 (USNRC 1977). The results of the assessment were to provide the relative deposition flux and relative concentrations (undepleted and depleted) based on numerical models acceptable for use in Appendix I evaluations.

Regulatory Guide 1.111 presented three acceptable diffusion models for use in estimating deposition flux and concentrations. These were (1) particle-in-cell model (a variable trajectory model based on the gradient-transport theory), (2) puff-advection model (a variable trajectory model based on the statistical approach to diffusion), and (3) the constant mean wind direction model referred to here as the straight-line trajectory Gaussian diffusion model (the most widely used model based on a statistical approach). It was resolved that for operational efficiency, the straight-line described in XOQDOQ Program for the Meteorological Evaluation of Routine Effluent Releases at Nuclear Power Stations (Draft), NUREG 0324 (USNRC September 1977) would be used for generating the required analyses of Appendix I. To provide a more realistic accounting of the variability of wind around the plant site, terrain/recirculation correction factors (TCF) were to be determined from a combined puff-advection/straight-line scheme for a one-year meteorological data base.

Dames & Moore was provided a one-year record of meteorological data from the on-site meteorological program at the H. B. Robinson Steam Electric Plant. These data consisted of all collected parameters at both the 11.03-meter and 62.39-meter tower levels for the year 1977. Dames & Moore computed dispersions and depositions using the model described in the reference. The following tables from the reference provide the basis for the meteorological dilution factor development of the technical specifications for Appendix I and were the source of the X/Q and D/Q values used to show compliance with 10 CFR 20 and 10 CFR 50 for noble gases and radioiodines and particulates.

Tables A-1 through A-6

Relative undepleted concentration, relative depleted concentration, and relative deposition flux estimates for ground level releases for both standard distances and special locations for long-term releases.

Tables A-7 through A-9

Relative undepleted concentration, relative depleted concentration, and relative deposition flux estimates for ground level releases for special locations for short-term releases.

The X/Q and D/Q values which are used in Appendix B for showing compliance with 10 CFR 20 and 10 CFR 50 when the HBR Plant vent has been modified such that it qualifies as a mixed mode release were based upon the following tables:

Tables A-10 through A-15

Relative undepleted concentration, relative depleted concentration, and relative deposition flux estimates for elevated release for both standard distances and special locations for long-term releases.

Tables A-16 through A-18

Relative undepleted concentration, relative depleted concentration, and relative deposition flux estimates for mixed mode releases for special locations for short-term releases. It should be noted that the short-term releases were based upon 100 hours per year of containment purges.

#### Future Operation Computations

The NRC "XOQDOQ" Program (Revision 1) was obtained and installed on the CP&L computer system. In general, Dames & Moore concluded that the straight-line model is as reasonable a projection of concentrations as the puff-advection



model. By inclusion of the terrain correction factors developed by a combination of the puff-advection/straight-line scheme with the results of the XOQDOQ Program, ready evaluation of on-site meteorological data may be made.

For routine meteorological dispersion evaluations, the "XOQDOQ" Program will be run with the appropriate physical plant data, appropriate meteorological information for the standard distances, and special locations of interest without a terrain/recirculation factor. The resulting computations will have applied the TCFs to produce a final atmospheric diffusion estimate for the site. The input to "XOQDOQ" for ground level releases at HBR are presented in Table A-19 and for mixed mode releases at HBR in Table A-20.

#### Reference

Chandler, Martin W. and George Hoopes, Revised Radiological Effluent Technical Specifications. Gaseous Effluent Dilution Factors, Prepared for Carolina Power & Light Company, Robinson Facility, Dames & Moore, January 18, 1979.

TABLE A-3

D/Q Values for Long-Term Ground Level Releases at Special Locations ( $m^{-2}$ )

Carolina Power & Light Company - Robinson  
 Release Type: Annual  
 Release Mode: Ground Level  
 Variable: Relative Deposition Rate ( $Meter^{-2}$ )  
 Calculation Points: Special  
 Model: Straight Line (ANNXOQ9)  
 Application of Terrain Correction Factors: Yes  
 Number of Observations: 8703

Affected Sector	Site Boundary	Meat	Dairy	Resident	Garden
NNE	9.80E-09	5.63E-09	0.00	9.09E-09	7.74E-09
NE	5.59E-09	4.65E-09	3.70E-09	4.42E-09	3.70E-09
ENE	8.06E-09	6.96E-10	0.00	7.59E-09	1.05E-09
E	1.24E-08	4.13E-10	1.80E-10	6.43E-09	5.11E-10
ESE	1.71E-08	1.46E-09	0.00	1.20E-08	1.20E-08
SE	4.23E-08	0.00	0.00	4.14E-08	4.14E-08
SSE	8.08E-08	0.00	0.00	6.21E-08	6.21E-08
S	4.39E-08	4.77E-10	0.00	3.82E-08	2.33E-08
SSW	5.92E-08	1.38E-09	0.00	6.12E-08	2.33E-08
SW	2.80E-08	6.49E-10	5.17E-10**	2.15E-08	1.65E-08
WSW	1.91E-08	4.37E-10	0.00	1.54E-08	8.84E-09
W	8.84E-09	1.09E-10	0.00	5.75E-09	5.75E-09
WNW	8.10E-09	1.88E-10	0.00	5.08E-09	2.97E-09
NW	2.44E-09	1.45E-09	0.00	2.16E-09	2.16E-09
NNW	2.44E-09	7.45E-10	0.00	6.83E-10	5.73E-10
N	1.76E-09	6.44E-10	0.00	6.67E-10	6.67E-10

\* Zeroes indicate that this point was not calculated

\*\* A milk goat is located here

TABLE A-6

D/Q Values for Long-Term Ground Level Releases at Standard Distances (m<sup>-2</sup>)

Carolina Power & Light Company Robinson  
 Release Type: Annual  
 Release Mode: Ground Level  
 Variable: Relative Concentration (Meter<sup>-2</sup>)  
 Calculation Points: Standard  
 Model: Straight Line (ANNXOQ9)  
 Application of Terrain Correction Factors: Yes  
 Number of Observations: 8703

BASE DISTANCE IN MILES/KILOMETERS

Aftd Sect	Design Dist	.25	.75	1.25	1.75	2.25	2.75	3.25	3.75	4.25	4.75
MI	.40	1.21	2.01	2.82	3.62	4.42	5.23	6.03	6.84	7.64	
NNE	0.	1.3E-07	2.4E-08	9.3E-09	4.8E-09	3.0E-09	2.0E-09	1.2E-09	8.2E-10	5.4E-10	3.4E-10
NE	0.	7.1E-08	8.9E-09	3.4E-09	1.8E-09	1.0E-09	6.5E-10	4.6E-10	3.4E-10	2.6E-10	2.0E-10
ENE	0.	5.5E-08	9.6E-09	3.1E-09	1.5E-09	7.9E-10	5.1E-10	3.3E-10	2.6E-10	1.9E-10	1.6E-10
E	0.	5.1E-08	8.7E-09	2.7E-09	1.4E-09	9.4E-10	4.7E-10	3.6E-10	2.4E-10	1.5E-10	1.1E-10
ESE	0.	5.0E-08	8.2E-09	3.2E-09	1.6E-09	1.1E-09	6.9E-10	5.1E-10	3.6E-10	2.5E-10	1.8E-10
SE	0.	4.8E-08	7.0E-09	3.1E-09	1.5E-09	8.6E-10	4.5E-10	3.1E-10	1.8E-10	1.5E-10	1.2E-10
SSE	0.	8.2E-08	1.3E-08	5.2E-09	2.6E-09	1.4E-09	7.7E-10	4.9E-10	3.9E-10	3.0E-10	2.5E-10
S	0.	4.8E-08	6.3E-09	2.2E-09	1.2E-09	4.8E-10	3.5E-10	2.6E-10	1.9E-10	1.6E-10	1.2E-10
SSW	0.	7.2E-08	1.4E-08	5.1E-09	2.0E-09	1.1E-09	6.8E-10	4.5E-10	3.2E-10	2.3E-10	1.8E-10
SW	0.	4.2E-08	6.5E-09	2.3E-09	1.0E-09	5.7E-10	3.7E-10	2.7E-10	1.8E-10	1.4E-10	1.1E-10
WSW	0.	3.0E-08	4.9E-09	1.7E-09	8.5E-10	6.3E-10	3.8E-10	2.5E-10	1.9E-10	1.6E-10	1.2E-10
W	0.	2.7E-08	3.4E-09	1.2E-09	6.1E-10	4.4E-10	2.7E-10	2.0E-10	1.3E-10	8.5E-11	6.7E-11
WNW	0.	3.0E-08	3.9E-09	1.4E-09	7.4E-10	5.4E-10	3.7E-10	2.6E-10	2.0E-10	1.4E-10	1.0E-10
NW	0.	3.4E-08	5.2E-09	2.2E-09	1.2E-09	6.3E-10	3.2E-10	1.8E-10	1.5E-10	1.1E-10	9.0E-11
NNW	0.	4.1E-08	7.4E-09	3.6E-09	2.5E-09	1.6E-09	8.0E-10	3.9E-10	2.4E-10	1.5E-10	1.2E-10
N	0.	6.7E-08	1.1E-08	4.1E-09	2.0E-09	1.1E-09	7.2E-10	4.7E-10	3.3E-10	2.5E-10	2.0E-10

Number of Valid Observations = 8703  
 Number of Invalid Observations = 57  
 Number of Calms Lower Level = 398  
 Number of Calms Upper Limit = 0

TABLE A-7

X/Q Values for Short-Term Ground Level Releases at Special Locations (sec/m<sup>3</sup>)\*

Carolina Power & Light Company - Robinson  
 Release Type: Purge  
 Release Mode: Ground Level  
 Variable: Relative Concentration (Sec./Cubic Meter)  
 Calculation Points: Special  
 Model: Purge (ACNPURG2)  
 Application of Terrain Correction Factors: No  
 Number of Observations: 8703  
 Purge Time: 100 Hours

Affected Sector	Site Boundary	Meat	Dairy	Resident	Garden
NNE	7.20E-06	5.00E-06	0.00	6.80E-06	6.20E-06
NE	5.30E-06	4.60E-06	4.00E-06	4.40E-06	4.00E-06
ENE	6.90E-06	1.50E-06	0.00	6.70E-06	1.90E-06
E	1.00E-05	1.10E-06	6.40E-07	6.20E-06	1.20E-06
ESE	1.50E-05	2.60E-06	0.00	1.10E-05	1.10E-05
SE	3.40E-05	0.00	0.00	3.30E-05	3.30E-05
SSE	5.10E-05	0.00	0.00	4.10E-05	4.10E-05
S	3.00E-05	1.20E-06	0.00	2.60E-05	1.80E-05
SSW	2.10E-05	1.30E-06	0.00	2.00E-05	9.80E-06
SW	1.10E-05	7.80E-07	6.70E-07**	9.10E-06	7.20E-06
WSW	8.10E-06	5.50E-07	0.00	6.90E-06	4.20E-06
W	5.50E-06	3.00E-07	0.00	4.20E-06	4.20E-06
WNW	5.30E-06	3.90E-07	0.00	3.70E-06	2.50E-06
NW	2.30E-06	1.70E-06	0.00	2.20E-06	2.20E-06
NNW	2.40E-06	1.20E-06	0.00	1.20E-06	1.10E-06
N	2.70E-06	1.50E-06	0.00	1.50E-06	1.50E-06

\* Zeroes indicate that this point was not calculated  
 \*\* A milk goat is located here

TABLE A-8

Depleted X/Q Values for Short-Term Ground Level Releases at Special Locations (sec/m<sup>3</sup>)\*

Carolina Power & Light Company - Robinson

Release Type: Purge

Release Mode: Ground Level

Variable: Relative Depleted Concentration (Sec./Cubic Meter)

Calculation Points: Special

Model: Purge (ACNPURG2)

Application of Terrain Correction Factors: No

Number of Observations: 8703

Purge Time: 100 Hours

Affected Sector	Site Boundary	Meat	Dairy	Resident	Garden
NNE	6.30E-06	4.09E-06	0.00	5.71E-06	5.31E-06
NE	4.71E-06	3.97E-06	3.37E-06	3.77E-06	3.37E-06
ENE	6.19E-06	1.21E-06	0.00	5.96E-06	1.53E-06
E	9.06E-06	8.80E-07	4.80E-07	5.51E-06	9.34E-07
ESE	1.36E-05	2.14E-06	0.00	9.90E-06	9.90E-06
SE	3.19E-05	0.00	0.00	3.08E-05	3.08E-05
SSE	4.71E-05	0.00	0.00	3.83E-05	3.83E-05
S	2.83E-05	9.74E-07	0.00	2.44E-05	1.67E-05
SSW	1.91E-05	1.05E-06	0.00	1.92E-05	8.93E-06
SW	1.02E-05	6.38E-07	7.64E-07**	8.49E-06	6.52E-06
WSW	7.50E-06	4.23E-07	0.00	6.30E-06	3.85E-06
W	5.16E-06	2.28E-07	0.00	3.85E-06	3.85E-06
WNW	4.82E-06	2.98E-07	0.00	3.33E-06	2.23E-06
NW	1.95E-06	1.41E-06	0.00	1.88E-06	1.88E-06
NNW	1.99E-06	9.53E-07	0.00	9.46E-07	8.59E-07
N	2.31E-06	1.19E-06	0.00	1.18E-06	1.18E-06

\* Zeroes indicate that this point was not calculated

\*\* A milk goat is located here



TABLE A-9

D/Q Values for Short-Term Ground Level Releases at Special Locations ( $m^{-2}$ )\*

Carolina Power & Light Company - Robinson

Release Type: Purge

Release Mode: Ground Level

Variable: Relative Deposition Rate ( $Meter^{-2}$ )

Calculation Points: Special

Model: Purge (ACNPURG2)

Application of Terrain Correction Factors: No

Number of Observations: 8703

Purge Time: 100 Hours

Affected Sector	Site Boundary	Meat	Dairy	Resident	Garden
NNE	1.06E-08	6.80E-09	0.00	9.86E-09	8.62E-09
NE	9.80E-09	8.37E-09	6.96E-09	7.96E-09	6.96E-09
ENE	1.26E-08	2.12E-09	0.00	1.21E-08	2.72E-09
E	1.94E-08	1.51E-09	8.00E-10	1.13E-08	1.67E-09
ESE	2.29E-08	3.22E-09	0.00	1.68E-08	1.68E-08
SE	4.25E-08	0.00	0.00	4.19E-08	4.19E-08
SSE	5.10E-08	0.00	0.00	4.22E-08	4.22E-08
S	3.99E-08	1.36E-09	0.00	3.59E-08	2.54E-08
SSW	5.92E-08	3.18E-09	0.00	6.00E-08	2.83E-08
SW	3.46E-08	1.93E-09	1.61E-09**	2.83E-08	2.20E-08
WSW	3.90E-08	2.07E-09	0.00	3.30E-08	2.03E-08
W	2.30E-08	8.40E-10	0.00	1.75E-08	1.75E-08
WNW	2.65E-08	1.38E-09	0.00	1.82E-08	1.22E-08
NW	7.08E-09	4.86E-09	0.00	6.42E-09	6.42E-09
NNW	4.46E-09	1.87E-09	0.00	1.86E-09	1.65E-09
N	3.27E-09	1.50E-09	0.00	1.50E-09	1.50E-09

\* Zeroes indicate that this point was not calculated  
 \*\* A milk goat is located here

TABLE A-10

X/Q Values for Long-Term Mixed Mode Releases at Special Locations (sec/m<sup>3</sup>)\*

Carolina Power & Light Company - Robinson  
 Release Type: Annual  
 Release Mode: Mixed Mode  
 Variable: Relative Concentration (Sec./Cubic Meter)  
 Calculation Points: Special  
 Model: Straight Line (ANNXOQ9)  
 Application of Terrain Correction Factors: Yes  
 Number of Observations: 8703

Affected Sector	Site Boundary	Heat	Dairy	Resident	Garden
NNE	3.33E-07	2.82E-07	0.00	3.23E-07	3.18E-07
NE	1.34E-07	1.40E-07	1.23E-07	1.39E-07	1.23E-07
ENE	2.74E-07	1.23E-07	0.00	2.79E-07	8.51E-08
E	2.40E-07	1.11E-07	5.39E-08	2.53E-07	1.33E-07
ESE	2.75E-07	1.25E-07	0.00	2.17E-07	2.17E-07
SE	5.13E-07	0.00	0.00	5.23E-07	5.23E-07
SSE	9.94E-07	0.00	0.00	7.61E-07	7.61E-07
S	4.57E-07	3.61E-08	0.00	4.00E-07	2.50E-07
SSW	5.54E-07	1.27E-07	0.00	5.71E-07	2.69E-07
SW	2.31E-07	5.38E-08	4.72E-08**	1.84E-07	1.51E-07
WSW	2.06E-07	4.64E-08	0.00	1.68E-07	1.02E-07
W	9.36E-08	1.87E-08	0.00	7.13E-08	7.13E-08
WNW	1.02E-07	4.28E-08	0.00	9.55E-08	9.80E-08
NW	1.52E-07	1.30E-07	0.00	1.54E-07	1.54E-07
NNW	1.71E-07	8.86E-08	0.00	8.30E-08	7.28E-08
N	9.32E-08	5.66E-08	0.00	5.80E-08	5.80E-08

\* Zeroes indicate that this point was not calculated  
 \*\* A milk goat is located here

TABLE A-11

Depleted X/Q Values for Long-Term Mixed Mode Releases at Special Locations (sec/m<sup>3</sup>)

Carolina Power & Light Company - Robinson  
 Release Type: Annual  
 Release Mode: Mixed Mode  
 Variable: Relative Concentration (Sec./Cubic Meter)  
 Calculation Points: Special  
 Model: Straight Line (ANNXOQ9)  
 Application of Terrain Correction Factors: Yes  
 Number of Observations: 8703

Affected Sector	Site Boundary	Meat	Dairy	Resident	Garden
NNE	3.33E-07	2.82E-07	0.00	3.23E-07	2.98E-07
NE	1.23E-07	1.28E-07	1.23E-07	1.28E-07	1.23E-07
ENE	2.59E-07	1.23E-07	0.00	2.63E-07	8.12E-08
E	2.40E-07	1.11E-07	4.39E-08	2.53E-07	1.23E-07
ESE	2.54E-07	1.18E-07	0.00	1.96E-07	1.96E-07
SE	4.93E-07	0.00	0.00	5.02E-07	5.02E-07
SSE	9.32E-07	0.00	0.00	7.21E-07	7.21E-07
S	4.39E-07	3.42E-08	0.00	3.82E-07	2.33E-07
SSW	5.35E-07	1.27E-07	0.00	5.51E-07	2.51E-07
SW	2.31E-07	5.14E-08	5.31E-08**	1.84E-07	1.45E-07
WSW	2.06E-07	4.46E-08	0.00	1.68E-07	9.91E-08
W	9.10E-08	1.82E-08	0.00	6.90E-08	6.90E-08
WNW	9.88E-08	4.07E-08	0.00	9.26E-08	9.54E-08
NW	1.51E-07	1.27E-07	0.00	1.54E-07	1.54E-07
NNW	1.64E-07	8.44E-08	0.00	8.04E-08	6.92E-08
N	8.91E-08	5.42E-08	0.00	5.56E-08	5.56E-08

\* Zeroes indicate that this point was not calculated  
 \*\* A milk goat is located here

TABLE A-12

D/Q Values for Long-Term Mixed Mode Releases at Special Locations ( $m^{-2}$ )\*

Carolina Power & Light Company - Robinson  
 Release Type: Annual  
 Release Mode: Mixed Mode  
 Variable: Relative Deposition Rate ( $Meter^{-2}$ )  
 Calculation Points: Special  
 Model: Straight Line (ANNXOQ9)  
 Application of Terrain Correction Factors: Yes  
 Number of Observations: 8703

Affected Sector	Site Boundary	Heat	Dairy	Resident	Garden
NNE	2.29E-09	1.39E-09	0.00	2.22E-09	1.89E-09
NE	1.79E-09	1.51E-09	1.23E-09	1.39E-09	1.23E-09
ENE	3.19E-09	3.41E-10	0.00	3.10E-09	4.78E-10
E	4.99E-09	2.31E-10	1.15E-10	2.92E-09	2.76E-10
ESE	4.86E-09	5.90E-10	0.00	3.75E-09	3.75E-09
SE	6.98E-09	0.00	0.00	7.20E-09	7.20E-09
SSE	6.22E-09	0.00	0.00	5.21E-09	5.21E-09
S	7.31E-09	1.77E-10	0.00	6.60E-09	5.17E-09
SSW	1.01E-08	7.41E-10	0.00	1.06E-08	6.81E-09
SW	4.62E-09	3.32E-10	2.66E-10**	4.14E-09	3.87E-09
WSW	4.85E-09	2.59E-10	0.00	4.34E-09	3.35E-09
W	2.64E-09	6.74E-11	0.00	1.95E-09	1.95E-09
WNW	2.59E-09	1.25E-10	0.00	1.94E-09	1.29E-09
NW	1.20E-09	7.66E-10	0.00	1.12E-09	1.12E-09
NNW	7.77E-10	2.53E-10	0.00	2.41E-10	2.03E-10
N	3.62E-10	1.41E-10	0.00	1.51E-10	1.51E-10

\* Zeroes indicate that this point was not calculated  
 \*\* A milk goat is located here

TABLE A-13

X/Q Values for Long-Term Mixed Mode Releases at Standard Distances (sec/m<sup>3</sup>)

Carolina Power & Light Company - Robinson  
 Release Type: Annual  
 Release Mode: Mixed Mode  
 Variable: Relative Concentration (Sec./Cubic Meter)  
 Calculation Points: Standard  
 Model: Straight Line (ANNXOQ9)  
 Application of Terrain Correction Factors: Yes  
 Number of Observations: 8703

BASE DISTANCE IN MILES/KILOMETERS

Aftd Design Sect	Dist MI	BASE DISTANCE IN MILES/KILOMETERS									
		.25 .40	.75 1.21	1.25 2.01	1.75 2.82	2.25 3.62	2.75 4.42	3.25 5.23	3.75 6.03	4.25 6.84	4.75 7.64
HNE	0.	1.5E-06	3.9E-07	3.1E-07	2.7E-07	2.3E-07	2.0E-07	1.6E-07	1.4E-07	9.8E-08	6.5E-08
NE	0.	1.0E-06	1.5E-07	1.1E-07	9.0E-08	6.7E-08	5.2E-08	7.8E-08	3.8E-08	5.4E-08	3.4E-08
ENE	0.	8.6E-07	2.6E-07	1.9E-07	1.7E-07	1.2E-07	1.1E-07	7.4E-08	6.2E-08	4.8E-08	4.2E-08
E	0.	7.2E-07	2.6E-07	2.2E-07	2.0E-07	2.1E-07	1.2E-07	9.4E-08	7.0E-08	4.7E-08	3.6E-08
ESE	0.	7.8E-07	1.9E-07	1.7E-07	1.3E-07	1.0E-07	7.6E-08	6.6E-08	4.9E-08	3.8E-08	2.9E-08
SE	0.	5.9E-07	1.0E-07	7.5E-08	5.1E-08	3.8E-08	2.4E-08	1.9E-08	1.2E-08	1.2E-08	1.1E-08
SSE	0.	1.0E-06	1.8E-07	1.2E-07	8.0E-08	5.4E-08	3.6E-08	2.6E-08	2.3E-08	1.9E-08	1.8E-08
S	0.	5.0E-07	9.4E-08	7.0E-08	5.9E-08	3.5E-08	3.2E-08	2.9E-08	2.5E-08	2.2E-08	1.9E-08
SSW	0.	6.3E-07	2.7E-07	2.4E-07	1.5E-07	1.2E-07	8.4E-08	6.3E-08	4.7E-08	3.6E-08	3.1E-08
SW	0.	3.5E-07	9.9E-08	8.8E-08	6.1E-08	4.6E-08	3.7E-08	3.2E-08	2.3E-08	2.0E-08	1.7E-08
WSW	0.	3.0E-07	6.5E-08	6.2E-08	5.4E-08	5.4E-08	4.1E-08	3.0E-08	2.7E-08	2.4E-08	1.9E-08
W	0.	2.4E-07	6.2E-08	6.0E-08	4.9E-08	4.9E-08	3.5E-08	3.0E-08	2.0E-08	1.5E-08	1.2E-08
WNW	0.	2.8E-07	8.4E-08	8.6E-08	6.8E-08	6.3E-08	5.2E-08	4.2E-08	3.6E-08	3.6E-08	3.4E-08
NW	0.	3.8E-07	1.2E-07	1.5E-07	1.2E-07	9.2E-08	6.5E-08	4.7E-08	4.1E-08	3.5E-08	2.9E-08
NNW	0.	4.2E-07	1.8E-07	1.4E-07	1.6E-07	1.4E-07	9.2E-08	5.4E-08	3.7E-08	2.5E-08	2.1E-08
N	0.	7.8E-07	1.7E-07	1.3E-07	9.5E-08	7.2E-08	5.9E-08	4.5E-08	3.8E-08	3.3E-08	2.9E-08

Number of Valid Observations = 8703  
 Number of Invalid Observations = 57  
 Number of Calms Lower Level = 60  
 Number of Calms Upper Limit = 5



TABLE A-14

Depleted X/Q Values for Long-Term Mixed Mode Releases at Standard Distances (sec/m<sup>3</sup>)

Carolina Power & Light Company - Robinson

Release Type: Annual

Release Mode: Mixed Mode

Variable: Relative Depleted Concentration (Sec./Cubic Meter)

Calculation Points: Standard

Model: Straight Line (ANNXOQ9)

Application of Terrain Correction Factors: Yes

Number of Observations: 8703

BASE DISTANCE IN MILES/KILOMETERS

Aftd Sect	Design Dist MI	BASE DISTANCE IN MILES/KILOMETERS									
		.25 .40	.75 1.21	1.25 2.01	1.75 2.82	2.25 3.62	2.75 4.42	3.25 5.23	3.75 6.03	4.25 6.84	4.75 7.64
NNE	0.	1.5E-06	3.7E-07	3.1E-07	2.5E-07	2.2E-07	1.8E-07	1.5E-07	1.3E-07	8.9E-08	6.1E-08
NE	0.	9.8E-07	1.4E-07	1.1E-07	8.5E-08	6.4E-08	4.9E-08	7.8E-08	3.6E-08	5.2E-08	3.1E-08
ENE	0.	8.3E-07	2.5E-07	1.8E-07	1.6E-07	1.2E-07	1.0E-07	6.9E-08	5.7E-08	4.5E-08	4.0E-08
E	0.	7.0E-07	2.4E-07	2.0E-07	1.9E-07	2.1E-07	1.1E-07	9.4E-08	6.6E-08	4.5E-08	3.4E-08
ESE	0.	7.3E-07	1.8E-07	1.6E-07	1.2E-07	9.6E-08	7.2E-08	6.1E-08	4.6E-08	3.6E-08	2.7E-08
SE	0.	5.7E-07	9.6E-08	6.9E-08	4.7E-08	3.6E-08	2.3E-08	1.8E-08	1.2E-08	1.0E-08	9.9E-09
SSE	0.	9.6E-07	1.7E-07	1.1E-07	7.4E-08	4.9E-08	3.3E-08	2.4E-08	2.1E-08	1.7E-08	1.6E-08
S	0.	4.8E-07	8.9E-08	6.7E-08	5.8E-08	3.8E-08	3.1E-08	2.7E-08	2.4E-08	2.1E-08	1.8E-08
SSW	0.	6.1E-07	2.5E-07	2.4E-07	1.5E-07	1.1E-07	8.0E-08	6.0E-08	4.5E-08	3.4E-08	2.9E-08
SW	0.	3.4E-07	9.5E-08	8.5E-08	5.8E-08	4.4E-08	3.6E-08	3.1E-08	2.2E-08	1.9E-08	1.6E-08
WSW	0.	2.9E-07	6.3E-08	6.1E-08	5.2E-08	5.2E-08	4.0E-08	2.9E-08	2.6E-08	2.2E-08	1.8E-08
W	0.	2.4E-07	6.0E-08	5.9E-08	4.8E-08	4.7E-08	3.4E-08	2.9E-08	1.9E-08	1.4E-08	1.2E-08
WNW	0.	2.6E-07	8.3E-08	8.4E-08	6.6E-08	6.2E-08	5.0E-08	4.0E-08	3.4E-08	3.4E-08	3.2E-08
NW	0.	3.8E-07	1.1E-07	1.5E-07	1.1E-07	9.0E-08	6.3E-08	4.5E-08	3.9E-08	3.0E-08	2.4E-08
NNW	0.	4.1E-07	1.2E-07	1.4E-07	1.6E-07	1.4E-07	8.8E-08	5.2E-08	3.5E-08	2.4E-08	2.0E-08
N	0.	7.5E-07	1.5E-07	1.2E-07	8.8E-08	6.9E-08	5.7E-08	4.3E-08	3.6E-08	3.1E-08	2.7E-08

Number of Valid Observations	=	8703
Number of Invalid Observations	=	57
Number of Calms Lower Level	=	60
Number of Calms Upper Limit	=	5

TABLE A-15

D/Q Values for Long-Term Mixed Mode Releases at Standard Distances (m<sup>-2</sup>)

Carolina Power & Light Company - Robinson  
 Release Type: Annual  
 Release Mode: Mixed Mode  
 Variable: Relative Deposition Rate (Meter<sup>-2</sup>)  
 Calculation Points: Standard  
 Model: Straight Line (ANNXOQ9)  
 Application of Terrain Correction Factors: Yes  
 Number of Observations: 8703

BASE DISTANCE IN MILES/KILOMETERS

Aftd	Design	.25	.75	1.25	1.75	2.25	2.75	3.25	3.75	4.25	4.75
Dist	MI	.40	1.21	2.01	2.82	3.62	4.42	5.23	6.03	6.84	7.64
NNE	0.	1.6E-08	5.0E-09	2.1E-09	1.2E-09	7.5E-10	5.2E-10	3.4E-10	2.7E-10	2.0E-10	1.4E-10
NE	0.	1.1E-08	2.6E-09	1.2E-09	6.2E-10	3.5E-10	2.3E-10	1.8E-10	1.2E-10	1.2E-10	1.0E-10
ENE	0.	1.1E-08	3.8E-09	1.4E-09	7.6E-10	3.7E-10	2.7E-10	1.8E-10	1.4E-10	1.2E-10	1.1E-10
E	0.	1.1E-08	3.7E-09	1.4E-09	7.2E-10	5.0E-10	2.6E-10	2.1E-10	1.4E-10	1.0E-10	7.8E-11
ESE	0.	8.6E-09	2.7E-09	1.2E-09	6.7E-10	4.3E-10	2.8E-10	2.1E-10	1.5E-10	1.0E-10	7.3E-11
SE	0.	7.0E-09	1.9E-09	9.5E-10	4.7E-10	2.8E-10	1.5E-10	1.1E-10	5.9E-11	5.0E-11	4.2E-11
SSE	0.	6.2E-09	1.8E-09	8.6E-10	4.6E-10	2.6E-10	1.5E-10	9.5E-11	7.7E-11	5.9E-11	5.0E-11
S	0.	7.1E-09	1.8E-09	7.6E-10	4.2E-10	1.8E-10	1.3E-10	9.9E-11	7.3E-11	6.1E-11	4.8E-11
SSW	0.	1.0E-08	5.0E-09	2.6E-09	1.1E-09	6.1E-10	3.9E-10	2.6E-10	1.8E-10	1.3E-10	1.0E-10
SW	0.	5.0E-09	2.0E-09	9.8E-10	4.7E-10	2.9E-10	1.9E-10	1.5E-10	9.8E-11	7.6E-11	6.4E-11
WSW	0.	4.9E-09	1.9E-09	8.4E-10	4.8E-10	3.7E-10	2.3E-10	1.5E-10	1.2E-10	1.0E-10	7.1E-11
W	0.	4.0E-09	1.4E-09	6.3E-10	3.4E-10	2.6E-10	1.6E-10	1.3E-10	7.9E-11	5.4E-11	4.1E-11
WNW	0.	4.6E-09	1.5E-09	7.1E-10	4.2E-10	3.2E-10	2.2E-10	1.6E-10	1.2E-10	9.9E-11	7.4E-11
NW	0.	5.6E-09	2.2E-09	1.1E-09	6.4E-10	3.6E-10	1.9E-10	1.2E-10	1.0E-10	1.1E-10	9.6E-11
NNW	0.	4.5E-09	1.9E-09	1.1E-09	8.1E-10	5.2E-10	2.7E-10	1.4E-10	8.8E-11	5.7E-11	4.5E-11
N	0.	5.9E-09	1.8E-09	8.2E-10	4.0E-10	2.4E-10	1.6E-10	1.0E-10	7.4E-11	5.8E-11	4.7E-11

Number of Valid Observations = 8703  
 Number of Invalid Observations = 57  
 Number of Calms Lower Level = 60  
 Number of Calms Upper Limit = 5

TABLE A-16

X/Q Values for Short-Term Mixed Mode Releases at Special Locations (sec/m<sup>3</sup>)<sup>a</sup>

Carolina Power & Light Company - Robinson  
 Release Type: Purge  
 Release Mode: Mixed Mode  
 Variable: Relative Concentration (Sec./Cubic Meter)  
 Calculation Points: Special  
 Model: Purge (ACNPURG2)  
 Application of Terrain Correction Factors: No  
 Number of Observations: 8703  
 Purge Time: 100 Hours

Affected Sector	Site Boundary	Meat	Dairy	Resident	Garden
NNE	8.40E-07	7.00E-07	0.00	8.30E-07	7.90E-07
NE	5.40E-07	5.30E-07	4.70E-07	5.20E-07	4.70E-07
ENE	8.90E-07	4.20E-07	0.00	8.80E-07	3.10E-07
E	1.00E-06	4.00E-07	2.50E-07	9.20E-07	4.50E-07
ESE	1.24E-06	4.70E-07	0.00	1.00E-06	1.00E-06
SE	2.20E-06	0.00	0.00	2.10E-06	2.10E-06
SSE	2.90E-06	0.00	0.00	2.40E-06	2.40E-06
S	1.90E-06	2.00E-07	0.00	1.70E-06	1.20E-06
SSW	2.00E-06	4.00E-07	0.00	2.00E-06	1.10E-06
SW	1.10E-06	2.40E-07	2.10E-07**	9.50E-07	7.70E-07
WSW	1.20E-06	2.20E-07	0.00	9.90E-07	6.30E-07
W	7.40E-07	1.30E-07	0.00	5.90E-07	5.90E-07
WNW	7.90E-07	2.20E-07	0.00	6.80E-07	6.20E-07
NW	6.30E-07	5.10E-07	0.00	6.20E-07	6.20E-07
NNW	5.10E-07	3.20E-07	0.00	3.10E-07	2.90E-07
N	3.50E-07	2.30E-07	0.00	2.40E-07	2.40E-07

\* Zeroes indicate that this point was not calculated

\*\* A milk goat is located here

TABLE A-17

Depleted X/Q Values for Short-Term Mixed Mode Releases at Special Locations (sec/m<sup>3</sup>)<sup>\*</sup>

Carolina Power & Light Company - Robinson

Release Type: Purge

Release Mode: Mixed Mode

Variable: Relative Depleted Concentration (Sec./Cubic Meter)

Calculation Points: Special

Model: Purge (ACNPURG2)

Application of Terrain Correction Factors: No

Number of Observations: 8703

Purge Time: 100 Hours

Affected Sector	Site Boundary	Meat	Dairy	Resident	Garden
NNE	8.40E-07	7.00E-07	0.00	8.30E-07	7.41E-07
NE	4.95E-07	4.86E-07	4.70E-07	4.77E-07	4.70E-07
ENE	8.40E-07	4.20E-07	0.00	8.31E-07	2.96E-07
E	1.00E-06	4.00E-07	2.03E-07	9.20E-07	4.15E-07
ESE	1.11E-06	4.44E-07	0.00	9.00E-07	9.00E-07
SE	2.11E-06	0.00	0.00	2.01E-06	2.01E-06
SSE	2.72E-07	0.00	0.00	2.27E-06	2.27E-06
S	1.82E-06	1.90E-07	0.00	1.63E-06	1.12E-06
SSW	1.93E-06	4.00E-07	0.00	1.93E-06	1.03E-06
SW	1.10E-06	2.29E-07	2.35E-07**	9.50E-07	7.36E-07
WSW	1.20E-06	2.12E-07	0.00	9.90E-07	6.11E-07
W	7.19E-07	1.26E-07	0.00	5.71E-07	5.71E-07
WNW	7.65E-07	2.09E-07	0.00	6.59E-07	6.04E-07
NW	6.24E-07	4.99E-07	0.00	6.20E-07	6.20E-07
NNW	4.90E-07	3.05E-07	0.00	3.00E-07	2.76E-07
N	3.35E-07	2.20E-07	0.00	2.30E-07	2.30E-07

\* Zeroes indicate that this point was not calculated

\*\* A milk goat is located here



TABLE A-19  
 Robinson Plant Site Information To Be Used  
 for Ground Level Calculations with NRC "XOQDOQ" Program

<u>CARD TYPE</u>	<u>COLUMNS</u>	<u>DESCRIPTION</u>	<u>VALUE TO BE USED IN XOQDOQ</u>
1	1	Print input data	1
	38	Calculate annual X/Qs for points of interest	1
	39	Calculate annual X/Q averages for site radial segments	1
	41	Print out set distance X/Qs and D/Qs	1
	55	Calculate annual D/Q averages for the set radial segments	1
	56	Allow depleted X/Qs (if Decays (1), (2), or (3) are negative)	1
	58	Calculate annual D/Qs for points of interest	1
2	1-80	Title card	N/A
3	1-5	Number of wind velocity categories	7
	6-10	Number of stability categories	7
	11-15	Number of distances within terrain data for each sector	5
	16-20	Total number of hours in joint wind frequency distribution	(1)
	21-25	Increment in % for which plotted results are to be printed	5
	26-30	Number of titles of receptor types	5
	31-35	Number of release exit locations	3
4	1-5	Height of the measured wind (meters)	11
	6-20	Half-life (days) used in the X/Q calculations	101.00
			226
			-8.00
5	N/A	N/A	---
6	1-80	Joint wind frequency distribution	(1)



TABLE A-19 (Continued)

<u>CARD TYPE</u>	<u>COLUMNS</u>	<u>DESCRIPTION</u>	<u>VALUE TO BE USED IN XQDDQ</u>
7	1-5 6-75	Wind velocity units correction Maximum wind speed in each wind class (m/sec)	200.00 0.75 3.5b 7.50 12.50 18.50 25.00 26.00
8	1-80	Distance in meters at which terrain heights are given	(2)
9	1-80	Terrain heights (in meters, above plant grade) correspond to distance in Card Type 8	(2)
10	1-25	Number of receptor locations for a particular receptor type	Site boundary - 16 Dairy - 1 Meat - 14 Residence - 16 Garden - 16
11	1-16	Title of receptor type for receptor locations	Site Boundary Dairy Meat Residence Garden
12	1-80	Receptor direction and distance	(See Table 1)
13	1-80	Title for release point whose characteristics are described on Card Type 14	(1)

TABLE A-19 (Continued)

<u>CARD TYPE</u>	<u>COLUMNS</u>	<u>DESCRIPTION</u>	<u>VALUE TO BE USED IN XQQDCQ</u>
14	1-5	Vent average velocity (m/sec)	20.1
	6-10	Vent inside diameter (m)	1.0
	11-15	Height of vent release point (m)	0.000
	16-20	Height of the vent's building (m)	59.0
	21-25	Minimum cross-sectional area for the vent's building (m <sup>2</sup> )	1370.0
	26-30	Wind height used for vent elevated release	11.0
	31-35	Vent heat emission rate (cal/sec)	0.0
15	1	Identification for release point	A
	2-5	Intermittent releases	1
	6-10	Number of intermittent releases per year for this release point	100
	11-15	Average number of hours per intermittent release	1

(1) Appropriate data to be supplied

(2) Obtained from cross-sectional topographic maps

TABLE A-20

Robinson Plant Site Information To Be Used  
for Mixed Mode Release Calculations with NRC "XOQDOQ" Program

<u>CARD TYPE</u>	<u>COLUMNS</u>	<u>DESCRIPTION</u>	<u>VALUE TO BE USED IN XOQDOQ</u>
1	1	Print input data	1
	38	Calculate annual X/Qs for points of interest	1
	39	Calculate annual X/Q averages for site radial segments	1
	41	Print out set distance X/Qs and D/Qs	1
	55	Calculate annual D/Q averages for the set radial segments	1
	56	Allow depleted X/Qs (if Decays (1), (2), or (3) are negative)	1
	58	Calculate annual D/Qs for points of interest	1
2	1-80	Title card	N/A
3	1-5	Number of wind velocity categories	7
	6-10	Number of stability categories	7
	11-15	Number of distances within terrain data for each sector	5
	16-20	Total number of hours in joint wind frequency distribution	(1)
	21-25	Increment in % for which plotted results are to be printed	5
	26-30	Number of titles of receptor types	5
	31-35	Number of release exit locations	3
4	1-5	Height of the measured wind (meters)	11
	6-20	Half-life (days) used in the X/Q calculations	101.00
			226
		-8.00	
5	N/A	N/A	---
6	1-80	Joint wind frequency distribution	(1)

TABLE A-20 (continued)

<u>CARD TYPE</u>	<u>COLUMNS</u>	<u>DESCRIPTION</u>	<u>VALUE TO BE USED IN X0QDOQ</u>
7	1-5 6-75	Wind velocity units correction Maximum wind speed in each wind class (m/sec)	200.00 0.75 3.50 7.50 12.50 18.50 25.00 26.00
8	1-80	Distance in meters at which terrain heights are given	(2)
9	1-80	Terrain heights (in meters, above plant grade) corresponding to distances in Card Type 8	(2)
10	1-25	Number of receptor locations for a particular receptor type	Site boundary - 16 Dairy - 1 Meat - 14 Residence - 16 Garden - 16
11	1-16	Title of receptor type for receptor locations	Site Boundary Dairy Meat Residence Garden
12	1-80	Receptor direction and distance	(See Table 1)
13	1-80	Title for release point whose characteristics are described on Card Type 14	(1)

TABLE A-20 (continued)

<u>CARD TYPE</u>	<u>COLUMNS</u>	<u>DESCRIPTION</u>	<u>VALUE TO BE USED</u> <u>IN X0QD00</u>
14	1-5	Vent average velocity (m/sec)	20.1
	6-10	Vent inside diameter (m)	1.0
	11-15	Height of vent release point (m)	60.7
	16-20	Height of the vent's building (m)	59.0
	21-25	Minimum cross-sectional area for the vent's building (m <sup>2</sup> )	1370.0
	26-30	Wind height used for vent elevated release	11.
	31-35	Vent heat emission rate (cal/sec)	0.
15	1	Identification for release point	A
	2-5	Intermittent releases	1
	6-10	Number of intermittent releases per year for this release point	100
	11-15	Average number of hours per intermittent release	1

- (1) Appropriate data to be supplied
- (2) Obtained from cross-sectional topographic maps



where:

- $P_{iI}$  - Dose parameter for radionuclide "i" for the inhalation pathway, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ ;
- $K'$  - A constant of unit conversion;  
-  $10^6$  pCi/ $\mu\text{Ci}$ ;
- BR - The breathing rate of the infant age group,  $\text{m}^3/\text{yr}$ ;
- $\text{DFA}_1$  - The maximum organ inhalation dose factor for the infant age group for radionuclide "i," mrem/pCi.

The age group considered is the infant group. The infant's breathing rate is taken as  $1400 \text{ m}^3/\text{yr}$  from Table E-5 of Regulatory Guide 1.109, Revision 1. The inhalation dose factors for the infant,  $\text{DFA}_1$ , are presented in Table E-10 of Regulatory Guide 1.109 in units of mrem/pCi. The total body is considered as an organ in the selection of  $\text{DFA}_1$ .

The incorporation of breathing rate of an infant and the unit conversion factor results in the following equation:

$$P_{iI} = 1.4 \times 10^9 \text{DFA}_1 \quad (\text{B.1-2})$$

#### B.1.2 Ground Plane Pathway

The dose factor from ground plane pathway is calculated by:

$$P_{iG} = K'K''\text{DFG}_i \frac{(1 - e^{-\lambda_i t})}{\lambda_i} \quad (\text{B.1-3})$$

where:

- $P_{iG}$  - Dose parameter for radionuclide "i" for the ground plane pathway, mrem/yr per  $\mu\text{Ci}/\text{sec}$  per  $\text{m}^{-2}$ ;
- $K'$  - A constant of unit conversion;  
-  $10^6$  pCi/ $\mu\text{Ci}$ ;

TABLE A-20 (continued)

<u>CARD TYPE</u>	<u>COLUMNS</u>	<u>DESCRIPTION</u>	<u>VALUE TO BE USED</u> <u>IN XQQDQ</u>
14	1-5	Vent average velocity (m/sec)	20.1
	6-10	Vent inside diameter (m)	1.0
	11-15	Height of vent release point (m)	60.7
	16-20	Height of the vent's building (m)	59.0
	21-25	Minimum cross-sectional area for the vent's building (m <sup>2</sup> )	1370.0
	26-30	Wind height used for vent elevated release	11.
	31-35	Vent heat emission rate (cal/sec)	0.
15	1	Identification for release point	A
	2-5	Intermittent releases	1
	6-10	Number of intermittent releases per year for this release point	100
	11-15	Average number of hours per intermittent release	1

- (1) Appropriate data to be supplied
- (2) Obtained from cross-sectional topographic maps

where:

- $P_{i1}$  - Dose parameter for radionuclide "i" for the inhalation pathway, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ ;
- $K'$  - A constant of unit conversion;  
-  $10^6$  pCi/ $\mu\text{Ci}$ ;
- BR - The breathing rate of the infant age group,  $\text{m}^3/\text{yr}$ ;
- $\text{DFA}_1$  - The maximum organ inhalation dose factor for the infant age group for radionuclide "i," mrem/pCi.

The age group considered is the infant group. The infant's breathing rate is taken as 1400  $\text{m}^3/\text{yr}$  from Table E-5 of Regulatory Guide 1.109, Revision 1. The inhalation dose factors for the infant,  $\text{DFA}_1$ , are presented in Table E-10 of Regulatory Guide 1.109 in units of mrem/pCi. The total body is considered as an organ in the selection of  $\text{DFA}_1$ .

The incorporation of breathing rate of an infant and the unit conversion factor results in the following equation:

$$P_{i1} = 1.4 \times 10^9 \text{DFA}_1 \quad (\text{B.1-2})$$

#### B.1.2 Ground Plane Pathway

The dose factor from ground plane pathway is calculated by:

$$P_{iG} = K' K'' \text{DFG}_i \frac{(1 - e^{-\lambda_i t})}{\lambda_i} \quad (\text{B.1-3})$$

where:

- $P_{iG}$  - Dose parameter for radionuclide "i" for the ground plane pathway, mrem/yr per  $\mu\text{Ci}/\text{sec}$  per  $\text{m}^{-2}$ ;
- $K'$  - A constant of unit conversion;  
-  $10^6$  pCi/ $\mu\text{Ci}$ ;

- $K''$  - A constant of unit conversion;  
- 8760 hr/yr;
- $\lambda_i$  - The radiological decay constant for radionuclide "i,"  $\text{sec}^{-1}$ ;
- $t$  - The exposure period;  
-  $3.15 \times 10^7$  sec (1 year);
- $DFG_i$  - The ground plane dose conversion factor for radionuclide "i,"  
mrem/hr per pCi/m<sup>2</sup>.

The deposition rate onto the ground plane results in a ground plane concentration that is assumed to persist over a year with radiological decay--the only operating removal mechanism for each radionuclide. The ground plane dose conversion factors for radionuclide "i,"  $DFG_i$ , are presented in Table E-6 of Regulatory Guide 1.109, Revision 1.

Resolution of the units yields:

$$P_{i_g} = 8.76 \times 10^9 DFG_i \frac{(1 - e^{-\lambda_i t})}{\lambda_i} \quad (B.1-4)$$

### B.1.3 Milk

The dose factor from the cow/goat-milk-man pathway is calculated by:

$$P_{i_m} = \frac{K' I Q_f (U_{sp}) F_m}{Y_p (\lambda_i + \lambda_w)} DFL_i e^{-\lambda_i t_f} \quad (B.1-5)$$

where:

- $P_{i_m}$  - Dose parameter for radionuclide "i" for the cow milk or goat milk pathway, mrem/yr per  $\mu\text{Ci}/\text{sec}$  per  $\text{m}^{-2}$ ;
- $K'$  - A constant of unit conversion;  
-  $10^6$  pCi/ $\mu\text{Ci}$ ;
- $Q_f$  - The cow's or goat's consumption rate of feed, kg/day (wet weight);

- $U_{ap}$  - The infant's milk consumption rate, liters/yr;
- $Y_p$  - The agricultural productivity by unit area, kg/m<sup>2</sup>;
- $F_m$  - The stable element transfer coefficient, pCi/liter per pCi/day;
- $r$  - Fraction of deposited activity retained on cow's or goat's feed grass;
- $DFL_1$  - The maximum organ ingestion dose factor for radionuclide "i," mrem/pCi;
- $\lambda_1$  - The radiological decay constant for radionuclide "i," sec<sup>-1</sup>;
- $\lambda_w$  - The decay constant for removal of activity on leaf and plant surfaces by weathering, sec<sup>-1</sup>;  
-  $5.73 \times 10^{-7}$  sec<sup>-1</sup> (corresponding to a 14-day half-life);
- $t_t$  - The transport time from pasture cow or goat to milk to infant, sec.

A fraction of the airborne deposition is captured by the ground plane vegetation cover. The captured material is removed from the vegetation (grass) by both radiological decay and weathering processes.

Various parameters which were utilized to determine the  $P_1$  values for the cow and goat milk pathways are provided in Table B-1. Table E-1 of Regulatory Guide 1.109, Revision 1, provides the stable element transfer coefficients,  $F_m$ ; and Table E-14 of the same regulatory guide provides the ingestion dose factors,  $DFL_1$ , for the infant's organs. The organ with the maximum value of  $DFL_1$  was used in the determination of  $P_1$  for this pathway. The incorporation of the various constants of Table B-1 into Equation B.1-5 results in the following:



For radioiodines and particulates from cow's milk:

$$P_{i_w} = 2.4 \times 10^{10} \frac{I F_m}{\lambda_i + \lambda_w} DFL_{i_1} e^{-\lambda_i t_i} \quad (B.1-6)$$

For radioiodines and particulates from goat's milk pathway:

$$P_{i_w} = 2.8 \times 10^9 \frac{I F_m}{\lambda_i + \lambda_w} DFL_{i_1} e^{-\lambda_i t_i} \quad (B.1-7)$$

The concentration of tritium in milk is based on its airborne concentration rather than the deposition rate and is calculated by:

$$P_{T_m} = K' K''' F_m Q_F U_{sp} DFL_T 0.75 (0.5/H) \quad (B.1-8)$$

where:

- $P_{T_m}$  - Dose parameter for tritium for the cow milk and goat milk pathways, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ ;
- $K''''$  - A constant of unit conversion;  
-  $10^3 \text{ gm}/\text{kg}$ ;
- $H$  - Absolute humidity of the atmosphere,  $\text{gm}/\text{m}^3$ ;
- 0.75 - The fraction of total feed that is water;
- 0.5 - The ratio of the specific activity of the feed grass water to the atmospheric water;
- $DFL_T$  - Maximum organ ingestion dose factor for tritium, mrem/pCi.

<u>Age Group (a)</u>	<u>Breathing Rate (m<sup>3</sup>/yr)</u>
Infant	1400
Child	3700
Teen	8000
Adult	8000

Inhalation dose factors (DFA<sub>1</sub>)<sub>o</sub> for the various age groups are given in Tables E-7 through E-10 of Regulatory Guide 1.109, Revision 1.

### B.2.2 Ground Plane Pathway

The ground plane pathway dose factor is calculated by:

$$R_{ig} = I_i K' K'' (SF) DFG_i \frac{(1 - e^{-\lambda_i t})}{\lambda_i} \quad (B.2-2)$$

where:

- R<sub>ig</sub> - Dose factor for the ground plane pathway for each identified radionuclide "i" for the organ of interest, mrem/hr per μCi/sec per m<sup>-2</sup>;
- K' - A constant of unit conversion;  
- 10<sup>6</sup> pCi/μCi;
- K'' - A constant of unit conversion;  
- 8760 hr/year;
- λ<sub>i</sub> - The radiological decay constant for radionuclide "i," sec<sup>-1</sup>;
- t - The exposure time, sec;  
- 4.73 x 10<sup>8</sup> sec (15 years);
- DFG<sub>i</sub> - The ground plane dose conversion factor for radionuclide "i;"  
mrem/hr per pCi/m<sup>2</sup>;

A tabulation of  $DFG_i$  values is presented in Table E-6 of Regulatory Guide 1.109, Revision 1.

SF = The shielding factor (dimensionless);

A shielding factor of 0.7 is suggested in Table E-15 of Regulatory Guide 1.109, Revision 1.

$I_i$  = Factor to account for fractional deposition of radionuclide "i."

For radionuclides other than iodine, the factor  $I_i$  is equal to one. For radioiodines, the value of  $I_i$  may vary. However, a value of 1.0 was used in calculating the R values in Table 3.5-2.

### B.2.3 Grass Cow or Goat Milk Pathway

The dose factor for the cow milk or goat milk pathway for each radionuclide for each organ is calculated by:

$$R_{iM} = I_i K' Q_f U_{sp} F_m (DFL_i) e^{-\lambda_i t_r} \left[ f_p f_m \left[ \frac{r(1-e^{-\lambda_{s_i} t_s})}{Y_p \lambda_{s_i}} + \frac{B_{iv} (1-e^{-\lambda_i t_s})}{P \lambda_i} \right] + \right.$$

$$\left. (1-f_p f_m) \left[ \frac{r(1-e^{-\lambda_{s_i} t_s})}{Y_s \lambda_{s_i}} + \frac{B_{iv} (1-e^{-\lambda_i t_s})}{P \lambda_i} \right] e^{-\lambda_i t_b} \right] \quad (B.2-3)$$

where:

$R_{iM}$  = Dose factor for the cow milk or goat milk pathway, for each identified radionuclide "i" for the organ of interest, mrem/yr per  $\mu\text{Ci}/\text{sec}$  per  $\text{m}^{-2}$ ;

- $K'$  - A constant of unit conversion;  
-  $10^6$  pCi/ $\mu$ Ci;
- $Q_F$  - The cow's or goat's feed consumption rate, kg/day (wet weight);
- $U_{ap}$  - The receptor's milk consumption rate for age group a, liters/yr;
- $Y_p$  - The agricultural productivity by unit area of pasture feed grass, kg/ $m^2$ ; -
- $Y_s$  - The agricultural productivity by unit area of stored feed, -kg/ $m^2$ ;
- $F_m$  - The stable element transfer coefficients, pCi/liter per pCi/day;
- $r$  - Fraction of deposited activity retained on cow's feed grass;
- $(DFL_1)_a$  - The organ ingestion dose for radionuclide "i" for the receptor in age group a, mrem/pCi;
- $\lambda_{E_1}$  -  $\lambda_i + \lambda_w$ ;
- $\lambda_i$  - The radiological decay constant for radionuclide "i,"  $sec^{-1}$ ;
- $\lambda_w$  - The decay constant for removal of activity on leaf and plant surfaces by weathering,  $sec^{-1}$ ;  
-  $5.73 \times 10^{-7} sec^{-1}$  (corresponding to a 14 day half-life);
- $\tau_f$  - The transport time from feed to cow, or goat to milk, to receptor, sec;

- $t_h$  - The transport time for harvest, to cow or goat, to consumption, sec;
- $t_b$  - Period of time that sediment is exposed to gaseous effluents, sec;
- $B_{iv}$  - Concentration factor for uptake of radionuclide "i" from the soil by the edible parts of crops, pCi/Kg (wet weight) per pCi/Kg (dry soil); -
- $p$  - Effective surface density for soil, Kg (dry soil)/m<sup>2</sup>;
- $f_p$  - Fraction of the year that the cow or goat is on pasture;
- $f_s$  - Fraction of the cow feed that is pasture grass while the cow is on pasture;
- $t_e$  - Period of pasture grass and crop exposure during the growing season, sec;
- $I_1$  - Factor to account for fractional deposition of radionuclide "i."

For radionuclides other than iodine, the factor  $I_1$  is equal to one. For radiiodines, the value of  $I_1$  may vary. However, a value of 1.0 was used in calculating the R values in Tables 3.5-9 through 3.5-16.

Milk cattle and goats are considered to be fed from two potential sources, pasture grass and stored feeds. Following the development in Regulatory Guide 1.109, Revision 1, the value of  $f_s$  was considered unity in lieu of site-specific information. The value of  $f_p$  was 0.667 based upon an 8-month grazing period.

Table B-1 contains the appropriate parameter values and their source in Regulatory Guide 1.109, Revision 1.



- $t_h$  - The average time between harvest of stored vegetation and its consumption, sec;
- $\gamma_v$  - The vegetation areal density, kg/m<sup>2</sup>;
- $t_e$  - Period of leafy vegetable exposure during growing season, sec;
- $I_1$  - Factor to account for fractional deposition of radionuclide "i."

All other factors as defined before.

For radionuclides other than iodine, the factor  $I_1$  is equal to one. For radioiodines, the value of  $I_1$  may vary. However, a value of 1.0 was used in Tables 3.5-3 through 3.5-5.

Table B-3 presents the appropriate parameter values and their source in Regulatory Guide 1.109, Revision 1.

In lieu of site-specific data default values for  $f_L$  and  $f_g$ , 1.0 and 0.76, respectively, were used in the calculations on  $R_1$ . These values were obtained from Table E-15 of Regulatory Guide 1.109, Revision 1.

The concentration of tritium in vegetation is based on the airborne concentration rather than the deposition. Therefore, the  $R_1$  is based on  $X/Q$ :

$$R_{T_v} = K'K''' [U_s^L f_L + U_s^g f_g] (DFL_1)_a 0.75 (0.5/H) \quad (B.2-8)$$

where:

- $R_{T_v}$  - Dose factor for the vegetable pathway for tritium for any organ of interest, mrem/yr per  $\mu\text{Ci}/\text{m}^3$ .

All other terms remain the same as those in Equations B.2-4 and B.2-7.

TABLE B-1

Parameters For Cow and Goat Milk Pathways

<u>Parameter</u>	<u>Value</u>	<u>Reference</u> <u>(Reg. Guide 1.109, Rev. 1)</u>
$Q_r$ (kg/day)	50 (cow) 6 (goat)	Table E-3 Table E-3
$Y_p$ (kg/m <sup>2</sup> )	0.7	Table E-15
$T_f$ (seconds)	$1.73 \times 10^5$ (2 days)	Table E-15
$r$	1.0 (radioiodines) 0.2 (particulates)	Table E-15 Table E-15
$(DFL_i)_a$ (mrem/pCi)	Each radionuclide	Tables E-11 to E-14
$F_m$ (pCi/day per pCi/liter)	Each stable element	Table E-1 (cow) Table E-2 (goat)
$T_b$ (seconds)	$4.73 \times 10^6$ (15 yr)	Table E-15
$Y_a$ (kg/m <sup>2</sup> )	2.0	Table E-15
$Y_p$ (kg/m <sup>2</sup> )	0.7	Table E-15
$t_h$ (seconds)	$7.78 \times 10^6$ (90 days)	Table E-15
$U_{ap}$ (liters/yr)	330 infant 330 child 400 teen 310 adult	Table E-5 Table E-5 Table E-5 Table E-5
$t_s$ (seconds)	$2.59 \times 10^6$ (pasture) $5.18 \times 10^6$ (stored feed)	Table E-15
$B_{iv}$ (pCi/kg [wet weight] per pCi/kg [dry soil])	Each stable element	Table E-1
$P$ kg (dry soil/m <sup>2</sup> )	240	Table E-15

TABLE B-2

Parameters For The Meat Pathway

<u>Parameter</u>	<u>Value</u>	<u>Reference</u> <u>(Reg. Guide 1.109, Rev. 1)</u>
r	1.0 (radioiodines)	Table E-15
	0.2 (particulates)	Table E-15
$F_f$ (pCi/kg per pCi/day)	Each stable element	Table E-1
$U_{ap}$ (kg/yr)	0 infant	Table E-5
	41 child	Table E-5
	65 teen	Table E-5
	110 adult	Table E-5
$(DFL_1)_a$ (mrem/pCi)	Each radionuclide	Tables E-11 to E-14
$Y_p$ (kg/m <sup>2</sup> )	0.7	Table E-15
$Y_s$ (kg/m <sup>2</sup> )	2.0	Table E-15
$T_b$ (seconds)	$4.73 \times 10^6$ (15 yr)	Table E-15
$T_s$ (seconds)	$1.73 \times 10^6$ (20 days)	Table E-15
$t_h$ (seconds)	$7.78 \times 10^6$ (90 days)	Table E-15
$t_e$ (seconds)	$2.59 \times 10^6$ (pasture)	Table E-15
	$5.18 \times 10^6$ (stored feed)	
$Q_f$ (kg/day)	50	Table E-3
$B_{iv}$ (pCi/kg [wet weight] per pCi/kg [dry soil])	Each stable element	Table E-1
P (kg [dry soil/m <sup>2</sup> ])	240	Table E-15

TABLE B-3

Parameters for The Vegetable Pathway

<u>Parameter</u>	<u>Value</u>	<u>Reference</u> <u>(Reg. Guide 1.109, Rev. 1)</u>
r (dimensionless)	1.0 (radioiodines) 0.2 (particulates)	Table E-1 Table E-1
(DFL <sub>1</sub> ) <sub>a</sub> (mrem/Ci)	Each radionuclide	Tables E-11 to E-14
Q <sub>r</sub> (kg/day)	50 (cow) 6 (goat)	Table E-3 Table E-3
U <sub>a</sub> <sup>L</sup> (kg/yr) - Infant	0	Table E-5
- Child	26	Table E-5
- Teen	42	Table E-5
- Adult	64	Table E-5
U <sub>a</sub> <sup>S</sup> (kg/yr) - Infant	0	Table E-5
- Child	520	Table E-5
- Teen	630	Table E-5
- Adult	520	Table E-5
T <sub>L</sub> (seconds)	8.6 x 10 <sup>4</sup> (1 day)	Table E-15
τ <sub>h</sub> (seconds)	5.18 x 10 <sup>6</sup> (60 days)	Table E-15
Y <sub>v</sub> (kg/m <sup>2</sup> )	2.0	Table E-15
τ <sub>a</sub> (seconds)	5.18 x 10 <sup>6</sup> (60 days)	Table E-15
T <sub>b</sub> (seconds)	4.73 x 10 <sup>6</sup> (15 yr)	Table E-15
P (kg [dry soil/m <sup>2</sup> ])	240	Table E-15
B <sub>iv</sub> (pCi/kg [wet weight] per pCi/kg [dry soil])	Each stable element	Table E-1

II. CHANGES TO THE RADIOACTIVE WASTE SYSTEMS

There were no changes to the Radioactive Waste System during this reporting period.

III. CHANGES TO THE PROCESS CONTROL PROGRAM

There were no changes to the Process Control Program (PCP) during this reporting period.

IV. CHANGES TO THE LAND USE CENSUS

There were no changes to the environmental sampling program as a result of the Land Use Census performed in the first six months of 1995.

V. INSTRUMENT INOPERABILITY

The Gas Analyzer, which monitors waste gas streams for potentially explosive mixtures of hydrogen and oxygen, was declared inoperable on November 30, 1993. The analyzer was removed from service when an Engineering Evaluation determined that it was no longer capable of performing "continuous monitoring" as required by plant Technical Specifications. The analyzer is to be upgraded by plant modification #1159 and PIR #92-295 which will replace broken components for which parts are no longer available. The Gas Analyzer remains out-of-service as of the date of this report.

Compensatory sampling is in progress as required by Technical Specifications for the above inoperability.

VI. LIQUID HOLDUP TANK CURIE LIMIT

There were no outside Liquid Holdup Tanks that exceeded the ten curie limit during this reporting period.

VII. WASTE GAS DECAY TANK CURIE LIMIT

There were no Waste Gas Decay Tanks with a curie content that exceeded the 1.90E+04 curie limit during this reporting period.

VIII. INDEPENDENT SPENT FUEL STORAGE INSTALLATION

The onsite Independent Spent Fuel Storage Installation, Docket No. 72-3/License No. SNM-2502, became operational during the first six months of 1989. See Addendum I for reporting requirements concerning this facility.



SUPPLEMENTS TO PREVIOUS  
SEMIANNUAL REPORTS

TABLE OF CONTENTS  
Enclosure 3

	<u>Description</u>	<u>Page</u>
I.	DISCUSSION . . . . .	2

I. DISCUSSION

There were no changes to previous reports during this reporting period.

CAROLINA POWER & LIGHT COMPANY  
H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT NO. 2  
INDEPENDENT SPENT FUEL STORAGE INSTALLATION

SEMIANNUAL ENVIRONMENTAL REPORT  
JANUARY 1, 1995 - JUNE 30, 1995

FACILITY OPERATING LICENSE NO. SNM-2502

DOCKET NO. 72-3

I. HISTORY OF THE FACILITY

The Independent Spent Fuel Storage Installation (ISFSI) is located within the Protected Area of H. B. Robinson Steam Electric Plant, Unit No. 2. Currently, the Installation contains eight (8) Dry Storage Canisters. The initial canister was loaded on 3/16/89 and other canisters were loaded on 4/11/89, 4/18/89, 4/24/89, 5/2/89, 5/8/89, 6/28/89, and 7/3/89.

II. EFFLUENT LIMITS AND CONTROLS

This Installation operates under effluent control limits as required by 10 CFR 72.44. However, there are, by design of the sealed storage canisters at the ISFSI, no effluent releases. All H. B. Robinson Steam Electric Plant, Unit No. 2 site cask loading and unloading operations and waste treatment will occur at the H. B. Robinson Steam Electric Plant, Unit No. 2 under the specifications of its Operating License (DPR-23).

III. RADIOLOGICAL EFFLUENT RELEASES

A review of the quarterly surveillance tests performed during this reporting period indicates that no radioactive liquid or gaseous releases occurred during this report period.

IV. THE ISFSI ENVIRONMENTAL PROGRAM

The ISFSI Environmental Program consists of two air samplers and three TLDs about the Installation plus an unaffected air sampler and TLD site 26 miles ESE of the facility. Two of the environmental TLDs are maintained at the air sampling sites adjacent to the plant boundary. These are located south at 0.2 miles and southwest at 0.3 miles from the ISFSI. A third TLD site is located 0.1 miles north of the Installation. The nearest residence is located south to south-southeast approximately 0.25 miles from the facility. Air samplers operate continuously and samples are changed weekly. TLDs are changed quarterly.

V. OTHER ENVIRONMENTAL PROGRAMS

In addition to the ISFSI Environmental Program, the H. B. Robinson Steam Electric Plant, Unit No. 2 Environmental Program is described in Technical Specification 3.17 (see Carolina Power and Light Company, "Technical Specifications and Bases for H. B. Robinson Unit No. 2," Appendix A to Facility Operating License DPR-23, Docket No. 50-261, Darlington County, S.C.). For a comprehensive summary of this program and its results, see also "Environmental Surveillance Report," H. B. Robinson Steam Electric Plant, Unit No. 2 issued in compliance with the above referenced Technical Specification for this report period.

VI. ISFSI ENVIRONMENTAL MEASUREMENTS

A. Environmental TLDs

<u>TLD (Location)</u>	<u>1st Qtr. (mrem/90 days)</u>	<u>2nd Qtr. (mrem/90 days)</u>
1 (26 miles ESE) (Control)	12.5	13.8
2 (0.2 miles S)	14.1	13.6
6 (0.3 miles SW)	15.9	14.4
56 (0.1 miles N)	15.7	13.2

B. Air Sampling

Gross Beta Measurements - 1st Qtr.  
(picocuries per cubic meter)

<u>Air Sampler (Location)</u>	<u>Average</u>	<u>Maximum</u>
1 (26 miles ESE) (Control)	2.47E-02	7.75E-02
2 (0.2 miles S)	2.13E-02	3.36E-02
6 (0.3 miles SW)	2.14E-02	2.97E-02

Gross Beta Measurements - 2nd Qtr.  
(picocuries per cubic meter)

<u>Air Sampler (Location)</u>	<u>Average</u>	<u>Maximum</u>
1 (26 miles ESE) (Control)	2.11E-02	2.60E-02
2 (0.2 miles S)	2.07E-02	2.84E-02
6 (0.3 miles SW)	2.14E-02	2.70E-02

A composite analysis of air samples detected no radionuclides from man-made sources for either quarter.



VII. CONCLUSIONS

Based on the above measurements performed during this reporting period, it is concluded that the dose issuing from the ISFSI to the most exposed member of the public did not exceed 1 mrem. This is best estimated as presented in the ISFSI FSAR.

VIII. SUMMARY

This report is submitted in compliance with ISFSI Specification 1.4.1 as required pursuant to 10 CFR 72.44(d)(3). Paragraph III specifies liquid and gaseous releases to the environment. Paragraphs VI and VII are provided for estimation of potential radiation dose commitment to the public resulting from effluent release.