



Donald C. Shelton
Vice President - Nuclear
Davis-Besse

300 Madison Avenue
Toledo, OH 43652-0001
(419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 2009

January 28, 1992

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: Davis-Besse Nuclear Power Station Reactor Containment
Building Integrated Leak Rate Test Summary Report

Gentlemen:

In accordance with 10CFR50 Appendix J, Paragraph V.B, enclosed is the Reactor Containment Building Integrated Leak Rate Test report for the Davis-Besse Nuclear Power Station, Unit Number 1 Reactor Containment Building. The results of the test show that the actual measured containment vessel leakage, when the containment vessel is pressurized to the peak calculated accident pressure, is less than 75 percent of the maximum allowable leakage assumed in the safety analysis.

Should further information be required, please contact
Mr. R. W. Schrauder, Manager - Nuclear Licensing, at (419) 249-2366.

Very truly yours,

A handwritten signature in dark ink, appearing to read 'D. Shelton', with a long horizontal flourish extending to the right.

PWS/dlm

Enclosure

cc: A. B. Davis, Regional Administrator, NRC Region III
J. B. Hopkins, NRC Senior Project Manager
W. Levis, DB-1 NRC Senior Resident Inspector
Utility Radiological Safety Board

9202030175 920128
PDR ADOCK 05000346
P PDR

Operating Companies
Cleveland Electric Illuminating
Toledo-Edison

A017
11