



NIAGARA MOHAWK POWER CORPORATION/301 PLAINFIELD ROAD, SYRACUSE, NEW YORK 13212/TELEPHONE (315) 428-7494

B. Ralph Sylvia
Executive Vice President
Nuclear

January 29, 1992
NMP2L 1336

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Re: Nine Mile Point Unit 2
Docket No. 50-410
NPF-69

Gentlemen:

Niagara Mohawk Power Corporation hereby transmits an Application for Amendment to Nine Mile Point Unit 2 (NMP2) Operating License NPF-69. Also enclosed is the proposed changes to the Technical Specifications set forth in A to the above-mentioned license. Supporting information and analyses demonstrating that the proposed changes involve no significant hazards consideration pursuant to 10 CFR 50.92 are included as Attachment B.

This submittal replaces the amendment request submitted to the Commission on November 6, 1991. The changes contained herein are to incorporate comments provided by NRC staff.

The proposed changes are to Technical Specification Sections 1.31 "Primary Containment Integrity", 3/4.6.1 "Primary Containment", 3/4.6.3 "Primary Containment Isolation Valves" and Bases, 3/4.8.4 "Electrical Equipment Protective Devices", and associated Tables 3.6.3-1, 3.8.4.1-1 and 3.8.4.3-1. The net result of these proposed changes will be to remove the above tables and all references thereto from the Technical Specifications Index, Definitions, Limiting Conditions for Operation, Surveillance Requirements and Bases in accordance with Generic Letter 91-08.

These proposed changes have no safety or environmental significance. The basis for concluding that this request does not involve a significant hazards consideration is included as Attachment B of our application.


Plant modifications scheduled for the NMP2 refuel outage will require revision of component designations presently described in Table 3.8.4.3-1. Niagara Mohawk requests that this amendment be processed by March 1992. This would allow this single amendment submittal to incorporate revisions required by the scheduled modifications and implementation of Generic Letter 91-08.

9202030189 920129
PDR ADOCK 05000410
P PDR

Handwritten initials/signature

Pursuant to 10 CFR 50.91(b)(1), Niagara Mohawk has provided a copy of this license amendment request and the associated analyses regarding no significant hazards consideration to the appropriate state representative.

Very truly yours,



B. Ralph Sylvia
Exec. Vice President-Nuclear

RJW/krc
002223GG
Attachments

xc: Regional Administrator, Region I
Mr. R. A. Capra, Project Director, NRR
Mr. J. E. Menning, Project Manager, NRR
Mr. W. L. Schmidt, Senior Resident Inspector
Mr. D. R. Haverkamp, Chief, Reactor Projects Section No. 1B
Ms. Donna Ross
Division of Policy Analysis and Planning
New York State Energy Office
Agency Building 2
Empire State Plaza
Albany, NY 12223
Records Management