

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004
(412) 393-5255

JOHN D. SIEBER
Vice President - Nuclear Group

January 30, 1992

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington DC 20555

**Subject: Beaver Valley Power Station, Unit 1 and 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Response to Generic Letter 91-11**

This provides our response to Generic Letter 91-11, [Resolution of Generic Issues 48, "LCOs for Class 1E Vital Instrument Buses," and 49, "Interlocks and LCOs For Class 1E Tie Breakers"]. The Generic Letter contains recommended action items which are as follows:


Ensure that your plant has procedures that include time limitations and surveillance requirements for:

- 1.) Vital instrument buses (typically 120V ac buses).
- 2.) Inverters or other power sources to the vital instrument buses.
- 3.) Tie breakers that can connect redundant Class 1E buses (ac or dc) at one unit or that can connect Class 1E buses between units at the same site.

The three recommended action items contained in enclosure one to Generic Letter 91-11 have been reviewed. Our review has determined that Beaver Valley Power Station Units 1 and 2 have each implemented the appropriate procedures in a manner which conforms to the guidance provided in the enclosure to the Generic Letter.

If you have any questions regarding this submittal, please call Mr. Steve Sovick at (412) 393-5211.

Sincerely,



J. D. Sieber

Enclosure

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. A. W. DeAgazio, Project Manager
Mr. M. L. Bowling (VEPCO)

050035 9202030195 920130
PDR ADOCK 05000334
P PDR

AD27



COMMONWEALTH OF PENNSYLVANIA))
) SS:
COUNTY OF BEAVER))

On this 30th day of January, 1992,
before me, Sheila M. Fattore, a Notary Public in and for said
Commonwealth and County, personally appeared J. D. Sieber, who being
duly sworn, deposed, and said that (1) he is Vice President - Nuclear
of Duquesne Light, (2) he is duly authorized to execute and file the
foregoing Submittal on behalf of said Company, and (3) the statements
set forth in the Submittal are true and correct to the best of his
knowledge, information and belief.

Sheila M. Fattore

Notarial Seal
Sheila M. Fattore, Notary Public
Sheepscott Boro, Beaver County
My Commission Expires Sept. 26, 1994
Not. Sec. Pennsylvania Association of Notaries