

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) **SAN ONOFRE NUCLE. GENERATING STATION, UNIT 3** DOCKET NUMBER (2) **0 5 0 0 0 3 6 2** PAGE (3) **1 OF 0 9**

TITLE (4) **DOSE EQUIVALENT IODINE LIMITS EXCEEDED**

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)	
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)
04	27	84	84	0115	01	06	08	84		0 5 0 0 0 0
										0 5 0 0 0 0

OPERATING MODE (9) **1**

POWER LEVEL (10) **0 8 0**

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)

<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.405(c)	<input type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)
<input type="checkbox"/> 20.405(a)(1)(i)	<input type="checkbox"/> 50.36(c)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)
<input type="checkbox"/> 20.405(a)(1)(ii)	<input checked="" type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(vii)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)
<input type="checkbox"/> 20.405(a)(1)(iii)	<input checked="" type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)	LCO 3.4.7, Action Statement 'd'
<input type="checkbox"/> 20.405(a)(1)(iv)	<input type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)	
<input type="checkbox"/> 20.405(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(x)	

LICENSEE CONTACT FOR THIS LER (12)

NAME **J. G. HAYNES, STATION MANAGER**

TELEPHONE NUMBER **7 1 4 4 9 2 - 7 7 9 0**

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

Pursuant to Limiting Condition for Operation (LCO) 3.4.7, Action Statement 'd' of Appendix A, Technical Specifications to Facility Operating License NPF-15 for San Onofre Unit 3, this submittal provides the required 30-day written Licensee Event Report (LER) for three occurrences involving the Reactor Coolant System specific activity exceeding 1.0 microcurie/gram Dose Equivalent (DE) I-131 at 1005 on April 27, 1984 with Unit 3 in Mode 1 at 80% power; at 0330, on May 5, 1984 with Unit 3 in Mode 3; and at 0820, May 7, 1984 with Unit 3 in Mode 1 at approximately 20% power. RCS activity was reduced to less than 1.0 microcurie/gram DE I-131 within 48 hours after each occurrence by purification flow.

During the third occurrence, on May 7, 1984, a required RCS sample due at 2025 was delayed until 2200 because all activities involving contaminated systems including RCS sampling, were suspended pending investigation of a Plant Vent Stack alarm. As a result, the 4-hour limit required by LCO 3.4.7, Action Statement 'd', was not met.

In addition, it was determined that there have been past occurrences when RCS samples were not taken and analyzed within the required 4 hours.

We will continue to monitor and evaluate primary coolant activity.

8406130187 840608
PDR ADOCK 05000362
S PDR

LICENSEE EVENT REPORT (LER)
TEXT CONTINUATION

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3	DOCKET NUMBER (2) 0 5 0 0 0 3 6 2	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQ. NUMBER	REV. NUMBER			
		8 4	- 0 1 5	- 0 1	0 2	OF	0 9

TEXT (If more space is required, use additional NRC Form 366A's) (17)

On April 27, 1984, at 1005, with Unit 3 in Mode 1 at 80% power, analysis of RCS sample indicated that the specific activity exceeded 1.0 microcurie/gram DE I-131. The specific activity was reduced to less than 1.0 microcurie/gram DE I-131 at 1400, on April 28, 1984, by purification flow.

On May 5, 1984, at 0330, with Unit 3 in Mode 3, RCS sample activity exceeded 1.0 microcurie/gram DE I-131. The specific activity was reduced to less than 1.0 microcurie/gram DE I-131 at 1545, on May 6, 1984, by purification flow.

On May 7, 1984, at 0820, with Unit 3 in Mode 1 at 20% power, RCS sample activity exceeded 1.0 microcurie/gram DE I-131. Specific activity was reduced to less than 1.0 microcurie/gram DE I-131 at 2045, on May 8, 1984, by purification flow.

The three occurrences, during which Dose Equivalent Iodine limits were exceeded resulted from temporary reactor coolant activity increases following power changes. Similar occurrences were reported in LER 83-111, LER-84-005 and LER-84-013. We will continue to monitor and evaluate primary coolant activity. No other immediate corrective action is planned. Neither the health and safety of plant personnel nor the public were affected by these events.

During the May 7, 1984 occurrence, a required RCS sample due at 2025 was delayed until 2200 because RCS sampling and all other activities involving contaminated systems were suspended pending investigation of a Plant Vent Stack alarm. As a result, the 4-hr limit required by LCO 3.4.7, Action Statement 'd' was not met.

During the preparation of this report, it was determined that there have been past occurrences when RCS samples were not taken and analyzed within the 4 hours required by LCO 3.4.7, Action Statement 'd'. Personnel have been instructed to perform the sampling within the required 4-hour period. No further corrective action is planned.

Additional information, required by LCO 3.4.7, Action Statement 'd' is provided on the following pages. Although the unit has a degassification path which operates continuously and takes pressurizer steam, condenses it, and directs it to Liquid Radwaste, de-gassing operation history is not applicable, because this system reduces the noble gas content of the Reactor Coolant System but has no effect on iodine.

LICENSEE EVENT REPORT (LER)
TEXT CONTINUATION

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3	DOCKET NUMBER (2) 0 5 0 0 0 3 6 2	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQ. NUMBER	REV. NUMBER			
		8 4	- 0 1 5	- 0 1	0 3	OF	0 9

TEXT (If more space is required, use additional NRC Form 366A's) (17)

CLEANUP FLOW HISTORY

<u>PERIOD</u>	<u>AVERAGE CLEANUP FLOW (GPM)</u>
4/25/84, 1000 to 4/25/84, 1300	82.8
4/25/84, 1300 to 4/26/84, 0100	85*
4/26/84, 0100 to 4/27/84, 1000	84.5
5/03/84, 0300 to 5/03/84, 2300	80.5
5/03/84, 2300 to 5/04/84, 0300	85*
5/04/84, 0300 to 5/05/84, 0300	77.46
5/05/84, 0800 to 5/05/84, 1700	85*
5/05/84, 1700 to 5/06/84, 1500	82.2
5/06/84, 1500 to 5/07/84, 0100	85*
5/07/84, 0100 to 5/07/84, 0800	79.5

*Hourly cleanup flow data not available. Figure used is taken from average flow with two charging pumps in operation.

LICENSEE EVENT REPORT (LER)
TEXT CONTINUATION

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3	DOCKET NUMBER (2) 0 5 0 0 0 3 6 2	LER NUMBER (6)			PAGE (3)		
		YEAR	SEQ. NUMBER	REV. NUMBER			
		8 4	- 0 1 5	- 0 1	0 4	OF	0 9

TEXT (If more space is required, use additional NRC Form 366A's) (17)

REACTOR POWER HISTORY

PERIOD

REACTOR POWER

4/25/84, 1000 to 4/27/84, 0200	100% Rated Power
4/27/84, 0300 to 4/27/84, 0600	95%
4/27/84, 0700	87%
4/27/84, 0800 to 4/27/84, 1100	80%
5/03/84, 0300 to 5/04/84, 1800	100%
5/04/84, 1900	93.3%
5/04/84, 2000	86.7%
5/04/84, 2100	73.2%
5/04/84, 2200	57.2%
5/04/84, 2300	43.6%
5/04/84, 2400	32.2%
5/05/84, 0100 to 5/05/84, 0400	0%
5/05/84, 0800 to 5/07/84, 0500	0%
5/07/84, 0600	16%
5/07/84, 0700 to 5/07/84, 0800	17%
5/07/84, 0900	20.8%

LICENSEE EVENT REPORT (LER)
TEXT CONTINUATION

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3	DOCKET NUMBER (2) 0 5 0 0 0 3 6 2	LER NUMBER (6)			PAGE (3)		
		YEAR 8 4	SEQ. NUMBER 0 1 5	REV. NUMBER 0 1	0 5	OF	0 9

TEXT (If more space is required, use additional NRC Form 366A's) (17)

REACTOR COOLANT SYSTEM SPECIFIC ACTIVITY ANALYSIS

<u>DATE</u>	<u>TIME</u>	<u>DE I-131 MICROCURIES/GRAM</u>
4/27/84	1005	1.04
4/27/84	1424	1.39
4/27/84	1831	1.40
4/27/84	2154	1.51
4/28/84	0200	1.19
4/28/84	0600	0.9957
4/28/84	1000	1.221
4/28/84	1400	0.833
5/05/84	0330	4.08
5/05/84	0730	5.08
5/05/84	1155	4.38
5/05/84	1540	3.70
5/05/84	1955	2.97
5/05/84	2330	2.47
5/06/84	0330	1.93
5/06/84	0727	1.52
5/06/84	1135	1.26
5/06/84	1405	1.05
5/06/84	1545	0.90
5/07/84	0820	2.170
5/07/84	1225	1.632
5/07/84	1625	1.430
5/07/84	2200	1.304
5/08/84	0225	1.22
5/08/84	0435	1.05
5/08/84	0830	1.11
5/08/84	1233	1.05
5/08/84	1630	1.02
5/08/84	2045	0.806

The total time with DE I-131 above 1.0 microcurie/gram for these events was 95.50 hours. Cumulative time with DE I-131 above 1.0 microcurie/gram for the last 12-month period is 185.6 hours.

