

JUN 5 1984

DMB 0/6

Docket Nos. 50-321/366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

SUBJECT: RESPONSE TO NUREG-0737, ITEM II.K.3.18,
ADS MODIFICATION

Re: Edwin I. Hatch Nuclear Plant, Units 1 and 2

By letter of June 3, 1983, the NRC requested Georgia Power Company to comply with the requirements of NUREG-0737, Item II.K.3.18 by choosing between two alternative modifications that the staff found acceptable.

As a result, Georgia Power Company submitted letters dated July 28, 1983 and May 21, 1984, which commit the utility to modifying the ADS logic by eliminating the high drywell pressure permissive and adding a manual inhibit switch. This modification was found acceptable by the staff in its Safety Evaluation enclosed in its letter of June 3, 1983.

Based on your July 28, 1983 commitment, we consider this issue to be closed.

Sincerely,

"ORIGINAL SIGNED BY:"

George W. Rivenbark, Acting Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page

~~DISTRIBUTION~~
~~Docket File~~
NRC PDR
Local PDR

ORB#4 Rüg
DEisenhut
OELD
RIngram

NPKadambi
RBevan
ELJordan
JNGrace

ACRS (10)
Gray File

~~DL:ORB#4~~
~~RIngram:ajs~~
~~06/1/84~~

NPK
DL:ORB#4
NPKadambi
06/5/84

DL:ORB#2
RBevan *RJB*
06/5/84

[Signature]
DL:ORB#4
GRivenbark
06/5/84

Hatch 1/2
Georgia Power Company

50-321/366

cc w/enclosure(s):

G. F. Trowbridge, Esq.
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Ruble A. Thomas
Vice President
P. O. Box 2625
Southern Company Services, Inc.
Birmingham, Alabama 35202

Ozen Batum
Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202

Chairman
Appling County Commissioners
County Courthouse
Baxley, Georgia 31513

Mr. L. T. Gucwa
Georgia Power Company
Engineering Department
P. O. Box 4545
Atlanta, Georgia 30302

Mr. H. C. Nix, Jr. General Manager
Edwin I. Hatch Nuclear Plant
Georgia Power Company
P. O. Box 442
Baxley, Georgia 31513

Regional Radiation Representative
EPA Region IV
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Resident Inspector
U. S. Nuclear Regulatory Commission
Route 1, P. O. Box 279
Baxley, Georgia 31513

Mr. James P. O'Reilly, Regional
Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Charles H. Badger
Office of Planning and Budget
Room 610
270 Washington Street, S.W.
Atlanta, Georgia 30334

J. Leonard Ledbetter, Commissioner
Department of Natural Resources
270 Washington Street, N.W.
Atlanta, Georgia 30334



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 5, 1984

Docket Nos. 50-321/366

Mr. J. T. Beckham, Jr.
Vice President - Nuclear Generation
Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302

Dear Mr. Beckham:

SUBJECT: RESPONSE TO NUREG-0737, ITEM II.K.3.18,
ADS MODIFICATION

Re: Edwin I. Hatch Nuclear Plant, Units 1 and 2

By letter of June 3, 1983, the NRC requested Georgia Power Company to comply with the requirements of NUREG-0737, Item II.K.3.18 by choosing between two alternative modifications that the staff found acceptable.

As a result, Georgia Power Company submitted letters dated July 28, 1983 and May 21, 1984, which commit the utility to modifying the ADS logic by eliminating the high drywell pressure permissive and adding a manual inhibit switch. This modification was found acceptable by the staff in its Safety Evaluation enclosed in its letter of June 3, 1983.

Based on your July 28, 1983 commitment, we consider this issue to be closed.

Sincerely,

A handwritten signature in cursive script that reads "George W. Rivenbark".

George W. Rivenbark, Acting Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page